

The Daily Environmental Redispatch Retrospective

An indepth report for **7/1/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	147	0	1119	101	727	1827	-195
HE02	0	148	0	857	414	1092	1572	-197
HE03	0	146	0	677	512	990	1367	-119
HE04	0	151	0	559	581	996	1305	-69
HE05	0	173	0	503	462	970	1323	-79
HE06	0	216	0	391	164	882	1519	-24
HE07	0	261	0	241	484	1182	2000	-93
HE08	0	295	0	120	380	1193	2000	-141
HE09	0	361	0	63	792	1256	2000	-402
HE10	0	514	0	25	860	1061	1936	-587
HE11	0	603	0	5	567	895	1850	-686
HE12	0	617	0	6	373	840	1850	-695
HE13	0	619	0	3	134	848	1850	-663
HE14	0	629	0	2	190	643	1850	-628
HE15	0	627	0	1	44	617	1850	-625
HE16	0	629	0	6	35	436	1850	-607
HE17	0	643	0	18	45	383	1850	-634
HE18	0	697	0	18	34	522	1850	-680
HE19	0	682	0	28	43	528	1850	-695
HE20	0	650	0	48	258	703	1850	-692
HE21	0	676	0	74	85	512	1878	-657
HE22	0	695	0	81	208	685	2000	-732
HE23	0	567	0	66	43	568	2000	-705
HE24	0	423	0	58	33	507	2000	-350
Day Total (MWh)	0	11170	0					
CUMM (MWh)*	11,143		86,062					

* Cumulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG% (TW)	Qspill (Davg-kcfs)	LEVEL 1 CAP (kcfs)	LEVEL 2 CAP (kcfs)	LEVEL 3 CAP (kcfs)	LEVEL 4 CAP (kcfs)
GCL	122.9	26.6	0	15	18	35
CHJ	117.0	86.2	189	200	210	250
LWG	129.0	34.4	45	52	63	85
LGS	121.8	40.6	52	59	70	95
LMN	123.6	40.8	40	55	80	120
IHR	124.8	73.0	75	85	110	124
MCN	127.2	261.2	190	235	240	280
JDA	121.9	131.6	144	177	190	206
TDA	120.3	161.1	135	140	269	294
BON	123.6	218.6	107	120	181	205

* Based on 6/26/11 07:42 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.