

The Daily Environmental Redispatch Retrospective

An indepth report for **7/2/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	201	0	45	33	721	2000	-68
HE02	0	191	0	31	48	752	2000	4
HE03	0	191	0	10	76	821	1952	-10
HE04	0	192	0	16	75	1000	1920	6
HE05	0	191	0	43	77	995	1909	13
HE06	0	194	0	55	122	862	1760	63
HE07	0	207	0	38	401	1382	2000	60
HE08	0	216	0	9	255	818	2000	194
HE09	0	215	0	12	591	1194	2000	166
HE10	0	212	0	17	178	944	2000	-322
HE11	0	210	0	25	525	1329	2000	-609
HE12	0	275	0	63	403	1033	2000	-626
HE13	0	358	0	112	319	870	2000	-600
HE14	0	355	0	58	422	1102	1904	-585
HE15	0	352	0	17	418	1096	1850	-559
HE16	0	386	0	6	416	1037	1850	-499
HE17	0	409	0	5	572	970	1850	-448
HE18	0	421	0	26	601	975	1850	-523
HE19	0	368	0	127	620	992	1850	-571
HE20	0	207	0	375	435	1068	1850	-612
HE21	0	204	0	822	412	1027	1850	-611
HE22	0	203	0	1378	378	878	1850	-603
HE23	0	201	0	2086	133	425	1602	-344
HE24	0	198	0	2424	43	405	1421	32
Day Total (MWh)	0	6156	0					
CUMM (MWh)*	11,143		86,062					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI trasmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG% (TW)	Qspill (Davg-kcfs)	LEVEL 1 CAP (kcfs)	LEVEL 2 CAP (kcfs)	LEVEL 3 CAP (kcfs)	LEVEL 4 CAP (kcfs)
GCL	123.0	26.6	0	15	18	35
CHJ	117.1	86.2	189	200	210	250
LWG	120.7	34.4	45	52	63	85
LGS	118.9	40.6	52	59	70	95
LMN	121.5	40.8	40	55	80	120
IHR	120.7	73.0	75	85	110	124
MCN	127.7	261.2	190	235	240	280
JDA	121.2	131.6	144	177	190	206
TDA	120.5	161.1	135	160	269	294
BON	125.2	218.6	107	120	181	205

* Based on 6/26/11 07:42 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.