

The Daily Environmental Redispatch Retrospective

An indepth report for **7/3/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	189	0	2305	182	742	1700	106
HE02	0	194	141	2250	109	693	1716	84
HE03	0	195	850	1356	81	620	1517	100
HE04	0	190	842	1127	91	699	1536	97
HE05	0	189	867	808	332	1113	1056	40
HE06	0	187	1185	236	458	1234	1245	12
HE07	130	186	1048	40	845	1428	1132	107
HE08	110	184	625	322	419	1486	1692	224
HE09	0	192	0	1501	604	414	1654	277
HE10	0	210	0	1799	240	263	1850	388
HE11	0	189	0	1852	354	865	1825	388
HE12	0	195	0	1842	241	448	1850	37
HE13	0	195	0	1798	144	189	1850	-133
HE14	0	188	0	1952	114	266	1850	-273
HE15	0	190	0	2044	91	232	1850	-180
HE16	0	193	0	2030	33	390	1850	-171
HE17	0	192	0	2061	35	580	1656	-238
HE18	0	195	0	2031	84	599	1740	-211
HE19	0	198	0	1770	69	624	1850	-314
HE20	0	198	0	1701	90	1350	1679	-285
HE21	0	196	0	1682	83	1110	1850	-253
HE22	0	189	0	1592	166	1112	1850	-163
HE23	0	200	0	1203	192	713	1491	-148
HE24	0	249	0	942	135	878	1813	-145
Day Total (MWh)	240	4685	5557					
CUMM (MWh)*	11,383		91,619					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	122.1	53.0	0	15	18	35
CHJ	116.9	82.9	189	200	210	250
LWG	119.9	45.4	45	52	63	85
LGS	117.7	41.8	52	59	70	95
LMN	120.3	46.2	40	55	80	120
IHR	120.4	74.2	75	85	110	124
MCN	126.8	237.3	190	235	240	280
JDA	119.9	114.2	144	177	190	206
TDA	119.0	134.5	135	160	269	294
BON	123.0	161.9	107	120	181	205

* Based on 6/26/11 07:42 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.