

The Daily Environmental Redispatch Retrospective

An indepth report for **7/6/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	206	0	295	45	593	1850	-255
HE02	0	201	0	342	57	726	1850	-24
HE03	0	200	0	389	32	725	1850	42
HE04	0	198	0	462	54	720	1850	68
HE05	0	201	0	336	506	806	1850	50
HE06	0	268	0	309	59	732	1850	94
HE07	0	382	0	201	220	662	1853	27
HE08	0	478	0	87	324	839	1850	-167
HE09	0	488	0	77	397	1333	1850	-353
HE10	0	524	0	56	370	1290	1850	-557
HE11	0	747	0	41	418	1140	1850	-595
HE12	0	1025	0	29	594	1043	1850	-553
HE13	0	1194	0	25	342	1116	1820	-584
HE14	0	1274	0	39	360	764	1783	-636
HE15	0	1288	0	61	448	378	1783	-631
HE16	0	1281	0	117	415	614	1783	-647
HE17	0	1275	0	210	459	958	1783	-741
HE18	0	1272	0	379	183	1474	1783	-755
HE19	0	1211	0	698	224	924	1788	-774
HE20	0	1097	0	1036	168	878	1850	-721
HE21	0	1142	0	1446	218	1084	1850	-602
HE22	0	759	0	1642	175	997	1850	-716
HE23	0	392	0	1742	145	499	1850	-858
HE24	0	371	0	1549	53	538	1850	-498
Day Total (MWh)	0	17474	0					
CUMM (MWh)*	11,854		92,599					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	123.1	54.5	0	15	30	35
CHJ	117.9	89.1	189	200	210	250
LWG	121.1	46.6	45	52	63	85
LGS	117.3	41.3	52	59	70	95
LMN	120.3	53.9	44	50	80	120
IHR	120.9	71.1	75	85	110	124
MCN	126.0	238.3	190	235	240	280
JDA	119.2	117.5	144	177	190	206
TDA	121.4	138.4	135	160	269	294
BON	120.8	170.7	107	120	181	205

* Based on 6/26/11 07:42 spill priority table

TDG%	
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.