

The Daily Environmental Redispatch Retrospective

An indepth report for **7/7/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	210	0	1422	145	643	1850	-230
HE02	0	205	0	1323	95	804	1505	-58
HE03	0	207	108	1045	-94	775	1132	-54
HE04	0	211	544	174	3	1129	1332	-67
HE05	0	208	1	499	341	849	895	-90
HE06	0	273	0	652	1553	721	1331	-95
HE07	0	408	0	1124	708	657	1850	32
HE08	0	510	0	1515	600	514	1850	-141
HE09	0	463	0	1897	734	599	1850	-332
HE10	0	699	0	1918	197	578	1850	-475
HE11	0	900	0	2353	38	272	1850	-542
HE12	0	900	0	2525	3	355	1850	-513
HE13	0	931	0	2629	15	198	1850	-518
HE14	0	895	0	2978	150	352	1850	-600
HE15	0	887	0	3041	8	156	1850	-512
HE16	0	851	0	3013	1	199	1850	-282
HE17	0	900	0	2957	6	216	1850	-300
HE18	0	918	0	3035	1	264	1765	-329
HE19	0	712	0	2880	1	297	1850	-388
HE20	0	441	0	3114	3	306	1850	-308
HE21	0	488	0	3068	66	280	1696	-217
HE22	0	477	0	2976	771	410	1265	-225
HE23	0	251	0	2782	97	420	1666	-146
HE24	0	243	0	2784	61	434	1104	-47
Day Total (MWh)	0	13187	652					
CUMM (MWh)*	11,854		93,251					

* Cumulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	123.9	57.7	0	0	15	30
CHJ	117.3	101.6	150	189	200	210
LWG	120.5	39.5	41	45	52	63
LGS	117.0	37.5	40	52	59	70
LMN	120.3	43.1	28	44	60	80
IHR	120.3	63.0	79	75	85	110
MCN	126.0	254.2	190	190	235	240
JDA	119.7	135.3	135	144	177	190
TDA	121.1	145.5	130	135	160	269
BON	119.7	184.1	121	107	120	155

* Based on 6/26/11 07:42 spill priority table

TDG%
120
122
125
127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.