

The Daily Environmental Redispatch Retrospective

An indepth report for 6/13/2011

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	191	100	487	754	1304	1409	155
HE02	0	187	598	54	1166	1590	1142	162
HE03	0	189	562	47	1295	1728	907	144
HE04	0	192	512	52	1297	1750	938	127
HE05	0	199	334	174	1208	1584	1086	184
HE06	0	261	0	905	818	1190	1303	309
HE07	0	301	0	1102	976	1679	1650	209
HE08	0	393	0	1305	1318	1664	874	185
HE09	0	417	0	1395	1314	1469	933	155
HE10	0	411	0	2075	1232	1294	969	105
HE11	0	411	0	2110	710	903	1227	162
HE12	0	464	0	2474	441	707	1275	152
HE13	0	405	0	2616	125	660	1820	120
HE14	0	382	0	3033	364	517	1194	76
HE15	0	382	0	2931	171	518	1266	1
HE16	0	385	0	2952	92	477	1296	-41
HE17	0	386	0	3062	96	593	961	-23
HE18	0	384	0	3022	233	578	1019	-133
HE19	0	383	0	3064	131	699	1133	-115
HE20	0	235	0	2896	270	566	1438	82
HE21	0	228	0	2758	355	559	1324	97
HE22	0	224	0	2599	468	556	1208	-13
HE23	0	213	0	2483	229	669	1347	38
HE24	0	204	0	2185	41	1027	1347	11
Day Total (MWh)	0	7427	2105					
CUMM (MWh)*	9556		76219					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

These unused COB and unused NOB amounts reflects the net unused non-firm capacity made available by BPAT, and the net unused capacity (could be either firm or non-firm) capacity of the other COB and NOB path owners. The maximum limit used is the WECC path rating, which may include capacity that may not be available for scheduling due to operational limits. All table values are in MWs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	139.6	71.9	19	21	25	32
CHJ	117.2	131.8	160	170	180	189
LWG	125.8	72.5	50	61	70	86
LGS	126.3	83.3	52	56	75	100
LMN	123.1	61.3	49	55	90	120
IHR	124.7	101.1	79	90	105	124
MCN	130.9	325.2	190	235	280	305
JDA	127.9	223.3	144	177	190	206
TDA	124.3	241.3	146	220	235	294
BON	128.4	280.4	107	120	215	234

* Based on 6/09/11 14:05 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127