

The Daily Environmental Redispatch Retrospective

An indepth report for 6/19/2011

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	189	67	2132	840	1094	799	49
HE02	0	183	400	1740	1088	1454	225	42
HE03	0	186	409	1448	1153	1638	282	54
HE04	0	183	467	1322	1261	1602	250	136
HE05	0	185	523	1036	1335	1690	397	74
HE06	0	184	523	944	1236	1802	600	38
HE07	0	188	434	945	1000	1735	475	124
HE08	0	223	0	1719	626	1247	1027	254
HE09	0	223	0	2062	737	1180	789	237
HE10	0	218	0	2367	307	1067	1097	131
HE11	0	217	0	2484	442	1216	1309	68
HE12	0	221	0	2507	413	1185	1121	104
HE13	0	228	0	2549	313	918	1639	85
HE14	0	224	0	2435	148	716	1251	-35
HE15	0	230	0	2617	83	559	1276	120
HE16	0	223	0	2561	26	425	1405	123
HE17	0	220	0	2908	30	383	1350	101
HE18	0	221	0	2874	30	415	1302	21
HE19	0	221	0	2854	32	458	1422	-31
HE20	0	225	0	2916	87	426	1463	-10
HE21	0	223	0	2923	34	444	1393	-13
HE22	0	221	0	2863	33	502	1694	-57
HE23	0	221	0	2728	42	665	1437	-27
HE24	0	208	0	2476	248	934	848	-27
Day Total (MWh)	0	5063	2822					
CUMM (MWh)*	10395		82691					

* Cumulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI transmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency which can prohibit them from buying third-party intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	139.1	75.5	0	5	19	21
CHJ	118.8	114.2	160	180	210	250
LWG	118.3	44.7	50	61	76	85
LGS	121.1	53.8	52	61	75	95
LMN	119.9	37.6	49	55	75	120
IHR	121.2	75.9	79	85	105	124
MCN	126.4	269.9	190	235	270	290
JDA	124.6	191.5	144	177	190	206
TDA	120.8	203.0	146	210	269	294
BON	125.4	260.1	107	120	215	234

* Based on 6/09/11 14:05 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127