

The Daily Environmental Redispach Retrospective

An indepth report for 6/2/2011

	ENV DISPL	ENV RDISP	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)	(VER Only)	(NOB)	(COB)	(NI)	(minus = import)
HE01	0	600	591	844	1512	176
HE02	0	1000	722	855	1396	166
HE03	0	592	274	974	1289	169
HE04	0	892	349	1200	1576	198
HE05	0	83	255	551	1514	236
HE06	0	0	286	671	1471	220
HE07	0	0	575	1203	616	116
HE08	0	0	626	1372	371	-96
HE09	0	0	571	1456	360	-24
HE10	0	0	499	1277	121	131
HE11	0	0	346	722	412	182
HE12	0	0	343	757	525	140
HE13	0	0	291	851	395	181
HE14	0	0	258	706	403	193
HE15	0	0	355	597	546	261
HE16	0	0	300	613	481	188
HE17	0	0	301	536	833	125
HE18	0	0	281	684	639	88
HE19	0	0	262	649	351	62
HE20	0	0	247	533	733	109
HE21	0	0	245	505	1006	96
HE22	0	0	272	718	1064	-32
HE23	0	0	125	685	1404	65
HE24	0	0	333	490	1476	115
Day Total (MWh)	0	3167				
CUMM (MWh)*	6348	55235				

* Cummulative totals since May 18th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit. (All table values are in MWs.)

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	140.6	96.2	19	21	25	32
CHJ	122.7	141.8	110	140	155	159
LWG	118.8	45.4	50	61	73	86
LGS	121.7	56.3	47	56	84	116
LMN	121.0	40.7	49	60	80	120
IHR	121.8	75.9	79	93	110	124
MCN	130.5	319.8	190	235	280	305
JDA	129.6	221.8	144	177	190	206
TDA	123.6	225.3	146	220	250	294
BON	127.6	284.3	107	120	215	234

* Based on 6/02/11 15:42 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127