

The Daily Environmental Redispatch Retrospective

An indepth report for 6/25/2011

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	169	0	1573	44	879	1352	148
HE02	0	167	0	1223	172	782	1242	198
HE03	0	170	0	964	430	928	987	186
HE04	0	167	0	785	425	1700	1235	78
HE05	0	167	0	619	608	1433	965	117
HE06	0	163	75	489	911	1628	1167	88
HE07	0	169	375	176	988	1718	1274	107
HE08	0	209	0	427	733	1241	1568	197
HE09	0	244	0	398	637	1090	1574	17
HE10	0	181	0	425	756	1163	2000	-125
HE11	0	178	0	351	415	1304	2000	-153
HE12	0	238	0	282	439	1387	2000	-142
HE13	0	244	0	284	272	939	2000	-152
HE14	0	321	0	336	162	805	2000	-155
HE15	0	347	0	453	85	730	2000	-172
HE16	0	419	0	516	150	576	2000	-150
HE17	0	431	0	569	82	561	2000	-181
HE18	0	377	0	734	179	544	2000	-172
HE19	0	335	0	908	251	561	1980	-151
HE20	0	334	0	1133	372	619	1740	-119
HE21	0	193	0	1291	162	794	1904	-44
HE22	0	189	0	1799	247	582	2000	121
HE23	0	178	0	1743	225	820	1862	253
HE24	0	174	0	1413	194	791	1563	240
Day Total (MWh)	0	5764	450					
CUMM (MWh)*	10,963		83,895					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI trasmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	124.0	30.1	0	5	19	21
CHJ	116.6	99.4	189	200	210	250
LWG	126.8	62.5	50	61	76	85
LGS	123.9	50.5	52	61	70	95
LMN	123.4	51.0	40	55	75	120
IHR	125.5	91.4	75	85	105	124
MCN	128.4	274.5	190	235	250	290
JDA	127.5	175.3	144	177	190	206
TDA	123.0	180.1	178	210	269	294
BON	132.0	240.2	107	120	215	234

* Based on 6/09/11 14:05 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127