

The Daily Environmental Redispatch Retrospective

An indepth report for **6/29/2011**

	ENV DISPL	Total BPA BA Thermal Generation	ENV RDISP	Total BPA BA Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	179	0	2016	43	700	1368	0
HE02	0	182	0	1953	33	718	1253	-94
HE03	0	183	0	1787	36	758	1220	-32
HE04	0	186	0	1669	130	772	1190	46
HE05	0	188	0	1927	102	672	1149	-33
HE06	0	195	0	1841	93	618	1275	59
HE07	0	196	0	1928	108	861	1659	89
HE08	0	185	0	1865	74	1035	2000	150
HE09	0	190	0	2163	125	768	1903	12
HE10	0	189	0	2429	80	1151	1817	-16
HE11	0	183	0	2756	33	622	1821	68
HE12	0	187	0	2753	39	645	1886	136
HE13	0	181	0	2884	83	646	1802	183
HE14	0	177	0	3089	59	781	1663	215
HE15	0	180	0	3126	43	839	1538	213
HE16	0	188	0	3151	39	748	1777	201
HE17	0	191	0	3257	39	568	1793	203
HE18	0	195	0	3310	42	567	1546	122
HE19	0	195	0	3312	39	857	1361	8
HE20	0	195	0	3150	53	860	1332	-59
HE21	0	188	0	3103	41	487	981	-155
HE22	0	261	0	2774	61	608	1074	-237
HE23	0	272	0	2338	193	620	1339	-146
HE24	0	189	0	2141	112	605	1438	18
Day Total (MWh)	0	4656	0					
CUMM (MWh)*	11,143		86,062					

* Cummulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

The Unused NOB, COB and NI trasmission values reflect total export limits minus total export usage of both BPAT and non-BPAT transmission capacity. BPA Traders sell surplus energy down to no cost to the Agency, which includes the cost of purchasing transmission from transmission services, but can prohibit them from buying third-parties' share of intertie capacity when power prices don't exceed third-party transmission costs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	122.3	32.4	0	15	18	21
CHJ	115.4	86.2	189	200	210	250
LWG	125.1	51.6	45	52	70	85
LGS	119.9	47.1	52	59	70	95
LMN	123.0	61.3	40	55	75	120
IHR	122.0	79.6	75	85	110	124
MCN	125.8	242.8	190	235	245	280
JDA	119.9	138.0	144	177	190	206
TDA	120.8	138.1	135	140	269	294
BON	124.9	209.7	107	120	195	205

* Based on 6/26/11 07:42 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127

The goal of this reports is to highlight when Environmental Redispatch and Environmental Displacement has occurred. Data included in this report should not be used for billing purposes. If you have questions about your bill, please contact your billing representative.