

The Daily Environmental Redispach Retrospective

An indepth report for 6/5/2011

| | ENV DISPL | ENV RDISP | UNUSED INTERTIE CAPACITY | | | MT EXPORT |
|-----------------|----------------|------------|--------------------------|-------|------|-------------------|
| | (Non VER Only) | (VER Only) | (NOB) | (COB) | (NI) | (minus = import) |
| HE01 | 0 | 0 | 495 | 933 | 1567 | 267 |
| HE02 | 68 | 16 | 337 | 1117 | 1465 | 268 |
| HE03 | 68 | 96 | 390 | 1045 | 1516 | 245 |
| HE04 | 69 | 53 | 534 | 1110 | 1325 | 210 |
| HE05 | 68 | 9 | 398 | 1023 | 1179 | 182 |
| HE06 | 69 | 43 | 725 | 1437 | 1349 | 154 |
| HE07 | 40 | 0 | 410 | 1617 | 958 | 166 |
| HE08 | 0 | 0 | 680 | 1215 | 1327 | 221 |
| HE09 | 0 | 0 | 586 | 1243 | 1347 | 251 |
| HE10 | 0 | 0 | 714 | 1584 | 1211 | -17 |
| HE11 | 0 | 0 | 411 | 1372 | 2000 | -81 |
| HE12 | 0 | 0 | 585 | 1261 | 2000 | -102 |
| HE13 | 0 | 0 | 451 | 1135 | 2000 | -146 |
| HE14 | 0 | 0 | 409 | 1242 | 2000 | -186 |
| HE15 | 0 | 0 | 358 | 1271 | 2000 | -158 |
| HE16 | 0 | 0 | 327 | 1127 | 2000 | -149 |
| HE17 | 0 | 0 | 226 | 1457 | 2000 | -168 |
| HE18 | 0 | 0 | 298 | 1278 | 2000 | -89 |
| HE19 | 0 | 0 | 352 | 1168 | 2000 | -141 |
| HE20 | 0 | 0 | 318 | 1048 | 2000 | -134 |
| HE21 | 0 | 0 | 586 | 1015 | 2000 | -171 |
| HE22 | 0 | 0 | 586 | 1175 | 2000 | -258 |
| HE23 | 0 | 0 | 291 | 987 | 1943 | -104 |
| HE24 | 0 | 67 | 363 | 853 | 1378 | 105 |
| Day Total (MWh) | 382 | 284 | | | | |
| CUMM (MWh)* | 6730 | 56713 | | | | |

* Cummulative totals since May 18th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit. (All table values are in MWs.)

Oregon High 12-hour average percent TDG

| | TDG% | Qspill | LEVEL 1 CAP | LEVEL 2 CAP | LEVEL 3 CAP | LEVEL 4 CAP |
|-----|-------|-------------|-------------|-------------|-------------|-------------|
| | (TW) | (Davg-kcfs) | (kcfs) | (kcfs) | (kcfs) | (kcfs) |
| GCL | 142.4 | 100.5 | 19 | 21 | 25 | 32 |
| CHJ | 120.8 | 145.1 | 110 | 140 | 155 | 159 |
| LWG | 120.5 | 50.1 | 50 | 61 | 73 | 86 |
| LGS | 123.5 | 63.2 | 52 | 56 | 84 | 116 |
| LMN | 120.8 | 43.0 | 49 | 60 | 80 | 120 |
| IHR | 121.7 | 83.0 | 79 | 93 | 110 | 124 |
| MCN | 130.5 | 329.9 | 190 | 235 | 280 | 305 |
| JDA | 129.4 | 224.5 | 144 | 177 | 190 | 206 |
| TDA | 125.8 | 240.0 | 146 | 220 | 250 | 294 |
| BON | 130.2 | 290.0 | 107 | 120 | 215 | 234 |

* Based on 6/02/11 15:42 spill priority table

| | TDG% |
|---------|------|
| LEVEL 1 | 120 |
| LEVEL 2 | 122 |
| LEVEL 3 | 125 |
| LEVEL 4 | 127 |