

The Daily Environmental Redispach Retrospective

An indepth report for 6/7/2011

	ENV DISPL	ENV RDISP	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)	(VER Only)	(NOB)	(COB)	(NI)	(minus = import)
HE01	109	700	576	1318	879	103
HE02	109	733	647	1489	416	80
HE03	109	967	620	1863	813	110
HE04	109	1217	935	1752	807	95
HE05	109	667	684	1714	695	97
HE06	0	0	316	1144	989	214
HE07	0	0	511	1246	930	218
HE08	0	0	571	1270	807	186
HE09	0	0	502	895	1018	179
HE10	0	0	490	687	1105	118
HE11	0	0	436	731	1407	23
HE12	0	0	259	617	1476	20
HE13	0	0	330	665	1840	76
HE14	0	0	202	439	2000	175
HE15	0	0	222	443	2000	126
HE16	0	0	365	641	1882	180
HE17	0	0	317	641	1502	134
HE18	0	0	201	834	1290	8
HE19	0	0	199	886	1129	31
HE20	0	0	408	789	872	189
HE21	0	0	250	634	1345	129
HE22	0	0	444	661	1306	78
HE23	0	0	204	551	1641	36
HE24	126	83	488	1237	1250	209
Day Total (MWh)	671	4367				
CUMM (MWh)*	8010	63680				

* Cummulative totals since May 18th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit. (All table values are in MWs.)

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	139.4	68.8	19	21	25	32
CHJ	118.1	118.8	150	160	170	180
LWG	128.3	77.6	50	61	73	86
LGS	127.4	87.1	52	56	75	116
LMN	125.6	76.2	49	55	80	120
IHR	125.6	105.2	79	93	110	124
MCN	132.2	342.9	190	235	280	305
JDA	129.2	230.4	144	177	190	206
TDA	123.3	227.1	146	220	250	294
BON	126.9	291.5	107	120	215	234

* Based on 6/07/11 15:05 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127