

The Daily Environmental Redispatch Retrospective

An indepth report for 6/8/2011

	ENV DISPL	ENV RDISP	UNUSED INTERTIE CAPACITY			MT EXPORT	Total Wind Generation	Total Thermal Generation
	(Non VER Only)	(VER Only)	(NOB)	(COB)	(NI)	(minus = import)		
HE01	0	483	804	1976	963	202	1638	159
HE02	0	450	644	1997	867	184	1502	153
HE03	0	700	1056	2084	1017	184	884	154
HE04	0	642	1182	2075	810	205	788	153
HE05	0	292	1041	1955	1157	202	902	152
HE06	0	0	776	1796	1211	253	1454	149
HE07	0	0	891	2408	1441	235	1689	198
HE08	0	0	1039	2171	887	182	1971	237
HE09	0	0	1000	2158	1031	96	1620	291
HE10	0	0	559	1941	1880	-7	1458	341
HE11	0	0	557	1578	1973	0	1430	281
HE12	0	0	697	1326	2000	-7	1365	366
HE13	0	0	935	1446	1871	-37	1261	380
HE14	0	0	718	1495	2000	-16	1612	382
HE15	0	0	490	1424	2000	-2	1800	372
HE16	0	0	1063	1023	1974	-30	1813	230
HE17	0	0	748	1152	1647	1	1505	256
HE18	0	0	757	1251	1468	-11	1351	253
HE19	0	0	678	1909	1296	-56	1147	230
HE20	0	0	687	1809	928	-163	1002	231
HE21	0	0	594	1441	1870	-150	976	231
HE22	0	0	689	1282	2000	-214	904	224
HE23	0	0	442	1483	2000	-148	592	229
HE24	0	0	343	1718	1568	-35	292	262
Day Total (MWh)	0	2567						
CUMM (MWh)*	8010	66247						

* Cummulative totals since May 1

Comments:

These unused COB and unused NOB amounts reflects the net unused non-firm capacity made available by BPAT, and the net unused capacity (could be either firm or non-firm) capacity of the other COB and NOB path owners. The maximum limit used is the WECC path rating, which may include capacity that may not be available for scheduling due to operational limits. All table values are in MWs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	135.7	51.3	19	21	25	32
CHJ	117.1	126.1	150	160	170	180
LWG	132.2	99.5	50	61	73	86
LGS	129.6	111.4	52	56	75	116
LMN	127.5	104.0	49	55	80	120
IHR	129.4	131.5	79	93	110	124
MCN	139.4	356.0	190	235	280	305
JDA	129.3	233.5	144	177	190	206
TDA	122.3	233.3	146	220	250	294
BON	127.6	292.8	107	120	215	234

* Based on 6/08/11 14:01 spill priority table

	TDG%
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127