

The Daily Environmental Redispatch Retrospective

An indepth report for 6/9/2011

	ENV DISPL	Total Thermal Generation	ENV RDISP	Total Wind Generation	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER Only)		(VER Only)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	210	0	103	985	1361	1511	38
HE02	0	196	0	63	1255	1675	1177	77
HE03	0	201	0	13	1300	1891	1260	60
HE04	0	201	0	12	1437	2242	1279	100
HE05	0	198	0	37	1267	2069	1405	181
HE06	0	193	0	61	1234	1724	1364	298
HE07	0	212	0	98	1683	2180	1586	219
HE08	0	231	0	134	1267	2195	1972	28
HE09	0	303	0	191	1071	2032	2000	-52
HE10	0	375	0	122	900	1997	1888	-55
HE11	0	454	0	49	904	1552	2000	-3
HE12	0	406	0	17	560	1679	2000	-70
HE13	0	492	0	4	583	1486	2000	-94
HE14	0	425	0	6	626	1499	2000	-123
HE15	0	387	0	4	544	1442	2000	-76
HE16	0	405	0	4	503	1545	1869	-66
HE17	0	428	0	8	255	1428	2000	-61
HE18	0	445	0	16	350	1769	2000	-78
HE19	0	418	0	35	359	1961	1858	-51
HE20	0	391	0	95	770	1834	1687	-10
HE21	0	372	0	238	525	1616	2000	-50
HE22	0	351	0	509	495	1425	2000	-93
HE23	0	184	0	458	814	989	1703	58
HE24	0	160	0	293	652	1218	1742	229
Day Total (MWh)	0		0					
CUMM (MWh)*	8010		66247					

* Cumulative totals since May 17th.

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

These unused COB and unused NOB amounts reflects the net unused non-firm capacity made available by BPAT, and the net unused capacity (could be either firm or non-firm) capacity of the other COB and NOB path owners. The maximum limit used is the WECC path rating, which may include capacity that may not be available for scheduling due to operational limits. All table values are in MWs.

Oregon High 12-hour average percent TDG

	TDG%	Qspill	LEVEL 1 CAP	LEVEL 2 CAP	LEVEL 3 CAP	LEVEL 4 CAP
	(TW)	(Davg-kcfs)	(kcfs)	(kcfs)	(kcfs)	(kcfs)
GCL	133.0	46.9	19	21	25	32
CHJ	117.3	89.7	150	160	170	180
LWG	130.4	97.1	50	61	73	86
LGS	129.1	105.3	52	56	75	116
LMN	126.7	96.9	49	55	80	120
IHR	130.6	134.9	79	93	110	124
MCN	137.4	339.8	190	235	280	305
JDA	129.8	239.5	144	177	190	206
TDA	124.2	238.1	146	220	250	294
BON	130.3	296.3	107	120	215	234

* Based on 6/09/11 14:05 spill priority table

TDG%	
LEVEL 1	120
LEVEL 2	122
LEVEL 3	125
LEVEL 4	127