

hydroAMP:
an equipment condition assessment framework

2012 Capital Investment Review Workshop
April 19, 2012
Portland, OR



-
- Equipment reliability significantly affects system generation availability and financial performance.
 - A significant amount of critical equipment in hydro facilities in North America is near or beyond its design life.
 - Substantial investment to repair, refurbish, or replace unreliable equipment is anticipated.
 - The process for identifying and prioritizing investments needs strengthening – capital is a limited resource.
 - Equipment condition assessment tools used in the past have been complex and costly to administer.
 - Establishing an objective, consistent and efficient assessment process is critical for informed decision making.

-
-
- In 2001, the Bureau of Reclamation (BOR), Hydro-Québec (HQ), the Army Corps of Engineers' Hydroelectric Design Center (HDC), and Bonneville Power Administration (BPA) began collaborating on a hydroelectric equipment condition assessment technique that was later named "hydroAMP", or hydro Asset Management Partnership.
 - The hydroAMP Partners worked on the program for 5 years and in 2006, with the publication of a report describing the condition assessment technique, its development and its potential applications, officially rolled out hydroAMP during HydroVision.

hydroAMP Concept




Condition Assessment Principles

- Objective results
- Developed from routine tests and inspections
- Simplified process
- Easy interpretation
- Technically sufficient (valid though not necessarily perfect)
- Consistent and repeatable results
- Start small, expand with time
- Open to improvement

Framework

- A guidebook currently outlines condition ratings for 11 equipment types.
- The guidebook was developed to facilitate asset management decisions using equipment condition assessments.
- The guidance is open and flexible to fit into the existing structure of each utility's maintenance, planning, budgeting and decision-making processes.



-
- Surge Arrestors
 - Transformers
 - Turbines
 - Generators – in revision - 2011
 - Governors
 - Exciters – revised 2011
 - Cranes
 - Batteries
 - Compressed Air System
 - Emergency Closure Gate and Valve

Condition Assessment: Two-Tier Approach

Tier 1

- The rating is based on condition indicators derived from tests, measurements, and inspections that are normally performed during routine O&M activities.
- The assessment results in a “Condition Index” with a rating scale of zero to 10; higher CI means better condition.
- Mid- to low-range values may trigger a Tier 2 evaluation.
- Assessment results are easily entered into CMMS or other databases for tracking and reporting.

Condition Assessment: Two-Tier Approach (cont.)

Tier 2

- Includes in-depth, non-routine tests or inspections that may be invasive and/or require specialized equipment and expertise not normally found at the hydro plant.
- Results are used to adjust the Condition Index score (either up or down).
- Adds confidence to the assessment results and conclusions.

Data Quality Indicator

- Is a stand-alone indicator used to reflect the quality of information available for performing the condition assessment.
- Recognizes that data may be missing, out of date, or of questionable integrity.
- Is important because poor data could affect the accuracy of individual condition indicator scores as well as the validity of the overall Condition Index.

Turbine Example



Tier 1 Condition Index and Data Quality Indicator

Tier 1 condition indicators:

- Age
- Physical Condition
- Operational Limitations
- Maintenance

Condition indicators are scored and weighted, then summed to calculate the Condition Index.

The Data Quality Indicator is scored separately.

Tier 1 Condition Indicator Scoring

Table 1 – Turbine Age Scoring

Age New / Full Rehabilitation	Age Partial Rehabilitation	Condition Indicator Score
0 – 25 years	0 – 15 years	3
26 – 35 years	16 – 25 years	2
36 – 45 years	26 – 35 years	1
> 45 years	> 35 years	0

Summary of Tier 1 Turbine Assessment

Tier 1 Turbine Condition Summary <i>(For instructions on indicator scoring, please refer to condition assessment guide)</i>				
No.	Condition Indicator	Score	X	Weighting Factor = Total
1	Age <i>(Score must be 0, 1, 2, or 3)</i>	2		1.000 2
2	Physical Condition <i>(Score must be 0, 1, 2, 3, or 4)</i>	3		1.000 3
3	Operations <i>(Score must be 0, 0.5, 1, or 1.5)</i>	1.5		1.000 1.5
4	Maintenance <i>(Score must be 0, 0.5, 1, or 1.5)</i>	1.5		1.000 1.5
Tier 1 Turbine Condition Index (Sum of individual Total Scores) <i>(Condition Index should be between 0 and 10)</i>				8

Turbine Data Quality Indicator <i>(Value must be 0, 4, 7, or 10)</i>	4
--	----------

Tier 2 Tests

Tier 2 Toolbox:

- Efficiency
- Capacity
- Off-Design
- Paint Film Quality
- Surface Roughness
- Cracking
- Other Specialized Tests
- Cavitation
- Condition of Remaining Parts
- Environmental
- Operating Conditions
- Maintenance

Tier 2 results are used to refine the Tier 1 score.

The Data Quality Indicator also may be adjusted.

Tier 2 Tests and Condition Index Adjustments

Condition assessment guides also provide criteria for using Tier 2 test results.

Table 12 – Cavitation Damage of Runner and Discharge Ring Test Scoring			Adjustment to Condition Index Score
Cavitation Damage			
Minimal: Stainless – frosting only Carbon – frosting only			Add 0.5
Moderate: Stainless Carbon	Depth < 1/8” < 3/8”	Area < 5% < 5%	No Change
Severe: Stainless Carbon	Depth > 1/8” > 3/8”	Area > 5% > 5%	Subtract 0.5

hydroAMP was intended to be used in conjunction with performing annual maintenance.

- Turbines: As your filling out your performing your cavitation mapping, the hydroAMP turbine assessment should be filled in.
- If you have Tier 2 data, use it: Cavitation, Reliable On-line Efficiency Monitoring, etc.

The idea was to “KEEP IT SIMPLE.”

- Minimal time to perform, if you’re doing it while you are performing maintenance.
- You’re already thinking about the equipment and how it’s performing.

How not to use it:

- Not a paperwork exercise.
- Last minute reporting of condition because of performance measures.

Make it meaningful.

Equipment guides and assessment data and are stored in a secure web-accessible database.

- The database stores and reports Tier 1 condition assessments.
- Adjustments for Tier 2 assessments have recently been added.
- It is expandable to include new plants and equipment.

www.bpa.gov/secure/hydroAMP

Thursday, April 16, 2009

HydroAMP

Home | Condition Assessments | Equipment | Reports | My Account | Help | Logout: jmclune@bpa.gov

Welcome to HydroAMP!

Aging and deteriorating equipment poses significant risk to hydroelectric equipment reliability and may result in low generating unit availability. Significant investment in replacing, repairing or refurbishing existing generation and support equipment within hydroelectric projects is required to assure the continued viability of hydropower assets. The four organizations involved in hydroAMP, the Bureau of Reclamation (BOR), Hydro-Québec (HQ), the US Army Corps of Engineers (COE) and the Bonneville Power Administration (BPA), joined together to develop a common framework or process to streamline, simplify and improve the evaluation and documentation of the condition of hydroelectric equipment and facilities in order to support condition-based prioritization of hydropower asset business decision-making.

A two-tiered approach for assessing equipment condition and risk of failure for hydropower equipment was developed. Tier 1 of the condition assessment process incorporates test results and/or inspections that are normally obtained during routine operation and maintenance activities. These condition indicators are combined to compute an equipment Condition Index. Tier 2 of the assessment relies on more in-depth, non-routine test results and inspections requiring specialized knowledge to further refine the equipment Condition Index.

This website represents an additional effort that was developed in order to allow plants and agencies to input their equipment condition data into a single database in a common format. It also allows for individual plant/utility analysis and reporting.

Please select an option from the list below:

- Condition Assessments**
Input equipment condition data for tier 1 assessment.
- Equipment**
Add, update and delete equipment for specific plants.
- Reports**
View and export condition assessment reports.
- My Account**
View and make changes to your account.
- Help**
Need help? Have comments?

What's New

- 6/4/2008 - On Thursday June 4th between 3:00 and 4:00 pm the hydroAMP system will be unavailable due to a system update. Please make sure that you are logged off the system during this time period. Thank you!
- 2/26/2008 - We are pleased to announce that the Phase II release of the hydroAMP system is complete. Please feel free to look around and experience some of the new features that are available. You can now manage equipment for both Generation facilities and Electrical facilities, many new reports and capabilities are available along with new tools to manage equipment and components within your facilities, the ability to download and upload complete condition assessment information, and many new enhanced features on the administration side that allows for better management from our side as well.

Thanks

Assessment Guides

- hydroAMP Guide Book - September 2006 (pdf)
- Circuit Breakers - September 2006 (pdf)
- Turbines - September 2006 (pdf)
- Transformers - September 2006 (pdf)
- Generators - September 2006 (pdf)
- Governors - September 2006 (pdf)
- Exciters - September 2006 (pdf)
- Surge Arrestors - September 2006 (pdf)
- Cranes - September 2006 (pdf)
- Batteries - September 2006 (pdf)
- Compressed Air System - September 2007 (pdf)
- Emergency Closure Gate & Valve - September 2007 (pdf)

Wednesday, April 04, 2012

HydroAMP

Home Condition Assessments Equipment Reports My Account Help

Logout: jmlune@bpa.gov

< Back

Tier 1 Condition Assessment



Turbine

Plant: **Grand Coulee** Unit: Type:
 Manufacturer: Partial Rehab Year (non runner): Rated Power: (HP)
 Rated Head: (ft) Discharge Diameter: (ft) Speed: (RPM)

Tier 1 Turbine Condition Assessment

(For Instructions on indicator scoring, please refer to the condition assessment guide)

No.	Condition Indicator	Score	x	Weighting Factor	=	Total Score
1	In-Service Year <input type="text" value="1980"/>	2		0.667		1.334
	Partial Rehab Year (runner) <input type="text"/> Age: 32 years					
2	Physical Condition Cracks <input type="text" value="Active Cracks"/>	1		1.25		1.25
	Cavitation and Surface Damage <input type="text" value="Fair Surface/ Moderate Cavitation Damage"/>					
3	Operation Limitations <input type="text" value="No Operating Restraints"/>	1.5		1		1.5
4	Corrective Maintenance <input type="text" value="Moderate Corrective Maintenance"/>	0.5		1		0.5
Turbine Condition Index						4.6
						Marginal

Data Quality Indicator **7**

Tier 2 Turbine Condition Assessment

(For instructions on how to adjust the Tier 1 Condition Index (CI) by conducting Tier 2 tests or inspections, please refer to the condition assessment guide)

Total Tier 2 Adjustment:

In this comment box, please list which of the Tier 2 tests or inspections you conducted and note the incremental adjustment for each that was used in calculating the total adjustment reported above:

Assessment Date:

Certification Information

Last Assessment Date: **10/4/2011**
 Evaluated By: **Strombach, Michael on 10/4/2011**
 Approved By: **N/A**

Refresh

Save Assessment

Approval Review

hydroAMP Database: Powertrain Summary Report

Wednesday, April 04, 2012

HydroAMP

Home | Condition Assessments | Equipment | Reports | My Account | Help | Logout: jmclune@bpa.gov

[< Back](#)

Open Condition Assessment Page

Report Viewer

PRINT Printing: For best results, export and print from Adobe Acrobat or Microsoft Excel

Report Date: 4/4/2012

Condition Index Summary (Power Train)


Plant Name	Unit ID	Generator		Transformer		Turbine		Governor		Exciter		Unit Breaker			
		Rotor	Stator												
		Condition Index	Condition Rating	Condition Index	Condition Rating	Condition Index	Condition Rating	Condition Index	Condition Rating	Condition Index	Condition Rating	Condition Index	Condition Rating		
Grand Coulee	1	5.9	Marginal	7.6	Fair	3.7	Marginal	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	2	5.9	Marginal	8.0	Good	6.6	Fair	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	3	5.9	Marginal	8.0	Good	10.0	Good	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	4	5.9	Marginal	10.0	Good	10.0	Good	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	5	5.9	Marginal	5.3	Marginal	5.8	Marginal	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	6	5.9	Marginal	7.1	Fair	8.1	Good	10.0	Good	6.8	Fair	3.5	Marginal	10.0	Good
Grand Coulee	7	5.9	Marginal	5.3	Marginal	5.8	Marginal	10.0	Good	6.8	Fair	4.6	Marginal	10.0	Good
Grand Coulee	8	5.9	Marginal	7.6	Fair	5.8	Marginal	10.0	Good	6.8	Fair	4.6	Marginal	10.0	Good
Grand Coulee	9	5.9	Marginal	10.0	Good*	10.0	Good	10.0	Good	6.8	Fair	4.6	Marginal	10.0	Good
Grand Coulee	10	6.9	Fair*	8.8	Good*	10.0	Good	10.0	Good*	7.8	Fair*	3.0	Marginal	10.0	Good
Grand Coulee	11	8.1	Good*	9.0	Good*	6.2	Fair	10.0	Good*	7.8	Fair*	4.2	Marginal	10.0	Good
Grand Coulee	12	8.1	Good*	9.0	Good*	4.5	Marginal	10.0	Good*	7.8	Fair*	4.2	Marginal	10.0	Good
Grand Coulee	13	6.9	Fair*	7.7	Fair*	7.3	Fair	10.0	Good*	7.8	Fair*	4.2	Marginal	10.0	Good

-
-
- Access to the database and website is restricted and requires a user account.
 - Accounts may be requested by e-mail to hydroAMP@bpa.gov, by providing the user's first and last name, company, job title, telephone number, and e-mail address. The request should also identify the hydro plants the user wishes to access.
 - The hydroAMP administrator will assign a log-in and password, and send this information via e-mail to the user.


Applying hydroAMP Results in Asset Planning



Current Condition by Plant: All Equipment





Current Condition: Unit Reliability Equipment



Risk: Condition Index vs. Likelihood of Failure

The hydro program correlates a condition rating with the likelihood of equipment failing to perform as expected. An equipment component with a low condition rating has a higher likelihood of failure than one with a higher rating. The correlation is shown below.



Likelihood	Condition Index	Description
	0 to 0.9	Poor
	1 to 1.9	
	2 to 2.9	
	3 to 3.9	Marginal
	4 to 4.9	
	5 to 5.9	
	6 to 6.9	Fair
	7 to 7.9	
	8 to 8.9	Good
	9 to 10	

Current Financial Risk Map


Likelihood	Almost Certain	1 Operations Support	1 Unit Reliability 2 Station Service 8 Operations Support 1 Water Control	21 Unit Reliability 9 Station Service 40 Operations Support 13 Water Control 25 Infrastructure	26 Unit Reliability 10 Station Service 4 Operations Support 5 Water Control 1 Infrastructure	4 Unit Reliability 2 Operations Support 3 Water Control	
	Likely	16 Operations Support	53 Unit Reliability 26 Station Service 19 Operations Support 2 Water Control 1 Infrastructure	92 Unit Reliability 38 Station Service 55 Operations Support 26 Water Control 9 Cranes 17 Infrastructure	182 Unit Reliability 118 Station Service 22 Water Control 11 Cranes	11 Unit Reliability 1 Operations Support 2 Water Control	
	Possible	18 Operations Support	44 Unit Reliability 22 Station Service 8 Operations Support 6 Infrastructure	213 Unit Reliability 33 Station Service 19 Operations Support 46 Water Control 48 Cranes 13 Infrastructure	330 Unit Reliability 63 Station Service 4 Operations Support 20 Water Control 34 Cranes 4 Infrastructure	32 Unit Reliability 2 Water Control	
	Unlikely	6 Operations Support	4 Unit Reliability 6 Station Service 10 Operations Support 2 Water Control 6 Infrastructure	114 Unit Reliability 21 Station Service 16 Operations Support 37 Water Control 4 Cranes 6 Infrastructure	240 Unit Reliability 17 Station Service 1 Operations Support 14 Water Control 7 Cranes 2 Infrastructure	29 Unit Reliability	
	Rare	52 Operations Support 1 Infrastructure	299 Unit Reliability 73 Station Service 43 Operations Support 2 Water Control 3 Cranes 12 Infrastructure	582 Unit Reliability 145 Station Service 69 Operations Support 5 Water Control 66 Cranes 57 Infrastructure	1254 Unit Reliability 62 Station Service 14 Operations Support 21 Water Control 35 Cranes 5 Infrastructure	223 Unit Reliability 1 Operations Support 1 Water Control	

Insignificant	Minor	Moderate	Major	Extreme
< \$ 10K	\$ 10K to \$ 100K	\$ 100K to \$ 1 M	\$ 1 M to \$ 10 M	> \$ 10 M
Consequence				

Risk Level	Low	Medium	High
-------------------	-----	--------	------

Without intervention, condition degrades over time and the risk of equipment failing to perform as expected increases. Three factors influence the prioritization of investments:


- Replacement Cost, Lost Generation Risk, and Direct Cost Risk



The **Total Cost** is the present value sum of replacement and risk costs. The cost minimum of this curve is the point at which cost risk is forecasted to begin growing faster than the benefit of investment deferral. This represents the optimum timing for equipment replacement.

Least Cost Case


- The least cost case represents all equipment being replaced at the cost minima.



Modeling Funding Constraints


When funding constraints are applied, Total Cost for the system (system cost) increases because new investments are deferred past their cost minima.

Large Capital Forecast




System Cost Impacts of Funding Constraints

- System costs increase as funding is further constrained because more investments are deferred past the cost minimum.




Condition by Plant in 2022: Unit Reliability Equipment

Condition by Plant in 2022: Unit Reliability Equipment



Lost Generation Risk by Plant in 2022

Lost Generation Risk by Plant in 2022



Thank you

Jim Clune, P.E.
Hydro Asset Planning
Bonneville Power Administration
jmclune@bpa.gov

