

## PSW Annual Energy Loads 1/ (aMW)

-

<u>Utility</u>	<u>1995</u>	<u>1996</u>	<u>1997</u>	<u>1998</u>	<u>1999</u>	<u>2000</u>	<u>2001</u>	<u>Sources:</u>
So. Calif. 2/	14935	15105	15406	15814	16154	16299	16739	Draft ER92 with CFM-10 adjustments
No. Calif. 3/	12356	12209	11724	11664	11714	11819	11957	Draft ER92 with CFM-10 adjustments
Utah	2688	2747	2814	2881	2956	2019	3115	PacificCorp RAMPP2
Nevada	2269	2310	2370	2429	2495	2554	2629	SPP and NPC
Arizona	5902	6025	6196	6367	6532	6673	6844	WSCC 92
New Mexico 4/	1978	2028	2081	2139	2197	2256	2307	WSCC 92

1/ includes T and D losses

2/ includes SCE, Azusa, Banning, Colton, Anaheim, Riverside, SDG&E, Vernon, and IID

3/ includes PG&E, WAPA, CCSF, NCPA, Redding, Santa Clara, SMUD, CDWR, MID, TID, LADWP, and BGP

4/ includes El Paso Electric

