

**TRANSMISSION GENERAL RATE SCHEDULE PROVISIONS**  
**SECTION III – DEFINITIONS**  
**Redline Version**

**20. INTENTIONAL DEVIATION**

An Intentional Deviation exists if one or more of the following conditions exist:

~~BPA, in its sole determination, may find that an *Intentional Deviation* exists if:~~

- a) a deviation is persistent during multiple consecutive hours or at specific times of the day;
- b) a pattern of under-delivery or over-use of energy occurs; or
- c) persistent over-generation or under-use during Light Load Hours, particularly when the customer does not respond by adjusting schedules for future days to correct these patterns.
- d) the generation schedule (i.e., generation estimate) submitted does not match the sum of the transmission schedules, including transmission schedules for the return of energy (i.e. payback schedules), before the start of that scheduling hour.
- e) Negative deviation (over generation) for 3 or more consecutive hours or positive deviations (under generation) for 3 or more consecutive hours, where deviation exceeds the greater of 15% of schedule or 20 MW for each hour. All consecutive hours meeting this condition are intentional deviation.
- f) No generation estimate submitted for any schedule for any hour or no corresponding schedule to a generation estimate is submitted.