

SERDP & ESTCP

Partners in Environmental Technology
Technical Symposium & Workshop

28-30 November 2000

Treatment of Perchlorate and
Other Contaminates to Produce
Drinking Water

Michael Girard

Aerojet Environmental Site Remediation

Treatment History

Aerojet Site (Sacramento CA)

- Soil & Groundwater contamination primarily VOCs, perchlorate and n-nitrosodimethylamine (NDMA)
- Aerojet is currently operating 5 Groundwater Extraction and Treatment (GET) Facilities
 - Treatment systems utilize air strippers and air stripper / UV oxidation / Bio combinations
- GET Facilities currently treating ~ 12 million gallons per day (47 billion gallons treated to date)

Aerojet's GET E/F Treatment Plant

- Treatment plant influent is groundwater pumped from GET E/F extraction wells
- Flow rate of 4000 gpm as-built with additional 4000 gpm expansion capacity
- Includes
 - Fluidize Bed Reactor Perchlorate / Nitrate
 - UV/OX system VOCs / NDMA
 - Air Stripping Towers VOCs

Aerojet's

Full Scale Perchlorate Treatment Plant


- Continuous flow, granular activated carbon (GAC) fluidized bed reactor (FBR)
- Construction completed in December 1998
- Substrate - Ethanol
- Nutrient - Nitrogen/Phosphorus
- Sand bed filters remove biomass solids from FBR effluent stream

Aerojet's Full Scale Perchlorate Treatment Plant

- 4 Fluidized Bed Reactors available
- Each reactor has a design capacity of
 - 1800 gpm Fluidization Rate
 - 900 gpm Feed Rate
- 4 reactors currently in use with combined feed rate of ~3500 gpm (~875 gpm each)
- Treating ~ five million gallons per day

Aerojet's

Full Scale Perchlorate Treatment Plant

 Bed Reactor	<u>Influent</u>	<u>Effluent</u>
– Dissolved O ₂	5.3 ppm	<0.5 ppm
– ClO ₄	~3500 ppb	<4.0 ppb
– TCE	1500 ppb	1500 ppb
– NDMA	110 ppt	110 ppt
– Nitrate-N	1.5 ppm	<0.11 ppm
– Nitrite-N	<0.076 ppm	<0.076 ppm
– Sulfate-S	6.0 ppm	6.0 ppm
– Ethanol	NA	<1.0 ppm
– pH	~7.5	~7.5





Baldwin Park Operable Unit Pilot Study

- Constructed at Aerojet's Sacramento Facility adjacent to GET E/F Treatment Plant
- Conduct a technology demonstration project that produces potable drinking water
- Evaluate complete treatment train
 - Multiple contaminants
 - Various treatment technologies in series

Pilot Study Objectives

- Construct and operate a pilot treatment system that will demonstrate process performance in a size and configuration applicable to a full scale water treatment system
- Confirm destruction and removal efficiencies for nitrate, perchlorate, VOCs, NDMA, and 1,4-dioxane
- Establish operating parameters to assure optimal, reliable, and consistent treatment performance
- Determine unit process requirements to meet drinking water standards
- Obtain technology approval from DHS for use of the treatment train to produce drinking water in the San Gabriel Basin


Pilot Study Design

- GAC/FB Bioreactor (Full Scale Plant)
- Multimedia Filters
- Air Stripper
- UV/Chemical Oxidation (UV/OX)
- Liquid-Phase Granular Activated Carbon Adsorption (LP GAC)
- Disinfection

Pilot Study Design

<u>Unit Process</u>	<u>Flow Rate</u>	<u>Target Contaminants</u>
GAC/FB Bioreactor	900 - 1500 gpm	Nitrate, Perchlorate
Multi-Media Filter	350 gpm	Suspended Solids, Ethanol, Pathogens
Air Stripper	100 gpm	VOCs
UV/OX System	100 gpm	NDMA, 1,4-Dioxane, VOCs, Pathogens
Liquid Phase GAC	100 gpm	VOCs, Polishing
Disinfection	10 gpm	Pathogens
Lamella Clarifier	25-50 gpm	Biosolids

Process Flow Diagram





Pilot Study Requirements

- ☞ Biological GAC/FB with Multimedia Filtration
 - Bioreactor effluent classified as Surface Water by DHS
 - Does bioreactor effluent contain pathogens?
 - Process stability for regaining performance after an upset event
 - Ethanol utilization efficiency and breakdown products
 - Process consistency in day to day operations
 - Using ORP as a control parameter
 - Biomass characterization
 - Minimum nutrient requirements
 - Cell yield (biological solids production), reaction rates
 - Lowering analytical detection limit for ethanol

Pilot Study Requirements

☞ Multimedia Filter

- Biologically active
- Removal of ethanol breakdown products
- Pathogen removal
- Loading rate
- Influent and effluent turbidity
- Influent and effluent particle counts

Pilot Study Requirements

☞ Air Stripper

- Verify removal efficiencies
- Removal of VOCs, TCE and Chloroform
- Air/Water loading rate

Pilot Study Requirements

☞ UV/Oxidation System

- Low energy design
- Optimize peroxide dose
- Interactions of peroxide, UV absorbance, and NDMA, 1-4 dioxane, and VOC removal
- Correlation between water quality and system performance
- Formation of DBP precursors

Pilot Study Requirements

☞ Liquid Phase GAC

- Removal of any remaining adsorbable compounds
- Final polishing step
- Biological removal of UV/OX breakdown products

Pilot Study Requirements

☞ Disinfection

- Sodium Hypochlorite
- THMs and DBPs
- CT requirements
- Microbial water quality and potential for biological regrowth
- NDMA reformation

Pilot Study Requirements

☞ Reclamation System

- Lamella clarifier
- Type of coagulant and dose
- Loading rate
- Solids production
- Clarified water reintroduced into main treatment train upstream of filter

Pilot Study Sampling Points

Groundwater
FBR4 Influent
FBR4 @ 1 ft
FBR4 @ 3 ft
FBR4 @ 6 ft
FBR4 Effluent
AT Effluent
Filter Influent
Filter Effluent
Air Stripper Influent
Air Stripper Effluent
UV Influent

UV Effluent
GAC Influent
GAC 1/4
GAC 1/2
GAC 3/4
GAC Effluent
Chlorine 0 min
Chlorine 2.5 min
Chlorine 7 min
Chlorine 12 min
Chlorine 17 min
Chlorine 22 min

Waste Biomass
Spent Backwash
Clarifier Influent
Clarifier Effluent
Clarifier Effluent Tank
Clarifier Sludge

Pilot Study Sampling Analytes

Perchlorate	VSS	Plate Count
Chlorate/Chlorite	TVS	Aldehydes
Nitrate	Ethanol	Halos/THMs/CP
Nitrite	Methanol	THMFP
Ammonia	TOC	Acetic Acid
Phosphorus	DOC	Hardness
Sulfate	AOC	Alkalinity
Sulfite	BDOC	UV Absorbance
Sulfur	BOD	Bromide
Sulfide	COD	Bromate
NDMA	F&T Coliforms	TOX
1,4-Dioxane	Giardia/Crypto	Complete Drinking Water
VOCs	Virus	
TSS	Coliphage	

Pilot Study Schedule

- Construction Start Dec 99
- System Start-up Feb 00
- Pilot Plant Operation Mar-Dec 00
- Reporting Monthly
- Final Report
– to EPA and CA DHS Jan 01

Conclusion

- Every site will have unique challenges associated with treatment options
- The intrinsic value of drinking water supplies will necessitate a critical evaluation of treatment options and water reuse issues
- These challenges can be met with a methodical and thorough scientific process

Acknowledgments

- ☞ Harding Lawson and Associates
- ☞ Envirogen
- ☞ Expert Peer Review Panel
 - Perry McCarty Stanford University
 - Rhodes Trussell Montgomery Watson
 - Robert Clark USEPA / NRMRL
 - Michael McGuire McGuire & Associates
 - Rick Sakaji and Gary Yamamoto CA DHS
 - Wayne Praskins EPA Region 9

Contact

Michael Girard

Aerojet
Environmental Site Remediation
Bldg 20001 / Dept. 0330
P.O. Box 13222
Sacramento, CA 95813-6000

916.355.2945

michael.girard@aerojet.com