

Transmission Cost of Service Analysis Workshop

February 8, 2012



Agenda

- COSA Process Scope

- FERC 12 CP Tests
 - FERC Staff Discussion Summary

 - BPA Transmission Planning

 - FERC 12 CP Tests with BPA Data

- ATC: Base Case NT Modeling

COSA Process Scope

- BPA Proposal
- Customer Comments

FERC 12 CP Tests: Summary of Discussion with Commission Staff

Discussion Summary

- 12 CP Analysis
 - Staff has not seen any 12 CP issues recently.
 - 12 CP analysis has usually been for allocation of generation demand cost.
 - Have not seen any cases for pure transmission situations.

Discussion Summary (cont'd)

- 12 CP Tests – Data used for test
- Basic principle is that the CP tests and subsequent cost allocation should be based on utility's system planning.
- For example, if utility plans its system based on long-term firm commitments, then CP tests should reflect:
 - Firm uses only.
 - NITS (NT Service) is load at time of system peak.
 - PTP Service should use long-term reservations.
 - No short-term or nonfirm (should only be included if planned for).
 - Legacy Contracts should be included with long-term demands.
- Analysis should reflect 5 – 10 years of data.

Discussion Summary (cont'd)

- Use of other than 12 CP
 - Staff estimated that 80% of filings are 12 CP.
 - Staff noted that a 3 CP cost allocation was approved for Detroit Edison (1997).
 - Staff was not aware of any recent filings that used 1 CP.

Discussion Summary (cont'd)

- Consideration of “Operating Realities” in addition to system demand.
 - Includes scheduled maintenance, outages, diversity, reserve requirements, and planned off-system sales.
 - Staff said that when 12 CP was developed it was for allocation of generation demand costs.
 - Most of these factors do not apply to transmission.
 - Staff noted they would need to consider how these factors might apply to transmission.

BPA Transmission Planning

BPA Transmission Planning

- BPA plans the transmission system so it will operate reliably to meet its obligations.
- The system must meet NERC and WECC transmission planning performance standards.
- BPA tests system performance using various simulation models (such as power flows).

BPA Transmission Planning

- The power flow models used represent different load-resource patterns.
 - BPA models normal non-coincidental summer and winter peak load conditions, as well as some other conditions as off-peak or heavy winter.
 - Resource patterns vary with season.
 - Base cases have all transmission facilities in service.

BPA Transmission Planning

- Performance testing.
 - Tests are made for a range of probable contingencies so that the system meets NERC and WECC performance requirements.
 - Peak loads conditions must meet all reliability requirements. Normal peak loads used are generally based on a 1 in 2 year probability of occurring.
 - An extra heavy load condition with a 1 in 20 probability is also studied for the main grid for winter, but must meet only single contingencies.

BPA Transmission Planning

- BPA adds facilities to the system for two primary reasons.
 - Reliability – facilities needed to meet existing commitments.
 - Capacity Expansion – to meet new requests for capacity, such as to deliver new generation to loads.
- The need for these facilities is based on the load/resource condition(s) where the performance requirements are not met.

FERC 12 CP Tests with BPA Data



FERC Coincidental Peak Test

- The following shows the results of the FERC 12 CP test for:
 1. Total Transmission System Loading (TTSL) data
 2. Long Term Firm Network Billing Factors data


Data based on FY 2006 - 2011

FERC Coincidental Peak Test based on TTSL

	(A)	(B)	(C)	(D)	(E)	(F)	(G)	
Fiscal Year	Annual Peak (MW)	Annual Average (MW)	Avg of 11 off-peak Months (MW)	Annual Minimum (MW)	Test #1 1-(C)/(A)	Test #2 (D) / (A)	Test #3 (B) / (A)	
1								
2	2006	26,153	22,562	22,236	18,983	15%	73%	86%
3	2007	27,925	24,250	23,915	20,946	14%	75%	87%
4	2008	26,397	24,504	24,332	21,244	8%	80%	93%
5	2009	26,397	22,765	22,435	20,581	15%	78%	86%
6	2010	26,219	22,404	22,057	20,291	16%	77%	85%
6	2011	26,690	23,761	23,495	20,965	12%	79%	89%
7					Average over 6 years:	13%	77%	88%
8					12 CP condition:	≤ 19%	≥ 66%	≥ 81%

9 Data is monthly transmission system peak (maximum hourly TTSL)

Six year Monthly Average of Monthly Peak TTSL (2006 - 2011)





FERC Coincidental Peak Test Based on Long-Term Firm Network Billing Factors (2006 – 2011)

	(A)	(B)	(C)	(D)	(E)	(F)	(G)	
Fiscal Year	Annual Peak (MW)	Annual Average (MW)	Avg 11 off-peak Months (MW)	Annual Minimum (MW)	Test #1 1-(C)/(A)	Test #2 (D) / (A)	Test #3 (B) / (A)	
1								
2	2006	28,255	27,536	27,471	26,606	3%	94%	97%
3	2007	31,844	29,988	29,820	28,713	6%	90%	94%
4	2008	31,594	30,203	30,076	29,222	5%	92%	96%
5	2009	33,457	30,978	30,753	29,376	8%	88%	93%
6	2010	35,505	31,913	31,586	30,892	11%	87%	90%
6	2011	33,949	32,389	32,247	31,559	5%	93%	95%
7					Average over 6 years:	7%	90%	94%
8					12 CP condition:	≤ 19%	≥ 66%	≥ 81%

9 Note: Data based on Network Integration load at Tx System Peak plus LT PTP and Legacy FPT and IR reserved capacity (billing factors)

Monthly Average Long-term Billing Factors (2006 - 2011)

6 year Monthly Avg of LT Firm Sales (aMW)



Modeling in Base Cases

- Regional loads are modeled in the **four** seasonal base cases.
 - January (Nov-Feb), May (Apr-May), June (June only) and August (Jul-Aug).
 - Results of the base cases are extrapolated across the remaining months.
- Each case uses **monthly** 1-in-2 non-coincidental peak load forecasts.
- Cases assume that federal generation serves **all** NT load, unless there is a DNR.
- In the real-time horizon, when schedules are received the difference between what is scheduled and reserved is released to the non-firm market.
 - For 100 MW reservation BPA receives a 75 MW schedule, therefore 25 MW is released to the non-firm market.

Next Steps

- Discussion on customer proposals for other options of allocation.
- Availability of Transmission Rate Analysis Model for customers.
- Next workshop: March 7, 2012