

# FERC Coincidental Peak Test

# FERC Coincidental Peak Test

## Based on Network Transmission Billing Factors

	(A)	(B)	(C)	(D)	(E)	(F)	(G)	
Fiscal Year	Annual Peak (MW)	Annual Average (MW)	Avg 11 off-peak Months (MW)	Annual Minimum (MW)	Test #1 1-(C)/(A)	Test #2 (D) / (A)	Test #3 (B) / (A)	
1								
2	2006	29,428	26,675	26,424	24,325	10%	83%	91%
3	2007	30,067	28,676	28,549	27,274	5%	91%	95%
4	2008	35,719	29,992	29,471	27,549	17%	77%	84%
5	2009	32,288	30,218	30,029	27,707	7%	86%	94%
6	2010	34,589	31,159	30,847	29,319	11%	85%	90%
7					<b>Average over 5 years:</b>	<b>10%</b>	<b>84%</b>	<b>91%</b>
8					<b>12 CP condition:</b>	<b>≤ 19%</b>	<b>≥ 66%</b>	<b>≥ 81%</b>

9 Note: Data based on NT load at Tx System Peak plus Average Monthly PTP (LT & ST) and IR reserved capacity (billing factors)

# Five-Year Avg Monthly Peak Billing Factors (2006 through 2010)

