

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
558th Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, December 4, 2008

Work Order No.: NRC-2568

Pages 1-336

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 558TH MEETING

5 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

6 (ACRS)

7 + + + + +

8 THURSDAY,

9 DECEMBER 4, 2008

10 + + + + +

11 ROCKVILLE, MARYLAND

12 + + + + +

13 The Advisory Committee met at the Nuclear
14 Regulatory Commission, Two White Flint North, Room
15 T2B3, 11545 Rockville Pike, at 8:30 a.m., Dr. William
16 Shack, Chairman, presiding.

17 COMMITTEE MEMBERS PRESENT:

18 WILLIAM J. SHACK, Chair

19 MARIO V. BONACA, Vice Chair

20 SAID ABDEL-KHALIK, Member at Large

21 JOHN SIEBER

22 SANJOY BANERJEE

23 JOHN W. STETKAR

24 J. SAM ARMIJO

25 DANA A. POWERS

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

COMMITTEE MEMBERS PRESENT (CONT.)

DENNIS C. BLEY

MICHAEL T. RYAN

OTTO L. MAYNARD

CHARLES H. BROWN, JR.

HAROLD B. RAY

MICHAEL CORRADINI

GEORGE E. ASPOTOLAKIS

ALSO PRESENT:

RICH MILLER

IRA POPPEL

STEVE KIMURA

AMY CUBBAGE

IAN JUNG

DENNIS GALVIN

HULBERT LI

DEREK WIDMAYER

JIM DAVIS

CHRISTIAN ARAGUAS

HOSUNG AHN

GARY STIREWALT

SARAH GONZALES

CLIFF MUNSON

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

BRUCE MUSICO

ALSO PRESENT: (CONT.)

WEIJUN WANG

BRET TEGELER

CARL CONSTANTINO

JOHN MA

PAUL CLIFFORD

KEN YUEN

WILLIAM RULAND

RALPH MEYER

RICHARD LOBEL

MARTY STUTZKE

BOB DENNIG

JACK ROWE

ZEYNA ABUDLLAHI

DESIGNATED FEDERAL OFFICIAL:

SAM DURAISWAMY

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

C O N T E N T S

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

Opening Remarks by the ACRS Chairman 4

Chapters 7 and 14 of the SER Associated with
the Economic Simplified Boiling Water
Reactor (ESBWR) Design Certification
Application 7

Early Site Permit Application and the Final SER
for the Vogtle Nuclear Plant 85

Status of Staff Activities Associated with
Potential Revision to 10 CFR 50.45(b) 171

NRC Staff's Initial White Paper on
Containment Overpressure Credit Issue 232

Adjourn

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P R O C E E D I N G S

1
2 CHAIR SHACK: The meeting will now come to
3 order. This is the first day of the 558th meeting of
4 the Advisory Committee on Reactor Safeguards.

5 During today's meeting the committee will
6 consider the following:

7 Chapters 7 and 14 of the SER associated
8 with the ESBWR design certification application; early
9 site permit application and the final SER for the
10 Vogtle Nuclear Plant; status of staff activities
11 associated with potential revision to 10 CFR 50.46(b);
12 and the NRC staff's initial white paper on containment
13 overpressure credit issue; and preparation of ACRS
14 reports.

15 A portion of the session dealing with the
16 ESBWR design certification application may be closed
17 to protect proprietary information applicable to this
18 matter.

19 This meeting is being conducted in
20 accordance with the provisions of the Federal Advisory
21 Committee Act.

22 Mr. Sam Duraiswamy is the Designated
23 Federal Official for the initial portion of the
24 meeting.

25 We have received no written comments or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requests for time to make oral statements from members
2 of the public regarding today's session.

3 Representatives of the Tennessee Valley
4 Authority will be on the phone bridge line to listen
5 to the discussion regarding the staff's initial white
6 paper on containment overpressure credit.

7 To preclude interruption of the meeting,
8 the phone line will be placed in a listen-in mode
9 during the presentations and committee discussion.

10 A transcript of portions of the meeting is
11 being kept, and it is requested that speakers use one
12 of the microphones, identify themselves, and speak
13 with sufficient clarity and volume so they can be
14 readily heard.

15 Our first item this morning is chapters 7
16 and 14 of the SER, design certification, and Mike will
17 be leading us through that.

18 MEMBER CORRADINI: Thank you, Mr.
19 Chairman.

20 So for all the members, just to remind you
21 where we are, we had a subcommittee meeting yesterday
22 afternoon on chapter 7. This was kind of a postponed
23 subcommittee meeting. We had originally scheduled
24 both 14 and 7 in October, and because of some
25 procedural things we weren't able to cover chapter 7

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 at that time.

2 So yesterday we went over chapter 7 with
3 open items, of the SER, that is, and GEH and the staff
4 presented where they are on those issues. So we're
5 going to have essentially a more summarized version of
6 that today. I didn't want to take up six hours of
7 your day when we're short of time.

8 So we'll start with Mr. Ira Poppel from
9 GEH will lead the discussion and Rich Miller and Steve
10 Kimura are both here to join in as necessary.

11 Ira.

12 MR. POPPEL: My name is Ira Poppel. I
13 work for GEH, and I am involved in the CNI Group and
14 the overall configuration of the ESBWR DCIS.

15 Previously I had done similar things for
16 the Lungman project on the ABWR.

17 This is a necessarily abbreviated
18 presentation, but we just want to give you an overview
19 of what the DCIS looks like.

20 MEMBER APOSTOLAKIS: Would you please
21 spell out the acronyms the first time you use them?

22 MR. POPPEL: Oh, I --

23 MEMBER APOSTOLAKIS: I think there is a
24 number of them coming up. So DCIS, what is that?

25 MR. POPPEL: Distributed control and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information systems.

2 MEMBER APOSTOLAKIS: Thank you very much.

3 MR. POPPEL: The ESBWR has very few of the
4 traditional hard wired switches, panel meters,
5 recorders, indicators, and controllers. It's
6 essentially in both the safety and nonsafety side, for
7 want of a better word, computer type controllers.

8 This is an overview of the DCIS. There
9 are several ways to present what the system looks
10 like. This is a very, very broad functional overview.

11 The interconnections are functional; they are not
12 meant to be specific.

13 In the lower left side you can see the
14 four safety divisions -- QDCI -- we call that QDCIS,
15 safety DCIS, and they are organized such that we have
16 multiplexing coordinate in the field, the field being
17 just the reactor building for the safety equipment.
18 And in the control building in what is sometimes
19 referred to as the back panel area or the QDCIS rooms,
20 we have four divisional QDCIS rooms that are in
21 separate fire zones from each other and from the main
22 control room.

23 The safety-related equipment is -- this is
24 another way of looking at the same picture, and in
25 this case we have -- and still in the lower left is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 QDCIS, but what this chart adds to it is what
2 functions are being accomplished by what boxes.
3 Again, functionally.

4 So if you look at QDCIS, you can see that
5 we are doing the reactor trip, we are doing neutron
6 monitoring, we are doing ECCS systems and safety-
7 related information systems.

8 It connects through gateways. Basically
9 there is physical, electrical, and data isolation of
10 the signals going from safety to nonsafety, and then
11 it goes into the nonsafety system.

12 The nonsafety systems are organized into
13 segments, so the important concept is in a traditional
14 DCIS you can refer to concepts like "the network."

15 In fact, there are five networks, each of
16 which are dual redundant in this system, and although
17 they are not the same sort of isolation you would
18 think about with safety, the networks -- the five
19 individual networks are capable of working
20 independently of one another and do not need
21 information from any of the other networks.

22 So, for example, in the unlikely event the
23 dual redundant PIP -- it means plant investment
24 protection -- network goes down, PIP A, it does not
25 affect the operation, control, monitoring of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 segment equipment and information on PIP B.

2 So normally if you look at the main
3 control room, all of these nonsafety displays here are
4 available to do any nonsafety function that the
5 operator wants. But as parts of the networks degrade,
6 as these things fail, it will gracefully fail into so
7 some displays won't work but others will.

8 So normally the segmentation is
9 transparent to the operator, but we are very well
10 assured of the fact that the system will degrade very
11 gracefully.

12 There is a balance of plant network which
13 is what you would consider to be traditional power
14 generation type stuff, okay, turbine generator
15 control, et cetera.

16 All of the equipment on these networks is
17 dual redundant at least; some are triply redundant.
18 So we expect a lot less transients to be caused by the
19 C&I system because there are no single failures in the
20 C&I portion, control instrumentation portion of the
21 design. Okay.

22 And this is generally called the unit data
23 highway, but it's basically the collection of the five
24 network segments, and we have a bridge to the plant
25 data highway which is basically lesser important

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things, like printers, okay.

2 So you might consider this the control
3 network, and you might consider this like a utility
4 type network.

5 The control network is unique also in that
6 the data on it is not ethernet TC PIP. It is not a
7 protocol where you can say, hey, I want your
8 attention, listen to me, I'm telling you something.

9 The controllers on that network are -- use
10 what's called ethernet global data, which means they
11 are programmed to look for things on the network, but
12 can't be forced to.

13 In other words, their application code
14 determines what it is they look at. Somebody else
15 can't come in and say, listen to me. They will ignore
16 that. That obviously has cyber security and network
17 security implications.

18 The other thing associated with that is
19 although we could -- I use the word control network.
20 The controllers are set up. We have many, many dual
21 and triple redundant controllers, and they are set up
22 such that the controller has remote data acquisition
23 in and out suitable for its function connected to it.

24 So, in other words, it doesn't have to ask
25 another controller for what reactor level is in order

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to control level. That controller measures level
2 itself, does the algorithms, and outputs to the feed
3 pumps all on its own little -- I'm using the word
4 network, but that's not the right way to phrase it.

5 But the idea is it's autonomous. So, in
6 other words, if this whole network was somehow flooded
7 with the traditional data storms or spoofing or bad
8 guys, these controllers continue to work autonomously.
9 They do not need the network.

10 Okay. So what we do use it for, you know,
11 is to provide operator inputs to things, and of course
12 for the controllers to send out information so that
13 the operators can see.

14 But the important thing is that if they
15 don't get any control inputs, they'll just operate at
16 their last known values.

17 It also happens to be -- these are -- we
18 call them managed network switches. They have far
19 more capabilities than a traditional ethernet switch.

20 So, for example, you might imagine a
21 switch which has, you know, 25 ports on it, and we
22 determine what gets plugged into the port and set up
23 the switch to say, okay, this is your configuration.
24 And so when somebody comes along with a laptop and
25 plugs into a port, the switch says, I don't know you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm not going to listen to you.

2 Okay. So -- and other things that it does
3 -- I can't get too far into cyber security in an open
4 meeting, but other things it does is it recognizes
5 traffic on its ports.

6 So, in other words, if a controller
7 decided to go completely berserk and flood that
8 switch, the switch will turn off the port.

9 And since everything is dual ported to two
10 switches, the processes still continue. So, in other
11 words, it's an ethernet switch that has all the
12 traditional functions of switches but has a lot more
13 functions in terms of what you might call network
14 security and network management.

15 And, of course, all these things that when
16 the switch determines that somebody is trying to do
17 something bad, the switch will of course end up with
18 an alarm in front of the operator, so that it won't be
19 silent, that this is happening.

20 So we have the controllers that very well
21 protect themselves from being talked to. We have the
22 switches that very well protect the controllers. We
23 have these bridging work stations between the two
24 networks, and then we have what you consider to be the
25 traditional firewall which is much more than a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 traditional firewall, but without getting into great
2 detail now, this is where the outside world is.

3 So the firewall is set up to be two
4 computers, two redundant computers, with a shared
5 memory between them.

6 So on this side of the plant, the internal
7 computers scarf up everything, whatever there is to
8 know about the plant, and dump it into a shared
9 memory.

10 So the only function of that computer is
11 to write into shared memory, and that is a very easy
12 function to verify.

13 It of course has no ability or programming
14 to read from the shared memory; it just dumps in.

15 On the other side of the shared memory are
16 the external processors. The external processors of
17 course can only read the shared memory but don't write
18 to it. And even if they did, of course, the internal
19 ones would ignore it.

20 So from the point of view of the external
21 processors, the data appears by magic in the shared
22 memory locations. Here's reactor level, here's
23 reactor pressure. I have no idea how those numbers
24 got there. I didn't ask for them, I don't know the
25 addresses of any internal stuff in the plant to even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 begin to ask for them.

2 If somebody completely spoofed me and
3 said, hey, shut me down, they still can't get through
4 the shared memory into the plant to control stuff.

5 The other important thing to say about
6 that concept is we don't have any other ports into the
7 plant. So, you know, there's not places for business
8 networks and stuff like that to plug into the plant
9 control system.

10 So basically we allow no external input
11 from the outside world, and what the outside world
12 sees from us is what we choose to put across the
13 shared memory.

14 MEMBER BANERJEE: What are the external
15 functions that you're --

16 MR. POPPEL: Technical support center,
17 emergency offsite facilities, nuclear data link, the
18 utility's business network, or the utility's
19 engineering network.

20 So they -- now the external computers have
21 like a traditional firewall function, so they will be
22 programmed to say this is a good guy who is allowed to
23 talk to me, and this is the kind of data we're allowed
24 to send across.

25 However, that computer only knows what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the shared memory. It has no ability to query the
2 inside computers in the plant. Okay.

3 So if we don't send it over, nobody gets
4 it, and we don't accept any data from somebody coming
5 in. Okay.

6 We believe that to be -- and, of course,
7 if they did get here, then they would be on this
8 network where the managed switches would basically be
9 saying, who are you? I'm not going to let you talk to
10 anybody.

11 So the point of all of this is that cyber
12 security and network security isn't a box we put in
13 there. It's baked into the system all the way
14 through.

15 And so in that context, the data isolaters
16 that go from safety to nonsafety are in fact just part
17 of that cyber security. But of course the software
18 and hardware for that is safety related, where the
19 other stuff is nonsafety related, but the function is
20 the data doesn't come backwards through the system and
21 it gets harder and harder and harder as you go further
22 in to do stuff.

23 And, of course, the safety systems are
24 organized into the reactor trip system, the ECCS
25 systems, and we have a special more or less not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 programmable hardware-software platform for ATWS/SLC
2 and vacuum breaker isolation function. They are not -
3 - they do not use multiplexing, they are hard wired,
4 et cetera, but they are safety related.

5 We have -- the system is deterministic.
6 We had some discussion about that yesterday, but that
7 should be understood to mean it's not event driven,
8 it's time driven. I'm going to look at reactor level
9 every X milliseconds, I don't care what else is going
10 on, that's how often I'm going to look at it in order
11 to make a decision as to whether or not to trip.
12 That's fairly standard stuff.

13 We have four divisions, and the four
14 divisions are used because we have -- the only data
15 that is shared between divisions is that data needed
16 to support two out of four voting.

17 And so all initiations, scrams, are any
18 two unbypassed light parameters will cause the trip.
19 So -- or we could send tons of information over the
20 intradivisional networks. We don't. What we send is
21 the trip status, the bypass status, and whatever we
22 need to do message authentication, say this is a
23 legitimate message coming from the other division.

24 Other than that, the divisions are
25 completely autonomous, they stand alone, they do not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 require any backwards information from nonsafety in
2 order to do their functions.

3 In fact, the nonsafety part of the system
4 could be not there, it could be broken, the fiber
5 could be disconnected, it doesn't matter. The safety
6 systems will still work autonomously.

7 The other thing is that our reactor trip
8 platform -- by platform I mean a hardware and software
9 operating system, chassis -- is different from the
10 ECCS. So they are not using the same operating
11 systems. They are not using the same hardware. They
12 are separate.

13 That carries through to the transmitters,
14 sensors, whatever you -- so, in other words, if ECCS
15 did one needs reactor level and reactor trip needs did
16 one needs reactor level, two separate transmitters.

17 So the two safety systems, if you will,
18 are not interconnected in the stuff that they have to
19 do. They can do all their safety functions by
20 themselves.

21 MEMBER BANERJEE: Are the electronic
22 components, diverse in design and manufacture as well,
23 or --

24 MR. POPPEL: Yes. Our product for the
25 reactor trip and neutron monitoring system is NuMAC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You may have heard the name. It's both a retrofit and
2 is on the AWBR.

3 SSLC/ESF, which is the ESF function, is
4 being done with Tricon, the Triconic system. That's a
5 triply redundant platform per division, and the
6 neutron monitoring and reactor trip stuff is NuMAC, no
7 common operating systems, no common hardware. Okay.

8 And that, incidentally, carries through --
9 we'll see that when we get to the diversity chart.

10 MEMBER STETKAR: I was just answering
11 Sanjoy.

12 You answered relative to the digital
13 platforms. Since you have large numbers of input
14 transducers, transmitters, whatever you call them, the
15 analog input devices -- for example, you mentioned
16 reactor vessel level, there might be 12 levels
17 transmitters for the reactor protection SSLC/ESF and
18 the diverse protection system, for example, or the
19 nonsafety equipment.

20 Are those sensors also diverse in the
21 sense -- from different manufacturers or are they
22 same, essentially the same equipment? Are all 12 of
23 them --

24 MR. POPPEL: No. The BWR as a fleet has
25 talked about that issue before. But essentially they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all use the same type of differential pressure
2 technology.

3 MEMBER STETKAR: Same manufacturers?

4 MR. POPPEL: They don't have to be, but we
5 didn't see any diversity gains in making them
6 different manufacturers.

7 MEMBER BLEY: The last time we looked at
8 that, some other manufacturers sold devices, but they
9 had the Rosemont internals.

10 MEMBER STETKAR: Okay. I didn't want to
11 get down to a specific. Thanks.

12 MR. POPPEL: Where we can do things --
13 like, for example, when we measure temperature, say,
14 for the feedwater temperature trip -- I don't want get
15 into too detailed -- the safety systems use
16 thermocouples and the nonsafety systems use RTDs. So
17 some places it's easy, and we do do that.

18 MEMBER STETKAR: I was more concerned
19 about, you know, the levels, pressures, flows, that
20 kind of stuff.

21 MR. POPPEL: Yes.

22 MEMBER BANERJEE: All of those
23 measurements are made how, for the flows?

24 MR. POPPEL: We don't have any -- yes, we
25 do have safety-related flow. They are also made by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 differential pressure measurements.

2 MEMBER BANERJEE: Orifices or venturis or
3 something?

4 MR. POPPEL: Yes, orifice venturis, yes.

5 This also applies to the nonsafety
6 systems, but I just want to show the example.

7 All of our DCIS components have redundant
8 power supplies, and the whole component will work off
9 of either. Each component has two power feeds, and
10 the two power feeds each have their own inverter and
11 battery systems.

12 So, in other words, we can lose one
13 battery, one inverter, one AC power feed, and the
14 entire system keeps working.

15 One of the reasons this was done is --
16 I'll say in a minute. But the important thing is it
17 supports the self-diagnostics because obviously if the
18 problem was power, and you only had one of them, you
19 wouldn't hear too much from the system.

20 So we end up with, you know -- we have to
21 ability to pretty much diagnose almost anything that
22 happens in that design.

23 Another thing that is very unusual about a
24 passive plant compared to an active plant, this plant
25 was designed to be N-2.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Basically what that means is we can
2 deliberately have a safety division out of service,
3 completely out of service, and we can take a single
4 random failure and we will have two divisions left
5 that will operate all the ECCS, not just Div. 1, Div.
6 2 of the ECCS.

7 Obviously you can't do that with a motor,
8 but what we have, for example, is all of our safety
9 valves are either explosive squib valves or solenoid
10 valves, or air-operated solenoid valve.

11 So we typically have multiple divisions on
12 that valve, so that, in other words, what I'm talking
13 now is DCIS, not mechanical.

14 We do have analyses for mechanical valve
15 failures, but assume that the valve works, okay, it
16 can work from division 1, division 2, division 3, and
17 in a diverse protection system that I'll discuss a
18 little bit later.

19 So the same valve can be operated by any
20 one of four systems. And that's how we can say that
21 all of the ECCS works even though two divisions are
22 completely gone.

23 Obviously that only works with a passive
24 plant and, you know, not anything like active motors
25 and pumps like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We mentioned that the safety systems are
2 diverse amongst themselves. The safety systems are
3 also -- this may be a hard thing to see. The safety
4 systems here are meant to -- this is meant to indicate
5 that they are diverse from the nonsafety systems, so
6 the nonsafety systems have a different hardware-
7 software platform than the safety systems.

8 This one is meant to indicate -- I'll talk
9 a little bit about the severe accident deluge system,
10 but the bottom line is the thing that operates the
11 deluge system is in fact diverse from safety and
12 nonsafety.

13 Then on the top line -- oh, also still on
14 the middle line, a new control system for the ESBWR
15 that has not previously been on any other BWR is the
16 diverse protection system that is a nonsafety system
17 that has been added to address common cause failure of
18 the safety systems.

19 That box has the ability to scram the
20 plant, isolate the plant, and ECCS functions, a subset
21 of them.

22 But the bottom line is that's this, and
23 it's diverse from these. So by definition it ought to
24 be common-cause-failure proof for failures of the
25 safety system. The thing that's addressing that has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to be diverse from the safety systems. Okay.

2 The nonsafety system, I had already
3 mentioned to you is divided up into the five segments.

4 Okay. The nonsafety system, even though it's
5 nonsafety, is in two different DCIS rooms that are not
6 the same rooms as the QDCIS rooms, and those rooms are
7 in different fire zones, and those rooms are separate
8 from the main control room fire zone.

9 So, in other words, all of our DCIS back
10 panel rooms are fire zone physically separate from
11 each other and from the main control room, and from
12 the remote shutdown panel.

13 We had a -- oh. I had mentioned the fire
14 zones. The nonsafety DCIS, like the safety, is
15 powered with two or three uninterruptible power
16 supplies, so it has the same robustness and power as
17 do the safety systems, and also the same diagnostic
18 capabilities if power goes away.

19 I mentioned we don't use the networks for
20 closed loop control, and the components are diverse.

21 The diverse protection system, this is a
22 little more detail about that, is the way the diverse
23 protection system works is we analyze the chapter 15
24 events, accidents and transients, assume the safety
25 systems have suffered a common-cause failure, and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 compare the results to 10 CFR 100.

2 Should that not be successful, we add the
3 function to the DPS system. So the DPS has a back-up
4 scram function. It doesn't have anticipatory scrams
5 like say control valve fast closure because if you
6 didn't have a control valve fast closure, you will
7 surely go out on flux or pressure with just a slight
8 delay. The delay is fine with 10 CFR 100 limits.
9 Okay.

10 MEMBER APOSTOLAKIS: Would you explain,
11 please, what you mean by common-cause failure?

12 MR. POPPEL: It's not well defined except
13 to say that for some reason all of the safety systems
14 simultaneously stop working. They will not perform
15 their functions. They will not scram and they will
16 not isolate, and they will not initiate ECCS.

17 MEMBER APOSTOLAKIS: Based on software?

18 MR. POPPEL: Because something in the
19 system, even though these divisions are asynchronous
20 between them is, as I described, the assumption is
21 they're gone.

22 MEMBER APOSTOLAKIS: So you are not really
23 looking for the causes of the common-cause failure,
24 you are saying if it happens, I have a way of managing
25 it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. POPPEL: We already tried the argument
2 about it ain't going to happen, and that's not the
3 answer. The answer is it happened.

4 MEMBER APOSTOLAKIS: You are managing the
5 failure due to some cause.

6 MR. POPPEL: Yes.

7 MEMBER APOSTOLAKIS: And you are not
8 exploring what the cause might be.

9 MR. POPPEL: Well, I mean obviously if we
10 found something that could cause a common-cause
11 failure, it would never make it through our software
12 QA, obviously.

13 But the point is we didn't cover
14 everything. The important thing is the diverse
15 protection system, if it needs to scram on level, it
16 has its own level and it's not the same level as the
17 safety system transmitters.

18 MEMBER CORRADINI: Just to say that a
19 different way, so this is in itself its own division.

20 It has its own sensor, its own controller, its own
21 feedback to this, so it's just another division.

22 MR. POPPEL: Yes, but it's a very special
23 division in this way: It's a triply redundant
24 controller. Because it's nonsafety and because we
25 want it to be very reliable, as do our utilities in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 terms of not inadvertently doing things, okay,
2 nonsafety is allowed to talk to each other, so you get
3 a lot more robust control system if you have triple
4 redundancy, and the controllers can diagnose
5 themselves.

6 We also don't make it fail-safe, unlike
7 the reactor protection system, because it's a back-up
8 to a back-up to a back-up, and it doesn't have one
9 level transmitter, it has four.

10 So the three -- the triply redundant
11 controllers are each doing two out of four logic for
12 say reactor level, reactor pressure, suppression pool
13 temperature, et cetera.

14 MEMBER CORRADINI: So the different
15 sensors, four of them, and they're voting for each of
16 the three controllers?

17 MR. POPPEL: Well, each of the controllers
18 sees all four sensors.

19 MEMBER CORRADINI: I'm sorry, I'm sorry.
20 You said it better.

21 MR. POPPEL: But the important concept --
22 I mean we're making it very reliable to scram and very
23 reliable to not scram inadvertently. But the point is
24 that hardware-software platform and those transmitters
25 and stuff are separate and get to the actuators in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 separate path, and in other words, they don't tell the
2 reactor protection system to scram, they separately
3 interrupt con to the scram solenoids.

4 So, in other words, we don't assume
5 anything that is working in the safety systems.

6 MEMBER CORRADINI: Okay.

7 MR. POPPEL: Now, as I said, it's a
8 subset. We don't isolate and scram on everything, but
9 what we do isolate and scram in ECCS on is enough to
10 get us through the 10 CFR 100 limits.

11 MEMBER CORRADINI: Can I ask an opposite
12 question? So you said you used the 10 CFR 100 limits.

13 What things did you not need to have a back-up for?

14 MR. POPPEL: So far that's an -- because
15 early analyses are not yet done, I can't answer that,
16 but for example, one thing I can answer you is the
17 example I just gave about the reactor will typically
18 scram on a turbine trip, it will measure the stop
19 valve, you know, fast closure and scram.

20 MEMBER CORRADINI: And you decided that
21 wasn't necessary?

22 MR. POPPEL: Right. Because that's an
23 anticipatory scram in the real reactor protection
24 system, but if you never had it, you would go out on
25 pressure or flux.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So basically what happens is you get a
2 scram, it just has a longer delay in it than --
3 delayed meaning, you know, tens of milliseconds as
4 opposed -- before you actually get the scram from the
5 DPS system.

6 MEMBER BROWN: Just to reiterate and
7 emphasize one point, Michael, that you brought out, is
8 that all four sensors feed all three of the triply
9 redundant controls. In the reactor protection system,
10 there's four water level sensors also, but it's only
11 one feeds each division.

12 So I just wanted to explicitly say what
13 that difference was, for the pressure level, nuclear,
14 whatever, ad nauseum.

15 MR. POPPEL: The IEEE-603 independence of
16 divisions wouldn't let us do the things that a single
17 triply redundant controller could do.

18 MEMBER CORRADINI: Got it.

19 MR. POPPEL: Okay.

20 MEMBER MAYNARD: I think you covered this,
21 but I wanted to make sure I understand. On the
22 diverse system, it will actuate if the safety system
23 fails to. Is there any way that -- there isn't any
24 communication between the two systems, though, is
25 there, where the safety system can't tell the diverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 system to not work?

2 MR. POPPEL: That is correct. And a
3 specific example of say the reactor scram, you may
4 recall that the boiling water reactor has two scram
5 solenoids, and they are energized to not scram. So
6 the reactor protection system has all the fancy load
7 drivers and stuff, if you will, in the 120-volt supply
8 to those solenoids, and then the diverse protection
9 system has a switch in the 120-volt return from those
10 solenoids.

11 So neither one can prevent the other from
12 scrambling, okay, and but of course that means either
13 one could scram you, so we want to make sure it's
14 reliable in terms of not scrambling you when you don't
15 have to scram.

16 MEMBER BROWN: Relative to the diverse
17 protection system, to the normal four divisions
18 reactor protection system, do you try to provide some
19 difference in set points so that the diverse
20 protection system wouldn't sense that it would need to
21 scram and the regular protection system would say,
22 hey, I'm happy? They're higher or lower, whatever the
23 --

24 MR. POPPEL: There has been a lively
25 discussion about that in GE. One of the things you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 should know is because of other jobs that the DPS does
2 in terms of ATWS and things like that, there is a data
3 link from the safety to the diverse protection system.

4 So the diverse protection system knows everything the
5 safety systems know -- not vice versa.

6 So one of the things they decided to do is
7 have the diverse protection system scram for any of
8 its functions, or if the reactor protection system
9 scrams.

10 MEMBER BROWN: It's a series.

11 MR. POPPEL: And so -- well --

12 MEMBER BROWN: I mean it's being told --

13 MR. POPPEL: -- it's an organ.

14 MEMBER BROWN: Yes, I got it.

15 MR. POPPEL: It doesn't need permission to
16 scram, but it will scram, because this way people
17 wanted to make sure that if you had a scram in one,
18 you'd have a scram in the other. That's sort of a
19 human factors thing. The data link is there to be
20 used and it's the specific programming of the DPS that
21 --

22 MEMBER BROWN: So if you had similar set
23 points, you had the exact same set points in each
24 system, the diverse protection system could scram you?

25 MR. POPPEL: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Independent and ahead of,
2 theoretically --

3 MR. POPPEL: Theoretically.

4 MEMBER BROWN: -- ahead of the reactor
5 protection system. Depending on tolerances, blah,
6 blah, blah. Their detectors, what they're feeding in
7 relative to the other systems.

8 MR. POPPEL: And not only tolerances, in
9 addition, the cycle times of the controllers. I mean
10 it take 10 milliseconds more to get to a scram
11 decision in this controller than in that controller.
12 Okay.

13 In general, the DPS will probably be
14 faster because it is synchronized between those three
15 control channels, whereas the reactor protection
16 system channels are completely independent and
17 asynchronous, so you could imagine at the two out of
18 four input gate, this one said reactor level and just
19 missed it, where this one said it was there. Because
20 their 25 milliseconds of looking at reactor level
21 aren't the same 25 milliseconds for each division.

22 MEMBER BROWN: Got it.

23 MEMBER BLEY: Ira.

24 MR. POPPEL: Yes.

25 MEMBER BLEY: What kind of separation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirements are there for the data and control cables
2 from the diverse system to the others?

3 MR. POPPEL: In fact, their requirements
4 are that they not be in -- well, first of all, all of
5 the safety equipment, just like a traditional plant,
6 has its own cable trays, conduits, duct banks, et
7 cetera, and in their own fire zones.

8 And the DPS system, in general, because
9 the reactor building is divided into four quadrants,
10 each of which is a safety division, but there's also
11 nonsafety equipment in there, including DPS nonsafety
12 equipment. So the DPS nonsafety equipment is always
13 located in at least -- in other words, if you will,
14 the four sensors and remote multiplexing equipment is
15 cut in half, and half of it is always in a separate
16 fire zone, okay. And it doesn't use any common cable
17 trays or -- and is the appropriate Reg Guide 175 away
18 from cable trays with other equipment in it.

19 The DPS system, like the reactor
20 protection system, will scram on any two like
21 unbypassed parameters. So, in other words, if half of
22 the remote multiplexers for DPS in the reactor
23 building go down, it's still capable of performing a
24 scram or an isolation. Okay.

25 So it's a very robust, redundant system

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all by itself, just implemented differently. And, of
2 course, it has to be implemented differently because
3 it's common cause.

4 MR. KIMURA: Ira.

5 MR. POPPEL: Yes.

6 MR. KIMURA: The rest of the -- the DPS
7 controller itself has to be in a separate fire area
8 from the nonsafety as well?

9 MR. POPPEL: I should have said that, yes.

10 MEMBER BLEY: But the cables have to run
11 through some of the same fire areas as the other?

12 MR. MILLER: They are going to be in
13 conduit so they'll be a separation.

14 MEMBER BLEY: The conduits are a
15 requirement?

16 MR. POPPEL: Yes. The -- this is like the
17 same thing as the cover slide. This is what the main
18 control room looks like. A few points to mention --
19 well, this is what the draft main control room looks
20 like.

21 Most of our stuff that interfaces with an
22 operator has a very formal HFE human factors process
23 to go through in terms of what they see, what alarms
24 they see, how they actually control stuff, and that
25 process is just starting. It is by no means complete.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What we have done is given them a backbone
2 architecture and stuff to do all of that stuff on.

3 So here are four divisional displays -- we
4 have one, two, three, four -- and here are four
5 divisional displays. So we have two displays per
6 division in the main control room.

7 The only way to talk to division one to
8 tell it to do anything is with a division one display.

9 It cannot be done from nonsafety, ever. No backwards
10 control from nonsafety into it.

11 Additionally, if you want to do something
12 in Div. 2, you cannot do it from a Div. 1 display.
13 You must go to a Div. 2 display to cause that.

14 So, in other words, when you think about
15 those solenoids, for example, or those squib igniters
16 and a manual initiation, if you want to fire the Div.
17 2 initiator, you're going to do it at the Div. 2 VDU,
18 and that's the only place you can do it.

19 MEMBER CORRADINI: I'm sorry. May I?
20 Just to follow that, so -- because you said it earlier
21 when you were just kind of in a general overview. And
22 then if you didn't do it in the main control room, you
23 have another location --

24 MR. POPPEL: Yes.

25 MEMBER CORRADINI: -- that again has the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 same sort of logic separation.

2 MR. POPPEL: Yes. One of the things
3 that's also -- the traditional remote shutdown panels
4 available to plants are a very, very small subset of
5 what is available in terms of control. And they have
6 all kinds of transfer switches, they have all kinds of
7 interesting problems associated with fire zones and
8 divisions in the panel.

9 We have two remote shutdown panels in
10 separate fire zones from the main control room and the
11 DCIS rooms.

12 Each remote shutdown panel has a Div. 1
13 and a Div 2. VDUI wherefrom you can do anything in
14 Div. 1 and Div. 2 that you can do from the main
15 control room. Not a subset; anything.

16 In addition, it has two displays
17 connected, one to the plant PIP A, plant investment
18 protection, A network, and one to the plant
19 investment protection B network.

20 The result of this is so four displays and
21 it has a manual scram switch and it has a manual
22 isolation switch.

23 Those switches are software free, just
24 like in the main control room. So if you push those,
25 you are going to scram; no software. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In terms of the displays, if you have
2 offsite power available, either preferred or
3 alternate, you can run the balance of plant, PIP,
4 RTNSS, and safety.

5 If you only have diesel power available,
6 you can't run the balance of plant. You can run the
7 displays, but of course you can't power any of the
8 equipment, but you can power the FAPCS, CRD pumps, you
9 know, all of the plant investment protection things.

10 And then if the diesels are not available,
11 you can run any of the Div. 1, Div. 2 safety stuff
12 from the 72-hour batteries of those divisions.

13 And since they are connected to the -- the
14 remote shutdown panels do not run through the main
15 control room. They connect in parallel to those back
16 panel areas appropriate to the division or nondivision
17 via fiber optic cable.

18 We also had a lively discussion yesterday
19 about inadvertent actuation. Our belief is that a
20 communication message authentication and robustness is
21 such that it will be highly unlikely that it would
22 ever -- that any stress in the main control room from
23 fire or smoke would cause an inadvertent actuation.

24 We can talk about that in some detail
25 later, but the bottom line is, the main control room

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 equipment being in trouble is not going to affect the
2 automatic or manual capabilities of the safety or
3 nonsafety systems because they are not in the same
4 environment.

5 We have -- these are the nonsafety
6 displays -- oh, I'm sorry.

7 MEMBER STETKAR: Can I back up to the
8 safety for just a moment? I want to get something
9 straight in my mind because you mentioned that got me
10 thinking.

11 You said that only -- if I go to a Div. 1
12 VDU, safety-related VDU, and I want to actuate ICS, I
13 can only actuate the Div. 1 signals for ICS from that
14 VDU. Is --

15 MR. POPPEL: Correct.

16 MEMBER STETKAR: -- that what you said.
17 Which means that to fully actuate ICS, I imagine that
18 I must do it from two different panels because of the
19 way that the signals -- I don't know how the signals
20 are distributed among all the valves, but I did a
21 little bit of reading in much detail for this meeting,
22 but I think that means to fully actuate ICS, to get
23 all of the ICS working, I need to do it from at least
24 two VDUs. Is that correct?

25 MR. POPPEL: That is the present design,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yes.

2 MEMBER STETKAR: Thanks. That helps.

3 MR. MILLER: Just to reiterate, in the
4 control room there's two Div. 1 VDUs, so you have
5 redundancy in case one --

6 MEMBER STETKAR: Yes. No, I just wanted
7 to get the fact that I couldn't go to one place and
8 say start ICS for everything.

9 MR. POPPEL: And as we discussed
10 yesterday, one of the human factors things that isn't
11 going to change is the operator always has to do two
12 things to get any action -- you know, select and fire;
13 arm, fire. You know --

14 MEMBER STETKAR: But that would be from
15 the --

16 MR. POPPEL: From the VDU.

17 MEMBER STETKAR: Yes.

18 MR. POPPEL: So that one single thing will
19 not -- you know, spilling the coffee, putting your
20 elbow on the display, will not cause something to
21 happen.

22 MEMBER MAYNARD: But for some of the
23 valves that are like the squib valves, initiating from
24 Div. 1 is going to fire all of them; right?

25 MEMBER STETKAR: No. No, it won't.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 That's my point. It will fire a subset of them. You
2 will fire one-fourth of them.

3 MR. POPPEL: We have -- here's the way
4 that is getting discussed in San Jose.

5 If the manual initiation for the division
6 goes in, if you will, ahead of the two out of four
7 logic, then your statement is correct, you need to
8 have say any two divisions where they say manual.

9 If it goes in after the two out of four
10 logic, then it will -- if you blow the Div. 1 thing.
11 And so the human factors folks are having a debate
12 about which is the best thing to do.

13 MEMBER BROWN: I didn't get that. Repeat
14 that.

15 MR. POPPEL: Forget manual. All of the
16 automatic actuation of the say the isolation
17 condenser, say on reactor level. So there's four
18 divisions. They each look at reactor level, they each
19 determine that there has been a reactor level
20 initiation, and then each division sends that
21 information to all the other divisions.

22 So at the input to the two out of four
23 logic, there is a Div. 1, Div. 2, Div. 3, Div. 4
24 decision that says you should initiate, and the two
25 out of four logic does that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Then the output of the two out of four
2 logic blows the Div. 1 squib. The output of the Div.
3 2 two out of four logic blows the Div. 2 squib.

4 So this debate for manual is am I going to
5 put the manual signal ahead of the two out of four
6 logic or after the two out of four logic.

7 And, you know, for everybody who argues
8 that, well, you know, if you put it ahead, that means
9 the operator will really have to think about it and do
10 two things, and the other half says, well, no, no, no,
11 but then you're forcing them to do two things in a
12 stressful situation.

13 We always need an odd number of people to
14 solve human factors discussions.

15 (Laughter.)

16 MEMBER STETKAR: You said that wrong. You
17 said an odd number of people. How about a number of
18 odd people?

19 (Laughter.)

20 MR. POPPEL: In any case, though, I mean,
21 in other words, the discussion we're having is a
22 question of the logic. It's not a question about the
23 hardware or the software of the system. It's just how
24 they want to implement it.

25 In the fullness of time there will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 detailed logic diagrams that in fact will show you
2 it's before or after that, and can be commented on.

3 MEMBER BROWN: In light of that, can the
4 reactor protection system for manual -- forget all the
5 other interrelations, but the operator decides to
6 scram, how many actions does he have to take to scram
7 all --

8 MR. POPPEL: TR is literally about 10
9 different ways to scram the plant, but this -- in the
10 case you're asking --

11 MEMBER BROWN: I'm talking about the --

12 MR. POPPEL: -- we have the traditional
13 two big red push buttons. If he pushes both
14 simultaneously, he will be directly interrupting,
15 without software, the con to the scram solenoid.

16 MEMBER BROWN: You said that yesterday.
17 We didn't ask the specific question, I didn't ask
18 about how many --

19 MR. POPPEL: But it's also possible --

20 MEMBER BROWN: But there's two --

21 MR. POPPEL: You can barely --

22 MEMBER BROWN: And they are not -- they
23 are strictly standard switches?

24 MR. POPPEL: Yes. There's no software --

25 MEMBER BROWN: Hardware? Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. POPPEL: No fiber optics, no software.
2 It basically winds its way down to a contactor and
3 the contactor -- normally closed contactor -- and the
4 contactor opens up the thing.

5 In other words, the contactor is in series
6 with the fancy load drivers.

7 MR. KIMURA: And the remote shutdown
8 system panels have the same buttons?

9 MR. POPPEL: Yes.

10 MEMBER BLEY: Rich, you pointed to one
11 place. Is there only one place where those two
12 buttons are?

13 MR. POPPEL: No, they are also in each
14 remote shutdown panel.

15 MEMBER BLEY: But there's not two sets of
16 them ?

17 MR. MILLER: Just one set. Just one set.

18 MEMBER BLEY: Okay.

19 MR. POPPEL: However, okay, I said the DPS
20 system can scram them automatically. They have
21 determined that it is useful to have the DPS system be
22 able to scram you manually. Okay. That's not
23 software free, but in other words, the operator, if he
24 really wants to scram, and he's pushed the RPS buttons
25 and for some reason it didn't scram, he can always

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 push the DPS buttons.

2 MEMBER BROWN: Are both on his panel?

3 MR. POPPEL: Yes.

4 MEMBER BROWN: You don't have to go to the
5 panels to do that?

6 MR. POPPEL: No. But you can go to the
7 VDUs and put in scrams, you know, like -- in other
8 words, you can do a two out of four reactor scram at
9 the VDU. Insert a trip in this division, and if you
10 do it in two divisions.

11 In addition, you guys know about ATWS and
12 SLC to shut down. It may -- I don't know how familiar
13 you are with the ABWR, but these rods are not --
14 control rod drives are not the traditional latching
15 piston. They are motor drives and a hydraulic scram.

16 So the scram is what you're used to, but
17 the normal positioning is a motor, not a hydraulic
18 latching piston drive.

19 And so if you will, there is a nonsafety
20 motor scram. In other words, the system says, oh, I
21 got to scram? I don't care whether it's scrambled
22 hydraulically or not, I don't care what position the
23 rods are being told to go to, you are now being
24 commanded to go all in.

25 MEMBER BLEY: You mentioned that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yesterday. How fast is that?

2 MR. POPPEL: It takes about two minutes.

3 MEMBER BLEY: Okay.

4 MEMBER ARMIJO: Compared to the hydraulic
5 is seconds?

6 MR. POPPEL: Yes, two or three seconds,
7 the traditional time you're used to.

8 MEMBER BROWN: I would take it that the
9 drive-in is not necessarily fast enough to provide a
10 safe reactor shutdown? Or is it?

11 MR. POPPEL: There are analyses which show
12 that if you can scram in two, three minutes, you'll
13 be, if you will, but obviously it's not going to be at
14 10 CFR 50 stuff.

15 MEMBER BROWN: One other question. You
16 think you can get the red button to scram. What about
17 the ECCS ESF type functions? If you wanted to
18 manually initiate those, can you do those manually,
19 bypassing all the software as well?

20 MR. POPPEL: You can, and you do it
21 through the VDUs. This has been another human factors
22 debate.

23 MEMBER BROWN: But that's not --

24 MR. POPPEL: That's not software free. We
25 wanted the software in the loop because what you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing, for example, when you open up the
2 pressurization valves, is you are initiating a LOCA.
3 And so, therefore, don't do it unless you really have
4 to.

5 And so therefore we want to make sure that
6 the operator is well supervised. On the other hand,
7 both DPS and the safety systems can in fact operate
8 that system.

9 They also have -- if you look at our aaes,
10 the depressurization sequence of the reactor starts
11 with the safety relief valves as opposed to the
12 pressurization valves.

13 There is a sequence blowdown, I guess is
14 the right way to phrase it, to get you to the pressure
15 where the gravity drain pool systems work. Okay. And
16 it's deliberately a very long sequence. Okay.

17 So there is no particular reason the
18 operator has to do anything fast for when this
19 happens. It takes a while to get to level one with
20 this plant.

21 MEMBER BROWN: One more question. The
22 VDUs are all touch screen?

23 MR. POPPEL: The safety VDUs are touch
24 screen. The human factors people are debating whether
25 or not the nonsafety ones should be touch screen.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The DPS ones will be touch screen. Okay.

2 Just so it will have the same sort of interface as
3 the safety ones, even though they -- incidentally, I
4 should say these aren't the same physical displays.
5 The safety displays have an operating system and a
6 physical display that's different than the nonsafety.

7 So, in other words, you can't have a
8 common-cause failure of the VDUs, either. You can't
9 have a common-cause manual failure just like you can't
10 have a common-cause automatic failure because of the
11 DPS and the two different ways to initiate.

12 MEMBER BLEY: Ira, I may be mixing up
13 different designs in my head right now, but in this
14 plant, can the operators locally -- or, you know,
15 local at breakers and contactors -- start pumps and
16 change valve positions or do they have to do that
17 through the DPS or through the control system?

18 MR. POPPEL: Well, normally you do it
19 through the control room, but the MCCs and switch gear
20 have manual operation capability on them, if for no
21 other reason to help you when you restart -- I'm
22 sorry, motor control center, or things that operate
23 valves.

24 That's not a relevant question to the
25 safety because we don't have motor-operated valves in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the safety systems, but it is a relevant question to
2 the plant investment protection and stuff like that.

3 So you can operate those things locally if
4 you -- should you have to.

5 Finally --

6 MEMBER BROWN: One more question on the
7 VDU touch screen issue. Is the human factors aspects
8 of inadvertent operation on the touch screens?

9 MR. POPPEL: Well, that's one of the
10 reasons we have the two actions. So, in other words,
11 in Lungman -- the reason I sound so hesitant is
12 because this is really a big HFE deal, but for
13 example, in Lungman, you can imagine looking at a P&ID
14 display of feedwater or something, and then you would
15 touch a valve or a pump, and what you get is a pop-up
16 that basically says you want to turn it off, you want
17 to turn it off.

18 If it's an analog positioning thing, you
19 can see the position, you can set the set point demand
20 moving.

21 So, in other words, the operator has to
22 select it, one action, and then he can do something
23 with it. But he can't -- you know, you need the two
24 things to cause the action to happen.

25 So a single VDU touch doesn't do anything,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in every system.

2 MR. MILLER: Was that question?

3 MEMBER BROWN: That's one of them. The
4 other was for -- I mean you've got your big wide
5 channel display to give you a general picture of the
6 whole plant. Normally the screens on the VDUs are
7 somewhat smaller, and so you would have subsets or
8 different screens, different displays that you would
9 want to call up.

10 Is that -- is every screen that you would
11 want to view -- and I view that as a screen selection
12 that has a number of displays on it, whatever they
13 are, that you predesigned to have certain types of
14 information. Do you have to menu-select those?

15 MR. POPPEL: Yes.

16 MEMBER BROWN: In other words, you call up
17 the menu, drive -- whatever you do with the thing --

18 MR. MILLER: You can do a menu, or you can
19 do --

20 MEMBER BROWN: It's a function of separate
21 -- as opposed to a separate touch which applies to
22 every one of say six or seven or eight screens?

23 MR. POPPEL: Well, actually, there are
24 hundreds and hundreds of screen formats that
25 accomplish various things. But when we say menu --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for example, what we did in Lungman is you can imagine
2 a main menu where it says, you know, here's the
3 reactor and here's the safety systems. I select a
4 safety system and then I get -- you want to see a
5 P&ID, you want to see alarms, you want to see this,
6 that, or the other thing.

7 In addition, because it's a screen it's
8 very hard to fit, you know, large systems on one
9 screen, and so one of the things you have on the
10 Lungman menus is on the screen you can have -- see
11 where this pipe runs off the screen? If you touch the
12 pipe there, there will be a little arrow, and you can
13 get to the screen that it connects to.

14 And you can also do things like let me see
15 the previous screen you just looked at. Okay.

16 So there's other ways than the
17 hierarchical main menu of getting through to things
18 that are organized by the HFE group in hopefully an
19 intelligible human-friendly way.

20 Additionally, I didn't say it yet, we
21 didn't talk about the wide display panel, but one of
22 the -- this is foreshortened, but one of the features
23 of that panel is an operator can select any display
24 he's looking at and put it up there.

25 So, in other words, if you said this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really interesting, everybody should see this, and he
2 can do that. So can the shift supervisor. Okay.

3 MEMBER BROWN: It doesn't take up the
4 whole display?

5 MR. POPPEL: No, no, it's not -- so, in
6 other -- basically the human factors rules are --
7 there are some signals that are so important and so
8 useful or so, you know, entry conditions to emergency
9 procedure guidelines, that we believe that even though
10 it's a display that they should be fixed. So the
11 operator level is always there, because that's really
12 important, and he really needs to see that.

13 And, of course, the HFE debate is what
14 signals are those. Everybody would agree on level,
15 but there's other signals. And so you end up with
16 like, if you will, a fixed mimic of the vessel with a
17 water level moving up and down with reference to level
18 one, two, three, and the core, and stuff like that,
19 and it's a very easy picture.

20 Plus the screen itself indicates that what
21 I'm showing you, at least transducers have agreed on.

22 So the operator, you know, gets his rule, like don't
23 do anything unless you get two things to agree. And
24 so that's important.

25 In general, we have the electrical system,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is also important, and then we have the variable
2 display. But the idea is that it's human factored,
3 and it has to be decided.

4 The physical -- the human factor parts
5 that everybody does agree with is the screen -- the
6 variable display begins here, so everybody in the
7 control room can see it. From every place in the
8 control room in that line, meaning the shift
9 supervisor, everybody has got a line of sight, and the
10 letters and numbers on it are sized so that you can
11 read them from that position. So, in other words,
12 it's not like six-point type from 35 feet away. And
13 so that's important, is everybody has sight lines to
14 it.

15 There's other "golly, gee whiz" stuff like
16 there's displays here where the operator can, you
17 know, call up P&IDs for the plant.

18 In other words, you know, like a tech
19 storage. These panels are also here to support
20 surveillance activities --

21 MEMBER CORRADINI: There's a question.

22 MR. POPPEL: Oh, I'm sorry.

23 MEMBER APOSTOLAKIS: No, finish your --

24 MR. POPPEL: I'm saying they're there to
25 support surveillance activities, basically so they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not standing in front of the operator or standing in
2 front of the wide display panel, you know, because
3 he's going to be there for a while doing stuff, so he
4 can do it over there, still be supervised, but
5 nevertheless, you know, not interrupt the control
6 room.

7 MEMBER APOSTOLAKIS: Is the thrust of your
8 question, Charlie, to explore what could go wrong? Is
9 that really what you're asking?

10 MEMBER BROWN: Well, I am just addressing
11 an issue we addressed similar to when we started
12 implementing this stuff. The same debate as to how
13 did you select and put information in front of the
14 operators in terms of what they would need normally
15 for their operations.

16 And I guess we have some menu items that
17 they were relegated to -- they were the maintenance
18 items, maintenance screens, stuff like that, where
19 your plant is shut down and we determined and figured
20 that there were half a dozen screens that illustrated
21 what would the operator want to have at his rapid beck
22 and call.

23 MEMBER APOSTOLAKIS: And this is not
24 what's being done here?

25 MEMBER BROWN: Well, I don't know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. CUBBAGE: Excuse me. This is Amy
2 Cabbage, NRR staff.

3 I think it's a fascinating topic, but it's
4 really not the topic we're here to discuss today. The
5 human factors interface is being covered under a
6 different chapter, and we'd be happy to get back to
7 you if you want any additional information about the
8 design process on that. Or GE would, because that's
9 their responsibility. But I think we need to move on
10 if you want to hear from the staff.

11 MEMBER BROWN: I thought we had these guys
12 until 9:45. So I thought we --

13 MEMBER CORRADINI: Well, we don't want to
14 capture the staff only for 15 minutes. We want to
15 give --

16 MR. MILLER: I think we're finished.
17 There's only one slide.

18 MS. CUBBAGE: I didn't mean to cut you
19 off, it's just that that wasn't the topic.

20 MR. POPPEL: But, as Amy said basically,
21 this part of the presentation --

22 MEMBER BROWN: Well, but the reason I
23 asked the question is to say -- okay, not necessarily
24 it would develop it to data flow. How much did they
25 need, how was it going to be relevant to some of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 comments, because there were questions yesterday.

2 MS. CUBBAGE: Okay.

3 MEMBER BROWN: That was the fundamental
4 thrust -- you asked, okay, was it -- depending on how
5 you did that, then you had different data flow
6 requirements, and so that's one of the reasons I was
7 asking.

8 MEMBER CORRADINI: You missed the joy of
9 January. We had that fun in January.

10 MEMBER BROWN: Which one, the HFE one?

11 MEMBER CORRADINI: Yes.

12 MEMBER BLEY: We're getting a bit more
13 information now than we got.

14 MEMBER CORRADINI: I'm just observing that
15 --

16 MEMBER BROWN: Oh, you mean what we've
17 done?

18 MEMBER CORRADINI: Well, no, we had the
19 first shot at --

20 MEMBER BROWN: I understood we weren't.

21 MEMBER CORRADINI: There was a lot of open
22 items, just to clarify. So in chapter 18 -- did I get
23 that right chapter -- we looked at chapter 18 then.
24 There was a lot of open items, but specifically on
25 human factors on how you display this, and we heard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from Brookhaven as the staff's consultant -- is that
2 the proper word -- to understand those open items at
3 that time.

4 But you're right, there is more now than
5 we had heard then.

6 MEMBER BROWN: Okay, we'll go on.

7 MEMBER ARMIJO: A quick question. Does
8 something like this physically exist at Lungman right
9 now?

10 MR. POPPEL: Yes. And at K-6, K-7.

11 MEMBER ARMIJO: So the heritage is the
12 Kashiwazaki plant's ABWRs, and to the Lungman with
13 some changes or improvements?

14 MR. POPPEL: The general layouts of the
15 control rooms of all three of those plants is the
16 same, although obviously the hardware, software, and
17 there are those who think that the science of human
18 factors has advanced over 15 or so years so that you
19 probably wouldn't display the same things on this
20 plant that you would in K-6, 7.

21 One of the things I should also --

22 MEMBER ARMIJO: Japanese.

23 MR. MILLER: We had started with those
24 plants and progressed with lessons learned and so
25 forth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Sure.

2 MR. MILLER: And this rendering here is
3 probably our fifth or sixth rendering on the ESBWRs,
4 starting from the Lungman design, moving to new
5 technology, and things of that nature, and being more
6 specific to the ESBWR systems.

7 MR. POPPEL: We should also mention that
8 this is an automated plant, okay. Without discussing,
9 you know, the details of automation, the human factors
10 of automation is to take burdens away from the
11 operator, okay, so that he can be a supervisor of
12 things happening rather than doing that.

13 So, for example, this reactor will pull
14 itself critical, okay. I mean there's an automation
15 sequence, and it says, okay, go to this break point,
16 and it says pull critical, you push the button, okay,
17 and the reactor will pull itself critical, and I mean
18 it's interesting to pull a reactor critical, but after
19 you have done it once, you've really had all the time
20 you ever need to do it. You know, it's boring, and
21 it's time consuming.

22 MEMBER BROWN: But these guys will never
23 do it once.

24 MR. MILLER: They might want to do it
25 manually.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. POPPEL: Well, I'm sure -- everything
2 in the simulator, I'm sure will be manual as they
3 train. But in the real plant, the intent is to take
4 burdensome things that are repetitive.

5 As an aside, because somebody, I'm sure,
6 will ask the question, all of the things that
7 supervise the operator in terms of when he does it
8 manually, rod blocks and neutron monitoring system
9 blocks, that's all still there with automation.

10 So the automation system is just as
11 supervised as the operator, and it's not supervised by
12 itself. In other words, those same things that would
13 block an operator rod pull will block an automation
14 rod pull.

15 So, in other words, we're not --
16 automation isn't trying to get away with something.
17 Automation is a tool to remove burdens from the
18 operator. That's pretty much the way the safety
19 systems are set up to respond to accidents also.

20 So the intent is that the operator should
21 be able to just see what's happening, follow the
22 sequences, and only have to intervene when something
23 doesn't happen that should. Because in general, it
24 will -- if it all works like it's supposed to, if any
25 two divisions work like they're supposed to, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactor will respond as analyzed.

2 MEMBER CORRADINI: Do we need to move on?

3 MR. POPPEL: Yes. This is the last slide,
4 and I've pretty well covered it by mentioning all the
5 stuff about the remote shutdown system, it's just
6 basically a little control room.

7 MEMBER BLEY: So I want to follow up your
8 last comment just a little, even though it's broaching
9 into the human factors engineering.

10 What do you guys do in designing the
11 system to keep the operator involved in that
12 supervisory role since he's not actively involved in
13 carrying out the steps?

14 MR. POPPEL: That one is straightforward.
15 It's not like one big switch that you say here's the
16 reactor cold iron, and when you're done, you're at 100
17 percent power.

18 Basically the automation system -- in
19 Lungman it was about 35 steps, so in other words, to
20 get the plant from cold metal to 100 percent power,
21 there were 35 break points, you know, so de-aerate the
22 reactor, pull it critical, heat up and pressurize the
23 reactor and stop at 400 pounds. Rated pressure and
24 temperature. Roll and synchronize the main turbine.

25 So, in other words, each time the operator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 said that, it went through that, and you could see it
2 on the steps on the screen, and then it would stop and
3 the operator has to give the next break point
4 permission.

5 So, of course, he can stop the automation
6 at any point, but the thought is that if we've done it
7 right, at the end of a break point he can look around,
8 look at the big screen, you know, does everything look
9 fine, and then he can press the next button.

10 So he's forced to be involved periodically
11 in the sequences.

12 MEMBER SIEBER: Do you actually roll out
13 the turbine?

14 MR. POPPEL: Yes. Matter of fact, all of
15 the stuff is -- the implementation is different, but
16 like, for example, back at K-6, 7, all of this stuff
17 is happening. The turbine roll, the reactor critical,
18 you know, power is -- although it's not likely to
19 happen in the U.S., for example, our customer contract
20 requirements in Lungman require that the plant be
21 remotely dispatched. Require, not allow.

22 And so, therefore, the grid operator can
23 say -- there's all kinds of controls on this, as you
24 might imagine -- Lungman should go to 900 megawatts.
25 And it will. Okay. And the operator can do the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing. Of course, he has to give permission for that
2 to happen.

3 That's not -- obviously isn't going to
4 happen in the States, but the capability is there in
5 both Japan and in Lungman, and in our European ESBWRs.

6 MEMBER SIEBER: They have to have a
7 license.

8 MR. POPPEL: In the United States.

9 MR. MILLER: Yes, in the United States you
10 need a license.

11 MR. POPPEL: Okay. But there they want to
12 treat the plants just like any other power plant on
13 the grid.

14 MEMBER SIEBER: Right.

15 MR. POPPEL: Okay.

16 MEMBER CORRADINI: Thank you very much. I
17 wanted to leave time for the staff and also so the
18 members can ask questions of the staff and back to
19 you, if necessary.

20 So is Mr. Li our lead staff member to
21 start us off? Oh, I'm sorry. Excuse me.

22 (Pause.)

23 Dennis, are you going to start us off?

24 MR. JUNG: Very briefly.

25 MEMBER CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. JUNG: I apologize, I don't have the
2 nametag with us. I'm Ian Jung, the chief of the
3 instrumental and controls branch.

4 MEMBER CORRADINI: We recognize you.

5 (Laughter.)

6 MR. JUNG: We spent a lot of time
7 yesterday.

8 Hulbert Li is the lead reviewer. We have
9 a number of actually staff members involved.

10 As you can see, through our SER, which is
11 about 240 pages long, it was a result of the
12 significant staff effort to cover the I&C area.

13 With that, Dennis is the project manager.

14 This is Dennis.

15 MR. GALVIN: Ian said most of what I
16 wanted to say, but --

17 (Laughter.)

18 The slides cover the topics in the SER 2
19 through 6. The reviewers -- we had the applicable
20 regulation and guidance, and we have about 70 RAIs
21 open out of 276. Ian is going to go into the details
22 of the review, and then our open items.

23 MR. JUNG: Thank you, Dennis.

24 I thank the committee for listening to us
25 and providing insights and perspectives yesterday. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 was quite useful, and we expect the same thing today.

2 Let's also take this opportunity to thank
3 many of my staff projects and other action leaders,
4 other divisions and branches, who worked together with
5 also GEH supporting us in terms of addressing safety
6 issues.

7 The bottom line is the staff used the
8 chapter 7 of the SRP as the main staff guidance which
9 references a lot of the regulatory guides, which also
10 endorses many of the industry standards.

11 Fortunately, in our digital I&C, in all
12 I&C in general, we kept up with our guidance document
13 to accommodate digital I&C through the experience of
14 the ABWR System 80-Plus and AP1000 and so on.

15 Are we up to the current state of
16 knowledge in terms of the current guidance? Maybe
17 there's always delta. We expect some delta all the
18 time, you know, technologies developing, and field
19 programmable gate arrays that might be in the new
20 power plants. We may need additional guidance.

21 But there are industry good practices. We
22 will try to use that information as we go through the
23 detailed design process.

24 Just to summarize, GEH is the design
25 certification submittal. As we have talked about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through the chapter 14, maybe also human factors
2 engineering chapter, GEH provided the design
3 information at a certain level. Not all the
4 information that is necessary and sufficient to force
5 that to make the original finding. That's the bottom
6 line.

7 And GEH opted to use the concept of a
8 design acceptance criteria, which has been endorsed by
9 the commission through several SECY papers in the
10 '90s, and the more recent Part 52 change actually
11 introduced word design acceptance criteria as an
12 example, and though the expression has been first time
13 introduced in the rule language.

14 So the use of the design acceptance
15 criteria has been a commission policy, if not
16 necessarily a rule. But we exercised the use of
17 design acceptance criteria through ABWR and AP1000 in
18 the past.

19 So for the staff going in, we wanted to
20 follow and improve upon what we've done in the past.
21 So what GEH has submitted, the high level of design
22 information functional requirements, and also design
23 acceptance criteria they had proposed. They are not -
24 - they are consistent, even better than what we have
25 seen in the past.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Yet on the steps, our initial desire is to
2 have as much design details as possible so that we
3 have a clarity in what the design looks like, and also
4 in combination of DAC description that is consistent
5 with the information policy, which is it is clear, and
6 once it is followed, the staff will be able to verify
7 it down the road without ambiguity and confusion or
8 contention.

9 So the staff had two approaches, basically
10 looking at GEH's submittal, make sure what they had
11 provided, even though it's a high level and GEH just
12 went through high level design, some of the
13 architecture information, high level functional
14 requirements. Some of what actually GEH said this
15 morning, that some of the information is not in DCD.
16 You recognize that, or will go through HFE process, or
17 will develop the detailed logic diagram.

18 So we looked at what we were provided with
19 in DCD, whether that be meeting the regulations that
20 we review under, SRP and the GDC, and IEEE-603, which
21 is endorsed by 50.55(a)(8), which is regulations.

22 That's one big area we focused on. A
23 second area, of course, we looked significantly, we
24 still are spending a lot of time on, a lot of the IAI
25 question 70 are related to actually the second part

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 related to the clarity in the tier 1 that you
2 mentioned, design acceptance criteria, and ITAAC
3 description. They are clear to the staff so that we
4 can verify down the road.

5 We had a lot of discussion about the level
6 of detail yesterday, and that's not unique. We have a
7 lot of discussion internally among the staffs.
8 Sometimes we have an odd number of people to make some
9 decisions on what level of detail we needed, maybe
10 even in the step side to it.

11 Some of it is subjective. You know, the
12 guide has not been fully exercised to be at plant
13 operational stage, so we are learning as we go at this
14 stage.

15 So I want the committee to recognize that.
16 This has been a first-time process. We are trying to
17 go through it and work with industry to make sure we
18 get to the success, which is a safe plant design,
19 completed and installed and operated in the future.

20 So --

21 MEMBER RAY: You used the word "verify
22 down the road," you used that phrase twice. I'm more
23 interested -- I mean it's important to get the design
24 right, and you talked about doing that. We've had a
25 lot of discussion about that. It looks quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 comprehensive.

2 But it seems daunting to imagine how you
3 verify that what is installed in the plant is actually
4 what you intend, that all of this isolation and all of
5 these features actually get implemented.

6 At what stage, is it now or is it later,
7 that the demonstration of the -- not some prototype,
8 but demonstration of the installed plant systems
9 actually do what we intend for them to do, and don't
10 ever do something different?

11 MR. JUNG: I agree with that, the
12 challenge of that information design details, the
13 verification activities, they are going to be
14 significant from the staff's perspective. Of course,
15 from the COL applicants and other's perspective when
16 they implement these design acceptance criteria, the
17 amount of documentation they have to develop, the
18 amount of the work they have to do to get to the
19 design, is extremely --

20 MEMBER RAY: Well, is that something you
21 deal with later, or do you think about it now?

22 MR. JUNG: No, that's the second part I
23 was getting to.

24 MEMBER RAY: Okay. Good.

25 MR. JUNG: So we are working with GEH and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 also with the industry in terms of the -- when and how
2 much, you know, the staff's involvement has to be
3 there. So maybe our process, PTP 7-14, has a life
4 cycle approach, the guidance related to a specific
5 life cycle stages describe what GEH has provided as an
6 example. Each life cycle stage is from the planning
7 through all the way down to the operational stage.

8 Each life cycle stage, they will develop a
9 certain -- when they are done with those life cycle
10 stages, that's when the staff is going to be involved
11 to verify that the design information is in compliance
12 with the regulation and the acceptance criteria we
13 have developed.

14 Not only that, for --

15 MEMBER APOSTOLAKIS: This is all for the
16 future. Can you tell us what's going on with slide 7?
17 Do you have any conclusions there?

18 MR. JUNG: Oh, yes, I'll just go over
19 that.

20 MEMBER APOSTOLAKIS: Okay. Let's do it.

21 MR. JUNG: Okay.

22 MEMBER APOSTOLAKIS: Unless there is
23 something very important you want to say before.

24 MEMBER RAY: Well, George, it may be about
25 the future, it may not. I guess I'm just wondering at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what point we hear about how it's going to be shown
2 that the plant actually is --

3 MEMBER APOSTOLAKIS: And I think that's a
4 good question. But we've spent 10 minutes talking.

5 MEMBER RAY: We're talking about ITAAC,
6 and that's what I'm asking about.

7 MR. JUNG: I understand. Let me just
8 complete this page.

9 MEMBER CORRADINI: If I could just
10 rephrase Harold's question, I think the nub of it is
11 within the ITAAC DAC structure, can you at least give
12 him some assurance that there are certain checkpoints
13 now that you know what you're looking at, so that in
14 the future those checkpoints then are followed
15 through? I think that's --

16 MEMBER APOSTOLAKIS: I thought the
17 question was different.

18 MEMBER CORRADINI: Oh, I'm sorry.

19 (Laughter.)

20 MEMBER RAY: The majority wants to move
21 on, so --

22 MEMBER APOSTOLAKIS: I thought you got
23 your answer, which was no answer. All right. Anyway,
24 ask it again.

25 MEMBER RAY: The tough part of this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 perhaps designing it, but it's equally daunting to
2 figure out how to verify that what you've got in the
3 plant is what you intended, and not something else.

4 MR. JUNG: The bottom line answer is yes,
5 we do have a plan, our DAC, ITAAC, the GEH has
6 proposed that allows that to happen, and staff is
7 continuously working on that subject to make sure
8 staff has a sufficient time and resources to be able
9 to look at the design details that are sufficient to
10 verify the detailed design is safe and sound.

11 MEMBER RAY: Well, I'm speaking of a
12 testing program, but go -- move on.

13 MR. JUNG: Okay. Looking at this slide, I
14 mean it's an oversimplification of what we went
15 through yesterday. The bottom line is staff looked at
16 the -- what GEH has provided in the DCD. We have
17 looked at one of the key items, IEEE-603 compliance
18 issue.

19 We have looked at the life cycle design
20 process. We just had a discussion. And the set point
21 methodology depends on that. Data communication
22 between the divisions and the safety, it is very
23 important in the digital systems.

24 We looked at all those areas, and the
25 bottom line is what they have submitted is in a high

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level of compliance with the regulation and our
2 acceptance criteria.

3 Yes, the design details have not been
4 implemented, but GEH has proposed the corresponding
5 design acceptance criteria for each of these items,
6 except for set point methodology, looking at the
7 conventional ITAAC.

8 And we are still working on some of the
9 verbiage here of these DAC they have proposed, but
10 although we believe we are on a successful path to be
11 able to go through the licensing process and make the
12 safety findings based on what they have submitted
13 alone, with the design acceptance criteria, which is
14 the design basis for the future COL applicants to
15 demonstrate that, and we are on a successful path.

16 The next slide.

17 The next slide just basically says that we
18 still have 70, plus or minus. We are continuously
19 going through RAIs process. We expect even additional
20 RAIs as needed because, you know, these 70 RAIs
21 actually are substantial work for GEH to make sure
22 their DCD tier 1 and tier 2 documents are consistent
23 and clear, especially on its own design acceptance
24 criteria.

25 Once we look at that, we will continuously

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 iterate to make sure we get to the clear, you know,
2 safety finding based on that language.

3 MEMBER CORRADINI: So your two bullets are
4 as you had yesterday, but in the discussion of your
5 two bullets yesterday, a few things popped out, and I
6 want to make sure that the whole committee hears it,
7 so that we're not going to go off in a discussion
8 later, perhaps, in a different way.

9 One that I heard was it seems minor, but I
10 heard it was major, that you are seeking by current
11 open items and potentially other RAIs a great deal of
12 clarification, so that what I heard yesterday was
13 there's going to be a DCD five-plus, five-point X in
14 terms of tier 1, so there's more clarification as to
15 what the -- in terms of the ITAAC DACs are you going
16 to expect and feel comfortable with relative to the
17 acceptance criteria. That's what I heard yesterday.

18 MR. JUNG: That's correct, and actually
19 tier 2, also.

20 MEMBER CORRADINI: Okay.

21 MR. JUNG: Because tier 2 captures what's
22 in tier 1.

23 MEMBER CORRADINI: Right. And the second
24 thing I heard yesterday was that there's going to be a
25 cross-reference table which connects essentially --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I'm just only talking about chapter 7 sort of stuff --
2 but what is in 14.3 relative to DAC, so that there's -
3 - we understand what things in terms of design
4 acceptance criteria and the more details in tier 1
5 connect to the systems and analysis in tier 2, I
6 heard.

7 MS. CUBBAGE: IEEE-603 compliance?

8 MEMBER CORRADINI: Right.

9 MS. CUBBAGE: Matric?

10 MR. JUNG: Yes, because as you put it,
11 603, all individual items of 603 are -- we wanted GEH
12 to spell out as part of their DAC language. That
13 should be cross-referenced in -- for chapter 14.

14 MEMBER CORRADINI: Okay. And then the
15 third thing I heard yesterday in the discussion of the
16 two bullets was that there were -- and I'm going to
17 get words wrong -- there were functional logic
18 diagrams that were sent to you to help clarify the
19 verbiage in the chapter 7 of the DCD that, although
20 not intimately part of the current review, help you
21 understand and could help us understand the functional
22 logic of the distributed control and instrumentation
23 system that --

24 MR. JUNG: We'll provide the committee a
25 copy of that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. Those are the
2 three things I heard yesterday, for the full
3 committee, that I thought at least for some of us gave
4 us a bit more confidence.

5 CHAIR SHACK: Again, you know, when we go
6 through things like the IEEE compliance, you know,
7 that will be sure we have the independence. Do you
8 think you have enough information to capture all the
9 features that we've heard about today? I mean there
10 are different ways to meet the IEEE-603.

11 Now they have described a number of
12 features here that seem very attractive, but I'm not
13 sure that they are all captured in the tier 2
14 information and thus correspondingly in the DAC.

15 MR. JUNG: Right now, the answer is no,
16 not in -- I would call that sort of sporadic in some
17 areas, because GEH's design stage is depending on
18 areas. The human factors engineering has -- is in
19 progress status right now, for example.

20 But I think that the issue of, you know,
21 how an applicant will achieve the goal for ICS
22 systems, for example, there's a functional requirement
23 that has been listed in the first system chapter as
24 well as the I&C being supporting area, which goes into
25 603 and all those requirements.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And if we really want every detail on how
2 one can achieve a certain criteria, 603 is obviously a
3 lot more detailed than GDC, and 603 actually goes into
4 single failure criteria, and then it will go -- our
5 Reg Guide also references the IEEE-379.

6 So those -- there are a lot of -- the
7 bottom line is that we believe there are a lot of
8 balances and checks in terms of the end goal of
9 achieving what specific things have to be done to
10 demonstrate the compliance or conformance with those
11 criteria.

12 We believe that from the staff's
13 perspective, if somebody can achieve that, that's what
14 our guidance is, and if you achieve that, we believe
15 it's safe enough.

16 But do we -- as a regulator, we do not
17 really tell the industry, especially on an evolving
18 technology, you know, how you're going to do that on a
19 design certification stage. We have to picture
20 ourselves 10 to 15 years down the road. The design
21 certification -- it goes way beyond that, so the
22 bottom line is that with the system components that
23 are already set in DCD, and they achieved that going
24 through this process.

25 MEMBER APOSTOLAKIS: So are you saying

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that it's not as simple, straightforward matter to
2 verify compliance with 603? That you have to use some
3 judgment to make sure that what they propose actually
4 meets the functional requirements?

5 MR. JUNG: There's some cases there's
6 judgments, there's some cases in black and white. You
7 know, the independence separation type of things, the
8 criteria is clear. You just can't -- you know, the
9 nonsafety systems cannot impact the safety function,
10 and we will verify those, and GEH's case, actually
11 those -- you know, GEH, as they explained this
12 morning, they really limit those communications and
13 even call the communication.

14 CHAIR SHACK: But that's how they're
15 achieving the independence, and I would like to make
16 sure -- I think that's a nifty feature and I like
17 that, and I want to make sure that that is captured or
18 at least it seems to me that that kind of detail of
19 how they're going to meet the high level requirement
20 is part of what I mean by a design.

21 I mean, every -- you know, a guy could
22 walk in and say I'm going to meet ASME Code IEEE
23 something or other, you know, give me a license
24 approval, you know. They're committing to meet it, it
25 seems to me, at a certain level, and it's -- you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't care if they're using MARK 6 controllers, but
2 I kind of like the notion of what they described in
3 terms of their isolation, and I would like to make
4 sure that those features are captured in the tier 2
5 description and the corresponding DAC.

6 And I guess that's the question: Do you
7 feel that -- I mean, you're sounding as though you're
8 hearing some of this for the first time, so obviously
9 it isn't captured in the tier 2 information you're
10 looking at.

11 Now in the five plus information --

12 MR. LI: May I make a comment? I think
13 the functional requirements already are specified in
14 the DCDs, and the DCD of the ESBWR is equivalent to
15 the FSAR for the operating plant. So for the NRC
16 regulation review, that's a level that we have.

17 And the IEEE requirement is a quality of
18 these hardware, software requirement, and it's subject
19 to the ODLE. So you kind of have to go through
20 testing or kind of on-site testing, so it's licensee
21 and GE's responsibility to demonstrate they satisfy
22 all those requirements.

23 We always have an avenue, and they have to
24 -- they must say to us they are meeting --

25 CHAIR SHACK: Well, you know, is this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 shared memory concept for the internal, external
2 firewall something that is captured as a particular
3 design feature of the ESBWR?

4 MEMBER RAY: Exactly.

5 CHAIR SHACK: And, you know, the IEEE says
6 I should keep them isolated. You know, they've picked
7 this particular feature. Now will that be captured as
8 part of the design?

9 MEMBER CORRADINI: Do you understand where
10 we're going?

11 MR. LI: I understand. To be licensed,
12 that's -- as long as they satisfy the separation
13 requirement and demonstrate to us.

14 MEMBER CORRADINI: So what I just heard in
15 your answer is no.

16 (Laughter.)

17 MS. CUBBAGE: If we could take a step
18 back, I think what caused some of the confusion, quite
19 frankly, yesterday is GE was not clear in their
20 presentation of what they were presenting was
21 conceptual and what were they presenting that was
22 actually before us for review and approval. And I
23 think we owe you an answer back on what of the details
24 you heard was conceptual and what is going to be
25 fixed, and we'll have to take a step back and take a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 look at that.

2 I think what you are hearing from Hulbert
3 is he thinks he satisfied, subject to the resolution
4 of the RAIs, that the level of detail that's captured
5 gives him assurance that the design will meet the
6 regulations and the design will be safe.

7 But I hear the committee's comments, and
8 we'd like to take a look at that.

9 MEMBER BLEY: So this will be something
10 for another meeting?

11 MS. CUBBAGE: Well, we have to come back
12 with all of these chapters at the FSER stage. This is
13 an SER with open items, and we're looking for an
14 interim letter to see if you have any concerns beyond
15 which the staff has identified, and this is a concern
16 that you have.

17 MEMBER CORRADINI: I think Amy, unless the
18 members disagree, I think she's captured it well in
19 terms of what is conceptual that we heard as examples
20 to give us a warm and fuzzy feeling versus what is
21 going to be captured in the tier 2 and tier 1.

22 CHAIR SHACK: But Hulbert is sort of
23 giving me a different -- you know, he's satisfied at a
24 different level than I think we're looking at, you
25 know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Right.

2 CHAIR SHACK: He's satisfied as long as
3 the IEEE independence is met. The shared memory is a
4 conceptual way to do that at the moment, and he's not
5 willing to nail that down as a feature of the ESBWR
6 system.

7 MEMBER CORRADINI: Can I say it a
8 different way just back at you? He's saying that he
9 doesn't feel that it needs to be captured in the DCD
10 tier 2-1 structure. Although he's heard it, it gives
11 him a warm and fuzzy, he doesn't need to be there. We
12 somehow feel that -- at least some of us feel that it
13 would be nice to see it there, so we would feel more
14 concrete.

15 MS. CUBBAGE: And I'm by no stretch of the
16 imagination an I&C expert, but I don't know the extent
17 to which some of these features lock them into a
18 technology, so that could be a consideration why GE
19 has proposed not to specify that. I don't know that
20 for sure, though.

21 MEMBER BROWN: This is very technology
22 independent, what we're asking for, and what you've
23 asked for, and what others have commented, it's
24 technology independent. I mean the idea that just
25 from the standpoint of voting operation, for instance,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they show a line going in between the divisions to
2 show the voting going to two out of the four voting.

3 CHAIR SHACK: That's a principle.

4 MEMBER BROWN: That's fine, but does that
5 go -- does that line input software into the other
6 thing, or is it a hard-coded line that goes to a two
7 out of four analog style logic device, which is far
8 more independent and far more isolated than tossing
9 the software into the other software loop, or that
10 loop where they're bringing all the RPS stuff.

11 Remember, they have all that stuff in that
12 ring bus distribution, and it's rolling around. It's
13 got to be picked up and it's gone to be done something
14 with. That's different than a hard-coded, turn
15 something on, it latches, and away you go, in some two
16 out of -- that's the level of detail that we're
17 looking not. Not the technology that whether they use
18 opto couplers or whether they use some new FEMTO
19 technology that arises here in the next 10 years. I
20 don't care.

21 What Chip said, you don't care. It's that
22 high level architecture that you're looking for in
23 terms of detail.

24 CHAIR SHACK: This is an ESBWR DCIS rather
25 than a generic IEEE-603 system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I mean, a couple of
2 comments in the DCD said "a function could be." Not
3 "the function is," "a function could be." In other
4 words, a way to do something.

5 MS. CUBBAGE: I know we're running late on
6 time. I don't know whether you want to give an GE an
7 opportunity to try to explain briefly what they
8 presented yesterday was conceptual versus what they
9 are committing to in the DCD.

10 MEMBER CORRADINI: I would say given the
11 time -- and I don't want Dr. Powers to remember that
12 I'm too late -- I would take it as an action item that
13 -- what you said, which is what conceptual versus what
14 is the action DCD in terms of design features,
15 something that we will expect to hear from the staff
16 after you have discussed with GEH.

17 MEMBER STETKAR: I don't know if I should
18 --

19 (Laughter.)

20 I want to follow up just a little bit on
21 what Bill said. And to give you specific examples of
22 this. And I think -- I don't think our role as ACRS
23 is to get into microfine structure detail of the
24 design, which is unfortunately a natural phenomenon
25 every time you talk about I&C. I&C people love to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 into fine structure.

2 I think our purpose -- this is my own
3 personal opinion -- is to step back and look at the
4 integrated design of I&C within the context of the
5 plant, from a safety perspective, from a
6 reasonableness of design perspective of whatever you
7 want to call it. And that requires something more
8 than what's available in the DCD, and it certainly
9 does not require the final detailed design.

10 You know, in all relay-driven technology,
11 I don't care whether I have a six-contact Westinghouse
12 relay or a four-contact GE relay, if I only need four
13 contacts, it doesn't make any difference. I don't
14 care.

15 Now a couple of examples of what do I mean
16 by this. Briefly.

17 For example, in the current design, an
18 ESBWR uses power at the -- whatever they call them,
19 power generation buses as the measure of loss of
20 feedwater flow, because it is assumed that that is the
21 only way you can lose feedwater.

22 Question: Why don't they use feedwater
23 flow as the input, because there are many other ways
24 of using feedwater.

25 Now that's a medium level of detail. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isn't designed -- it isn't final hardware, software
2 specific, it is an input functional signal. You can
3 say it's high level, medium level, I don't care what
4 it is, why are they using loss of power at a bus as a
5 surrogate for loss of feedwater flow?

6 So that's one level of information.

7 Another level of information is there are
8 probably a dozen different ways that you can meet
9 single failure or even double criteria. There are
10 some that are better than others in terms of
11 distribution of signals among pieces of equipment.

12 A little bit of that came up when we
13 talked about the DCD manual initiation that touching
14 one division actuates less than all of the equipment.

15 That is, again, an intermediate level of
16 detail that is not currently in the DCD. It doesn't
17 depend on software or hardware architecture. It's a
18 design specification.

19 If you can look at that level of detail
20 and say, yes, they seem to have accounted for all the
21 different ways you can lose feedwater because of the
22 signals that they use as an input. Yes, their design
23 specification for how they distributed the signals
24 among different pieces of equipment satisfies system
25 interactions, both within the I&C system, and within

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different systems in the plant.

2 I think that we would feel a lot more
3 comfortable about saying that, yes, indeed, the design
4 is robust and that those criteria then can be verified
5 when the thing is finally built. Because, you know,
6 how do you do the logic is a matter of construction
7 rather -- it's how it's implemented is the final
8 construction. It's not affected by the original
9 decisions.

10 That's enough.

11 MEMBER BROWN: But you've got information
12 in the DCD that allows them to --

13 MEMBER STETKAR: That's right.

14 MEMBER BROWN: -- that status profile and
15 what they test to verify. And that's -- the point is
16 that's not their --

17 MEMBER STETKAR: Right.

18 MEMBER CORRADINI: So I was going to ask
19 for member comments, but I think I got them, anyway.

20 Are there any questions of the staff at
21 this point? Beyond what we have just gone through?

22 Therefore, Mr. Chairman, I want to thank
23 the staff and GEH for their summary presentation, and
24 I remind everybody we have the summary presentation at
25 the last meeting in chapter 14, and together we will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 come up with something we hope today.

2 CHAIR SHACK: We will take a break for 10
3 minutes, and I would like to remind those of you who
4 haven't seen Sherry yet that she's looking forward to
5 meeting you.

6 (Recess.)

7 CHAIR SHACK: Let's come back to the
8 session.

9 Our next topic is the early site permit
10 application and the final SER for the Vogtle Nuclear
11 Plant, and Dana will be leading us through this
12 matter.

13 MEMBER POWERS: Thank you. Let me begin
14 by noting that in this matter, Said has a conflict of
15 interest, and though he is welcome to comment for
16 purpose of qualification and purpose of opinion, he is
17 not to be listened to.

18 (Laughter.)

19 We are here to finalize our review of the
20 Vogtle early site permit. This is in fact the fourth
21 early site permit that the committee has reviewed.
22 Some of the members, I note, have never had the
23 opportunity to participate in an early site permit
24 review, so this will be exciting.

25 The application has some unusual features

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to it, that instead of calling it a plant parameter
2 envelope or site characterization, it calls out a
3 specific plant, the AP1000.

4 It also is unusual in the sense that it
5 calls out a complete integrated emergency plan rather
6 than just the major features of an emergency plan.

7 And in this particular application, there
8 is also an unusual feature that they have conjoined
9 with the early site permit a limited work
10 authorization under the provisions of a relatively new
11 rule.

12 So it has some unusual features to it.

13 The modifications to the site that have
14 been proposed are dramatic. I'll let the speakers
15 discuss that, but not unusual in the sense that they
16 are analogous to modifications that have been made to
17 adjacent units.

18 The subcommittee met yesterday to discuss
19 this thoroughly. Quite frankly, we have been over the
20 major portions of the early site permit request both
21 in subcommittee and in full committee, but I have
22 asked the speakers to review some of that material,
23 but there are so many members who have not seen it
24 before, and in many respects you can just trust that
25 the committee -- subcommittee plunged into the details

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of closing out various orphan items, and we may be
2 purely summary in our presentation of those.

3 The dominant list at this site, as with
4 most -- not all, but most -- early site permits is a
5 seismic source term posed by the Charleston seismic
6 zone, and we did discuss some of that.

7 Like all seismic zones on the East Coast
8 in the central United States, they are a bit more
9 mysterious than those in California. But don't ask
10 for the details that you would in the San Andreas
11 Fault.

12 MEMBER RYAN: All righty, then.

13 (Laughter.)

14 MEMBER POWERS: The subcommittee has
15 formulated a draft position with respect to this early
16 site permit. Our draft position is that the Vogtle
17 site is suitable for the location of a light-water --
18 two new light-water reactors.

19 We note, however, the projected ground
20 motion seismic response spectrum is not bounded by a
21 good design spectrum for the AP1000 reactor, and that
22 would be something that would have to be resolved in
23 the future if that's the plant they want to locate
24 there.

25 What we are proposing is our draft

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 presentation with the emergency plan is acceptable,
2 and that a limited work authorization is also
3 acceptable, and analyses have shown that even with an
4 AP1000 on this site, it would not be subject to
5 overturn or sliding as a result of the proposed work.

6 So bear those positions in mind as the
7 speakers go through that.

8 I have asked the applicant and the staff
9 to somewhat coordinate their presentations because
10 they are trying to summarize in a relatively limited
11 time material that it took us a full day to go
12 through, as well as providing background for members
13 that have not seen this before.

14 We are going to try to accomplish quite a
15 bit here in a limited period of time. So with that, I
16 will turn to Mr. Davis to give us some background on
17 the site.

18 MR. DAVIS: I do apologize, we're having
19 somebody retrieve our electronic files, but if
20 everybody has a handout similar to this, this is what
21 we're going to be going through, and I'll just walk
22 you through it. I'll try and say the number of the
23 slide.

24 I am Jim Davis. I am the ESP project
25 manager for Southern Nuclear. I am responsible for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the development of the ESP application.

2 If you will flip the page to part two.

3 As Dr. Powers mentioned, we are trying to
4 divide up the presentation material since we have both
5 covered a lot of the same stuff with the NRC and the
6 applicant yesterday, so I'll try and give an overview
7 of what the content of the application and the type of
8 things that are in there, and later I'll turn it over
9 to Christian to talk more about the technical details
10 of what they evaluated.

11 So basically I am going to cover a short
12 introduction, I'll give you a feel for our schedule of
13 activities, when we are going to begin construction,
14 some of the preconstruction activities, a quick
15 overview of the early site permit and its content, and
16 an overview of our limited work authorization request.

17 Southern Nuclear has submitted an early
18 site permit in accordance with 10 CFR 52, subpart (a)
19 for early site permits, and also as Dr. Powers
20 mentioned, we have requested a limited work
21 authorization under the new rule for 10 CFR 50.10.

22 Basically the ESP grants -- if you'll go
23 to page 3 -- the ESP grants approval of a site for one
24 or more nuclear power facilities separate from the
25 filing of an application for a construction permit, or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a combined license.

2 I think my slides just showed up.

3 MR. WIDMAYER: As long as they weren't x-
4 rayed or anything.

5 (Laughter.)

6 MR. DAVIS: No, no x-rays. The kids'
7 pictures are on there, too. We'll try not to load
8 those up.

9 (Pause.)

10 On slide 6 on page 3, the Vogtle
11 application is the fourth ESP application that has
12 been pursued under the new Part 52, and basically Dr.
13 Powers mentioned some of the differences.

14 The first three applicants had a plant
15 parameter envelope approach where they wanted to
16 qualify their site for multiple designs for a nuclear
17 power plants.

18 The difference for ours is we took a look
19 at the first three applicants. We tried to do our
20 lessons learned based on what issues cropped up for
21 them. The environment report specifically. It's hard
22 to draw a conclusion based on a parameter envelope, so
23 we decided to go with a specific technology, and the
24 technology that Southern Nuclear selected was the
25 Westinghouse AP1000.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Basically what that allowed us to do was
2 have specific conceptual design developed for our site
3 so that we could evaluate our site to a specific --
4 particular design, which was the AP1000, and that
5 allowed us to pursue things more in depth and more in
6 detail.

7 The other thing that Dr. Powers mentioned
8 is that we chose, instead of a major -- for our
9 emergency planning, we chose to do the detailed
10 complete and integrated emergency plan, and the first
11 three applicants did not pursue an LWA, which Vogtle
12 has done.

13 So we have a lot of differences from the
14 first three. We tried to learn from how they did it
15 and tried and come up with a better, more complete
16 application that would allow us to achieve more
17 finality.

18 Basically, just if you will flip to page
19 4, slide 7, it's just an overview of our schedule. If
20 you'll take a look at -- we put about 19 months into
21 developing the ESP application, which we submitted in
22 August of '06, and since August '06 until today, the
23 NRC has been reviewing it and going through our
24 application. We've been working with them.

25 Basically we're hoping for the ESP and LWA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the fall of 2009, which would support our
2 construction schedule. And I'll go into a little more
3 detail on the schedule as we proceed through the
4 slides.

5 The Vogtle site is an existing two-unit
6 nuclear facility. It's a 3,169-acre site. It's in
7 Burke County, Georgia. It's located on the Savannah
8 River, directly across the river from the Savannah
9 River site, the DOE site, and it's about 26 miles
10 southeast of Augusta, Georgia, and approximately 150
11 river miles from the port of Savannah.

12 Just to give you a little better
13 perspective where that is, you can see Augusta,
14 Georgia above the site, and if you look at the little
15 legend on the right-hand side, you'll see where it is
16 on the border between Georgia and South Carolina,
17 approximately where it is.

18 Basically the early site permit was five
19 parts. The first part is the introduction which
20 identifies the owners and who is applying for the
21 application, a few administrative details.

22 Part two is the safety analysis report.
23 This is where most of the safety work is done --
24 evaluation is done along with part five, which is the
25 emergency plan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This gives all the details of our site,
2 how we analyze the site, and I'll go into a little
3 more detail about what's in that part.

4 Part three was a complete environmental
5 report where we evaluated both the impacts to the
6 environment during construction and operation, so that
7 we had a complete scope of the environmental impacts
8 due to the addition of two additional units at the
9 Vogtle site.

10 And part four is a redress plan. That's
11 what is necessary if you want to pursue an LWA. It's
12 kind of remediation. If you for some reason decide
13 not to pursue construction of the site, it's what you
14 would do to bring the site to an acceptable condition.

15 And then part five, of course, which I
16 mentioned, was the complete and integrated emergency
17 plan.

18 Getting into a little more detail about
19 what's actually in the early site permit. Basically
20 we followed the same format as an FSAR for an
21 operating unit. And the sections that are included in
22 the ESP are those sections necessary to support
23 evaluation of the site and support our LWA.

24 So as you can see here, we have chapter 1,
25 which is general introductions. Chapter 2 and 3

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably contain the most information. It's the
2 largest section because it's actually evaluating our
3 site characteristics, are they acceptable for the
4 design we propose to put on the site.

5 Chapter 3, we have a little more detail
6 than normal in an ESP because we have some foundation
7 information that's necessary to support our LWA
8 activities that we have requested, so there's a little
9 more there than in a normal ESP.

10 We also have rad waste evaluations on
11 liquid and gaseous effluents, and chapter 13 is a
12 little more than normal for an ESP as well because
13 when you request an LWA, you also have to have the
14 programs in place to support those activities,
15 specifically your fitness-for-duty program.

16 So there are certain elements that are a
17 little more than a normal ESP because of the LWA.

18 Also chapter 15 is accident analysis, and
19 17 is our quality assurance program.

20 Here is an overview, a sunlight picture of
21 the site, with a little artist's rendering that shows
22 our new units. The existing units, 1 and 2, are on
23 the right.

24 To the west of those units is our proposed
25 unit 3 and 4. We have an existing intake structure --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there we go.

2 (Pause.)

3 The first structure is the existing one.
4 I can barely -- I don't know if you -- this is
5 existing structure, the existing units 1 and 2, where
6 we are putting in a new intake structure for 3 and 4.

7 And this is the new units 3 and 4, which
8 are going to be to the west of the existing units.

9 MEMBER BANERJEE: What size are the
10 existing units?

11 MR. DAVIS: They're about, what is it,
12 1240?

13 MEMBER SIEBER: About. Four-loop.

14 MR. DAVIS: Yes, four-loop PWR
15 Westinghouse units.

16 MEMBER STETKAR: Are the existing units
17 and the new units going to share the same switchyard,
18 500 kV switchyard?

19 MR. DAVIS: We're going to expand the
20 switchyard. We're going to have a new 500 kV line
21 coming into the switchyard. They will be physically
22 connected, so even though this looks like it's
23 separate, they really are connected, but they're kind
24 of stretched out. Just, you know, from logistics.

25 Actually the current plan is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 eventually we will swap out some of the transmission
2 lines that are going to 1 and 2, one of those lines
3 will go to 3 and 4.

4 MEMBER BANERJEE: That's okay.

5 MEMBER SIEBER: In addition, you have two
6 lines, 230 kV lines?

7 MR. DAVIS: We have a 500 kV line, and
8 then we have a set of 230 kV lines coming in.

9 MEMBER SIEBER: And that kV lines goes to
10 --

11 MR. DAVIS: The current one is the
12 Macintosh. It goes south down towards Savannah. And
13 we're going to add a new -- we have a 500 kV line that
14 goes to Share, so I think there's two 500 kVs, and
15 some 230 kVs. We're adding an additional 500 kV which
16 is going up towards the Augusta area, west of Augusta,
17 to handle the transmission.

18 MEMBER SIEBER: West of Fort Gordon?

19 MR. DAVIS: West of Fort Gordon, yes.

20 This next slide just illustrates the fact
21 that we are a little bit different from a lot of the
22 other COL applicants in that we are a deep soil site.

23 Most of the other applicants are rock sites, which
24 was analyzed specifically in the DCD. It made their
25 seismic evaluation a little easier than ours. Even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the soil sites that were evaluated by the DCD don't go
2 near as deep as ours do.

3 We're in the coastal plains, and we have
4 over 1,000 feet of soil above our bedrock, so that
5 kind of complicated things when we did our seismic
6 evaluation. But this is just a slide to illustrate
7 that. It's not to scale.

8 Basically we had a very rigorous review by
9 the NRC, and they did a very good job. We tried to
10 work the best we could with them. We didn't always
11 agreement on the method or level of detail --

12 (Laughter.)

13 MEMBER POWERS: What a shock.

14 (Laughter.)

15 MR. DAVIS: But we both eventually arrived
16 at the same conclusion, that it was a good site to
17 build a plant on.

18 This just gives you kind of a feel for the
19 number of issues we had to deal with. We had 189 RAIs
20 prior to receiving our SER with open items, and these
21 are the numbers associated with the different subject
22 areas.

23 If you'll notice in tier 5, geology got
24 the most RAIs.

25 And then we received our SER with open

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 items. You again can see that geology was our
2 favorite subject, so we spent a lot of time on that.
3 We've worked with NRC to reach resolution on these
4 open items.

5 MEMBER BANERJEE: Did you have to do a lot
6 more work compared to what you'd done for the other
7 two units?

8 MEMBER SIEBER: Yes.

9 MR. DAVIS: Yes. Much more.

10 Part of what the timing on our LWA,
11 initially we -- and I'll get into this in a little
12 more detail -- we requested an expanded LWA for the
13 safety-related work right about the time they were
14 issuing the SER with open items, and as a result we
15 got 26 more RAIs specifically with our expanded scope
16 LWA.

17 Basically they covered site investigation
18 information, enduring properties of the subsurface
19 materials, and the backfill requirements, the design
20 of the engineering field we wanted to put in as part
21 of that LWA.

22 MEMBER BANERJEE: So between the time of
23 these two submittals, we learned a lot about geology?

24 MR. DAVIS: Yes.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DAVIS: I have a lot of experts that
2 work for me, and I've been on a lot of phone calls,
3 and I would say that I know a lot more than I ever
4 did, or maybe even wanted to, when we first started
5 to.

6 MEMBER SIEBER: You learned more about
7 geology and you learned more about your site.

8 MR. DAVIS: That's true. We know a lot
9 about the Vogtle site. In fact, I would be surprised
10 if anybody knows as much as we do about their site.
11 It's been very thoroughly investigated.

12 MEMBER POWERS: I don't know, the Clinton
13 folks probably will -- they'd be willing to match page
14 for page, I suspect.

15 (Laughter.)

16 MR. DAVIS: Now I'm going to cover a
17 little bit about the LWA and preconstruction just to
18 give you a feel for what we asked for, and about what
19 our schedule is right now.

20 Basically if you look at our initial
21 submittal in August of 2006, we requested an LWA-1
22 under the old rule. An LWA-1 basically is like
23 preparation for construction -- building the roads,
24 putting the infrastructure in, facilities, and
25 warehouses to support construction.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Then in August of 2007, we requested the
2 LWA-2, which expanded the request to a limited scope
3 safety-related work activities.

4 Then once the new rule came out, we
5 converted all that to the new LWA, and under the new
6 rule basically you don't have to have an LWA for
7 preconstruction activities, but you do have to have an
8 LWA for safety related.

9 So we converted our LWA-1 and LWA-2 to the
10 new rule.

11 Basically I'll just kind of hit some
12 highlights on preconstruction activities.

13 This is actually a list from -- directly
14 from the regulation. It says what kind of things are
15 not defined as construction, and as you can see, it's
16 site exploration, kind of like the borings and stuff
17 that we do when we're trying to qualify a site. A lot
18 of the preparation for is developing the construction,
19 infrastructure including grading and drainage and
20 other things.

21 And just to point out, the excavation is
22 something that is not considered construction. We can
23 dig the big hole. We can't put anything in it, but we
24 can dig the big hole.

25 Basically we can do parking lots, railroad

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 spurs, transmission lines. You know, we talked a
2 little bit about you can do those without an LWA.

3 Also one thing I will point out, the last
4 bullet, some of this new concept for the passive
5 plants is dependent on modular construction. So as
6 long as a module is being built, there's a fabrication
7 shop off site, or assembly into a big module on site,
8 those things aren't considered construction. We plan
9 to have some laydown areas for that activity to go on.

10 Basically what we have asked for --

11 CHAIR SHACK: Say that one again.

12 MR. DAVIS: If we have modules, okay,
13 which are plant pre-fabbed assemblies, if we had a
14 contract with a vendor to build that for us, okay,
15 that's not covered under the LWA or it's not
16 considered construction until it's placed in its final
17 location.

18 So some of our vendors, subsuppliers,
19 we're going to allow space on site to do some final
20 assembly to stage the components for the construction.

21 Now I won't say that that timing actually
22 brings them in before we get our LWA or our COL, but
23 there might be some staged materials on site, and
24 that's not considered construction until you put it in
25 place and start connecting everything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: It's all totally
2 reasonable.

3 MR. DAVIS: The things that we have asked
4 for, because we had such a large excavation -- and
5 I've got several slides to kind of illustrate that for
6 you, and the time period it's going to take us to dig
7 the hole and then fill the hole back up, that was the
8 reason, the primary reason, that we pursued the LWA.
9 And so we asked for engineered backfill under our LWA,
10 retaining walls -- and I'll give you an illustration
11 of this -- mechanically stabilized earth wall, which
12 we're going to do, leaning concrete backfill for
13 around any things that are hard to use soil to
14 backfill around.

15 We're going to put in some mud mats
16 underneath the nuclear island. We're also going to
17 install some waterproofing on those mud mats and some
18 of the walls which will actually be forms for the
19 nuclear island walls.

20 Along with that, I mentioned earlier you
21 have to have certain programs to do safety-related
22 work, including our fitness-for-duty program, our QA
23 program, and also our problem identification and
24 resolution or corrective action program.

25 Just to give you a feel for what our near-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 term schedule is and some of our key milestones at the
2 beginning of construction, for us a key milestone is
3 our PSC approval. That allows us to actually spend
4 money. You know, even though we can't do any safety-
5 related work --

6 CHAIR SHACK: You get reimbursed.

7 MR. DAVIS: That's right.

8 (Laughter.)

9 MR. DAVIS: So that's a key milestone for
10 us to actually begin spending money.

11 Also the ESP approval, with the other day,
12 we're anticipating that we'll get that in the fall of
13 '09, and then actually our COL application, which we
14 hope to get in the fall of 2011.

15 Basically we are already starting some of
16 our preconstruction activities. We are doing
17 demolition of old structures and slabs that are in the
18 footprint of the new units. So we've already got that
19 started, but when we really want to spend big money is
20 the excavation of the hole, which we are going to
21 remove about 3.6 million cubic yards of material. So
22 we've got a very large excavation. It's going to take
23 us about six months to dig the hole.

24 Once the hole is finished, we are going to
25 do some geological mapping because it's going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expose all those layers of material, and at that point
2 in time the NRC is going to be invited to come down
3 and evaluate the site and take a look at that aspect
4 of our program.

5 And late in 2009, we will begin the
6 backfill, backfilling the hole, proceed from our
7 bearing layer, and I've got a couple of slides to
8 illustrate this, of about 50 feet, so we have to go
9 down approximately 80 to 90 feet, and then we come
10 back up with engineered fill to about 50 feet, and
11 then is when we start putting in the mud slabs for the
12 nuclear island.

13 We will start an MSE wall, which will
14 actually be kind of the form, the outside dimensions
15 of the slab, and continue the MSE wall up the grade.
16 We'll pour a mud mat inside of these walls for --
17 which will go underneath the nuclear island. We'll
18 install waterproofing on that mud slab and beginning
19 at the walls, and we'll do a work surface mud mat on
20 top of the waterproofing to protect that from the
21 rebar installation.

22 Again, this is just a layout. You've seen
23 this slide again. I'm just going to show you the
24 following slide.

25 Here is the excavation, just an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 illustration of how big the holes are in relationship
2 to the -- next. Basically here is another slide that
3 shows. And the reason we had to excavate our site was
4 because we had limestone above our bearing layer and
5 the upper sands were were subject to liquefaction, and
6 I think Christian has got a real nice slide on that
7 later to illustrate what that is.

8 But during a seismic event, the upper
9 sands have the potential of liquefying, so you don't
10 want to build a unit on it. That's why we're taking
11 it all out.

12 This shows you the extent of the hole, and
13 we've got some cross-sections on it. Basically how we
14 established what the bottom of the hole was going to
15 be is we took a zone of influence from all the
16 buildings, and we took the outside corners of the
17 buildings, and we drew a 45-degree angle coming down
18 to the bearing layer, and that's how we established
19 the outside dimensions of the wall.

20 And then we're going to bring the fill
21 back up -- this kind of illustrates the 50 feet that
22 comes up from the wall, and then we start the mud mat,
23 and the MSE walls will come up the side, and we're
24 going to bring it up to the grade.

25 MEMBER BANERJEE: So where do you get all

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the material that you're going to use to backfill
2 this?

3 MR. DAVIS: We have -- out of that
4 excavation we hope to save -- I think it's about 40
5 percent is what we estimate, and we have other borrow
6 areas that we identified during the ESP base where we
7 have more material that's acceptable, and as it comes
8 out of the holes, we will have like soils labs to test
9 the material and we'll segregate it. The stuff that
10 we can use, we'll put in a borrow pile. The stuff we
11 can't use we'll put to a spoils pile.

12 MEMBER BANERJEE: Well, is the other 60
13 percent coming from off your site?

14 MR. DAVIS: No. All -- we plan on having
15 to retrieve all material, fill material, from our own
16 site. We've got a 3,169-acre site, so we've
17 identified other sources of borrow material on our
18 land.

19 We have --

20 CHAIR SHACK: Now when you built the
21 previous units, you took the foundation all the way
22 down to the blue marl, and you're not doing that now?

23 MR. DAVIS: Well, I would like to thank
24 you for that.

25 CHAIR SHACK: You're my straight man.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. DAVIS: That's right. Yesterday we
2 did mention that some of our facilities are on the
3 marl. The aux building, the NECW towers are on the
4 marl, but the actual -- like the container building, I
5 think it has like about 26 feet of fill material, just
6 like the reactors here will have. The ones we have
7 now are 50 feet, but they actually are on the fill,
8 certain portions of the plant are on the fill,
9 including the reactor building for unit 1 and 2.

10 MEMBER ARMIJO: Now one thing I missed,
11 I'm just looking at your previous drawing, the turbine
12 building is not on the same -- will not have this mud
13 mat, deep rock, so its foundation will be at a higher
14 level.

15 MR. DAVIS: Yes.

16 MEMBER ARMIJO: Okay.

17 MR. DAVIS: The nuclear island is the
18 deepest structure, and that's the first -- you know,
19 the first level we get to that has a structure on it
20 is 50 feet, it's the nuclear island.

21 Most of the rest of them are much nearer
22 the surface.

23 As part of our ESP and COLA process, we
24 actually did do a test-fill program for the MSE wall.
25 We wanted to demonstrate that the small equipment in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 our backfill material would be acceptable. We brought
2 in some industry, you know, experts to help us with
3 this, plus some of our soils people to test our
4 material as we put it in.

5 Basically we were trying to figure out if
6 our methodology would work the way we expected it to.

7 And it's not new technology, MSE walls.
8 You see them everywhere. Here's one near -- on the
9 Atlantic Expressway near the airport, so it's nothing
10 unique or special about them. We're just taking them
11 and applying them to our site.

12 Here's just an example of the waterproof
13 membrane that we're going to be using. It's an
14 elastomeric spray-on product that goes on in two
15 layers, and once we get the MSE wall started and the
16 mud mats poured, we'll put in a layer of this
17 material, and it will actually go up the side of the
18 walls as the MSE walls come to the surface.

19 Basically when we get done, this is --
20 this is what we're trying to achieve to prepare
21 ourselves for construction. We're going to have a big
22 swimming pool out there. The backfill is going to be
23 up to grade, and we're going to be ready to roll once
24 we got our COL.

25 And because it takes, you know, a year and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a half to do the backfill, we're trying to get a jump-
2 start on that so we'll be ready for construction.

3 MEMBER SIEBER: Did you ever get the
4 question resolved about the issue of the grounding
5 mat?

6 MR. DAVIS: We did follow up on that last
7 night, and there will be a grounding mat put in late.

8 MEMBER SIEBER: Under the membrane?

9 MR. DAVIS: It will penetrate the membrane
10 at some point, okay, but --

11 MEMBER SIEBER: It's probably at multiple
12 points.

13 MR. DAVIS: Right. But when we contacted
14 the Westinghouse people about what method they use,
15 they gave us like three options, so I don't know we
16 have settled on a particular one, but each one of them
17 did penetrate.

18 MEMBER SIEBER: There is a way to do it
19 and keep it waterproofed.

20 MR. DAVIS: Right. Right. This product
21 was qualified for penetration.

22 MEMBER STETKAR: Just so people realize,
23 there has to be penetration.

24 MR. DAVIS: Right. And one thing we
25 pointed out yesterday, this is part of the certified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design to have the water proofing in there for in-
2 leakage of water. It's not safety related, but for
3 the Vogtle site we're putting it in, but our normal
4 groundwater elevation is about well below our -- the
5 nuclear baseline.

6 MEMBER BANERJEE: So you said this is a
7 spray-on. Is it a polymeric system or what does it
8 do? You spray it on and it sort of evaporates across
9 all this stuff?

10 MR. DAVIS: Yes.

11 MEMBER POWERS: It's rubber.

12 MEMBER SIEBER: It's thick, though. Six
13 inches, maybe.

14 MR. DAVIS: No, it's much thinner than
15 that. And that basically gave -- are there any
16 questions on that? If not, I'll turn it over to
17 Christian.

18 MEMBER POWERS: Now I'll ask the staff to
19 go into a little more of the detailed evaluations that
20 they did. Needless to say, as Jim pointed out, this
21 is a lengthy application. It required quite a team of
22 people to review because it covers a diversity of
23 things.

24 One of the things to recognize here is
25 that the seismicity of the area has been studied a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in the past because of the proximity of Savannah
2 River, and it was studied even more in connection with
3 this early site permit.

4 (Pause.)

5 MR. ARAGUAS: All right, my name is
6 Christian Araguas. I'm the project manager for the
7 safety review for the Vogtle ESP application.

8 As Dana pointed out, we have really
9 truncated the slides so if you guys have any
10 questions, feel free to stop us and ask. It's a lot
11 of material to get through, so trying to do it in a
12 45-minute timeframe is going to be tough.

13 And having said, what we are going to
14 cover, as Jim pointed out, is two aspects of this.
15 One is the review of the ESP application and closure
16 of the open items, and the other aspect is the staff's
17 review of its first LWA request under the new rule,
18 and then we will address any questions.

19 So just really quickly, we wanted to cover
20 the agenda for the next hour. I'll go through some of
21 the remaining milestones for the project, and then at
22 that point I will turn it over to the technical staff
23 to go through how we closed out some of the open
24 items, and then at that point we'll summarize the
25 review of the SER and we'll move on to the LWA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discussion, and we'll go through some of the key areas
2 that were reviewed and exactly what it is they are
3 planning to do under their LWA.

4 So as I mentioned, this slide just really
5 quickly is here to demonstrate what we have left.
6 We're expecting a final letter from the ACRS sometime
7 in the December-January timeframe.

8 Following that, we will issue the final
9 SER in February 5th of 2009, and then the Atomic
10 Safety & Licensing Board has set its hearing schedule
11 to start March 23rd, 2009.

12 Following that, we would expect a decision
13 from the ASLB in the I think it's July timeframe, and
14 then depending on what the commission wants to do, if
15 they decide to weigh in or not, we would expect a
16 decision on the issuance of the ESP in the summer or
17 fall timeframe.

18 Okay. So this slide, I just wanted to
19 show similar to what Jim has already shown. These are
20 the review areas.

21 On the left-hand side, you will see the
22 areas that we focused on that are strictly for the
23 ESP. On the right-hand side you will see the areas
24 that were looked at for the LWA.

25 Where we have areas that were highlighted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in bold, the areas where we had open items, we don't
2 plan to cover all the open items. As you can see,
3 there were 40 of them, so it's a lot to get through.
4 We will focus on the major issues that we thought were
5 pertinent for today's meeting.

6 The other key aspect of the slide that I
7 wanted to point out, and it tends to be a little bit
8 confusing because we have two actions going forward,
9 is what exactly you're approving under an ESP, what
10 exactly you're getting under an LWA with respect to
11 the design.

12 So for an ESP, unlike the previous three
13 applicants, Southern has requested site suitability
14 review done for and has referenced the AP1000
15 certified design.

16 When you approve an ESP, it is not
17 allowing approval for that design at that spot.
18 You're just approving the characteristics that were
19 looked at as part of that ESP, such that at the COL
20 stage you're do a comparison to verify that that
21 design will fit on that site.

22 The LWA, it's a little bit more tricky.
23 With the LWA you're actually pulling out portions of
24 the COL, and that now you have to rely on portions of
25 the design, but only those that are necessary for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approval of those specific activities that were
2 requested under the LWA.

3 So I wanted to highlight that going
4 forward so that way with respect to the LWA, it's only
5 those areas, as Dana pointed out, with respect to
6 sliding and overturning that we knew to look at design
7 aspects.

8 With that, I will start with our
9 hydrologist.

10 MR. AHN: My name is Hosung Ahn,
11 hydrologist with the NRC.

12 I will start with a brief introduction of
13 what we did under SER section 2.4, and what are the
14 major findings of the section. Then I will describe
15 the open item and how we resolved that open item.

16 Section 2.4 consists of over 14
17 subsections, and half of them are telling me the
18 flooding issues, maybe it's by either precipitation,
19 the in-break, or hurricane and the tsunamis.

20 So we analyzed each and every flooding
21 event, and determined what are the impacts of the
22 flooding.

23 In flooding there are a lot of different
24 parameters, like what is the maximum flooding level,
25 or what is the step in the dynamic forces of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 flooding, but one of the critical flooding parameters
2 is the maximum flooding level. And you use a lot of
3 moderating technique to estimate the flooding
4 scenario, and they identified the dam break is the
5 most critical bounding flooding event.

6 Especially for a dam break, on this side
7 upstream there are about 14 major dams, and they
8 picked the two most high volume reservoirs, and used
9 the cascading dam failure to estimate the flooding
10 level. So that's the consolidated approaches.

11 A step used for similar modeling approach,
12 even more conservative parameter set.

13 Therefore, we concluded that the site is
14 safe from any flooding event.

15 The maximum flooding level they estimate
16 is about 178 feet from the river, and the site grade
17 is about 220 feet, so they have a lot of margin on the
18 flooding, so that's the basis of the safety on
19 flooding.

20 And we also analyzed the low-flow impact
21 as there was the ice condition, on-site groundwater
22 use for the safety-related water supply, and we
23 identified that we found that for those safety-related
24 water supply are not impacted over this hydrologic
25 hazard.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The last two things dealing with
2 groundwater flow and the radionuclide containment and
3 transport.

4 MEMBER STETKAR: How far from a hurricane
5 zone is this site?

6 MR. AHN: It is about 150 miles from the
7 coastal line, and the site is located about 120, so a
8 hurricane may not affect this site. Flooding is not
9 affected on the site.

10 MEMBER APOSTOLAKIS: So what contaminants
11 is the groundwater transporting?

12 MR. AHN: To analyze the contamination, we
13 postulated one of the rad waste pipe failure scenario
14 and analyzed the contamination on the receptor area.

15 The lower left corner features basically
16 show the water table contaminant for the official
17 output, and the bottom layer is bounded by the blue
18 marl, and the aquifer is subject to the radionuclide
19 transport contamination.

20 So we at the beginning we listed the
21 aquifer system, and the depth groundwater region may
22 be quite sensitive to the change.

23 MEMBER BANERJEE: Is that picture on top
24 of a real flood in that region?

25 MR. ARAGUAS: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. AHN: Not on the site.

2 (Laughter.)

3 MEMBER POWERS: I explained to the
4 speakers that there are many new members that might
5 not be familiar with everything.

6 (Laughter.)

7 And obviously that's one of the things
8 that we're concerned about.

9 MR. AHN: These pictures show the --

10 (Pause.)

11 -- units, and that area is bounded by the
12 Savannah River and then we have a small creek on that
13 side, and it's also bounded by a small creek on this
14 other side.

15 There is a groundwater transport pathway,
16 major pathway. However, the extensive excavation and
17 the facility installation, that groundwater region
18 might change. So at the beginning we pushed the --
19 how that groundwater region may change.

20 MEMBER RYAN: And in light of that
21 explanation, there was a change in groundwater
22 pattern?

23 MR. AHN: At the beginning.

24 MEMBER RYAN: I'm sorry?

25 MR. AHN: That's what we assume at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 beginning. That's why we asked through the RAI and
2 open items, put your analysis in detail so that how
3 the groundwater changes and how the pathway may
4 change, and what are the alternative potential
5 pathways. These pathways going to the north, but how
6 about to the sites or to west. So we asked the
7 applicant to analyze, to do that. So I'll explain
8 that a little further.

9 MEMBER RYAN: But that's a work in
10 progress, that's an open item?

11 MR. AHN: Yes.

12 MEMBER RYAN: Okay. Thank you. That's
13 fine.

14 MEMBER POWERS: This is a closed item.

15 MR. AHN: I'm sorry?

16 MEMBER POWERS: This is a closed item.

17 MR. AHN: It was an open item, but we
18 closed that.

19 MEMBER RYAN: Okay. I just wanted to
20 understand. Thank you.

21 MR. ARAGUAS: Your question was did the
22 model assume that the back wall had been placed down;
23 is that right?

24 MEMBER RYAN: My real question is what is
25 the impact of a new island on the groundwater flow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Have you modeled what that will look like when it's
2 all done?

3 MR. ARAGUAS: Right.

4 MEMBER RYAN: That ultimately determines
5 the flows of the pathways, monitoring programs, all
6 that other stuff.

7 MR. AHN: Let's explain the open item.

8 MEMBER RYAN: Okay.

9 MR. AHN: We discussed that in detail
10 yesterday, but I would just briefly introduce that
11 open item, and how we resolved that.

12 The first open item, 2.4.81, we had the
13 issues that whether the section 2.4.8 is the safety of
14 the canal and reservoir, so that they can provide a
15 safety-related water even during the hazard condition.

16 So we asked that whether they used the
17 canal or reservoir as a safety-related water supply.
18 And the second question is in case the applicant
19 proposed two water tanks for safety-related water
20 supply, when they're initially fitting the tank, or
21 when they make up water for the tank, is that safety
22 related or not. So that was our initial concern.

23 So we issued the RAI, and the applicant
24 responds that they are not going to use the river and
25 canal as a safety-related facility, and even initial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 filling of makeup water is not a safety-related
2 activity.

3 So -- and they said that for the initial
4 filling makeup, they will use the true groundwater
5 wells, and the water they will extract from the
6 aquifer. So on section 2.4.12, that's the groundwater
7 section, we reviewed based on the hydrologic, whether
8 that aquifer provided enough supplemental water to
9 provide water to the tank. And we found that they
10 have a sufficient -- the aquifer itself has a
11 sufficient capacity. There are aquifers below that
12 aquifer. So we closed that open item No. 1.

13 The second and the third and the fourth
14 item are related to the groundwater models. In
15 general, from both sides, the hydrologic pathway is
16 very simple, so we may not need a groundwater model,
17 but in this case groundwater could be very sensitive
18 based on the excavation and the facility installation.

19 That's why we pushed this issue very hard.

20 So open item No. 4 is after the preconstruction, how
21 high the natural groundwater level will change. The
22 applicant estimated about natural groundwater level
23 really 165. That estimation is based on historical
24 data, but historical data doesn't mean anything for
25 future conditions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So we asked them the groundwater, natural
2 groundwater will change. The applicant, in their
3 response, they provided additional hydro-geologic data
4 based on the COL filing and LWA drilling, and they
5 provided --

6 MEMBER RYAN: Just before we get to this
7 slide that's behind you on the screen, just so I
8 understand it, the water table elevation is 165 in the
9 cell, and the grade is 220. That's between 165 and
10 220 in terms of water. Is it an unsaturated zone?

11 MR. AHN: It's an unsaturated zone.

12 MEMBER RYAN: How can that be? This is
13 Georgia. The saturated zone is very close to the
14 surface in Georgia and South Carolina.

15 MR. AHN: On this slide --

16 MEMBER RYAN: This is just the
17 explanation.

18 MR. AHN: No, no, that's the current
19 condition, 165.

20 MEMBER RYAN: The unsaturated zone is 50
21 feet thick?

22 MR. AHN: Yes. It's very low.

23 MEMBER RYAN: Okay.

24 MR. AHN: And because of the extensive
25 excavation, the rate might increase, so therefore can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we make up, that was our initial question. So we
2 asked them to elaborate your estimation, and they
3 estimated that the groundwater level, to validate that
4 value, and then they demonstrate that that area is
5 quite ready for -- at the construction. And the step
6 used more conservation more approaches to estimate
7 that, and we found that there are enough margin.

8 MEMBER BANERJEE: Are these models pretty
9 well established?

10 MR. AHN: That was very well effective.
11 It was well documented, and they did the calibration,
12 and it showed it is quite acceptable. So that's why
13 we accepted their model.

14 We conformed that measurement groundwater
15 level and we closed this open item No. 2.

16 Open item No. 3. This is quite similar to
17 the previous open item, but it is related to the
18 ultimate conceptual model considering variability and
19 uncertainty on the hydro-geologic parameter. And as I
20 mentioned before, they provided additional data, and
21 the groundwater level, and they confirmed the
22 postulated pathway. And on the part of that step
23 using more conservative hydro-geologic parameter to
24 identify pathway to either the eastern side or the
25 western side, and in an extreme case, the pathway for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that is not highly plausible. And at the end of it,
2 we did containment consequence analysis and found that
3 the pathway is the most critical pathway. That's what
4 we found. So we closed that open time, too.

5 The last open item, we considered the
6 location of the receptor area and the different source
7 location, and made some combinations of a different
8 pathway, alternate cable crossover pathway, and
9 analyzed what is the most significant contamination
10 pathway and what are the consequences, and then we
11 identified that both the pathway to the middle of the
12 pond is again the most critical, but this other
13 pathway Appendix A compliance. So that means the site
14 meet the external release of contamination criteria.

15 So that is the close of my presentation.

16 MEMBER APOSTOLAKIS: What is a chelating
17 agent?

18 MR. AHN: Oh, chelating.

19 MEMBER CORRADINI: How do you pronounce?

20 MR. AHN: Chelating.

21 MR. ARAGUAS: Chelating agent.

22 MEMBER POWERS: Citric acid, EDTA,
23 nitrilotriacetic acid.

24 MEMBER BANERJEE: I don't understand what
25 the issue there is. Why is there no chelating agent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will be --

2 MEMBER RYAN: Chelating agents tend to
3 make the radionuclides more mobile, as opposed to
4 ionic or, you know, nonreactive with other things.

5 MR. AHN: So when we do the consequence
6 analysis, the applicant did his own, without the
7 chelating. That means there's no contamination,
8 there's no chelating agent appeared on there. But
9 when they used the chelating agent and that is mixed
10 with rad waste material, transport will be faster.

11 MEMBER CORRADINI: What systems in the
12 plant use such agents?

13 MR. AHN: What systems?

14 MEMBER POWERS: Any time you do a
15 cleaning.

16 MEMBER CORRADINI: Okay. Like a steam
17 generator cleaning or --

18 MEMBER POWERS: Yes, something like that.

19 MEMBER CORRADINI: Okay.

20 MR. AHN: So there are two issues, whether
21 that chelating agent will mix with the rad waste
22 material and if that is mixed with rad waste material,
23 we may need to do the analysis again with considering
24 that chelating agent.

25 MEMBER BANERJEE: So you can separate out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the chelating agents if you use it as cleaning from
2 the rad waste? Is that possible?

3 MEMBER POWERS: You treat it with a little
4 peroxide mix on it.

5 MEMBER BANERJEE: Okay. So you change the
6 chemical structure.

7 MEMBER RYAN: Right.

8 MR. AHN: I think they need some operating
9 the plant, but our concern is whether that chelating
10 agent is mixed with the rad waste or not.

11 MEMBER BANERJEE: The effluent stream.

12 MR. AHN: Yes, effluent. And what are the
13 impact of that.

14 MEMBER BANERJEE: Go ahead. Thank you.
15 Very well.

16 MR. AHN: So for that, NRC said we may
17 need more detailed design on the condition and the
18 structure in there. That's why we put that as a COL
19 action item.

20 MR. STIREWALT: Good morning. I am Gary
21 Stirewalt, and I would like to talk just briefly
22 really about the sorts of things that we reviewed in
23 section 2.5.

24 MR. ARAGUAS: Hey, Gary, can you back up a
25 slide? There you go.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STIREWALT: But again, just to sort of
2 set the scene for the sorts of things that we really
3 reviewed in section 2.5 now, basically -- and Mr.
4 Davis reminded you really how many RAIs we generated.

5 Well, the point is that geology really is
6 the framework in which everything sits. Of course,
7 I'm a geologist, what else would I say?

8 But the point is that we really did chew
9 on it pretty hard. We went through the entire
10 section, site, regional, and geology, vibratory ground
11 motions, surface faulting, stability of subsurface
12 materials, and slope stability -- all of those issues
13 are going to be spoken to.

14 And the applicant again, as Mr. Davis
15 specified, really did identify and assess rather
16 carefully the site and regional geology
17 characteristics and features as, of course, is
18 required.

19 I want to show this slide just to sort of
20 set the scene really for what the geology is, and sort
21 of point out some key features that were of concern to
22 use that we really did want to deal with.

23 I would like to point for one thing the
24 Pen Branch fault. I would also like to point out this
25 little blue line that happens to be the outcrop trace

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of that blue bluff marl that is in fact the bearing
2 unit.

3 The Pen Branch fault, since it is a
4 structure, was a concern because it is a structure,
5 and that's a key issue, really. But even though there
6 were no OIs, no open items associated with that, it
7 was something that both the applicant and the
8 geologists were really quite concerned about.

9 Let me just look at that in a bit more
10 detail in a quick slide to sort of show you -- and
11 again, Mr. Davis showed this is a more cartoon-like
12 cross-section.

13 But this actually illustrates the location
14 of the Pen Branch, and you will note that in fact it
15 will dip beneath the area of the nuclear island. This
16 blue line is in fact the blue bluff marl, so the
17 sequence that people have spoken about, the Atlantic
18 coastal plain set here, you have older rock that's in
19 excess of 200 million years old on both sides of this
20 structure. So this is sort of the geologic setting,
21 and again this feature was proven rather concisely to
22 be a noncapable fault. That is to say it was less
23 than 1.8 million years old. The quaternary is our
24 cut-off.

25 So that's sort of an introduction to why

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the geology is important.

2 I'm going to pass it now to Sarah who will
3 talk about the seismology features.

4 MEMBER BANERJEE: Does that mean it's not
5 active or something?

6 MR. STIREWALT: That means it is not
7 active, exactly right. Thank you for the question.

8 MEMBER CORRADINI: And so the numbers that
9 you quoted were the limits where you do an estimate,
10 but if it's less than this, it's considered active; if
11 it's longer than such, it's considered not active?

12 MR. STIREWALT: That is correct. If it is
13 older, prequaternary, then it's nonactive, noncapable,
14 nonseismogenic.

15 MS. GONZALES: I'm going to talk about
16 section 2.5.2 and some of the open items we had, the
17 significant ones.

18 One of the main review areas for 2.5.2 is
19 the applicant's probabilistic seismic hazard
20 assessment, or PSHA.

21 The applicant used the 1986 EPRI PSHA size
22 source model as a starting point in its PSHA. This
23 model is comprised of input from six different teams.

24 This figure shows an example of one of the
25 teams' seismic source characterization, and you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see that there's various areas on the map.

2 In the central and eastern United States,
3 seismic source -- earthquakes are modeled as area
4 sources rather than discrete fault sources. So that's
5 what those areas correspond to.

6 I just want to show you these on the map.
7 This is the Vogtle site here.

8 MEMBER BROWN: Does the green, blue, and
9 orange represent areas?

10 MS. GONZALES: Yes, those are all
11 different area sources.

12 MEMBER BROWN: That's fine.

13 MS. GONZALES: Yes. This is the Vogtle
14 site, and these are all the various source sites that
15 one of the EPRI teams defined, and this is the
16 Charleston source zone that they defined, and here
17 just outside the 200-mile site radius is the eastern
18 Tennessee seismic zone, and way out here is the New
19 Madrid seismic zone.

20 MEMBER BROWN: So even Charleston is a
21 zone?

22 MS. GONZALES: Charleston is a zone.

23 MEMBER BANERJEE: Is that where there was
24 a big earthquake?

25 MEMBER BROWN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Okay.

2 MS. GONZALES: And so since the model was
3 developed in the '80s, there's been a lot of updates,
4 you know, various new data since then. So a lot of
5 our review was focused on determining whether the
6 applicant adequately updated the EPRI model to make
7 sure that -- to account for any new information.

8 MEMBER APOSTOLAKIS: Now the update means
9 a new zone, or different numerical characteristics of
10 the same zone, or both?

11 MS. GONZALES: Anything. I mean anything,
12 new data, new source zones possibly, or --

13 MEMBER BANERJEE: Is this sort of an
14 expert elicitation or --

15 MS. GONZALES: The EPRI model, six or 16,
16 they used input from the six different teams, so
17 that's kind of like an expert.

18 MEMBER APOSTOLAKIS: It's more of an
19 expert interpretation rather than elicitation.

20 MEMBER CORRADINI: Right. We had a day of
21 tutoring of this. Remember?

22 MEMBER APOSTOLAKIS: Yes.

23 MEMBER BANERJEE: Moving on.

24 MEMBER CORRADINI: I remember the faces in
25 the crowd, so we must have done something.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. GONZALES: So a major update the
2 applicant formed was of the Charleston seismic source
3 zone. Even though the EPRI teams did the final
4 Charleston seismic source zone, new geologic data had
5 been become available, which required an update.

6 MEMBER STETKAR: I was going to ask, does
7 this include the 2008 U.S.G.S. update?

8 MS. GONZALES: That's a different model.
9 The applicant kind of looked at that to help it --

10 MEMBER STETKAR: Did they incorporate it
11 somehow?

12 MR. MUNSON: Actually -- this is Cliff
13 Munson, the branch chief.

14 This was done before that 2008 update, but
15 the actual U.S.G.S. 2008 model captures this update
16 that was done for the Vogtle site. So the U.S.G.S.,
17 when they updated their 2002 hazard, they used this as
18 part of their update. So it's kind of meshed
19 together.

20 MEMBER STETKAR: Okay.

21 MS. GONZALES: So this figure shows their
22 updated model and you can see there are four different
23 source zones that they used to characterize the source
24 zone, and they each had different weights, and the
25 most weight was given to the source zone A, which is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this area here.

2 MEMBER APOSTOLAKIS: So does this mean
3 from the seismic point of view, things are more
4 severe?

5 MS. GONZALES: Yes, the update
6 incorporated paleoliquefaction data, which I'm going
7 to talk about in the next slide a little bit. But the
8 return periods, since they had this data, the return
9 periods of large earthquakes were shorter than
10 predicted by seismicity, which was used as the -- the
11 EPRI teams were out on seismicity to determine happen
12 large earthquakes occur.

13 MEMBER APOSTOLAKIS: I remember seeing
14 100,000 years going down to --

15 MS. GONZALES: Right, between 600 and
16 1,000 years, large earthquakes occur at that interval.

17 MEMBER RYAN: The return date means how --
18 when it may come back?

19 MS. GONZALES: Yes. How frequently the
20 earthquake occurs.

21 MEMBER BROWN: So instead of a longer
22 time, the time was shorter?

23 MS. GONZALES: It was shorter, yes, so the
24 hazard was higher from that source zone.

25 MEMBER APOSTOLAKIS: So if I don't much

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about earthquakes, I'm a member of the public, what is
2 it that guarantees to me that if I do it again in 20
3 years, we won't go down to 60 years?

4 MS. GONZALES: Well, they used what
5 available data they had, and I mean if they find new
6 data, then there's, you know --

7 MEMBER CORRADINI: No guarantee.

8 MS. GONZALES: That could change things
9 but, you know, if the record is longer, they could --

10 MEMBER POWERS: If it drops down to 60
11 years, then historically that record works.

12 MS. GONZALES: Well, they had a 5,000-year
13 record that they looked at, and you know, they
14 determined that those time intervals from now.

15 MEMBER APOSTOLAKIS: Do we have reasonable
16 assurance that the 600 years will not go down to 100?

17 MEMBER POWERS: Of course, George. If
18 it's 100, then you've got at least two data points and
19 a historical record.

20 MEMBER APOSTOLAKIS: No, because it's
21 deterministic.

22 MS. GONZALES: Well, they have a 2,000-
23 year -- the 2,000-year paleoliquefaction record is
24 pretty complete.

25 MEMBER APOSTOLAKIS: I mean that's pretty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 serious reduction from 100,000 to 600.

2 MEMBER RYAN: I think the point is the
3 record of 2,000 years is not spotty, it's fairly --

4 MS. GONZALES: The paleoliquefaction
5 record is pretty complete.

6 MEMBER APOSTOLAKIS: So there is some
7 evidence, scientific evidence, that it's not going to
8 go below the current estimate, significantly, anyway?

9 MEMBER RYAN: That would be low.

10 MEMBER APOSTOLAKIS: Be low.

11 MEMBER POWERS: Just tell him -- just
12 explain to George that it's a Bayesian update of the
13 prior created back in the 1980s based on opinion that
14 the liquefaction data has discovered since then.

15 MEMBER APOSTOLAKIS: I read the document,
16 and it says from 1986 to now, in this period of 20
17 years, we had this dramatic change in the return
18 period. I'm wondering what's going to happen in the
19 next 20 years. So I shouldn't worry? I mean can you
20 give me an answer?

21 MS. GONZALES: Well, the 2,000-year
22 paleoliquefaction record, the applicant determined
23 that to be complete, very complete based on their
24 field work, and the return periods are, you know, 600
25 years, 550 to 600 years.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: So what you are
2 saying is that it is not likely that we will have
3 additional information in the next 20 years with
4 dramatic changes in it?

5 MS. GONZALES: Not likely unless, you know
6 -- yes, in this new field they dig up a hole that
7 shows something they hadn't seen, but that small area
8 is pretty well investigated as far as --

9 MR. STIREWALT: And again, that's what the
10 paleoliquefaction does suggest. I mean that's good,
11 strong, solid geologic evidence for that possibly a
12 500-year or so interval. So that's really nailing it
13 better than we can nail anything else pretty much on
14 the East Coast. That's really a good, solid, strong
15 data point, and really quite good geologic for talking
16 about that timeframe.

17 MEMBER CORRADINI: So to put it a
18 different way, I guess, just so from the standpoint of
19 assurance, this is one of the places you have high
20 assurance compared to where you might have more
21 uncertainty in other places in the U.S.?

22 MEMBER RYAN: Correct me if I'm wrong,
23 folks, but to me the Charleston earthquake of 1886 and
24 all the study that's gone into that, and across the
25 state of South Carolina and over into Georgia, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably more robust than a lot of other areas of the
2 country that haven't been studied at all.

3 MEMBER CORRADINI: Definitely.

4 MEMBER APOSTOLAKIS: But people studied in
5 '86, too. It was studied in 1986, also, and yet in
6 the period of 20 years, we have such an enormous
7 charge.

8 MS. GONZALES: Well, I guess in 1986 they
9 relied on just the seismicity, the historical
10 seismicity that was recorded, so that, you know,
11 there's only one earthquake, the large Charleston
12 earthquake that they could really rely on.

13 MEMBER RYAN: Well, I think the point is
14 things didn't change, they just broadened their data
15 base, and they made their estimate robust.

16 MR. CONSTANTINO: The pinnacle of
17 liquefaction studies began in '85, '86, and they
18 mainly had to do with studies associated with the
19 Savannah River site across the way. That's the part
20 that nails it down. Prior to '86, there wasn't good
21 paleoliquefaction studies that were performed, and I
22 think that's really what Sarah is saying, that nails
23 down --

24 MS. GONZALES: Yes, they relied on
25 seismicity data instead for the return period.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR SHACK: So we should be suspicious
2 of any place where they're working with just
3 seismicity data.

4 MR. CONSTANTINO: Yes, that's right. In
5 all of those areas they're really spending a lot more
6 time now on the paleoliquefaction side.

7 MEMBER POWERS: Let's move on.

8 MS. GONZALES: So the Charleston record --
9 I said on the previous slide the Charleston update was
10 based on liquefaction features from historic and
11 prehistoric earthquakes.

12 Liquefaction features occur in response to
13 strong ground shaking, and this slide just summarizes
14 what liquefaction is.

15 You can see -- that's strong ground
16 shaking and the soil will become like a fluid, and
17 this fluid can penetrate the overlying layers, and you
18 can get the formation of sand dikes as well as sand
19 blows at the surface, and this also shows a sand dike.

20 And these could get preserved in the geologic record.

21 So that's what the applicant used to help better
22 define the geometry of the Charleston source zone as
23 well as the recurrence interval. They just relied on
24 that data.

25 MEMBER SIEBER: So if you are looking for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these things, you look for features like that and then
2 you have to use some kind of program technique to find
3 out where the fault is and how it's opened up?

4 MS. GONZALES: For sand blows, they are
5 visible from the surface, that that's a sand dike.
6 Usually they're exposed in the stream of river banks
7 and things like that.

8 MEMBER SIEBER: That's not the only fact.

9 MS. GONZALES: Yes.

10 MEMBER SIEBER: That's not the only form.

11 MS. GONZALES: No, that's true.

12 MEMBER SIEBER: It's characteristic of --

13 MS. GONZALES: Yes.

14 On the next slide I'm going to discuss
15 briefly the three significant open items we had
16 related to geology and seismology.

17 The first one has to do with one of the
18 EPRI-SOG teams, the Dames and Moore team. We were
19 concerned with the way that they had modeled their
20 source zones and its effect on the seismic hazard.

21 However, the applicant -- to resolve this
22 open item, the applicant determined the Dames and
23 Moore contribution to the hazard was very
24 insignificant at the Vogtle site, and this has mainly
25 to do with the dominance of the Charleston hazard, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that that closed that open item.

2 And the next open item was to do with the
3 the eastern Tennessee seismic zone. The applicant
4 didn't perform any updates on this seismic zone.

5 However, we were concerned because more
6 recent studies assigned much larger maximum magnitudes
7 to the source zone than the EPRI teams had assigned.

8 So what we did, we did our own sensitivity
9 study, and we increased the maximum magnitude of the
10 eastern Tennessee seismic zone, and the results showed
11 that the hazard was still insignificant at the Vogtle
12 site. It was too far away to really contribute to the
13 hazard. So that closed that open item.

14 And lastly, we had an open item to do with
15 the presence of injected sand dikes in the area. We
16 requested more information to ensure that these sand
17 dikes weren't related to earthquakes.

18 MEMBER BROWN: What is an injected sand
19 dike versus one that's related to earthquakes?

20 MS. GONZALES: They're both injected, but
21 one is related -- the earthquake can cause the sands
22 to liquefy, whereas the applicant in this case, they
23 provided us with field evidence to show that these
24 sand dikes were to do with collapse and dissolution of
25 the overlying Utley limestone.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay, not earthquake
2 generated?

3 MS. GONZALES: That's true. That's
4 correct.

5 MEMBER CORRADINI: In this case then, due
6 to aquifers or just water flowing and dissolving the
7 minerals?

8 MS. GONZALES: Yes, the limestone was
9 dissolved.

10 MR. STIREWALT: In this case, they are
11 located in three specific spots at the site. The
12 Utley sort of underlies it, but we know there's
13 dissolution and in fact it's related specifically -- I
14 mean spatially directly related to those little
15 pockets of dissolution.

16 So the thought is dissolution occurred in
17 the Utley. You had literally collapse of sediments
18 above, and that was the process for fluidizing the
19 obviously water-saturated sediments and moving them.

20 MEMBER CORRADINI: Okay. Thank you.

21 MS. GONZALES: So moving on to -- well,
22 that closed that open item, so moving on to section
23 2.5.4, the main topics here are engineering properties
24 of soils and rocks, site exploration, geophysical
25 surveys, liquefaction potential, and static stability.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So for the Vogtle ESP, we had 12 open
2 items addressing the adequacy of the field and lab
3 testing of subsurface materials. Measurements of
4 shear wave velocity as well as serial degradation
5 properties.

6 There is also a chronic condition, too,
7 which is added, and that required the removal of the
8 upper sand layer.

9 And there were also 12 COL action items.

10 MEMBER BANERJEE: And the shear wave
11 velocities were measured in situ? Or in samples or?

12 MS. GONZALES: They were rated in situ.

13 MEMBER BANERJEE: In situ.

14 MEMBER ARMIJO: Just a quick question.
15 Was the permit condition a result of the RAIs, or did
16 the applicant come forward initially with the intent
17 of removing the upper sand layer?

18 MS. GONZALES: Well, the upper sand layer
19 was susceptible to liquefaction, so the applicant's
20 liquefaction analysis assumed that that upper layer
21 was removed, and the site response analysis also
22 didn't include that upper layer as well. So --

23 MEMBER ARMIJO: Okay. So they intended,
24 when they made their application, to remove it.

25 MS. GONZALES: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: You just made --

2 MR. ARAGUAS: That was their proposal.

3 MEMBER ARMIJO: Okay.

4 MS. GONZALES: And so as part of the LWA,
5 the applicant provided us with a significant amount of
6 additional data, which is shown in this table here,
7 and this additional information was sufficient to
8 resolve the open items and the COL action items.

9 CHAIR SHACK: I'd say that's more data.

10 MS. GONZALES: That's it.

11 MR. MUSICO: Good morning. My name is
12 Bruce Musico. I'm a senior emergency preparedness
13 specialist within the Office of Nuclear Security and
14 Incident Response, NSIR, and I am here to just briefly
15 go over the Vogtle early site permit application and
16 the complete and integrated emergency plan that they
17 propose for the site.

18 As you can see in the first slide, the
19 emergency plan that Southern proposed for the Vogtle
20 site is unique in that it is the first time that a
21 complete emergency plan has been proposed under the
22 new Part 52 licensing process.

23 What they proposed again was a complete
24 and integrated emergency plan which in essence means
25 it includes the on-site plan as well as the off-site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plans, which consist of the state plans and local
2 county plans.

3 We conducted this review in conjunction
4 with or along with FEMA. FEMA actually reviewed the
5 offsite emergency plans, and they did a very detailed
6 review.

7 We looked primarily at the on-site, but we
8 also reviewed the offsite as well, just to see how it
9 was integrated with the on-site plan.

10 So when you see the term "complete and
11 integrated emergency plan," that means the on-site and
12 offsite plan working together.

13 Also this was a first-of-a-kind use of the
14 ITAAC, emergency planning ITAAC -- inspections, tests,
15 analysis, and acceptance criteria. And a number of
16 the RAIs that we were asked were associated with this
17 first-of-a-kind use of ITAAC, and we were able to
18 resolve those.

19 In the SER with open items, the initial
20 SER with open items, we identified 13 emergency plan
21 open items and three COL action items.

22 In the subsequent advanced SER, which is
23 what we are looking at now, all of the open items were
24 closed, resolved, and the three COL action items
25 actually were eliminated and change into permit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conditions.

2 On the next slide of interest is open item
3 13.3-4, which dealt with emergency action levels, or
4 EALs. This is unique here because in our review of
5 the emergency plan, it is utilizing the EAL scheme
6 that will be endorsed in the Nuclear Energy
7 Institute's document, NEI 0701, which is a document
8 that will reflect advanced passive reactors consisting
9 of the AP1000 and the ESBWR.

10 We are currently reviewing NEI 0701 for
11 endorsement, but that's a work in progress right now.

12 That is a parallel dependent licensing action that
13 this application is dependent upon. Hence we have
14 permit conditions associated with it.

15 In addition, we have an ongoing parallel
16 licensing dependent action in the AP1000 design
17 control document, DCD, in which Westinghouse has
18 submitted proposed amendments to the AP1000 certified
19 design, some of which are EP related, primarily the
20 location of the technical support center, and that is
21 undergoing current review by the NRC in the context of
22 a rulemaking proceeding.

23 So, again, we have two parallel dependent
24 licensing actions that we had to accommodate and
25 consider in the review of this application because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it's dependent upon those two. Hence we have permit
2 conditions; we also have ITAAC.

3 As I said before, the EAL resolution --
4 the EALs had been resolved by the introduction of six
5 permit conditions, 2 through 7. Specifically we have
6 three sets. We have 2 and 3, which deal with NEI
7 0701, 4 and 5, the AP1000 amendments, 6 and 7 deal
8 with a broader description of the requirements for
9 EAL, but basically it parrots what's in Appendix E of
10 10 CFR Part 50.

11 The reason there's two for each one is
12 that we have separated them out where unit 3 applies
13 to permit condition 2, 4, and 6, and unit 4 is permit
14 condition 3, 5, and 7.

15 And that fully covers the requirements for
16 emergency action levels, but to add an additional
17 assurance, we also proposed an ITAAC 1.1.2, which
18 requires a complete EAL scheme be eventually developed
19 that's consistent with Reg Guide 1.101.

20 If you're familiar with Reg Guide 1.101,
21 that is the vehicle by which we endorse various
22 documents such as NEI 0701.

23 And so when NEI 0701 is endorsed by us
24 through that separate ongoing proceeding, we will
25 issue a revision to Reg Guide 1.101 which will endorse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it.

2 So six of the seven EP permit conditions
3 relate to the emergency action levels. We have a
4 final permit condition that relates to the location of
5 the technical support center.

6 This was interesting because the AP1000
7 DCD amendments above, one of the amendments has to do
8 with changing the characterization of the TSC location
9 in the certified design from a tier 1 information item
10 to a tier 2*. And I won't get into the details.
11 Those are defined in Appendix D of Part 52. But in
12 essence it eliminates the need for a subsequent COL
13 applicant to submit an exemption request with the COL
14 application. They merely request a different location
15 for the TSC in the COL application, which is what we
16 have here for the Vogtle application.

17 So that has to do with the TSC.

18 With respect to the early site permit, we
19 made it a permit condition that the COL applicant will
20 subsequently have to resolve the difference between
21 the application, which says we're going to have a TSC
22 separate from that which is identified in the AP1000
23 design, yet identifies the AP1000 certified design,
24 which identifies the TSC being in the annex building
25 close to the control room. So we have a conflict

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there.

2 So we identified that as a permit
3 condition and we are actually reviewing the COL
4 application that's come out in this regard, and the
5 applicant has proposed a departure from the AP1000
6 certified design to accommodate this.

7 But the ESP itself basically approves the
8 relocation of the TSC subject to resolution of this
9 conflict in the subsequent COL application. So that's
10 what the TSC is about. We don't have a problem with
11 that.

12 Now a question was brought up yesterday
13 with respect to the two-minute walking distance. I'm
14 not going to get into a lot of detail here, but I made
15 reference to NUREG 0696, which is the applicable
16 guidance document, 1981 guidance document, which
17 recommends an approximately two-minute walking
18 distance between the technical support center and the
19 main control room.

20 We had quite a lengthy discussion
21 yesterday with respect to the precedence of allowing a
22 TSC, approving a TSC here, that's farther away. And I
23 made reference yesterday to a prior licensing action
24 that I couldn't recall the plant, but it had to do
25 with our approval of a TSC located 15 minutes away

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from the main control room.

2 I subsequently dug up the case. It was
3 for the Clinton station. It was a January 19, 2007
4 safety evaluation report that we wrote. It's a
5 nonpublic document, ADAMS No. ML070110425, entitled
6 "Subject: Relocation of the Technical Support Center
7 for the Clinton Power Station Under Docket 50-461."

8 The purpose was the proposed change would
9 relocate the technical support center from its current
10 location adjacent to the main control room to the
11 training facility on the east side of the owner-
12 controlled area.

13 In our analysis -- and this was done by a
14 different reviewer, and I was not aware of this study
15 at the time, this safety evaluation report at the time
16 when I reviewed and approved the relocation for
17 Vogtle. But it turns out we were consistent.

18 In fact, the reviewer had brought it to my
19 attention and said, well, you didn't know about this,
20 but we are still on the same wave length here. And I
21 sort of was glad to hear that. I was glad to hear
22 that.

23 MEMBER SIEBER: That's not the only plant
24 that's had to take exception.

25 MR. MUSICO: And this was given as an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 example, not the only example, but one example of
2 prior approvals that we have given with respect to
3 relocation of the technical support center.

4 Specifically it says the transit time
5 between the proposed TSC and the main control room
6 will be approximately 15 minutes and includes time to
7 traverse through the security barriers and it also
8 mentions the two-minute walking distance.

9 However, it comes to the conclusion,
10 "While the transit time is greater than the
11 recommended NUREG-0696, the enhancement to the
12 communications and instrumentation as well as the
13 enhancements based on an increase in the physical size
14 of the TSC is an acceptable alternative to the
15 functional requirements of NUREG-0696 and is
16 acceptable."

17 So the precedent has already been set in
18 prior evaluations that we have done.

19 So the Vogtle application was merely
20 consistent with what we have approved in the past, so
21 it wasn't necessarily precedent setting. So I just
22 wanted to clarify that and bring that to your
23 attention.

24 Okay. And then finally, as I said, with
25 respect to the EALs, we identified an ITAAC. The four

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bullets correspond to the four columns that are in the
2 ITAAC table.

3 The first bullet merely is the first
4 column, which parrots 10 CFR 50 Part 47(b)(4), which
5 deals with the requirement for a standard emergency
6 classification scheme, which includes the four
7 classifications as well as the EAL, associated EAL
8 scheme.

9 The second bullet merely parrots the
10 evaluation criteria in NUREG-0654(d)(1), which again
11 talks to the EAL scheme required. And you will see
12 there that in the first bullet, it says "the basis of
13 which includes facility system and effluent
14 parameters."

15 Now these are specific as-built aspects of
16 the reactor, details that you don't have to solve yet
17 until you build the building, the reactor and the
18 systems. And so that's why we need placeholders to
19 accommodate that, hence the permit conditions in
20 ITAAC. So ITAAC was well suited for this.

21 Secondly, the second bullet, the specific
22 instruments, parameters, and equipment status shall be
23 shown.

24 And finally, the plan shall identify the
25 parameter values and equipment status.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Again, these are dependent upon the as-
2 built aspects of the plant.

3 And then the final two bullets are the
4 most important here, in that the ITA inspection,
5 tests, and analyses says that the analysis of the EAL
6 technical basis will be performed to verify as-built
7 site-specific implementation of the EAL scheme, and
8 acceptance criteria is the EAL scheme is consistent
9 with Regulatory Guide 1.101, which is expected to be
10 endorsed -- which is expected to endorse NUREG-0701
11 following the staff's review.

12 And that's it in a nutshell. Any
13 questions? Thank you.

14 MR. ARAGUAS: All right, that brings us to
15 our discussion on LWA.

16 All right, so just to reiterate Jim's
17 comments on the activities that have been requested as
18 part of the limited work authorization, they have
19 asked for placement of engineered backfill on the
20 site. They have asked to place the mechanically
21 stabilized earth retaining walls. They have asked for
22 placement of links to be backfilled, mud mats, and
23 water proofing material, and with that we will speak
24 to each of those, and with respect to the area that we
25 reviewed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WANG: Okay. My name is Weijun Wang,
2 geotechnical engineer of the NRO. I will briefly
3 present the staff review on LWA request, section
4 2.5.4, the subsurface material in the foundation.

5 The staff issued 26 RAIs addressing the
6 concerns about the LWA request. Basically the first
7 one is the adequacy of the borings at the site.
8 Because during the ESP, the applicant performed 14
9 borings and only three of them to the load-bearing
10 layer, which is blue bluff marl. And because of that,
11 and also that 14 borings did not cover the whole
12 footprint of the AP1000, so that's one concern of
13 staff.

14 And the second concern is the adequacy of
15 the determination of engineering properties of the
16 subsurface materials. To continue, they had 12 tubes
17 of samples for the laboratory test, again for the
18 load-bearing layer. So that is not sufficient to
19 provide us reliable soil properties.

20 We are sort of concerned with the adequacy
21 of the DAC field soils. Through the ESP, the
22 applicant did not provide the most details about the
23 backfill, especially about the property of the
24 backfills. It's all the parameters were assumed or
25 used from based on unit 1 and 2 site investigations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We found staff concerns. The applicant
2 did the following. Regarding the further concern, the
3 applicant come back additional 174 borings, with 42
4 borings -- the 44 borings penetrated into the blue
5 bluff marl layer. Again, that's load-bearing layer.
6 And also 70 borings cover the footprint of the unit 3
7 and the 4, so which sufficiently provided enough
8 borings for the site investigation.

9 So this responded to our concern. You can
10 see because they conducted a lot more borings. They
11 collect a lot more samples, too. And also they
12 performed more field tests. For example, for the
13 load-bearing layer, the blue bluff marl, they
14 performed 742 SPT measurements. And also 94 soil
15 samples.

16 And for the lower sand layer, they
17 measured 111 SPTs, and another 29 undisturbed samples.

18 So because of that --

19 CHAIR SHACK: That's that 1,000-foot
20 coastal plain sediment, is that what you mean by the
21 lower sand stratum?

22 MR. WANG: The lower sand stratum is
23 underneath the blue bluff marl. So because the
24 applicant collected more samples and come back with
25 more laboratory tests, and they provide a lot more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 data to determine the engineering property, including
2 the static and the dynamic property of the subsurface
3 material in the site. They responded to our concern
4 about backfill. Besides providing the detailed
5 information about backfill material, the applicant
6 also provided a two-phase test path program. The test
7 path program, we provide the in-field property of the
8 backfill.

9 In addition to that, they also provide
10 what developed ITAAC for the backfill. The ITAAC, you
11 can see concentrates on two major parameters. One is
12 the minimum compaction, the minimum 95 percent
13 compaction of the backfill. Another one is the
14 minimum shear wave velocity, which is 1,000 feet per
15 second.

16 These two major parameters will ensure
17 that the backfill soil property will meet the design
18 requirements. In turn, it will ensure the stability
19 of the material underneath the foundation.

20 Based on staff review of the applicant
21 responded to our concerns, and also based on the two
22 site audits conducted by staff, one was in December
23 '07, another one in July of this year, the staff
24 concluded the applicant adequately answered our
25 concerns. Therefore, the 26 RAIs were resolved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Any questions?

2 MR. TEGELER: Good afternoon. My name is
3 Bret Tegeler, and I work in the structural engineering
4 branch in the Office of NRO. I am here to present
5 with John Ma and Carl Constantino, our consultant, the
6 structural engineering review of the LWA application.

7 To start off, as you recall, the applicant
8 is requesting to place foundation supporting elements
9 that will eventually -- that will be below the nuclear
10 island base mat.

11 As a result of that, the structural
12 engineering branch reviews the seismic demands on
13 those elements, namely, the reinforced -- I'm sorry,
14 the concrete mud mat and the waterproof membrane.

15 So the three SRP sections that we
16 performed our review under are 3.7.1., 3.7.2, and
17 3.8.5.

18 The primary, if you will, finding resides
19 in 3.8.5, the foundation, the assessment of the
20 sliding and overturn stability of the nuclear island
21 base mat placed on these elements.

22 To support that 3.8.5 finding, we need to
23 determine the seismic loads, which are fed from 3.7.1
24 and 3.7.2.

25 I'll just quickly cover it. In 3.7.1, our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 primary goal or review is of the site GMRS, the site
2 SSE, and we take that and compare that to the design
3 response spector for the AP1000.

4 And that's the next slide here.

5 In 3.7.2, we essentially review the
6 seismic analysis or soil-structure interaction
7 essentially looking to make sure and verifying that
8 the results make sense for use in the 3.8.5
9 evaluation.

10 I alluded to this one. This is a
11 comparison of the Vogtle site GMRS, essentially the
12 ground motion response spectra, which becomes the SSE
13 for the site.

14 The GMRS exceeds the AP1000 design
15 response spectra in essentially two frequency ranges,
16 below 1 hertz, and a higher range above 7 hertz.

17 As a result of the exceedance, the
18 applicant has to perform site-specific soil-structure
19 interaction to demonstrate that while though you have
20 an exceedance, a site-specific analysis is required to
21 demonstrate the -- sort of the appropriateness of the
22 site for the AP1000 design.

23 MEMBER SIEBER: That analysis was done and
24 you have it?

25 MR. TEGELER: Yes. That was performed by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the applicant and it was submitted.

2 MEMBER SIEBER: And your conclusion is
3 based not so much on that as on the analysis?

4 MR. TEGELER: Our conclusion -- this --
5 these data, if you will, are input into that SSI. The
6 SSI results reflect these data.

7 MEMBER APOSTOLAKIS: I can't hear you very
8 well.

9 MR. TEGELER: I'm sorry. The applicant's
10 2-D SSI analyses that were performed reflect these
11 design -- these spectra.

12 MEMBER APOSTOLAKIS: So even the spectrum
13 is different --

14 MR. TEGELER: That's right.

15 MEMBER APOSTOLAKIS: -- it's about -- what
16 matters ultimately is what?

17 MR. TEGELER: What ultimately happened,
18 that your loads and in-structure response spectra are
19 below the design basis. I'm sorry, I should say with
20 design basis.

21 MEMBER SIEBER: And if I look at that,
22 that doesn't tell me that.

23 MR. TEGELER: That's because this is just
24 a first input. The actual -- the first piece of the
25 analysis is a comparison of your site to the certified

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design response spectra.

2 If you exceed that, that's not the end of
3 the day. That doesn't mean that you can't stick an
4 AP1000 on the site. What it means is you have to do
5 site-specific analysis to make that demonstration.

6 MEMBER CORRADINI: Which you said earlier,
7 and I didn't hear, has been submitted to you?

8 MR. TEGELER: Yes.

9 MEMBER CORRADINI: Okay.

10 MR. TEGELER: This does not reflect --
11 this slide itself is not a result, if you will, of the
12 2-D analysis. This is a site -- this is the response
13 of the site which drove the applicant, because they
14 had a site exceedance, drives them to do a site-
15 specific SSI analysis.

16 MEMBER SIEBER: Do you have similar
17 graphics that would show the result of this site-
18 specific analysis?

19 MR. TEGELER: I have a back-up slide that
20 may help that. Maybe right when I --

21 MEMBER SIEBER: Yes, when you get to the
22 end of your portion, I'd like to see that, because
23 right now the only thing I'm convinced of is why we
24 ought not put that --

25 MEMBER APOSTOLAKIS: Is this site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specific?

2 MR. TEGELER: This is site specific in
3 that the site GMRS, that blue line, is a global site
4 condition.

5 CHAIR SHACK: The red line is the
6 certified spectra, right?

7 MR. TEGELER: That's correct.

8 CHAIR SHACK: That's not site specific,
9 that's --

10 MEMBER SIEBER: That's the design.

11 MR. TEGELER: So recall for Rev. 15,
12 that's the hard rock design, the Rev. 16, now 17, is
13 going to be a soil design, and so you -- in addition
14 to this -- these -- in addition to comparing to just
15 the Reg Guide 160 spectra or the red line, you also
16 look at the soil profile, so that's the other --

17 MEMBER ARMIJO: Does it follow that the
18 loads as a result of -- would be different or you'd
19 have greater loads on the structure, the structures
20 and the components in the plant? Would the actual
21 spectra then be bounding curves?

22 MR. TEGELER: What happens is you are, for
23 this case, you have exceeded the design at the -- in
24 the far field. When you do your SSI analysis, you
25 know how the nuclear island is embedded in a soil

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 column that's 1,000 feet deep. You have a lot of
2 energy dissipation due to soil damping, radiation
3 effects from the structure itself compared, and so
4 what I'm saying is I'm jumping ahead to the results of
5 the SSI analysis, but they demonstrate that while you
6 have the exceedance at the site, because you have your
7 embedded 40 feet in this 1,000-foot soil column, you
8 have a tremendous attenuation and you don't see the
9 exceedances to this degree in the in-structure.

10 MR. CONSTANTINO: Can I say something,
11 Bret?

12 MR. TEGELER: Thank you.

13 MR. CONSTANTINO: The design is based on
14 that design, the red spectra, put onto a number of
15 different sites, and it's the envelope of all of
16 those. And now we come to particular site-specific
17 evaluation. If the spectra fall below the design it
18 is clearly no problem. If it exceeds, there's still
19 probably no problem because of the detailed site-
20 specific characteristics which are different than the
21 envelope.

22 So that's really -- the 2-D results show
23 that, and we still have this open issue which we are
24 doing 3-D to confirm that.

25 But the basic idea is even if we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exceedances, we don't necessarily have exceedances in
2 structure demands on equipment and the structures.

3 MR. TEGELER: Thank you.

4 MEMBER SIEBER: But is the item closed, in
5 your mind?

6 MR. TEGELER: It's not closed in that
7 we're -- that's an ongoing review.

8 MR. ARAGUAS: But let me jump in and
9 clarify. It is closed for the LWA, and we've got to
10 be clear about that. It is closed for the LWA. We
11 have found that 2-D is acceptable, but for the purpose
12 of in-structure response, 3-D is what we're asking
13 for, and that's being reviewed as part of the COL.
14 But that's separate from the LWA.

15 MEMBER SIEBER: On the other hand, a
16 modification, which basically was designed for, which
17 the LWA is issued, could be a potential fix for this
18 issue. You know, you go deeper, pull in better soil,
19 but it is deemed not to be necessary at this time?

20 MR. TEGELER: That's true.

21 MR. CONSTANTINO: There is no such as bad
22 soil. Unless we go to concrete or something, and we
23 don't want to face that issue.

24 MR. TEGELER: So essentially, I'll wrap up
25 our findings in 3.7.1.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We found that the proximate method for
2 developing the FIRS at the site was adequate, and that
3 the FIRS also satisfied the regulatory requirements
4 for a minimum spectral change for the foundation.

5 3.7.2, again, we just talked about seismic
6 fouling. We did find the use of the applicant's 2-D
7 models appropriate for developing the seismic demands
8 for the purposes of sliding and overturning stability.

9 And just as a check on that, we compared
10 those, the applicant's results, to the soft soil case
11 of the AP1000 design.

12 And as I mentioned, these demands are then
13 passed to 3.8.5, for the actual stability evaluation
14 conducted under John Ma.

15 MR. MA: My name is John Ma. I work for
16 the structural engineering branch of NRO.

17 As you have been presented by the
18 applicant, the last slide showed you the boundary of
19 the MSE, the wall. That boundary wall will be the
20 boundary for the base mat of the nuclear island
21 structure.

22 So at this stage we are only saying you
23 can do the base mat preparation work, not including
24 the base mat. So the base mat is what we call
25 structural foundation for the nuclear island

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structure.

2 So initially they came in, they want to do
3 the foundation. They want to put the rebar cages
4 assembly for foundation. We said no, no, no, you
5 cannot do that because we have not resolved many RAIs
6 with the Westinghouse AP1000 base mat yet. So they
7 withdrew that, so as of now the only two preparation
8 work for the base mat is the mat, mud mat, and
9 membrane. They want to put a membrane between the mud
10 mat.

11 The thickness of the mud mat is 12 inches,
12 so they want to put the waterproofing membrane between
13 the mud mat, which we said if you want to do that,
14 you'd better show me the result of the mud mat will
15 not slide, the upper portion of the mud mat will not
16 slide relative to the lower portion of the mud mat
17 during SSE.

18 So they went out, they got the test result
19 and showed us, I think just the first -- yes, the
20 first one they said it's the coefficient of friction
21 of .7 or greater, and they showed us those test data.

22 And the second we got from the applicant
23 is their test result of their soil with a coefficient
24 of friction .45.

25 Now because this .45 is lower than .7,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 therefore the membrane will not control the sliding
2 effect. So the soil will control.

3 MEMBER CORRADINI: This was, I'm sure,
4 discussed yesterday, but just so I understand what you
5 just said, so they're putting in the mud mat, the
6 membrane is going inside the mud mat.

7 MR. MA: Yes.

8 MEMBER CORRADINI: That's the last thing
9 they are allowed to do ahead of time per your
10 approval.

11 MR. MA: Yes.

12 MEMBER CORRADINI: And the soil that's
13 naturally there falls below that, unnaturally there --
14 no --

15 (Laughter.)

16 MEMBER CORRADINI: The backfill soil is
17 what you're talking about, and it's that interface
18 between that backfill soil and the mud mat that you're
19 talking about.

20 MR. MA: Yes.

21 MEMBER CORRADINI: Thank you.

22 MR. MA: And the third data we got from
23 the applicant is the dynamics bearing capacity of the
24 soil is 42 kips per square foot.

25 Now let's go to the second slide now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 As you recall, Bret told you, their soil
2 motion input exceeded the AP1000 design spectra.
3 Because of that we said -- we asked the licensee --
4 the applicant, because you exceeded already, now you
5 got to show me during an SSE your base mat or your
6 nuclear island structure will not slide during an SSE.

7 So they made a calculation, the inertial
8 force during the SSE are large. They also made a
9 calculation the frictional forces, which use the .45
10 coefficient of friction multiplied the total dead
11 weight of the nuclear island structure.

12 As you can see here, the frictional force
13 is greater than the inertial force. Now, remember,
14 this inertial force is calculated based on the site-
15 specific spectra, so from this site has nothing to do
16 with AP1000 itself.

17 CHAIR SHACK: Except for the weight.

18 MR. MA: Except the weight, yes. Sure.
19 Okay.

20 And now let's go to the next slide.

21 A more important phenomenon in structure
22 during an earthquake is the break into the soil, and
23 some of you may have seen, especially in Japan, during
24 an earthquake, the whole building just turns over,
25 some totally, but some just, you know, go down and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 will not come back anymore.

2 The reason for that is because the dynamic
3 pressure on the soil exceeded the soil capacity. So
4 it goes down.

5 So we asked the applicant, you calculate
6 that number for us. So they did. As you can see, the
7 first line, they said the maximum dynamic soil
8 pressure during an SSE, the greatest one is under the
9 nuclear island, which is 17.95 kip per square feet.

10 In the first slide they already told us
11 the soil capacity is 42 per kip per square feet. So
12 if you divide 42 kip per square feet by 17.95, you get
13 a safety factor of more than two.

14 So in this case we know the footprint,
15 right now they have it under their MSE wall. In the
16 future when they build this plant, according to
17 AP1000, according to their weight, just like I
18 mentioned, if their weight is correct, we know it will
19 not slide, we know it will not overturn in an SSE.
20 And therefore we said for the LWA, this is okay.

21 MEMBER BROWN: Did anybody validate their
22 calculations?

23 MR. MA: We did the same calculation, and
24 this -- we wanted to make sure, you know, their
25 calculation is in the right part, so we made our own

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hand calculation.

2 MEMBER APOSTOLAKIS: Was it on the back of
3 an envelope?

4 MR. MA: What? Well, no, not really, and
5 very close to their number.

6 MEMBER BROWN: Okay. So you came out
7 approximately what they came out with?

8 MR. MA: Yes. Yes, approximately the
9 same. So we think that's good enough. And with this
10 kind of, you know, safety factor, over two, we think
11 that's good enough.

12 Thank you.

13 MR. ARAGUAS: Okay, so that brings us to
14 our last slide, the conclusion slide, and if you'll
15 bear with me, I'll just quickly read through the
16 conclusions for both the advanced SER and the LWA.

17 MEMBER STETKAR: One thing, Christian, let
18 me just -- the slide before that, and I know we're
19 short on time, but you said nothing about the in-plant
20 equipment response. That's still an open --

21 MR. ARAGUAS: Correct. That's part of the
22 COL.

23 MEMBER STETKAR: The COL?

24 MR. ARAGUAS: That's correct.

25 MEMBER STETKAR: That's fine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ARAGUAS: Okay. So for the SER and
2 the LWA, the conclusions, you can tell, are shared by
3 the two.

4 I would say the only area where it's
5 different with the SER with respect to the LWA is with
6 the LWA we're not approving site characteristics or
7 design parameters in terms of conditions as part of
8 the LWA. So that's totally specific to the SER.

9 But having said that, I'll read through
10 these.

11 The application meets the applicable
12 standards and requirements of the act and the
13 commission's regulations.

14 Site characteristics, site parameters, and
15 terms and conditions to be proposed to be included
16 into the ESP meet the applicable requirements of 10
17 CFR Part 52.

18 There is reasonable assurance that the
19 site is in conformity with the provisions of the act
20 and the commission's regulations.

21 The proposed ITAAC, those being the
22 emergency planning ITAAC and those associated with the
23 LWA, are necessary and sufficient and within the scope
24 of the ESP, provide reasonable assurance that the
25 facility has been constructed and will be operated in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conformity with the emergency plans and LWA, the
2 provisions of the act, and the commission's
3 regulations.

4 And lastly, the issuance of the permit and
5 the LWA will not be inimical to the common defense and
6 security or the health and safety of the public.

7 That concludes our presentation.

8 MEMBER POWERS: Thank you very much.

9 Do members have any additional questions?

10 Okay, we will draft a letter conforming
11 with the DAC provision submitted by the subcommittee.

12 CHAIR SHACK: We will recess for lunch
13 until 1:30.

14 (Whereupon, at 12:24 p.m., the committee
15 was recessed, to reconvene at 1:30 p.m.)

16
17
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 1:30 p.m.

3 CHAIR SHACK: I'd like to come back into
4 session. Our next presentation will be on a review of
5 staff activities associated with potential revisions
6 for 10 CFR 50.46(b) and Sam will be leading our
7 discussion.

8 MEMBER ARMIJO: Thank you, Mr. Chairman.

9 On the second of this morning, the
10 Materials, Metallurgy and Reactor Fuels Subcommittee
11 met with the staff and with members of the industry,
12 representatives of the industry. It was a full-day
13 meeting. We went into a lot of detail on this subject
14 and there was some new experimental information.
15 There was also a concept, an approach, that the staff
16 wants to present to us and did present to us on a
17 rule-making process which I believe is both practical
18 and efficient if it's followed.

19 There is general agreement or growing
20 consensus on the major phenomena that are involved in
21 cladding embrittlement, the dominant role of hydrogen
22 in controlling the embrittlement phenomena, obviously
23 the benefits of having zirconium alloys with very low
24 hydrogen pick-up rates during normal oxidation, normal
25 operation. The validity of testing hydrogen-charged

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unirradiated specimens to obtain properties equivalent
2 to those of irradiated fuel cladding I think is very
3 valuable information. There's recognition that low
4 temperature quenching after a LOCA or slow cooling
5 after a LOCA has some beneficial effect. The fact
6 that some highest-burn-up fuel can't achieve the very
7 high temperatures such 1200 degree Centigrade
8 compensates somewhat for the hydrogen pick-up during
9 normal corrosion that you find in high-burn-up fuel.
10 Anyway, a number of things. There's convergence.

11 The industry still has issues on some of
12 the phenomena that were being discussed and the
13 importance that the staff ultimately would place on
14 those phenomena, but I think even there was some
15 flexibility and a very good rule could be written and
16 I think with that I'd like to turn it over to Paul
17 Clifford and he can give us a summary review. We have
18 25 minutes allocated for Paul and 20 minutes for the
19 industry and we're going to try and hold to our time.

20 Paul.

21 MR. CLIFFORD: Thank you, Dr. Armijo.

22 As he mentioned, my name is Paul Clifford.

23 I am in NRR. I'd like to begin by stating the Office
24 of Research has recently completed a momentous
25 research program which has truly expanded our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 knowledge of fuel performance during loss of coolant
2 accidents. As you are aware, a description of this
3 research program along with key findings as documented
4 with a NUREG/CR-6967 and RIL-0801.

5 I'm here today to provide conceptual
6 changes to the rule. The structure of the rule is
7 being revised to provide an optional flexibility in
8 response to some comments we received from the
9 industry and the structure that's really still being
10 developed as we speak. We're in the early stages of
11 this process. It's a long path forward. As such,
12 things like specific rule language is still being
13 developed.

14 At this time, the staff does not need a
15 written response on our draft strategy or conceptual
16 rule changes. However we welcome any comments from
17 this body. As the rule-making matures, the ACRS will
18 have an opportunity to weigh on the specifics of a
19 future proposed rule and, with that, I will begin.

20 Following Commission directive, the staff
21 was tasked with developing a performance-based rule
22 which enables licensees to use advanced cladding
23 alloys such as M5 without the need for an exemption.
24 Specifically, we need to expand the applicability
25 beyond the words "beyond Zircaloy or ZIRLO" and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 text actually appears at 50.46.

2 In parallel, a second objective was to
3 capture the results of a high-burn-up LOCA research
4 program and, as I described, in NUREG/CR-6967 and RIL-
5 0801. This research identified new embrittlement
6 mechanisms which were beyond the known phenomena when
7 the rule was written back in 1973.

8 MEMBER RAY: And that's independent of the
9 desire for performance-based rule-making, the last
10 thing you said.

11 MR. CLIFFORD: It really is. It really is
12 two sided.

13 MEMBER RAY: Well, that wasn't clear a
14 couple of days ago as you've made it now. I just
15 wanted to be real clear.

16 MR. CLIFFORD: Okay.

17 I'm going to run through each of the
18 changes in the structure of the rule. First is the
19 Applicability. The current regulation in paragraph
20 (a)(1)(I) limits the applicability of "zircaloy" or
21 "ZIRLO." The research included a wide variety of
22 zirconium alloys, ZIRC 2, ZIRC 4, ZIRLO, etc., the
23 results of which have been shown in many cases to be
24 alloy-independent in some phenomena. In other
25 phenomena, we're developing specific test procedures

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to evaluate the effects of things such as burn-up and
2 alloy composition.

3 Expanding the rule has no impact on plant
4 safety. I'll set that straight and the strategy is to
5 replace the terminology "zircaloy" and "ZIRLO" with
6 something more generic such as "an approved zirconium
7 alloy." And consistent with current practice, the
8 applicability of any generic criteria within the rule
9 will have to be demonstrated by testing for any new
10 alloy further down the road.

11 Peak Cladding Temperature, the criterion
12 is provided in paragraph (b)(1) of 50.46 and today
13 it's limited to 2200 degrees Fahrenheit. The research
14 findings show that post quench ductility dramatically
15 decreases if the sample is oxidized in steam above
16 2200 degrees Fahrenheit. As such, it confirms the
17 current limit of 2200 degrees, that ceiling, and right
18 now we don't intend to change or increase that limit
19 above 2200 degrees Fahrenheit. There's no plant
20 safety because we're maintaining the same criterion
21 and there's no change.

22 MEMBER APOSTOLAKIS: When you say "beyond
23 2200" I mean how far?

24 MR. CLIFFORD: No, we're not changing it
25 beyond 2200.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: In the --

2 MR. CLIFFORD: The testing that was done
3 at 2200 shows that only after brief period does the
4 cladding become embrittled. So the 2300, timing would
5 be so short. So it really wouldn't be practical.

6 Local Oxidation, I have a couple slides on
7 this one. Paragraph (b)(2) specifies a limit on local
8 oxidation of 17 percent ECR. New embrittlement
9 phenomena were identified during this research.

10 MEMBER ARMIJO: Paul, you might want to
11 tell the rest of the staff what ECR means.

12 MEMBER APOSTOLAKIS: Thank you, Sam.

13 MEMBER ARMIJO: Since I heard you this
14 morning.

15 MR. CLIFFORD: ECR stands for Equivalent
16 Cladding Reacted. It's the amount of zirconium metal
17 that's converted to oxide. The research that was done
18 at Argonne identified new phenomena associated. It
19 showed a synergistic effect between oxygen diffusion
20 within the base metal or into the base metal and pre-
21 existing hydrogen. As such, the 17 percent criterion
22 that's currently specified is not always adequate to
23 ensure post quench ductility.

24 In addition, they determined that the --
25 Let me go back. Ten years ago, we issued information

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 known as 98-29 stating that licensees should subtract
2 the initial corrosion oxide layer in new ECR from the
3 17 percent. So if they had a equivalent cladding
4 reacted, if they had 20 mils which is equivalent to
5 say four ECRs, then their limit wouldn't be 17. It
6 would now be 17 minus 4 which would 13. But the
7 research findings show that even that correction was
8 not always adequate to ensure post quench ductility.

9 MEMBER SIEBER: So we can conclude from
10 that that the current rule was not conservative in all
11 cases.

12 MR. CLIFFORD: That is correct.

13 MEMBER SIEBER: With regard to oxidation.

14 MR. CLIFFORD: That is correct.

15 MEMBER SIEBER: And a change is necessary,
16 right?

17 MR. CLIFFORD: That is correct.

18 MEMBER SIEBER: Thank you.

19 MEMBER RAY: Both Jack and I have gotten
20 here to underscore that point.

21 MR. CLIFFORD: Now here's a slide that the
22 subcommittee didn't see on Tuesday and I think it was
23 stated that we wanted to see some more information on
24 plant safety. What I've done is I converted the
25 allowable ECR or measure the ECR to the brittle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 transition which is a function of hydrogen. I
2 converted that to local burn-up using oxidation
3 properties of each of these with these different
4 alloys and, as you can see, the measured brittle
5 transition for these particular alloys was above the
6 current 17 percent.

7 However, as you introduce initial hydrogen
8 during normal operation, this isn't hydrogen during
9 the transition. It's initial hydrogen as result of
10 normal steady state corrosion. The allowable ECR
11 would decrease such that as you move up in burn-up it
12 would drop below the current 17 percent.

13 Now with respect to plant safety, during
14 normal operation, time and temperature you built an
15 oxidation layer and there's some hydrogen that's up-
16 taken up into the metal which the research shows has a
17 direct impact on allowable ECR. But during the
18 buildup of corrosion you're also depleting U-235. So
19 as you burn up the rod, the rod power decreases and
20 we're just showing this. As for fresh fuel, you're
21 allowed a higher ECR but you're at a higher burn-up or
22 I should say a higher rod power and as your allowable
23 ECR was to diminish with burn-up or actually with
24 hydrogen pickup, the rod power would come down.

25 This is the TMOL. This is the thermal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mechanical operating limit for a typical BWR. It just
2 shows you the tradeoff between rod power and allowable
3 ECR.

4 Now the strategy for revising the local
5 oxidation, the 17th percent, is there's going to be two
6 options or two alternatives I should say. The first
7 alternative would be that a generic post quench
8 ductility criteria would be specified within the rule.

9 This would replace the constant 17 percent that's in
10 there now and this would be based on the Argonne
11 results. Here's just an illustration. I'm not sure
12 what the lines would look like, but it would be
13 something like this. And, in addition, the licensees
14 or the fuel vendors will have the option of using this
15 alternative approach to showing compliance which would
16 be to run a specific test program for defining
17 specific criterion for their alloy and I have a few
18 slides later on that show what flexibility this allows
19 the industry and I'll get to that.

20 Now the next issue identified at Argonne
21 was ID Oxygen Diffusion. The research identified that
22 if there's a fuel bonding layer present on the
23 cladding ID that the oxygen can diffuse into the base
24 metal from the ID and hence embrittling the cladding
25 much faster than if there wasn't oxygen diffusing from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the inside, if there was only oxygen diffusing from
2 the OD. There are no current regulations on this.

3 With respect to plant safety, current
4 methods already require double-sided oxidation within
5 the balloon region. So there wouldn't be a
6 significant difference in the limiting time and
7 temperature between the balloon region and outside the
8 balloon region. And also since this a burn-up
9 phenomenon you're not going to get a fuel bonding
10 layer until you're at mid to high burn-up and by the
11 time you were to obtain a fuel bonding layer rod
12 powers, you could have depleted the U-235. Rod powers
13 would be lower and hence there would be much more
14 benign transient for that rod. The strategy is to
15 introduce a new requirement within the rule which
16 requires the licensee to specifically account for ID
17 oxygen diffusion if a bonding layer exists.

18 Another new phenomena is Breakaway
19 Oxidation. Now the research identified this is a new
20 embrittlement. Essentially it involves the protective
21 tetragonal oxide transforms into an unstable
22 monoclinic structure and as the monoclinic structure
23 degrades it allows hydrogen to be taken up by the base
24 metal which promotes embrittlement. But all zirconium
25 alloys will undergo this transformation in the oxide

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 layer. The question is timing. When does it occur
2 and the requirement -- Timing is very important and
3 one of the key findings was that the timing was
4 sensitive to the manufacturing process. There are no
5 current requirements on this phenomena.

6 With respect to plant safety, currently
7 for domestic alloys the time for which transformation
8 occurs exceeds 3,000 seconds and we feel that the
9 current LOCA analysis even though they're conservative
10 coupled with reasonable operator actions show the
11 duration that any fuel rods are at these elevated
12 temperatures is beyond the timing of breakaway
13 oxidation.

14 The strategy would be to introduce a new
15 performance requirement.

16 MEMBER BROWN: You said it beyond the
17 timing. You meant below?

18 MR. CLIFFORD: Below, sorry.

19 The strategy for breakaway oxidation is to
20 introduce a new requirement within the rule that would
21 require specific testing on each vendor's alloy to
22 establish what the measured breakaway time was and
23 then the rule would require that the analysis show
24 that the rods aren't at elevated temperatures up to
25 that point up to that established measured time. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we are also considering required periodic testing
2 which we're sure that changes in the fuel fabrication
3 shop don't introduce changes in the behavior of the
4 fuel which it causes breakaway time to decrease.

5 We have -- There's a lot of challenge with
6 writing a performance-based rule which meets both the
7 rule-making objectives and also satisfies legal
8 requirements for a specific enforceable criteria. In
9 addition --

10 MEMBER APOSTOLAKIS: Can you tell us why?

11 MR. CLIFFORD: Well, the rule is going to
12 be somewhat complex because there's going to be --
13 Right now, it's just says 17 percent. No exceptions.

14 Now you're going to put in the hydrogen-based
15 criterion for local oxidation and an alternate
16 approach to meeting the rule which would be a required
17 test part which would be an optional test program. So
18 the rule becomes much more complex because there are
19 options essentially in the rule. That makes it a
20 little more difficult to write and to satisfy. And
21 another reason, too, is --

22 MEMBER APOSTOLAKIS: Longer, but I don't
23 know about --

24 MEMBER ARMIJO: Yes, it could be longer.
25 It would not be so simple.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR SHACK: The other thing, George, to
2 reflect is we actually wrote a letter one time that
3 told them to put in a performance-based rule. We told
4 them the performance was just to maintain ductility
5 and that one they really objected to on the basis of
6 specificity because there was really almost nothing
7 that was sort of enforceable about it. I mean that
8 was our recommendation when we last wrote a letter on
9 this topic was to have this performance-based rule and
10 that was one of the things that they came back with.

11 MEMBER APOSTOLAKIS: It could take longer,
12 but I mean difficult to split.

13 MR. CLIFFORD: Well, it is. Another
14 reason is because for instance you're defining a test
15 that needs to be done. Now you have to define certain
16 aspects of the test which would be legal requirements,
17 but you need to give flexibility for the laboratory to
18 figure out actually how to run the test.

19 MEMBER APOSTOLAKIS: They could just tell
20 them what the test results should be.

21 (Laughter.)

22 MEMBER RAY: George, maybe I can -- One of
23 the debates is over whether periodic testing or not is
24 needed. Paul mentioned, for example, the effect of
25 manufacturing process. You don't really know what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effect is. So that's why they're talking about
2 periodic testing. Well, there's an objection to
3 periodic testing because it seems so superfluous or
4 unnecessary and unjustified. So things like that they
5 get debated.

6 Do you, for example, prescribe -- How do
7 you define a change in the manufacturing process that
8 requires a new qualification test to be done? Those
9 are the issues he's talking about.

10 MR. CLIFFORD: And this slide shows, for
11 instance, in the regulation, in the rule itself, you
12 need to specify what post-quench ductility means.
13 What is your figure of merit for post-quench
14 ductility?

15 MEMBER CORRADINI: So can I just get back
16 to one thing that Bill mentioned just to -- But I
17 thought the objection at the time for that was that
18 they didn't want a qualitative rule even though
19 details would be in reg guide.

20 CHAIR SHACK: It's the same question about
21 enforceability and in this case now they've moved it
22 off to the test and what's an enforceable testing
23 requirement in the rule level without getting into the
24 reg guide level with detail of --

25 MEMBER RAY: Without being over

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 prescriptive.

2 CHAIR SHACK: -- how you run a test.

3 MR. CLIFFORD: And like in this slide
4 right here you try to define what ductility is.
5 You're saying you would have to expand this bullet
6 quite a bit.

7 MEMBER ARMIJO: Ductility as measured.

8 MR. CLIFFORD: It would be five percent
9 velocity strain as measured using ring compression
10 test on a double-sided or steam oxidized sample of
11 this size and then you start saying, "Well, okay. If
12 that's it, how do you prepare the sample?" You don't
13 want to get into sample preparation in a rule. You
14 want to move that out and now you start saying, "Okay.
15 Well, it's in a ring compression. What's your rate
16 that you're loading? How much loss are you applying"
17 like there may be aspects of the test that are down in
18 the dirt that you want to include in a reg guide.

19 MEMBER CORRADINI: I understand, but it's
20 not -- What I guess I'm trying to understand is the
21 complexity is what to put in the rule and to put in
22 the reg guide or the complexity is to put anything
23 other than a straight-up number. I'm trying to
24 understand what makes it complex. Is that where it
25 goes?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: Right. Correct. It's
2 where it goes.

3 MEMBER RAY: And also how can you be
4 flexible?

5 MR. CLIFFORD: Right.

6 MEMBER RAY: You mentioned there's a big
7 desire to give as much flexibility, to be innovative
8 and to improve as possible and yet without giving away
9 the goal that we have.

10 MEMBER ARMIJO: I mean it's going to take
11 some work, but I think it's doable. I think there's
12 enough known that I think you can put together. You
13 could say ultimately you want one percent strain
14 capability, classic strain capability.

15 Now unfortunately it's not like the
16 melting point of a metal. It's a mechanical
17 measurement and sometime you don't get it on a brittle
18 material and different ways of testing will get you a
19 different answer. So that's why he has to say as
20 measured by a certain kind of test and clear how you
21 put that in the rule or in the reg guide.

22 MEMBER APOSTOLAKIS: Shouldn't the rule
23 just say what you would expect the test to show, a
24 test to show, and then the reg guide --

25 MEMBER ARMIJO: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: So what's the --

2 MEMBER ARMIJO: There may be different --
3 There's probably different ways to do it. I'm just
4 saying --

5 MEMBER APOSTOLAKIS: Just say an
6 acceptable way.

7 MR. CLIFFORD: The reg guide. The reg
8 guide is always optional.

9 MR. RULAND: The fundamental question we
10 ultimately face in this matter is making sure we pass
11 the wickets set before us by the lawyers. The
12 lawyers are ultimately going to ask a hard question.
13 Okay. How can you tell something is a violation or
14 not and we typically cannot have those requirements in
15 a regulatory guide. They must be in the rule. So
16 what is in the rule by itself must be able to
17 withstand legal scrutiny so we can say, "Okay. If
18 such and such a thing happens, can we demonstrate that
19 it would be a violation or not?" And that is the part
20 of the complexity of drafting this rule is including
21 sufficient detail in the rule, but not so much detail
22 that it then becomes far too prescriptive.

23 MEMBER CORRADINI: So if I might just make
24 sure I understand that, the wrong way to do is to say
25 one percent plastic strain using your income pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 test with appropriate procedures and the reg guide
2 says what appropriate is because that leaves too much
3 vagueness to determine whether or not there was a
4 violation by or there was an incorrect, inappropriate
5 --

6 MR. RULAND: That would be one way to
7 think about it, yes.

8 MEMBER ARMIJO: Approved procedures and
9 then they have to come to you with their preferred
10 test and get your concurrence. That's an acceptable
11 way of doing it compared to what's already in the reg
12 guide.

13 MR. CLIFFORD: In an ideal world, you
14 would define the test procedures or test protocols in
15 an ASTM standard and reference the standard in a rule.
16 That's the ideal.

17 MEMBER ARMIJO: That would be nice.

18 MR. CLIFFORD: But I'm not sure if we
19 could get there.

20 MEMBER ABDEL-KHALIK: If one were to
21 measure the ductility with a bend test, for example,
22 what would be the corresponding acceptable plastic
23 strain?

24 MR. CLIFFORD: Do you want to take that
25 one?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MEYER: Yes. I think it would be the
2 same.

3 MEMBER ABDEL-KHALIK: It would be the
4 same. So why worry that's classifying the method of
5 testing if that's the case?

6 MR. MEYER: Well, for example, this
7 ductility threshold that we talk about which is shown
8 on this line is actually an intercept of a bunch of
9 ductility measurements of some very low value and you
10 have to decide where zero is.

11 MEMBER ABDEL-KHALIK: The point I'm trying
12 to make is that all the argument back and forth
13 pertain to the difficulty of being so specific about
14 the method that you're going to use for testing to
15 show that you have one percent plastic strain and if
16 it doesn't matter what method you use you can just
17 specify that you'll have one percent plastic strain.

18 MEMBER ARMIJO: You have to tie that other
19 method to the database that generated the --

20 MEMBER ABDEL-KHALIK: But that's why I was
21 asking.

22 MEMBER ARMIJO: -- these values. And in a
23 way you'd have to say, "Okay. The ring compression
24 test will get us one percent strain and we set our
25 criteria based on that. Now I want to use a tensile

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 test or a bend test." Then you'd have to do make a
2 connection that said that they're equivalent and prove
3 to the staff that they were. Then you probably would
4 get an approval to do that.

5 CHAIR SHACK: One problem is that you're
6 not actually measuring the plastic strain in this
7 test. You're measuring one percent plastic strain in
8 a ring compression test. If I did the finite element
9 analysis of what the true plastic strain was all
10 through that ring I would get a range of answers.

11 MEMBER ARMIJO: Right.

12 CHAIR SHACK: And if I tried to do the
13 same thing with a bend test, I would have to have --
14 to get the same local plastic strain, I might well
15 have a different criteria.

16 MEMBER RAY: The embrittlement is very
17 non-uniform. I don't know whether that goes to the
18 bend vs. ring test. But that was one of the points
19 they made.

20 MR. CLIFFORD: I mean, this is something
21 we're going to have to work through.

22 (Simultaneous conversation.)

23 MEMBER ARMIJO: I don't think this
24 committee is going to solve your problem, but it's a
25 real problem. But I think there's ways to get at it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and with time I think the staff will work that out.

2 MR. CLIFFORD: Okay. A few slides on
3 implementing the alternative post-quench ductility
4 criteria. Even if we were to have a single line or
5 curve in the regulation which you could say, "Well,
6 that's really not performance-based" when you convert
7 that allowable CPR versus initial hydrogen as I showed
8 in a previous curve or set of curves taking into
9 account the alloy oxidation cannot and hydrogen
10 pickup, actually it's really hydrogen pickup relation,
11 you are going to get a performance-based family of
12 curves for each alloy.

13 Now the Optional Test Program would
14 provide flexibility to the licensees where they could
15 go and run tests on their specific alloys. They could
16 run tests to not only define something specific for
17 their alloys, but they could define criteria specific
18 to their transient like, for instance, each size break
19 when you simulate a LOCA, a large break vs. a small
20 break. You could have a different style, a different
21 temperature profile.

22 Maybe one will have a really fast quench
23 and one will have more of a slow cool. And you could
24 define -- you could run tests to define criteria for
25 here's different transients. Here's a slow cool.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Here's a quench and expand it further where you could
2 say, "Well, what if I want to account for burn-up and
3 the fact that different rods are going to be operating
4 at different powers. Fresh rods are going to oxidize
5 at 2200 degrees Fahrenheit, whereas burnt rods may
6 only get up to 1900 degrees Fahrenheit and we've
7 already shown through some testing that there's some
8 potential benefit to be gained by testing, by doing
9 your ring compression test, on samples that have been
10 oxidized at a lower temperature. So you could have a
11 family occurrence for samples oxidized at 1900 degrees
12 versus these ones were done at 2200 degrees. So you
13 can make this as complex or as simple as you want
14 depending on how much margin you need for your given
15 alloy or for a given plant design.

16 Path Forward. There are a few ongoing
17 research activities which are being done to enhance
18 the existing technical database. The first one is
19 very important and that is the development and
20 validation of a comprehensive performance-based test
21 procedure for, as I mentioned, the flexibility of
22 running tests to establish post-quench ductility and
23 breakaway oxidation times.

24 MEMBER ARMIJO: You have two test
25 procedures then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: Correct. Absolutely.

2 MEMBER ABDEL-KHALIK: Could you please go
3 back to the previous slide. If you allow people that
4 level of flexibility, that still does not change the
5 fact that the current rule is non conservative with
6 regard to the 17 percent. Is that correct?

7 MR. CLIFFORD: That's correct.

8 MEMBER ABDEL-KHALIK: Okay.

9 MR. CLIFFORD: Even if we weren't going to
10 add the flexibility, we would have to change the rule
11 because of the 17 percent. It does not always show
12 conservative results or post-quench ductility, I
13 guess.

14 MEMBER ARMIJO: If you -- There is
15 inherent margin in these materials that haven't been
16 taken into account yet.

17 MR. CLIFFORD: Right.

18 MEMBER ARMIJO: And there's inherent
19 margin in the system behavior that hasn't been taken
20 into account yet. But if you made one size fits all,
21 you're going to wind up with a conservative rule
22 that's over conservative for some materials and for
23 some situations and if it turns out to be acceptable
24 to a licensee, they can come in with a justification,
25 topical report or something that would show that they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have the adequate ductility by virtue of real test
2 data, using real test data. So I think --

3 MEMBER ABDEL-KHALIK: But my question was
4 the graphs that he showed earlier showed, for example,
5 ZIRLO crosses the 17 percent line with a burn-up of
6 about 30,000 megawatt-days per ton. If people were to
7 do all these tricks and apply different limits to
8 different LOCAs, different cooling rates, different
9 initial temperatures, etc., that will still be a
10 constraint for some transients.

11 MR. CLIFFORD: It may for certain alloys,
12 but for certain other alloys we'll actually benefit
13 from this. Other alloys will see that they can go
14 above 17 percent for almost the entire cycle and if
15 they start getting into where they start looking at 19
16 percent, I'm sorry, you know, oxidizing at a lower
17 temperature for their higher burn-up fuel they're
18 going to buy themselves more flexibility. But, yes,
19 certain alloys that have a high hydrogen uptake are
20 going to be somewhat penalized and they will require
21 more time and effort and more complex reload analysis.

22 MEMBER ARMIJO: It will encourage the
23 development of better alloys and discourage the use of
24 materials that are marginal and that's a good rule.

25 (Off the record comments.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Sam explained to me the
2 other day. I asked the question about if you're
3 changing your ramp, your linear generic line, just for
4 example, the option that you had in the thing, that
5 the existing fuels you could still use the depleted
6 fuel rods as long as you put them in areas of low
7 power so that they now put under. So the non
8 conservative you try to put them in a high power --
9 and maximize fuel utilization which is desirable I
10 guess economically. But you don't. You take a hit.
11 You put them in a low power area. Then you still
12 maintain a satisfactory safety margin relative to this
13 phenomena, the hydrogen oxidation, breakaway,
14 whatever.

15 MR. CLIFFORD: I don't see anything we're
16 doing here is discouraging licensees from going into
17 the spent fuel pool.

18 MEMBER BROWN: Well, except that they have
19 to know that they have to do that. If you change the
20 rule, they would have to know that they now have to
21 have a better evaluation or knowledge of their fuel
22 conditions so that they make sure the higher burn-ups
23 in low power locations. I wanted to confirm my
24 understanding.

25 MR. CLIFFORD: That's 100 percent correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay. So it's not like the
2 world's falling apart right now. It's just they have
3 to be more careful about how they do it.

4 MR. CLIFFORD: Right.

5 MEMBER POWERS: How would they be more
6 careful than you would be in a reload analysis?

7 MEMBER BROWN: I'm not a reload analysis
8 guy. It just seemed to me that if you put it in a low
9 power part in a reload analysis or wherever you do it.

10 MEMBER ARMIJO: It would tend to keep you
11 from doing something really foolish to drive a really
12 high burn-up rod just to get the last few neutrons out
13 of it. People won't do that anyway. It's not that
14 economical. The high burn-up fuel just it doesn't
15 make a lot of sense to try and stuff it into the
16 middle of the core. Some of the core designers may
17 like to do that but this would discourage that.

18 MR. CLIFFORD: And right now, the power
19 envelope for a fuel rod is limited by thermomechanical
20 criteria, mostly rod internal pressure.

21 MEMBER ARMIJO: Right.

22 MR. CLIFFORD: And you can't have a rod
23 operating at 60 gigawatt-days operating at 14
24 kilowatts a foot.

25 MEMBER ARMIJO: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: You just can't. First of
2 all, you could never get there and second of all the
3 fission gas release from these would cause the thing
4 to pop. So that's limited now. Would this be more
5 restrictive? I doubt it.

6 MEMBER ARMIJO: I think it's going in the
7 --

8 MEMBER BROWN: That's not fair looking for
9 inter TMOL curve relative to the --

10 MR. CLIFFORD: Yes, they're not related.

11 MEMBER BROWN: They're not apples and
12 apples.

13 MR. CLIFFORD: Right.

14 Okay. We have three ongoing activities as
15 I mentioned. The first one is the comprehensive test
16 program which is very important because we've already
17 seen lab-to-lab variations and results which we don't
18 want to be in the situation where in the future we ask
19 licensees to spend millions of dollars to come up with
20 one test and come up with criteria and then we start
21 questioning the validity of the results. So it's very
22 important to come up with a very comprehensive,
23 detailed test program that the staff finds acceptable
24 that the industry can just follow. The second and
25 third activities are a few more testing done at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Argonne to enhance our understanding and overall
2 complete detectable dose.

3 MEMBER APOSTOLAKIS: I get the feeling
4 that you are not too enthusiastic.

5 MEMBER ARMIJO: You have a bad feeling
6 there, George.

7 MEMBER POWERS: Well, he gets this feeling
8 because there's always a few more tests to do.

9 MEMBER APOSTOLAKIS: Yes. And it's
10 difficult to this.

11 MEMBER ARMIJO: You've got to do it right,
12 George.

13 MR. RULAND: It's our goal to make these
14 few more tests the last few more tests.

15 MEMBER POWERS: I'm enthused about that,
16 but I'm suspicious.

17 (Laughter.)

18 MEMBER ARMIJO: Go on.

19 MR. CLIFFORD: Okay. This slide just
20 identifies a process we're considering called the
21 Advanced Notice for Proposed Rule-making. The key
22 feature of this process, it allows us to complete the
23 rule-making while, I'm sorry, to complete the few more
24 research tests while we're working with the industry
25 and the public stakeholders to give opinions on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 rule and just allows us to work in parallel as opposed
2 to working in series.

3 And the last slide --

4 MEMBER POWERS: This Advanced Notice for
5 Proposed Rule-making has traditionally been used when
6 the staff has questions about exactly how a rule ought
7 to be written. What are those questions that are in
8 there?

9 (Off the record comments.)

10 MR. CLIFFORD: Well, I think the key
11 feature of the ANPR is going to be asking the industry
12 to comment on the detailed comprehensive test program.
13 To me, that's the biggest issue. Because if we put
14 out a test program and the industry finds out that
15 they can't follow, then it has no use. So that
16 certainly is the key to the ANPR. There's a lot of
17 other questions to ask as far as the impact and
18 implementation and when you actually write rule
19 language ask them to comment on the rule language.

20 MEMBER ARMIJO: Ambiguity. Clarity.

21 MEMBER ABDEL-KHALIK: Now the point was
22 made during the subcommittee meeting that for high
23 burn-up fuel there is significant azimuthal variation
24 in the hydrogen pickup.

25 MR. CLIFFORD: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: And if that is the
2 case, do you have any hope of coming up with a test
3 procedure that would give you a definitive answer as
4 to the ductility given the fact that whatever results
5 you're going to get from a ring test will depend on
6 the orientation of the ring?

7 MR. CLIFFORD: Absolutely.

8 MEMBER ABDEL-KHALIK: And if you have
9 significant variation in the hydrogen concentration,
10 you can get results that vary significantly. So
11 whatever graphs --

12 MR. CLIFFORD: One way of addressing that
13 is when --

14 MR. MEYER: I don't think that's the
15 correct assessment. The ring compression test will
16 not give you good deformation data, good quantitative
17 deformation data, but they are very good at
18 identifying where the transition occurs from ductile
19 to brittle behavior and it does not depend strongly, I
20 don't even thing weakly, on the orientation of the
21 specimen.

22 MEMBER ABDEL-KHALIK: This just can't be
23 right because the underlying hypothesis here is that
24 the transition depends on the amount of hydrogen.

25 MR. MEYER: That's correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: And if there is
2 significant variation in the amount of hydrogen --

3 MR. MEYER: Yes.

4 MEMBER ABDEL-KHALIK: -- you can't tell me
5 that the transition is independent of how much
6 variation you have in the ring.

7 MR. MEYER: I'm sorry. No. You're
8 absolutely right regarding the true variation of
9 hydrogen because it will tend to find that place where
10 the hydrogen has peaked and break there. And so if
11 you then go to that fracture location and measure the
12 hydrogen you get the right answer.

13 MEMBER ARMIJO: Right.

14 MR. MEYER: And that's exactly what we've
15 done.

16 MEMBER ARMIJO: Right. So it's kind of
17 self-correcting in that the most embrittled parts of
18 the ring or the sample as where it cracks and that's
19 where the hydrogen is concentrated. That's from your
20 test data.

21 MR. MEYER: Yes. We've measured hydrogen
22 concentrations azimuthally around the specimen for our
23 six different locations and correlated that with the
24 ductile-brittle transition.

25 MEMBER POWERS: It might affect your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ability to compute your hydrogen in your actual fuel
2 samples to correlate with your ductility.

3 MR. MEYER: Certainly. It makes it
4 difficult to develop a correlation for a given fuel
5 cladding type as a function of burn-up because you do
6 have this variation. The variation doesn't seem to
7 show up strongly until you get very high hydrogen
8 concentrations. So at the lower concentrations, I
9 don't think there's -- We haven't seen much.

10 MEMBER ARMIJO: But it's an issue, but
11 that's the way normal fuel rods work. Depending on
12 the fuel rod design, there will be variability along
13 the length and circumferentially on some types of
14 fuel.

15 MEMBER ABDEL-KHALIK: But the whole
16 purpose is to come up with a unique design guide that
17 gives us a unique limit that people would apply in
18 their safety analyses.

19 MEMBER ARMIJO: Right.

20 MEMBER ABDEL-KHALIK: And if there's a
21 huge error bar on that because of the manner in which
22 the test is done or because of the nature of hydrogen
23 pickup and high burn-up fuel, then there is something
24 fundamentally wrong with the process.

25 MEMBER ARMIJO: It's really the extent to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which the laboratory test. The hydrogen charged
2 specimen reflects the properties of a real fuel rod
3 with nonuniformity because in the hydrogen charged
4 specimen it's going to be uniform. It's done in a
5 furnace.

6 MR. CLIFFORD: And another way to address
7 it is in the implementation. When you develop a
8 hydrogen model, I mean, if you wanted to be overly
9 conservative I should say, when you develop a model to
10 implement a hydrogen-based rule you would have a
11 licensee get a lot of, you know, high -- fuel rods, go
12 to the hot cell and then measure the variation and
13 maybe take a two signal on that or something.

14 MEMBER ARMIJO: Right.

15 MR. CLIFFORD: I mean there are different
16 ways to address the variability in the application of
17 a curve. It's something we need to think about.

18 MR. MEYER: Yes. I think the whole
19 problem is on that side of the equation. Because on
20 the measurement side, we're able to determine what we
21 have and to correlate that with the threshold that
22 we're looking for.

23 Besides I just can't resist commenting
24 about a whole thread of discussion here, but there's
25 not that much deviation from this behavior that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 see in the dataset taken at Argonne. There's almost
2 no alloy dependence. There's a small dependence if
3 you tested a different temperature or if you tested a
4 different cooling rate. So it's not like you're
5 throwing the flood gates open and you can go out and
6 run a bunch of tests and get wildly different results.

7 They're going to be very close to the results that
8 we're indicating with that straight line.

9 MEMBER ARMIJO: And I think to your point,
10 Ralph, where you have the most variability in
11 circumferential hydrogen is under high burn-up rods
12 which have the least driving forces from the
13 standpoint of peak temperatures. Yes. It's
14 complicated, but you can handle it. I think you can
15 come up with a practical test that's meaningful.

16 MR. CLIFFORD: And also if you draw the
17 curve, if you take your empirical data and you draw
18 your acceptance criteria based on the average hydrogen
19 and essentially slid the curve in the conservative
20 direction relative to the peak, it almost penalized
21 the experiment due to these axial or circumferential
22 variations. It's got to be looked into.

23 Okay. My last slide is just essentially
24 the process for rule-making and it lists some
25 milestones. I'm not going to walk through each, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're essentially right here step one. As we
2 mentioned the ANPR we're considering and we're going
3 to go out for public comment, probably have another
4 workshop because it's always good to solicit as much
5 information as we can during this process and at some
6 point we'll need to a backfit for 10 CFR 50.109 and
7 then the ACRS will be back here by the time we get to
8 a proposed rule. So you guys will obviously be in the
9 loop.

10 Any more questions?

11 MEMBER MAYNARD: On the backfit
12 determination, is it your intent to make this to
13 effect both the existing plants?

14 MEMBER SIEBER: Sure.

15 MR. CLIFFORD: That's correct.

16 MEMBER MAYNARD: Or for existing fuel and
17 stuff out there?

18 MR. CLIFFORD: No. Our view is that the
19 current rule is inadequate. So we will be revising
20 the current rule.

21 MEMBER MAYNARD: That's what I thought.

22 MEMBER APOSTOLAKIS: Is there going to be
23 a regulatory guide somewhere there or after the rule?

24 MR. CLIFFORD: When we develop Step three,
25 the comprehensive test procedures, we still hadn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 decided what the best vehicle is for that, whether
2 it's a reg guide or -- We don't want to commit to
3 where we're going to put it, but it has to go
4 somewhere.

5 MEMBER CORRADINI: What are your other
6 options other than a reg guide?

7 MEMBER APOSTOLAKIS: Put everything in the
8 rule.

9 MEMBER ARMIJO: No.

10 MR. CLIFFORD: Putting it in the rule
11 would be my last option. I mean that would be my last
12 choice.

13 MEMBER APOSTOLAKIS: Is somewhere in there
14 you begin to develop the guide?

15 MR. CLIFFORD: Correct.

16 MEMBER CORRADINI: Okay.

17 MEMBER ARMIJO: Okay. Very good. Next is
18 Ken from EPRI.

19 Let's go.

20 MR. YUEH: Thank you, Dr. Armijo.

21 Before I start, I just want to acknowledge
22 the industry's appreciation for collaborative work
23 together with NRC Research Branch and as we move
24 forward to rule-making it looks like things are going
25 to accelerate. I think it's more important to have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more exchanges to resolve the many issues.

2 I have a very quick presentation. The
3 first slide I have is a follow-up to yesterday's
4 discussion of safety significance, you know, what we
5 just talked about. Industry position, hydrogen is a
6 surrogate for irradiation. Talk about data gaps,
7 three areas, estimate of implementation costs and
8 summary.

9 This slide is actually from Dr. Meyer's
10 presentation on I guess different scenarios where the
11 allowable CP-ECR will fall. On the lefthand side,
12 this chart shows a Westinghouse 3-loop. I think it's
13 a core-to-core model. It has a peak from each of the
14 sampling. It basically just shows core cycle, 2nd
15 cycle and third cycle.

16 What I tried to do is plot ECR for a
17 typical LOCA scenario onto this chart. The first
18 cycle -- Basically I stretched the temperature at the
19 pickup location to 1200 degrees Celsius and then
20 calculated the ECR. For a realistic scenario, the ECR
21 is way down here, you know, in the first cycle, the
22 second cycle and third cycle.

23 And then I did the maximum. I assumed the
24 sample was, the fuel rod was, at 1200 degrees Celsius
25 and then I calculated the time where you would reach

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that peak and then I scaled down based on the
2 difference here that you can expect in the first and
3 second cycle. The ECR, the achievable ECR, is scaled
4 below the potential New RIL-0801 and taken together
5 with potential pickup cladding temperature which is
6 shown in the red line which Dr. Meyer asked if it
7 could be done at four percent. I added three percent.
8 This is where this line falls.

9 I do want to point out also that this line
10 here IN 98-29 I think is based on a hydrogen pickup
11 fraction of about 25 percent. I think that's a
12 abnormally high pickup fraction. I think the average
13 of Zirc-4 is about 15 percent. If 15 percent pickup
14 fraction is used for this line it will fall somewhere
15 along here. So clearly from this there is no safety
16 concern.

17 MEMBER ARMIJO: That may not be clear to
18 everybody what you just said.

19 MR. YUEH: There may be odd core designs
20 as you discussed earlier where somebody could have a
21 high -- fuel in the middle, but those would be
22 exceptions. I think in general 90 percent, 95
23 percent, of fuel samples will behave this way.

24 MEMBER ARMIJO: So your expectation is
25 Zircaloy-4, modern zircaloy-4.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. YUEH: Yes.

2 MEMBER ARMIJO: Could meet these new
3 criteria.

4 MR. YUEH: Yes.

5 MEMBER ARMIJO: Does. That the criteria
6 -- line that you're in trouble.

7 MR. YUEH: I do want to follow up on what
8 was discussed on the hydrogen level on the ring test.

9 MEMBER ABDEL-KHALIK: Before we go there,
10 this must be a very conservatively designed core
11 because the maximum pin power is 1.4.

12 MEMBER ARMIJO: Those are peaking factors.

13 MEMBER ABDEL-KHALIK: Right, but what is
14 the -- That means the bundle average power peak value
15 much be way below 1.4.

16 MR. YUEH: It's a little bit. This is a
17 peak rod.

18 MEMBER ABDEL-KHALIK: Yes, I know. This
19 is the peak rod.

20 MR. YUEH: Yes.

21 MEMBER ABDEL-KHALIK: Which means that the
22 peak bundle average power must be way below 1.4.

23 MR. YUEH: Yes.

24 MEMBER ABDEL-KHALIK: Which means that
25 this is really a very conservatively designed core.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. YUEH: Yes. So this kind of power --

2 MEMBER ABDEL-KHALIK: It's sort of biased
3 story, don't you think?

4 MR. YUEH: Sorry.

5 MEMBER ABDEL-KHALIK: This would be a
6 biased story. That's the point you're trying to make.

7 MR. YUEH: But I do want to present a case
8 from the high temperature side to show that it still
9 falls below the line, the new one.

10 MEMBER ABDEL-KHALIK: Okay.

11 MR. YUEH: That's the point I want to try
12 to make even for a very conservative core design where
13 you have high power and then I scale the temperature
14 to the maximum 1200 Celsius. If the second cycle is
15 limited here, it's still below the --

16 MEMBER MAYNARD: You're saying that this
17 shows that they're safety significant. Aren't you
18 also showing that there would be no problem meeting
19 the new rule?

20 MEMBER SIEBER: That's right.

21 MEMBER ARMIJO: For that particular
22 design.

23 MR. YUEH: Yes. Well, for -- That's why
24 we're trying -- On Tuesday, Westinghouse was trying to
25 argue there is no real benefit because the new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 limitations from hydrogen, it really applies to high
2 burn-up fuel and with high burn-up fuel the
3 temperature is much lower, less than 1000 Celsius.
4 You accumulate almost no ECR and ECR accumulation is
5 only significant above 1000 Celsius and below that
6 it's very slow and even there's a big difference 1200
7 and 1100.

8 And the point that we just talked about
9 with high burn-up fuel rods, even though you have a
10 lot of hydrogen in there, the temperature is not
11 capable of reaching temperatures. You cannot
12 accumulate ECR. So the ductility there is not an
13 issue because --

14 MEMBER ARMIJO: But it does point out that
15 the real risk, the safety risk, is in your second
16 cycle or first cycle fuel that has plenty -- that's
17 had some burn-up and if you pick up too much hydrogen
18 you're going to get in trouble.

19 MR. YUEH: Yes. I have used 400 ppm
20 hydrogen for end of the second cycle and I've been
21 criticized that that's too high for other industries.

22 It's too high because Zirc-4 it is a little bit on
23 the high side and for advanced alloys these datapoints
24 were even below it.

25 MEMBER SIEBER: But there's some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 subtleties in here that can change this a little bit,
2 too, for example, addition of burnable poisons and how
3 they're lumped and the extent to which they burn off
4 over -- The total burn-up of the fuel can change these
5 power ratios.

6 MR. YUEH: There could be temporary
7 spikes, yes.

8 MEMBER SIEBER: Well, it could be more
9 than slightly depending on how aggressive you tried to
10 do these things. The fact though is that the current
11 rule is technically not correct.

12 MR. YUEH: Right.

13 MEMBER SIEBER: And you can meet the new
14 rule doing the same fuel design and manufacture that
15 you do now. So you know your argument is to make the
16 rule technically correct and not disturb fuel design,
17 fuel manufacturing, core -- The core analysis seems to
18 me not all that bad a deal to just to achieve more
19 technically a correct picture by rule as to what's
20 going on in the plant.

21 MR. YUEH: Yes, exactly. It's going to
22 coast \$300 million to do.

23 (Simultaneous discussion.)

24 MEMBER ARMIJO: Go see the Treasury;
25 they're giving money away.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 Okay. We really have to move along.

3 MR. YUEH: I will just say this. This
4 here is the test data for red irradiated and black
5 hydrogen pre-charged. I just want to show that the
6 data falls on the same trail line even though the
7 tubing material is made from different manufacturers
8 and different processes and they all fall on the same
9 line and the industry certainly believes that hydrogen
10 can be a surrogate for irradiation.

11 CHAIR SHACK: Are you planning any more
12 work to support that?

13 MR. YUEH: Apparently, NRC Research is
14 planning to conduct tests to fill up a couple of
15 datapoints in here.

16 MEMBER ARMIJO: The answer, yesterday, at
17 the subcommittee meeting, they presented data saying
18 they were going to do more.

19 MR. YUEH: Yes.

20 MEMBER ARMIJO: At EPRI.

21 MR. YUEH: We are going to do non-
22 irradiated.

23 MEMBER ARMIJO: I understand the non-
24 irradiated stuff.

25 MR. YUEH: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MEYER: What the NRC is going to do is
2 we're going to get one more red point in the middle of
3 that.

4 MEMBER ARMIJO: Will that be on ZIRLO?

5 MR. MEYER: Yes.

6 CHAIR SHACK: I guess the question is do
7 you presume this is not true for all zirconium-based
8 alloys or is that something that has to be
9 demonstrated?

10 MR. MEYER: If you're asking me, the
11 answer is I'm quite sure it's true for all zirconium-
12 based alloys based not only on the data that we've
13 taken which you see is quite consistent but also on
14 our understanding of the process that causes this
15 embrittlement which doesn't look like it should be
16 strongly dependent upon the alloy.

17 CHAIR SHACK: That certainly makes people
18 very happy.

19 MEMBER CORRADINI: Yes, the vendors.

20 MR. MEYER: But you have to make a clear
21 distinction between this and the breakaway process
22 because -- And I'm not sure that that distinction has
23 been made clearly here because the breakaway process
24 which is a totally different phenomenon is sensitive
25 to alloy and fabrication details.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. CLIFFORD: I think it's important to
2 notice I don't think the staff has consensus on that
3 issue. I would like to see in my opinion some of the
4 irradiated tests and there are many irradiated tests
5 up there. I mean, each one of those points is a
6 handful of tests, not just a single one. I would like
7 to see the same stock material pre-hydrided and run
8 for a direct, you know, if you have a irradiated piece
9 with 425 ppm, I'd like to see the same stock material
10 pre-hydrided to 425.

11 CHAIR SHACK: You want to see the true
12 comparison.

13 MR. CLIFFORD: Into a true comparison and
14 see where it falls with the exact same point. So on
15 my slide Tuesday, I believe I had a bullet that said
16 it's up to the industry to validate the pre-hydrided.

17 CHAIR SHACK: I sort of noticed it was
18 missing from your slide today.

19 MR. CLIFFORD: There was a lot of material
20 missing from my slide today.

21 CHAIR SHACK: All right.

22 MR. YUEH: That's something we can follow
23 up on if they can find stock material. We don't know
24 if the material is there.

25 MEMBER ARMIJO: Okay. We should go on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Keep moving.

2 MEMBER POWERS: Can I just ask?

3 MEMBER ARMIJO: Yes, sir.

4 MEMBER POWERS: About this concern about
5 the region between 100 and 300 ppm? Is there someone
6 out there that thinks there's a resonance or something
7 like that that they were going to see something wildly
8 deviating from this line?

9 MR. YUEH: Well, you do have the non-
10 irradiated datapoints there and in a LOCA all the
11 irradiation history, it's mostly wiped out.

12 MEMBER POWERS: What I'm asking, why is it
13 so crucially important to get a datapoint? I mean,
14 you got -- I have no idea whether this is a 100 to 300
15 datapoint occurred or a straight line through these
16 datapoints. But unless somebody has some hypothesis
17 that there is some sort of a resonance phenomena
18 occurring between 100 and 300 datapoint, it's
19 difficult for me to imagine that it's crucial to get a
20 datapoint in there.

21 CHAIR SHACK: Which I think is why it's
22 the last test Ralph is running.

23 MEMBER POWERS: If I were going
24 to hit datapoints out here and add to this, it would
25 be in the 600 to 700 range.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Let me point that there is
2 two zircaloy-2 datapoints on basically fresh cladding
3 on this curve, a whole bunch of ZIRC-4, ZIRLO C5 and
4 I'm just not a full believer yet that this one curve
5 is representative of all alloys. In a laboratory
6 test, many you can do that with hydrogen charging, but
7 it doesn't necessarily correlate with irradiated fuel.

8 I think it's conservative. I believe it
9 would be conservative, but I just think we're putting
10 apples and oranges and we're saying that they're all
11 going to behave the same and probably in a laboratory
12 test of unirradiated material that you hydrogen-
13 charged, you're going to get very similar results
14 because they're basically zirconium. But in a fuel
15 rod, that's not evidence to me anyway. The irradiated
16 datapoints in that middle range are needed. That's
17 what I think.

18 MEMBER POWERS: But then it's going to be
19 wildly off to the right or the left. How far could it
20 go?

21 MEMBER ARMIJO: If you have a big gap.
22 Look here. You have an irradiated datapoint at 100
23 ppm hydrogen and at 550. You have a big gap in the
24 middle and you fill it in with --

25 CHAIR SHACK: The tests will be run soon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You can buy the loser a beer.

2 MEMBER ARMIJO: I'll buy him a beer
3 anyway.

4 (Laughter.)

5 Anyway, they're going to do the test. At
6 least, that's what I heard.

7 MR. RULAND: For the record, the staff has
8 had this same debate.

9 (Laughter.)

10 MEMBER ARMIJO: Okay.

11 MR. YUEH: Some gaps in data space and
12 industry concerns. Those were worked on at ANL at
13 1200 Celsius and the benefits to conduct testing at
14 lower temperature. You get higher ductility for the
15 same ECR. This is where industry is conducting
16 testing at 1200 degrees as well as the lower
17 temperatures with different hydrogen pre-charge.

18 We were concerned with requirements for 2-
19 sided oxidation away from the ballooned region. It's
20 right now not supported by ANL data at Limerick. The
21 integral tests does not show a very significant alpha
22 layer build-up on ID.

23 And then with respect to the Halden test
24 which is a reference in the RIL, the impact of an ID
25 oxide, the oxygen diffusion into the material that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 burns up the cladding, I think still needs to be
2 quantified. And with this uncertainty, at this point
3 it's difficult for me to imagine how this could be
4 incorporated into the rule. Once it's in the rule,
5 it's very difficult to change and then the industry
6 feels that that should be in a lower level document.

7 The periodic testing on breakaway
8 oxidation at this point is driven by the short E 110
9 breakaway time. Paul Clifford has already stated that
10 the shortest breakaway time for the Westinghouse
11 alloys is 3,000 seconds and the system, the procedure,
12 response before that. So that sort of refutes the
13 need for periodic testing or treat this as a concern.

14 Also by the time you reach 3,000 seconds
15 at 1,000 Celsius if the 2-sided oxidation is enforced,
16 you will have also reached the 17 percent you see at
17 1,000 Celsius. So these are sort of arguments against
18 it.

19 The industry believes that breakaway
20 oxidation can be addressed through a QA program. The
21 short breakaway time absorbed in E 110 is due to the
22 initial processing of the material. The electrolytic
23 process from the beginning uses fluorine in the
24 process that fundamentally changes the process and
25 nobody in the west is using that process. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 even the Russians themselves some of them are away
2 from that.

3 Implications for Proposed Change, Cost
4 Estimate, you know, the proposed change will require a
5 re-licensing. All operating reactors will need to
6 demonstrate compliance. The vendors will also need to
7 conduct expanded hot cells to measure hydrogen to be
8 able to resolve the correlation of -- between
9 corrosion of hydrogen because hydrogen is not readily
10 measurable. Oxide is.

11 The costs to vendors and licensees to
12 comply with the anticipated new rule is estimated at
13 several hundred million dollars. And in addition to
14 that, implementation will be really resource
15 intensive. Each application will need to be reviewed
16 and somebody estimated that in years for the efforts.
17 And if this proceeds, the industry will obviously
18 request a phased in implementation.

19 MEMBER ABDEL-KHALIK: No, part of that is
20 sort of the explanation for the several hundred
21 million dollar figure was the comment that they would
22 have to redo the LOCA analysis for each reload to see
23 if it complies with the new rule.

24 MR. YUEH: Also, each plant, I think they
25 have re-license.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: Right. But don't
2 they already have to redo the LOCA analysis for each?
3 I don't understand that.

4 MEMBER ARMIJO: Why wouldn't you just do
5 it with a --

6 MEMBER SIEBER: They don't do it that way.

7 MEMBER ARMIJO: They don't. For new
8 material, you could come in with a licensing --

9 MEMBER SIEBER: No, they don't.

10 MEMBER ARMIJO: I'm talking about new
11 material.

12 MEMBER SIEBER: Reload safety analysis can
13 be done by seeing if your important core parameters
14 fit in the box of the outline of the window that the
15 LOCA analysis covers which you means you don't have to
16 redo the LOCA analysis. You have to make a parameter
17 comparison between the limits of the bounding LOCA
18 analysis to the core parameters of the reload you want
19 to install which is a relatively quick and relatively
20 inexperienced process.

21 In order to implement a new rule as I
22 picture it, each vendor is going to have to come up
23 with a new set of core analysis done from scratch to
24 rebuild the envelope upon which reload analysis must
25 fit and it's been awhile since I actually signed the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bills to pay for this stuff, but I don't remember the
2 cost of that.

3 MEMBER ARMIJO: It's certainly going to
4 cost something, but I can't see several hundred
5 million dollars. I think that was an estimate when
6 there was a vision that the staff was totally
7 inflexible and was going to ram some arbitrary overly
8 conservative criteria.

9 MR. YUEH: I was surprised about the
10 numbers myself. You know, Westinghouse did the
11 estimate and we had phone calls with utilities and
12 they agree with the numbers. I'm not an expert in
13 this area. So I don't really know, but that's what
14 they --

15 MEMBER ARMIJO: Okay.

16 MEMBER SIEBER: Try to picture if you did
17 an actual core analysis for every plant as opposed to
18 the enveloping technique on every reload where you
19 could build up the bill.

20 MR. YUEH: This is for every -- for the
21 every plant.

22 MEMBER MAYNARD: If there are 100 plants
23 and you have to do LOCA analysis and especially if
24 there's any retesting that has to be done.

25 MEMBER SIEBER: The testing may drive the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cost.

2 MEMBER RAY: It seems to me like the
3 industry ought to be thankful that nobody is running
4 around here saying the sky is falling and that we're
5 persuaded by the reasonableness that has been
6 described here today that this is something that can
7 take place on the kind of timeline that is described.

8 But it just doesn't seem to me plausible you can walk
9 away from it and do nothing and say this must not be a
10 problem. I mean, that's ridiculous.

11 MEMBER SIEBER: the current rule in my
12 view is technically an error and there is new
13 phenomenon that needs some further investigation.

14 MEMBER RAY: Yes.

15 MEMBER SIEBER: It may apply. It may not
16 apply. You can't just say it doesn't exist.

17 MEMBER ARMIJO: The expanded hot-cell
18 campaigns to license corrosion hydrogen correlations,
19 every manufacturer has a database of hydrogen
20 corrosion going back to time and memorial which they
21 use in a variety of ways and they're going to continue
22 to gather that data anyway. For new material, you'd
23 have to generate that data and you should. You
24 shouldn't be introducing a new material without
25 sufficient basis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And it's expensive I grant you. For new
2 materials this would be expensive. But you would do
3 it anyway to introduce some cladding.

4 MEMBER MAYNARD: Now you can get the cost
5 of --

6 MEMBER ARMIJO: Yes.

7 MEMBER MAYNARD: First of all, I think
8 that the worst case estimate with unknowns of what's
9 going to come out. The other thing it's total
10 industry. It's not a per plant basis. So I think we
11 need to focus more on what's wrong with the rule and
12 we need to -- But I think that analysis will sort that
13 out once a rule is kind of drafted out.

14 MEMBER ARMIJO: Okay. You have a summary.

15 MR. YUEH: Last slide. The evaluation so
16 far indicates there are no safety concerns and the
17 industry does not see a need to rush through the rule-
18 making. The industry supports a flexibility rule.
19 There's some elements of it already proposed and
20 proposing or using lower level documents for details.
21 There are regulations guides.

22 The industry supports qualification
23 testing, but not rule-mandated periodic testing and
24 the final comment we have is pre-hydriding appears to
25 be a good surrogate for irradiation. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Okay. Questions?

2 MEMBER POWERS: Yes. I'm still perplexed
3 by your comments on periodic testing. It may be
4 because I admit to a certain failure to understand the
5 subtleties of breakaway oxidation. It has always been
6 my interpretation of the E 110 experiments is that it
7 simply said, "Gosh, these always can be very sensitive
8 to things that you don't anticipate readily."

9 And that the concept of periodic testing
10 came about because there are things that change in
11 processes that you don't know about. I think Dr.
12 Shack brought up the possibility that changing the
13 solvent you use to wipe down the cladding could induce
14 an impurity that subsequently affected breakaway
15 oxidation.

16 All that seems very reasonable to me. Why
17 shouldn't you have in the program a periodic test for
18 breakaway oxidation to make sure these uncontrolled
19 and unknown things aren't creeping in some way either
20 in your process or in your supplier's processes.

21 MR. YUEH: At this point, what caused E
22 110 is really not known and we think it's related to
23 the electrolytic process and obviously you can have
24 other things that get introduced into it if you make a
25 process change. But every time you make a process

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 change the process needs to be qualified and we're not
2 saying that don't do it altogether. Whenever you
3 qualify the process, do it at that time.

4 There are implications from periodic
5 testing. How often do you do it and if you do it if
6 one failed, what do you -- Depending how the gap is
7 you could already have fuel in your reactor and how do
8 you disposition that. And also --

9 MEMBER POWERS: So what you're saying is
10 that there is between each conscious change in a
11 process there are absolutely, positively guaranteed
12 and assured no changes occur. Even though they earn
13 emission, you don't know exactly what change
14 precipitated the problem in E 110.

15 MR. YUEH: We think that the E 110, we
16 don't know exactly what it is, the missing element or
17 extra elements in there, but we believe it's linked to
18 the electrolytic process which Westinghouse is not
19 using.

20 MEMBER POWERS: This is a faith-based
21 experiment.

22 MEMBER ARMIJO: No, it's a flag-based,
23 Dana. I have to step in and --

24 MEMBER POWERS: No, you don't
25 step in because I'm talking right now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Okay. I'll step in after
2 your opinion.

3 MEMBER POWERS: After my opinion, all
4 right. I'm asking is that your hypothesis. Do you
5 assure that there's absolutely and no possibility of
6 an unknown change occurring in a process between
7 conscious changes?

8 MR. YUEH: There's no -- From my
9 experience, there are no absolute guarantees. We look
10 at what is practical, you know, realistic.

11 MEMBER ARMIJO: Can I step in now?

12 MEMBER POWERS: You may.

13 MEMBER ARMIJO: Ken may not have run a
14 fuel factory, but I have and cladding is one of the --
15 Other than the pellet, cladding is the most important
16 component in a nuclear fuel fabrication and enormous
17 care is taken into every step in that process and
18 we've learned a lot over the years. There is periodic
19 testing going on in the laboratories for just normal
20 corrosion behavior so something doesn't go wrong.

21 You don't change cleaning solvents willy-
22 nilly. You don't change heat treatments willy-nilly.

23 You don't change belt polishing. All of these things
24 are under very tight quality assurance controls.
25 People can screw up data. I don't deny it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 But in my experience and what I've seen,
2 I've never seen a failure of a fuel rod by corrosion,
3 variable corrosion, unanticipated high corrosion,
4 never heard of in PWRs and I've never seen it in BWRs
5 for which I know a lot about. So corrosion
6 variability is really kind of more of a visual and a
7 problem, but it's not a failure problem because of
8 these tight controls.

9 E 110 was a bizarre material. It's made
10 by a totally different process starting with the
11 zirconium that they make by an electrolytic process
12 which is not the same as pro process we use and it's
13 not as clean.

14 The other thing is the material was
15 cleaned by some perhaps fluoride containment result
16 and the ANL data shows that if you remove that surface
17 you get much better performance on this susceptible
18 material.

19 And the third thing is in the testing
20 that's been done on breakaway corrosion by ANL they've
21 demonstrated that there's a lot of margin to the
22 limit, let's say, for small break LOCA. But if you
23 were right on the borderline your material would go
24 into breakaway corrosion in 1500 seconds and your time
25 was 1400 seconds. Sure. Maybe you ought to change

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 materials completely. Maybe you shouldn't be doing
2 periodic testing. So it depends on how robust and how
3 much margin you have to the allowable time.

4 All of these things, it boggles my mind to
5 say because of a goofy Russian material, my apologies
6 to Mr. Putin, because of that that American fuel
7 manufacturers have to go in through a periodic
8 regulatory, mandated testing process is just not -- It
9 just doesn't make sense. Whether they do it in their
10 factory is part of a normal thing. It's another thing
11 to worry about. That makes sense. But then getting
12 into it, turning it into a regulatory number for
13 regulatory staff and manufacturing staff are circling
14 around this nonsensical process just strikes me as
15 something we ought to avoid.

16 MR. YUEH: I also want to add that this
17 phenomena only happens here at the material at a fixed
18 temperature for a period of time. In a real LOCA, the
19 fuel rod is not sitting at a single temperature. It's
20 going to go through a cycle and whether you still see
21 breakaway even after an extremely long time is still
22 in question that it may not happen if you just pass it
23 through it.

24 MEMBER ABDEL-KHALIK: Can I just ask the
25 question, a follow-up, to what Sam said? Were runaway

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 oxidation tests routinely done as a part of alloy
2 development?

3 MEMBER ARMIJO: Alloy development, sure.
4 All sorts of bizarre tests are done in alloy
5 development.

6 MEMBER ABDEL-KHALIK: So this phenomenon
7 was known and recognized as being a non-issue for the
8 alloys that -- Or was it just by the grace of God that
9 we use processes that didn't result in this issue?

10 MEMBER ARMIJO: I think a little bit of
11 what you're saying that the materials that we
12 developed for good corrosion resistance tended to be
13 pretty good. Our data shows that they tend to be
14 pretty good for breakaway corrosion as well. But
15 nobody just routinely runs zircoloid cladding at 1,000
16 degrees or 900 degrees Centigrade for 5,000 seconds or
17 6,000 unless there's some new phenomena that they're
18 worried about and that's what the breakaway corrosion
19 tests are supposed to do.

20 MEMBER SIEBER: Breakaway corrosion is
21 sort of a unique --

22 MEMBER ARMIJO: It's new. It's not your
23 standard thing.

24 MEMBER SIEBER: It's recently been
25 discovered and the kind of testing program you would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do in the development of an alloy probably would not
2 identify it. On the other hand, it appears to be, at
3 least to me because I lack knowledge, concentrated in
4 one kind of an alloy.

5 MEMBER ARMIJO: Yes, if you were going to
6 make an alloy today and you didn't do a breakaway
7 corrosion as part of that qualification that would be
8 irresponsible. But if you already know that the
9 cladding you're making today with standard, very
10 controlled processes has a lot of margin against
11 breakaway corrosion based on testing, then why in the
12 world do you mandate some regulatory requirement that
13 it has to be repeated every so often because your
14 factory is out of control or could be out of control.

15 MEMBER SIEBER: Well, the PAKS failure in
16 Bulgaria, that fuel sat at high temperature for days
17 before it failed and that was E 110 with --

18 MEMBER ARMIJO: Well, that's another
19 thing.

20 MEMBER SIEBER: -- breakaway oxidation.
21 So it's not the kind of thing you would experience
22 during a LOCA accident. It would not sit there and
23 just percolate forever.

24 MEMBER ARMIJO: Okay. I'm sure there's
25 going to be more debate on this subject. Thank you,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Ken, and I'll be quiet.

2 I'll address the Committee. I think a
3 good issue has come up. The staff has not requested a
4 letter, but some members of the Committee think a
5 letter from the full Committee would be in order. I'm
6 one of them. But I'd like to get a sense from --

7 CHAIR SHACK: Let's discuss that later
8 this afternoon when we get into our letter writing
9 session.

10 MEMBER ARMIJO: Okay.

11 MEMBER SIEBER: It will give us something
12 to do on Saturday.

13 (Simultaneous speaking.)

14 CHAIR SHACK: At the moment, I'd like to
15 take a 15 minute break and come back at 3:10 p.m. Off
16 the record.

17 (Whereupon, a short recess was taken.)

18 CHAIR SHACK: We can come back into
19 session. Our next topic is the presentation on the
20 NRC Staff's initial White Paper on containment
21 overpressure credit issue, and Mario will be leading
22 us through this discussion.

23 VICE CHAIR BONACA: We have the connection
24 on the -

25 CHAIR SHACK: Yes. As far as we know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that's open.

2 VICE CHAIR BONACA: All right. Good.

3 CHAIR SHACK: I should mention that TVA
4 has asked to call in, and is listening in. But,
5 again, they're in listen-in mode, so there'll be no
6 interruption in the presentation.

7 VICE CHAIR BONACA: Okay. Before we begin
8 the presentation and discussion on the NRC Staff's
9 Position Paper on Containment Accident Pressure
10 Credit, I'd like to make some introductory remarks
11 regarding the ACRS concern on this issue. It will be
12 very brief, because you all have heard those worries,
13 and we expressed them to the Commission a month ago,
14 and pretty much are the same.

15 Historically, most plants in the U.S. have
16 been licensed with no credit for containment
17 overpressure. This approach preserved independence of
18 barriers to release of fission product, and provided
19 significant margin for the ECCS pumps. Credit for
20 accident pressure was first broadly allowed to
21 licensees in responding to the BWR suction strainer
22 clogging issue. This is an excellent example of how
23 a regulatory margin that is there to deal with what we
24 don't know can be used to address a newly discovered
25 issue. And there are still potential issues that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't know of that may need some additional margin in
2 NPSH.

3 Now, remaining margin is being used by
4 some licensees to support voluntary licensing actions,
5 such as EPU's. ACRS has consistently expressed concern
6 with this use of NPSH margin. We have accepted this
7 use of margin if supported by Reg Guide 1.74-type of
8 demonstration of low risk, or if supported by amount
9 and length of credit being small.

10 Conversely, the Staff approach focuses on
11 regulatory criteria, and imposes no limits on the
12 amount and length of credit as long as these
13 regulatory criteria are met. Margins to material are
14 significantly reduced, in fact, pump cavitation and
15 operator intervention to manage cavitation are allowed
16 under certain circumstances. We are working with the
17 Staff to see that we can resolve our difference on the
18 evaluation criteria, and to determine what information
19 can be requested of licensees that would allow the
20 ACRS to perform its assessment against its own
21 criteria, and these remain different from those of the
22 Staff.

23 The first step that we have in this
24 process of communication is the White Paper that was
25 put together by the authors which are in front of us,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and we haven't had a chance to review it, but it's a
2 significant document, and we really believe that we
3 will need probably another meeting after this to
4 further clarify some of the issues, and would depend
5 on that, or make a decision after we've gone through
6 this preliminary meeting here that I believe is
7 scheduled for two hours.

8 CHAIR SHACK: Yes.

9 VICE CHAIR BONACA: With that, I will now
10 proceed with the meeting, and I call upon Mr. Ruland
11 of NRR to start the meeting.

12 MR. RULAND: Thank you, Dr. Bonaca. Good
13 afternoon. My name is Bill Ruland, and I'm the
14 Director of the Division of Safety Systems in NRR.

15 On November 4th, we transmitted a White
16 Paper to the ACRS on a subject that the Staff has
17 discussed with the Committee for several years, the
18 use of containment accident pressure in determining
19 the available net positive suction head for ECCS
20 pumps. The White Paper collects our reasoning for
21 this practice in one document, with the hope that it
22 would increase the clarity of our position, and
23 improve communications, particularly with the
24 Committee.

25 The White Paper is an initial version, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the purpose of the White Paper for us, in particular,
2 was to focus our attention on what our collective
3 position was on this matter.

4 As we will discuss shortly, we have --
5 because of that focus, have already identified some
6 minor improvements that need to be done to the
7 document since it was issued. We are trying to
8 emphasize that we are still listening.

9 Previous ACRS comments have been
10 incorporated into our reviews of containment accident
11 overpressure. ACRS has recommended that we look at
12 the issue from a broader perspective than just LOCA,
13 and we're doing that. ACRS was interested in our
14 concept of applying statistical analysis on this
15 issue. We are now reviewing a BWR Owner's Group
16 Topical Report prepared at the suggestion of the
17 Staff, which applies statistical methods to this
18 issue.

19 The last two extended power uprates we
20 proposed using containment accident pressure,
21 including realistic calculations in their submittals
22 or in responses to Staff RAIs. We know the Committee
23 is interested in seeing more realistic analyses. We
24 look forward to your comments on the White Paper, and
25 we will revise the paper, if warranted.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We will continue to drive this issue to
2 closure. We believe our position is well supported,
3 as documented in the White Paper, and as we will
4 discuss here today, it is consistent with the
5 assumptions of containment integrity made in other
6 areas of reactor safety.

7 Finally, we understand that this is a
8 information briefing, and, accordingly, it's our
9 understanding that the Committee does not intend to
10 send a letter based on this briefing. The Staff also
11 understands that based on a recent ACRS Commission
12 meeting, that the Commissioners are considering
13 issuing a Staff Requirements Memorandum in this area.

14 Based on the previous Staff SRM for a Commission
15 meeting, the Staff was requested to issue a Commission
16 paper to the Commission on this issue, basically, if
17 our disagreements continue. So one of the things that
18 we are trying to get out of this meeting is to try to
19 understand how the Committee sees this issue based on
20 us trying to document all this information in one
21 place, to try to make a determination when and if a
22 Staff Commission paper needs to go forward.

23 With that, those are my opening remarks.
24 If there are no questions, I will turn give the mic to
25 Rich Lobel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: Good afternoon. My name is
2 Richard Lobel. I'm a Senior Reactor Systems Engineer
3 in the Office of Nuclear Reactor Regulation. With me
4 is Marty Stutzke, Senior Technical Advisor for PRA
5 Technologies in the Office of Nuclear Regulatory
6 Research.

7 The purpose we're here today to discuss
8 the NRC Staff position on the use of accident pressure
9 in determining the available net positive suction
10 head, NPSH, of the ECCS and containment heat removal
11 pumps. In particular, the Staff position and
12 discussion provided to the ACRS in a memorandum to the
13 ACRS Executive Director dated November 4th, 2008. The
14 White Paper enclosed with the memorandum is the result
15 of a Staff re-examination of this issue.

16 These are the topics we'd like to cover
17 today; the regulatory background provides a
18 perspective on this issue. Dr. Bonaca briefly
19 mentioned some of this. The Staff position has
20 changed over time. I'll discuss the regulatory
21 guidance and policies next, the technical bases for
22 using containment pressure in determining available
23 NPSH. Marty will discuss the risk aspects, and
24 finally some discussion of future actions and
25 conclusions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: I have a question.
2 Reading the White Paper, I didn't see a clear
3 statement what the failure criteria is. It starts out
4 with an inequality, and the available NPSH must be
5 greater than the required NPSH. Then there is
6 discussion on erosion rates, there's discussion of
7 time, some tests that were done and for half an hour
8 required NPSH was exceeded and nothing happened. Is
9 there a place, or are you going to tell us what the
10 failure criterion is? How does time come into this?
11 How do other things come into this? There are
12 discussions of various aspects, but they don't seem to
13 come to a single inequality or equality that says if
14 this happens, then I have a failure.

15 MR. LOBEL: Well, that's a good comment.
16 I've been thinking about that, and I think I have an
17 answer. And there's a slide later on that talks about
18 NPSH margin, and I think that's the place to talk
19 about it.

20 MEMBER APOSTOLAKIS: Okay.

21 MR. LOBEL: It's kind of an interesting
22 and complicated subject, and I'm not sure that the
23 pump industry agrees on exactly what margin -- well, I
24 know they don't agree on exactly what margin there
25 should be. But I think the basic answer is it's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 required NPSH, however that's defined. And as you've
2 seen in the different reviews we've done, licensees
3 have proposed different values.

4 The Hydraulic Institute has a value and a
5 way of deriving the value, but people in the industry
6 have used different values, and people in the industry
7 have credited for limited amounts of time exceeding
8 the required NPSH, and the pumps in the analysis have
9 cavitated for some length of time. And the purpose of
10 that table with the different tests was just to show
11 that there has been prototypical testing done for
12 that.

13 MEMBER APOSTOLAKIS: I understand that.

14 MR. LOBEL: But I think the basic answer -

15
16 MEMBER APOSTOLAKIS: If you'll cover it
17 later, that's fine.

18 MR. LOBEL: Okay.

19 MEMBER APOSTOLAKIS: I'll wait.

20 MR. LOBEL: Okay. There are several
21 changes to the White Paper since it was sent to you.
22 First, the White Paper stated that Reg Guide 1.1 would
23 be withdrawn. Reg Guide 1.1 was the NRC's first Reg
24 Guide, and has only a single position, and that is
25 that containment accident pressure should not be used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 when determining available NPSH.

2 We've determined that withdrawal is not
3 necessary. Reg Guide 1.1 will be revised to state
4 that Reg Guide 1.82 is the current guidance. Reg
5 Guide 1.1 is part of a licensing basis for some
6 licensees, and it may continue to be used for that
7 purpose. In other words, there's no reason for
8 licensees to go back and change their licensing basis,
9 especially because that's the most conservative
10 position to begin with.

11 VICE CHAIR BONACA: Are you talking about
12 1.82?

13 MR. LOBEL: I'm sorry?

14 VICE CHAIR BONACA: Reg Guide 1.82 is very
15 focused on the strainers issue.

16 MR. LOBEL: Well, what we're trying to do
17 with Reg Guide 1.82 is make it the one place that will
18 have Staff guidance on pump suction issues.

19 VICE CHAIR BONACA: Okay.

20 MR. LOBEL: So it'll have the guidance on
21 debris, it'll have the guidance on air entrainment,
22 sump design, and NPSH all in one place, so it's going
23 to serve several purposes. A lot of that information
24 is already in Reg Guide 1.82.

25 MEMBER BANERJEE: Will it be revised?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Because at the moment it says that containment
2 overpressure should be minimized. And there are
3 several places where it addresses this issue, which -

4 MR. LOBEL: I'm going to talk about that a
5 little later, too. Well, we tried to revise it once,
6 and came to ACRS, and got a letter saying make some
7 changes before you issue it. So my thinking was
8 before we try to rewrite the Reg Guide, we, the Staff
9 and ACRS, ought to come to some kind of agreement, or
10 there's no point coming back with another Reg Guide
11 until we all agree.

12 MEMBER BANERJEE: But the intent is to
13 revise it.

14 MR. LOBEL: The intent is to revise it,
15 yes.

16 MEMBER BANERJEE: Okay.

17 MR. LOBEL: The White Paper described a
18 process for the risk analysis that had elements of
19 Standard Review Plan 19.2 Appendix D, and elements
20 that were not part of that procedure. We've decided
21 that it's more appropriate to use the existing
22 guidance in 19.2 Appendix D. Marty will discuss this.

23 The discussion of NPSH margin needed to be
24 revised, and I will do that -

25 MEMBER ABDEL-KHALIK: With regard to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 second point, is there a clear and distinguished
2 equivalent statement as far as EPU submittals?

3 MR. LOBEL: For what?

4 MEMBER ABDEL-KHALIK: I mean, you're
5 saying for non-EPU submittals risk procedures will
6 follow SRP 19.2 Appendix D.

7 MR. LOBEL: Oh. That's because for EPU
8 submittals, the licensees already provide a risk
9 analysis. What we're talking about is really non-EPU
10 submittals that deal with the subject, since EPU
11 submittals are already taken care of.

12 MEMBER ABDEL-KHALIK: Okay.

13 CHAIR SHACK: Just on that point, your
14 summary makes that statement that the 1.82 would be
15 revised to include that request for risk information
16 on the EPU submittals, but the Executive Summary
17 doesn't, so that you have to go all the way to the
18 very end of the White Paper to find that. And it
19 seems to me that's an important enough element, it
20 should go in the Executive Summary.

21 MR. LOBEL: Well, Marty is going to talk
22 about that. And the position has changed a little,
23 and we want to spend a lot of time talking about that.

24 Well, the reason basically was we were outside of
25 procedure, and we have a written procedure. It's gone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through an approval process with our management, and I
2 believe even up to the Commission level, so we want to
3 stick with that process. So it's different in some
4 ways than what's described in the paper, but it's in
5 perfect agreement with other regulatory documents that
6 are already issued. We'll go into all that.

7 MEMBER CORRADINI: Just to clarify, Said,
8 just so I'm on the same page, so Said's point was
9 what's the converse of the second bullet? And your
10 point is that the converse of the second bullet is
11 that any EPU submittal must have a risk analysis.
12 Following that 19 point, for this purpose. That's
13 what I thought -

14 MR. STUTZKE: For EPUs they also follow
15 Appendix D.

16 MEMBER CORRADINI: Okay. That was my
17 question.

18 MR. STUTZKE: They're non-risk-informed,
19 everything that's non-risk-informed license amendment
20 falls under that appendix.

21 MEMBER CORRADINI: Okay.

22 MR. LOBEL: Okay. And we changed the
23 discussion a little bit on NPSH margin, and I'll talk
24 about that.

25 Okay. ECCS and containment heat removal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pumps in BWRs and PWRs are centrifugal pumps.
2 Centrifugal pumps are capable of operation over a wide
3 range of flow rates and pressures. Their operation is
4 well understood. There are numerous books and
5 standards on their use. They're used in a wide
6 variety of applications, but one of their drawbacks is
7 that they're subject to cavitation, as are other
8 devices subject to flowing liquids. Pump cavitation
9 can lead to delivery of less than expected flow and
10 discharge pressure. It can also lead to pump damage.

11 In some operating reactors, the Staff has
12 allowed use of containment accident pressure and
13 available NPSH calculations to avoid pump cavitation
14 or limit it to a short time at an acceptable level.

15 Regulations allow use of containment
16 accident pressure in determining the available NPSH of
17 safety-related pumps. The regulatory guidance on this
18 issue has changed over time, as discussed in the White
19 Paper. The Staff has allowed use of containment
20 accident pressure in demonstrating adequate NPSH in
21 situations where calculations predict that the pumps
22 would otherwise cavitate.

23 MEMBER RAY: Wait a minute. Is there any
24 assumption about what is required to produce this
25 containment accident pressure? In other words, does

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it matter?

2 MR. STUTZKE: Nothing special is done in
3 the way of containment accident pressure for these
4 types of calculations except to minimize it. The
5 pressure is predicted to be there as a result of the
6 accident.

7 MEMBER RAY: Well, supposing it requires
8 the operator to take some action. Is that a
9 consequence of the accident?

10 MR. STUTZKE: The analysis -- the only
11 operator action that's -- there's a couple of operator
12 actions that are assumed. For a BWR at ten minutes,
13 it's assumed that the operator -- let me back up for a
14 second.

15 MR. RULAND: You're going to cover this,
16 aren't you, Rich, this whole issue of operator action
17 later, or do you want to answer it now?

18 MR. LOBEL: Not that question.

19 MR. RULAND: Okay.

20 MR. LOBEL: The RHR system in a BWR has
21 several modes. One of them is -- and the way it's set
22 up at first is for injection, so given a LOCA, the RHR
23 system is in the injection mode. At ten minutes, it's
24 assumed that the operator changes the RHR, assuming he
25 has proper core cooling. He changes from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 injection mode to the suppression pool cooling mode.

2 The only other operator action -- and that
3 mode can be either cooling the suppression pool
4 directly, or he can initiate spray. He can also, if
5 he has both trains, he can continue to inject with one
6 train, and use one train for suppression pool cooling,
7 or he can use that train in the spray mode. Either
8 mode cools the containment, because the flow is going
9 through the same heat exchanger, so either way is
10 cooling the containment.

11 The operator has a caution in the EOPs
12 that if the pressure gets below a certain value, the
13 operator terminates the spray. And that value where
14 no credit is taken for containment pressure is zero
15 psig. If that plan is taking credit for containment
16 pressure, then it would be a different pressure.

17 The operator in a BWR also has curves, and
18 I was going to talk about this a little later, of
19 suppression pool temperature versus pump flow with
20 pressure as a parameter. So pressure is already
21 considered in the EOPS, and the operator can tell by
22 looking at those curves whether he has adequate NPSH.

23 MEMBER RAY: So I think your answer is
24 yes, operator action to provide, or insure, or
25 maintain containment pressure is accepted, and part of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the current licensing basis for existing plants.

2 If one was to ask the question, though,
3 what change in risk has occurred as a result of some
4 new need to call upon the operators to maintain
5 containment pressure, how is that - and I know Marty
6 is going to talk about risk - how is that factored
7 into the regulatory position you're talking about?

8 MR. LOBEL: If it were an operator action,
9 it would be included in either the EOPs or the
10 abnormal operating procedure.

11 MEMBER RAY: How do you assess the risk of
12 it going awry? Somehow it fails to achieve the
13 required containment pressure that you're assuming
14 exists.

15 MR. STUTZKE: Well, in our view, the
16 standard suite of human reliability analysis
17 techniques speak well to this operator action.

18 MEMBER RAY: Okay. So you'll talk about
19 that later.

20 MR. STUTZKE: Yes, a little bit more.

21 MEMBER RAY: Okay. That's fine.

22 MR. LOBEL: Would it be worthwhile to go
23 through the background in view of the questions and
24 other things? That was pretty straightforward, I
25 think, in the White Paper. I could go through it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fast.

2 VICE CHAIR BONACA: Yes, let's do that.

3 MR. LOBEL: Okay. Well, we already talked
4 about Reg Guide 1.1 a little. It was issued in
5 November 1970. It had only one position, which was
6 that the ECCS and containment heat removal system
7 should be designed so that adequate available NPSH is
8 provided using only the containment pressure prior to
9 the accident. And it also specified that the
10 temperature of the sump water, the suppression pool
11 should be the maximum expected.

12 Then there were a series of revisions to
13 Reg Guide 1.82. Reg Guide 1.82, Revision Zero, was
14 issued in June of '74, and was concerned with the
15 design of sumps for ECCS. The Staff was licensing
16 plants at that time, and was concerned with the design
17 of the sumps and different utilities were doing actual
18 model tests of sumps, testing for air entrainment and
19 NPSH.

20 Reg Guide 1.82, Revision Zero, also
21 specified that the assumed blockage of the sump
22 screens should be 50 percent of the total sump screen
23 area. More reviews led to a revision to that Reg
24 Guide 1.82 that was issued in 1985 that incorporated
25 positions that reflected the results of a USI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 unresolved safety issue, A-43, which was containment
2 emergency sump performance. And it went into more
3 detail, had a lot more positions about the design of
4 the sump, and insulation, and that kind of thing, but
5 it also maintained Reg Guide 1.1 as the cited guidance
6 for containment accident pressure.

7 The positions in Reg Guide 1.82, Revision
8 One, weren't backfit. The accompanying Generic Letter
9 stated that the guidance developed by the USI should
10 be used for future plant changes.

11 Reg Guide 1.82, Revision Two was issued in
12 May 1996, and it was the result of work that led up to
13 NRC Bulletin 96-03 that dealt with BWR ECCS strainer
14 blockage. As a result of installing larger ECCS
15 suction strainer screens, and a new debris source
16 term, some BWRs with Mark-1 containments requested use
17 of containment accident pressure. And those requests
18 were approved after a detailed review.

19 I didn't mention, I should say at the
20 beginning that some BWRs were licensed, initially
21 licensed with credit for containment accident
22 pressure. That's what led to the issuance of the
23 first Reg Guide 1.1.

24 MEMBER BANERJEE: But they were
25 grandfathered. Right? I mean, they still have that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as license -

2 MR. LOBEL: It's just part of their
3 licensing basis. And when they put in the larger
4 strainers, some of them, and with the new source term,
5 some of them needed even more pressure than what they
6 had had before.

7 In 1996 and 1997 there were a series of
8 LERs and other operational experiences that led to
9 some questions about the use of overpressure for
10 operating plants, and the NRC issued a Generic Letter
11 97-04 in October of 1997, where we asked the industry,
12 asked licensees for information about how they were
13 using containment -- whether they were using
14 containment overpressure and how they were using it.

15 The Staff reviewed all those responses.
16 When some licensees went back and looked at this
17 issue, they found that their analyses weren't correct,
18 that they made incorrect assumptions in some places,
19 they found problems when they went back and looked at
20 their analysis in terms of assumptions they made for
21 screen flow resistance and that kind of thing. So
22 some licensees with that Generic Letter had to redo
23 their accident analysis for NPSH.

24 Reg Guide 1.82 Revision Three was issued
25 in November of 2003, and it incorporated guidance that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 came from NRC Bulletin 2003-01, that dealt with the
2 PWR sump screen blockage issue, and GSI 191. It was
3 at that time that we included NPSH guidance in Reg
4 Guide 1.82. And the idea was that we had come up with
5 criteria that were used for review of the Generic
6 Letter, but weren't published, separately accepted
7 individual plant SERs, so we put the NPSH guidance
8 into the Reg Guide.

9 And, finally, we started work on a draft
10 Reg Guide 1.82, Revision Four, and we discussed this
11 with the ACRS. And the ACRS wrote a letter to the
12 Staff, either the Staff or the Chairman, in 2005 that
13 recommended revisions and further restrictions on the
14 use of containment accident pressure prior to issuing.

15 And like I explained, we haven't tried to rewrite the
16 Reg Guide.

17 The NRC position on this issue is that the
18 NRC allows use of containment accident pressure in
19 determining available NPSH when analysis using
20 conservative assumptions have demonstrated that the
21 pressure will be available for postulated design-basis
22 accidents, and when examined from a broader
23 perspective beyond design-basis accidents, an
24 acceptable level of safety is maintained.

25 MEMBER CORRADINI: Can I ask just about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that historical point? So those conservative
2 assumptions are not documented; that is, on a case-by-
3 case basis the containment analysis that minimizes
4 that pressure has to be kind of discussed with the
5 Staff. There is not a set laundry list of
6 assumptions. Is that correct?

7 MR. LOBEL: That's true, basically. But,
8 actually, for the BWRs the analyses are pretty much
9 the same, same set of assumptions are used for each
10 one. There are some little changes from one to
11 another that get reviewed.

12 MEMBER CORRADINI: And the conservatism,
13 of course, is to drive the pressure as low as possible
14 for this analysis.

15 MR. LOBEL: Well, two things; to drive the
16 pressure as low as possible - well, not as low as
17 possible - to drive in a conservative direction to the
18 point where everybody agrees it's conservatively
19 lower. But the important thing is for BWR, and for
20 PWR, is the temperature of the water. And the
21 analysis at the same time tries to minimize the
22 pressure and maximize the temperature of the water.
23 The temperature of the water is important mostly
24 because if you look at the equation for NPSH, it has a
25 minus vapor pressure term in it, and that's a non-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 linear term. And as the temperature gets higher,
2 vapor pressure gets much higher.

3 MEMBER CORRADINI: Okay.

4 MR. LOBEL: And that's the limiting point.

5 MEMBER CORRADINI: But that still all goes
6 to containment analysis, because the only way to
7 affect that is besides an uncertainty in decay heat,
8 is what the efficiency of the heat exchanger is that's
9 pulling the heat out of the system.

10 MR. LOBEL: The efficiency of the heat
11 exchanger is a very important input.

12 MEMBER CORRADINI: So are those -- back to
13 my original question. Are those assumptions pretty
14 much the same in all BWR analysis relative to heat
15 exchanger, heat losses to cold surfaces, a decay heat
16 so that -

17 MR. LOBEL: The values aren't the same,
18 but the assumptions are basically the same. Every
19 plant has heat exchangers with slightly different
20 levels of fouling, and tube plugging, and that kind of
21 thing.

22 MR. DENNIG: Rich, isn't it true that the
23 core analysis has been done usually by the NSSS vendor
24 in most cases?

25 MR. LOBEL: Well, for this case it's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 containment. There's a core analysis that's done, a
2 mass and energy release analysis, but it's done by the
3 vendor usually.

4 MEMBER BANERJEE: You mention in your
5 White Paper that containment pressure is needed to --
6 in some cases, should not exceed Appendix K limits.
7 Can you tell me a little bit about that, because the
8 first peak is usually when the floor is choked, I mean
9 the system is choked, so why does the -

10 MR. LOBEL: It's during the re-flood that
11 you take credit for containment pressure.

12 MEMBER BANERJEE: But not the blow-down.

13 MR. LOBEL: Not the blow-down, no. It's
14 during the re-flood, because the higher the
15 containment pressure, the faster the core re-floods,
16 so Appendix K requires that the containment pressure
17 be conservatively minimized.

18 MEMBER CORRADINI: But back to my original
19 question. Those assumptions for Appendix K are not
20 the same assumptions used to do this.

21 MR. LOBEL: No.

22 MEMBER CORRADINI: Okay.

23 MR. LOBEL: Containment analysis isn't
24 covered by -

25 MEMBER CORRADINI: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: They are minimizing the
2 pressure.

3 MR. LOBEL: They're actually pretty much
4 the same assumptions.

5 MEMBER CORRADINI: They're both minimizing
6 it, but how they're forcing them to minimize it is not
7 the same set of assumptions. That's my point.
8 They're both minimizing, because if you minimize, you
9 have more bypass for the Appendix K calculation.

10 MR. LOBEL: A lot of them are the same.
11 If you look at the -- there's a Standard Review Plan
12 section on minimizing the pressure for LOCA, and a lot
13 of assumptions that the guidelines in the SRP are the
14 same as what's used for the NPSH analysis.

15 MEMBER CORRADINI: All right. Thank you.

16 MEMBER RAY: I want to just add to what
17 Mike said. I think the issue will come down, there's
18 an awful lot of rhetoric here, not misplaced, but a
19 lot of it that you have to wade through dealing with
20 the issue, is it okay to use containment pressure,
21 when the real issue on the table, I think, is the
22 demonstration of conservative assumptions. So trying
23 to get to that place where we say yes, we have
24 demonstrated conservative assumptions were used, is
25 what we're all struggling with here. And we're having

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to wade through an awful lot to get to it.

2 MR. LOBEL: Well, there's tables in the
3 White Paper, a list of assumptions, conservative
4 assumptions.

5 MEMBER RAY: Well, we can argue about
6 whether they're conservative or not, for example, but
7 that's not my point now. I'm just saying that's the
8 focus of interest, I think, on many of our parts, is a
9 demonstration of conservative assumption, as opposed
10 to the strawman, which is, can we use containment
11 pressure?

12 MR. LOBEL: Well, the conservative
13 assumptions are used for the LOCA analysis. That's a
14 design-basis analysis. Conservative assumptions are
15 not used for these other events, the Appendix R, ATWS,
16 and Station Blackout, because they're not design-basis
17 events, and the Staff guidance has always been to use
18 realistic analysis. All the ATWS, Appendix R, and
19 Station Blackout analysis is done realistically, not
20 just -

21 MEMBER RAY: As you wish, but non-
22 conservatively.

23 MR. LOBEL: Non-conservatively.

24 MEMBER BANERJEE: So when it's needed for
25 LOCA to meet your Appendix K requirements, how long,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and how high?

2 MR. LOBEL: Not for very long, just until
3 re-flood, until the core is quenched, just until the
4 re-flood.

5 MEMBER BANERJEE: Relatively short time.

6 MR. LOBEL: Relatively short time, right.

7 MEMBER BANERJEE: And how much?

8 MR. LOBEL: Oh, I can't give you value off
9 the top of my head, but probably around the same value
10 as -- well, maybe a little higher than what's used
11 here. Actually, some licensees, if they can, make the
12 conservative assumption that they don't need
13 containment accident pressure, and they assume that
14 pressure in the containment doesn't change. And
15 they're able to demonstrate that they can quench the
16 core without that. But, again, the -

17 MEMBER BANERJEE: This is a PWR problem,
18 mainly. Right?

19 MR. LOBEL: Yes, it's mostly PWR, although
20 not entirely. Okay?

21 Okay. As ACRS has pointed out, the Staff
22 position doesn't explicitly mention the duration of
23 using containment accident pressure or the amount of
24 pressure used. The duration of the use of containment
25 accident pressure we feel is not risk significant,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 since the significant contributors to a loss of
2 containment integrity occur at the start of the
3 postulated accident, either pre-existing leak or
4 failure of containment isolation.

5 MEMBER STETKAR: Let me ask you about
6 that, and Marty may pick it up. Are you going to pick
7 it up more in the risk -

8 MR. STUTZKE: I hadn't planned to, so ask
9 now.

10 MEMBER STETKAR: Okay. Let me ask this.
11 Because in the risk part of the White Paper, that
12 sounds like an innocuous assumption, but it's really
13 important because there are conditions where there is
14 no pre-existing leak, and there is no failure of
15 containment isolation, and yet you may have a high
16 likelihood of not having adequate net positive suction
17 head if, for example, the operators don't do
18 something.

19 MR. STUTZKE: Right.

20 MEMBER STETKAR: And a lot of the things
21 in the risk assessment are based on this premise that
22 these are the only ways that you can have inadequate
23 net positive suction head. So I was -- I had to wade
24 through a lot of things to figure out how there's an
25 equation in there. I had to wade through a lot of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 things to figure out how that equation, some of the
2 risk insights work. And it only works if this is
3 absolutely true, if they are the only ways.

4 MR. STUTZKE: Well, I would disagree with
5 that. It's fair to say that what we've examined so
6 far, these were the only ways. But I believe back in
7 -- I talked about the need to reconsider the human
8 reliability analysis, and so you would have to add in,
9 for example, an operator failure to turn drywell
10 coolers.

11 MEMBER STETKAR: Right. And that's, for
12 example. That may have a lot higher likelihood than
13 either of these things.

14 MR. STUTZKE: No, I don't think it does.

15 MEMBER STETKAR: Okay. That's an opinion,
16 but it might.

17 MEMBER RAY: That's right. It's a matter
18 could be demonstrated, is all. It's not -

19 MR. STUTZKE: That's right.

20 MEMBER STETKAR: And Harold said, it's -
21 what is the conservative analysis? Okay. Continue.

22 VICE CHAIR BONACA: The White Paper is
23 focused very much on initial conditions, in fact,
24 assuring that programs assure that you have
25 containment isolation at the beginning. There isn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 much of a discussion regarding tests being done to
2 address potential degradation of seals, for example.

3 MR. LOBEL: Well, I was going to talk a
4 little bit about that now, too.

5 VICE CHAIR BONACA: Okay.

6 MR. LOBEL: I think we're going to -

7 MEMBER ABDEL-KHALIK: But that goes
8 directly to the statement that you're making. A
9 failure of a polymeric seal depends on the time at
10 temperature. Wouldn't this statement be incorrect?

11 MR. LOBEL: If it did, yes, it could be
12 incorrect, if that were another mechanism for failure.

13 MEMBER ABDEL-KHALIK: Do we have data that
14 show that that is not true, that would support this
15 sort of totally blanket statement?

16 MR. LOBEL: Well, I was going to talk
17 about that later, and I think Dr. Powers already has a
18 comment on that. I think that's going to be a good
19 part of the discussion here in just a couple of
20 slides.

21 MEMBER ABDEL-KHALIK: All right.

22 MR. LOBEL: The possible exception that I
23 identified was in the case of an Appendix R fire, the
24 associated circuits could be a problem at any time
25 during the event, but that is looked at as part of any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 license amendment that deals with Appendix R. The
2 Staff would review that as part of an Appendix R
3 review, and also independent of containment accident
4 pressure, it's also called multiple spurious operation
5 issue as part of the fire protection closure plan.
6 But the basic response, I think, would be that that
7 issue of associated circuits would be looked at on a
8 plant-specific basis for any license amendment request
9 that dealt with fire.

10 The magnitude of the pressure it needed is
11 also not included in the Staff's position, since we
12 feel it's not risk-significant. There is a
13 calculation of peak LOCA containment pressure that
14 demonstrates that the pressure is below the design-
15 pressure of the containment, and the pressure at the
16 time of peak sump or suppression pool temperature is
17 much less than the containment design pressure.

18 VICE CHAIR BONACA: So the issue here has
19 to do with the amount of credit for back-pressure?

20 MR. LOBEL: Well, I guess -

21 VICE CHAIR BONACA: It is. So what you're
22 saying is that the amount of credit for back-pressure
23 is not risk-significant. And the question I have is,
24 how can you make a flat statement? Doesn't it depend
25 on how much credit is needed?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: Well, I guess the point I'm
2 trying to make, and maybe I'm missing something, is
3 that if the pressure is much less than the containment
4 design pressure, it's hard to see why pressure would
5 be significant. The pressure is there. The operator,
6 in general, doesn't do anything to increase the
7 pressure, or decrease the pressure. Well, I won't say
8 decrease. He doesn't do anything to increase the
9 pressure. He doesn't add mass to the containment. He
10 follows his procedures for cooling down after an
11 accident, but the pressure is there. And it's much
12 less than the peak pressure, the design pressure or
13 the peak pressure, so it's hard to see, unless I'm
14 missing something, why the magnitude of the pressure
15 is important.

16 MEMBER ABDEL-KHALIK: I guess, if I were
17 to write the first bullet to capture what you're
18 trying to say, I would say as long as the pressure is
19 below the design pressure, the magnitude of the
20 pressure needed is not risk-significant. Is that what
21 you're trying to say?

22 MR. LOBEL: That's what we're trying to
23 say.

24 MEMBER ABDEL-KHALIK: Okay. Now, the
25 implication, of course, if I have two accident

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 scenarios, and the pressure history in both accident
2 scenarios, the peak pressure is the same, but one of
3 them, the duration of the high pressure in both cases,
4 the peak pressure is below the design pressure, that
5 regardless of how long this peak pressure period is
6 going to be, the risk from these two scenarios is
7 going to be the same.

8 MR. LOBEL: Well, this slide is talking
9 about the magnitude. The previous slide was talking
10 about the time. And that gets back to the discussion
11 of the duration of the event.

12 MR. DENNIG: I think there's two, the
13 pressure goes two ways here. I think the pressure
14 that you're trying to talk about is that there's no
15 threat to the containment, where you're going to lose
16 the containment, because the pressure is too high at
17 that point.

18 MR. LOBEL: Well, there's no threat on -

19 MR. DENNIG: And there are conservatisms
20 in the calculation for the pressure for the NPSH
21 calculation that go into that margin.

22 MR. STUTZKE: Let me jump in for a minute.

23 MR. LOBEL: Yes.

24 MR. STUTZKE: Because if you look at the
25 types of failure mechanisms that could lead to a loss

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of pressure in the system, for example, containment
2 isolation doesn't isolate. You either have the
3 pressure or you have no pressure at all. It's hard
4 for the PRA to distinguish between a scenario that
5 says I need 3 psi overpressure for 10 hours, versus 3-
6 1/2 psi for 12 hours. I couldn't compute the delta
7 risk in that and convince you guys that the number was
8 right. Okay?

9 CHAIR SHACK: But in terms of defense-in-
10 depth for my unknown, or say my sump blockage issue, I
11 am reducing my defense-in-depth here. Again,
12 something that I'm really fairly highly uncertain
13 about, which are my head losses and sumps during
14 accidents.

15 MEMBER BANERJEE: Which is, of course, a
16 point we should visit eventually, the uncertainties
17 part of this.

18 MEMBER APOSTOLAKIS: But it seems to me
19 that this slide and the previous slide are the basis
20 for the risk assessment, where you're really
21 evaluating only the existence or non-existence of
22 containment overpressure.

23 MR. STUTZKE: Yes.

24 MEMBER APOSTOLAKIS: That's all you do
25 there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: Yes.

2 MEMBER APOSTOLAKIS: When we say risk
3 assessment, that's all you do. And the basis for that
4 is these two slides.

5 MR. STUTZKE: That's true.

6 MEMBER APOSTOLAKIS: Okay.

7 MR. STUTZKE: That's true.

8 MEMBER CORRADINI: So maybe I'm getting
9 ahead of you, so you can tell me to stop. But I'm
10 kind of -- what I hear in all the discussion is saying
11 that - what you said, Marty, at the end was, is that I
12 can't tell the difference between 3 and 5, and 10
13 hours and 20 hours. As long as it's high enough that
14 I don't kill the pumps by bad performance, and low
15 enough that I don't fail containment, or exceed design
16 pressure.

17 MR. STUTZKE: Right.

18 MEMBER CORRADINI: But that almost says
19 now I've crossed the two defenses-in-depth, and I'm
20 going to sit here with a magical regulator that makes
21 it just high enough to make it work, and just low
22 enough not to fail containment. That's what I hear in
23 terms of the behavior. Am I mishearing?

24 MEMBER APOSTOLAKIS: So what?

25 MEMBER CORRADINI: Well, that tells me I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have a very intelligent operator that can sit there
2 with a dial to dial it in between the two.

3 MR. LOBEL: The operator doesn't have to
4 do anything but follow his procedures, and his
5 procedures are basically to cool the plant down, but
6 make sure that he -- cool the plant down, cool the
7 core, cool the containment, but make sure he has
8 adequate NPSH. And that's only -- he doesn't really
9 have to take any actions. All he's doing is looking
10 to make sure he's okay.

11 MEMBER CORRADINI: Okay. But let me push
12 back one more time. So let's just take a few numbers.

13 So let's say I needed an NPSH of -- I needed a delta
14 above P-zero at time-zero of 10 psi, and the design
15 pressure is 40. That means I've got a 30 psi D dead
16 band that I have to operate in, and the uncertainty of
17 whether it's 10 or 15, or it's 40, or 38, and as I
18 approach it, and that uncertainty is nowhere in this,
19 so that it would seem to me that the procedures could
20 get fairly complex.

21 MR. LOBEL: The operator -- whatever is
22 happening in containment is happening in containment
23 pretty much, and if he has 40 when he needs 10, all
24 he's going to look at is I have 40, and he might --
25 and in a BWR, he might look over at these curves just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to make sure he's okay, but that's all he'd do, and
2 he'd satisfy himself that he was okay. He doesn't
3 have to take any actions.

4 MEMBER SIEBER: If he's supposed to get 40
5 but only gets 30, there isn't anything he can do about
6 that.

7 MR. LOBEL: That's true, too. Well,
8 there's -- not necessarily. Not necessarily. And
9 we'll just talk about that a little later, too.

10 MEMBER RAY: I'll defer to you here in a
11 second, Otto, but I'm going to piggyback on something
12 Sanjoy said. The first observation is, you're saying
13 well, this is just more of the same. The operator
14 does all these things. He can do this next thing as
15 part of the EPU package. Okay. I understand that
16 argument.

17 It still raises the question of what's the
18 incremental risk involved, because you can't tell me
19 that there isn't some risk of operator error. If
20 that's what you're trying to say, then we can stop
21 there.

22 The other thing, though, is the
23 uncertainty associated with something, let's say the
24 heat transfer to the plant structure. It seems
25 axiomatic that we're trying to minimize the assumed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pressure loss due to heat transfer when we're
2 concerned with the containment integrity question.

3 This is the opposite. True? In other
4 words, true enough, as Jack says, he may have
5 insufficient pressure, and there's nothing he can do
6 about it, because we've misestimated what the loss of
7 pressure would be due to heat transfer, and this gets
8 to Said's question about time. Time is relevant here.

9 MEMBER BANERJEE: If you've missed Jack's
10 last point, you can head for the parking lot.

11 MEMBER RAY: Well, I'll be done in a
12 second, because I realize I'm lecturing rather than
13 asking a question. But my point is, how is it that we
14 do all the right things in assuming not too much
15 temperature heat transfer, and therefore maximize the
16 pressure from a containment integrity standpoint, and
17 do the opposite when it comes to heat transfer that
18 may result in a loss of pressure.

19 MR. LOBEL: Well, in real life, if you had
20 one of these events, the operator would follow his
21 procedures, and the plant would do what the plant
22 does. The operator isn't controlling that kind of
23 thing. The plant is doing what the plant does.

24 MEMBER RAY: You have a discussion in
25 there about, you referred to it a minute ago, about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looking at this pretty variable graph and throttling,
2 and operating the system. Okay. Granted, all of
3 that's there. But then, ultimately, I'm going to ask
4 you, all right, what is the incremental risk then
5 that's associated with this extra task that has now
6 become required for the operator to perform?

7 MR. DENNIG: Rich, don't we do a different
8 calculation to maximize the heat content of the water
9 to drive the temperature up for the NPSH calculation,
10 and then we do -

11 MR. LOBEL: Well, we're trying to separate
12 -

13 MR. DENNIG: -- the other way around to
14 maximize the pressure.

15 MR. LOBEL: I'm trying to separate --
16 there's two things, there's what would really go on.
17 There's what would really go on in the real world,
18 and then there's the way the analysis is done. The
19 analysis is done in a way that actually minimizes the
20 heat transfer around the suppression pool. For
21 example, you don't take any credit for heat transfer
22 from the torus wall to the reactor building. That's
23 assumed to be adiabatic because what that does is it
24 drives up the temperature of the suppression pool,
25 which is conservative in the calculation. In the real

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 world, there's going to be heat transfer to the
2 reactor building, and the operator has no control over
3 that.

4 MEMBER RAY: Yes, that's so, but on the
5 other hand, we're looking at pressure margins here
6 which are really tiny. Even assuming the operator is
7 perfect all the time, it's a tiny margin.

8 MR. RULAND: What are you looking at?

9 MEMBER RAY: The question is how much
10 uncertainty should be assumed?

11 MR. RULAND: What are you looking at?

12 MEMBER RAY: I'm just looking at a table
13 of pressures versus different operating conditions.

14 MEMBER BANERJEE: I'm having a much more
15 fundamental problem, and maybe Marty can address this.

16 From what you're saying, is as long as I let my
17 containment pressure stay below the design pressure,
18 it doesn't matter for how long. There's no incentive
19 for me to actually try to reduce this pressure.
20 Everything gets easier if the pressure is high;
21 obviously, the steam is more compressed so my RHR
22 system pumps less steam out, the pressure losses are
23 less, so why do I try to reduce the pressure? By your
24 argument, I'll simply keep it as high as I can below
25 design pressure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: The problem is I think here
2 we're focusing on this one issue. The operator in the
3 control room after the LOCA has a lot of other things
4 to worry about, and he is trying to shut down -- he is
5 trying to cool down the suppression pool, and the
6 core.

7 MEMBER BANERJEE: By the risk analysis it
8 doesn't show up. Right?

9 MEMBER SIEBER: Well, the idea is that the
10 operators will bring the plant to a cold shutdown.

11 MR. LOBEL: Right. And he's going to do
12 that. And the only place that this comes in is, he's
13 going to check, he has a caution in his procedures to
14 make sure that he doesn't cool down more than he
15 should, but that's just one -

16 MEMBER RAY: Wait a minute. No, no,
17 that's not fair. He's got to secure these doggoned
18 drywell coolers in, what is it, two hours I guess it
19 is. And if he doesn't do that, the long-term pressure
20 that Said is worried about isn't going to be achieved.

21 MR. LOBEL: But he has other operator --
22 the operator has other actions he has to take, too.

23 MEMBER RAY: That's why I said, you're
24 just saying well he does more of the same thing.

25 MR. LOBEL: Well, at some point, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not a reasonable thing to assume.

2 MEMBER STETKAR: I think what Harold is
3 getting at, and what you said, the operator does have
4 a lot of other things to do. However, all of those
5 other things are pointing at a certain trajectory;
6 that is, cooling the core and reducing the heat load
7 inside the containment. That's what all of those
8 other actions are pointing him to do. This is
9 contrary to all of those other actions. This is
10 contrary to all of those other actions.

11 MR. LOBEL: He has -

12 MEMBER STETKAR: There's a specific focus
13 only on the containment. So, yes, he does have other
14 things to do, but at least they're consistent.

15 MR. LOBEL: He already has an action -

16 MEMBER SIEBER: You have to cut down the
17 rate of cooling. That defeats the purpose.

18 MEMBER STETKAR: That's right.

19 MR. LOBEL: The operator has an action -

20 MEMBER SIEBER: That's a different kind of
21 activity.

22 MR. LOBEL: The operator has a similar
23 action to turn off the containment sprays before he
24 gets to a certain point.

25 MEMBER SIEBER: That's -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: I'm sorry?

2 MEMBER SIEBER: If you don't cool the
3 core, once you start cooling water inside -

4 MR. LOBEL: Let me just -

5 MEMBER SIEBER: -- in circulation mode,
6 once you -- that's your only way of removing heat from
7 it.

8 MR. RULAND: This sounds like what we've
9 heard before as the counterintuitive argument, that
10 somehow operators -- that this whole notion of cooling
11 the plant down and stopping at some juncture is
12 somehow counterintuitive. Well, in 1979 there was a
13 small accident that occurred at Three Mile Island
14 where the operators, in fact, acted on their
15 intuition. They had an intuition that the plant was
16 going to go solid. And, in fact, the plant wasn't
17 going to go solid. Okay? They were acting on their
18 intuition.

19 Since Three Mile Island, what has happened
20 is, we have trained operators to obey their
21 procedures. And, in fact, we use simulators that they
22 didn't have, so this notion that operators somehow
23 can't operate a nuclear plant in accordance with their
24 procedures, I don't believe has the merit that I think
25 I'm hearing from the Committee.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Well, I just -- I don't think
2 - I don't agree with you at all.

3 MEMBER STETKAR: Let me step in here,
4 because I was -- I happened to have a Senior Reactor
5 Operator's license and was operating a pressurized
6 water reactor at the Zion Nuclear Power Plant in March
7 of 1979, and had been through license training, and
8 had procedures. And one thing that we were very well
9 trained on was do not let the pressurizer go water
10 solid. So this idea that the operators were acting on
11 their intuition is not quite accurate, because they
12 had high level indication in the pressurizer. They
13 had all the indications available to them that they
14 had adequate inventory, and adequate core cooling, and
15 they acted exactly in response to their training to
16 put the plant in what they thought was a safe
17 condition. So it's not just guys acting on their
18 intuition. They were acting according to their
19 training.

20 (Simultaneous speech.)

21 MEMBER STETKAR: -- to putting the plant
22 on a trajectory towards what they thought was safe.

23 MEMBER BROWN: But we also teach
24 operators, at least we did, to believe your
25 instrumentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: That's right. That's why
2 I'm saying, your instrumentation -

3 MEMBER BROWN: I'm just throwing that in
4 as part of the -

5 MEMBER RAY: But this is a question not of
6 believing instrumentation, but of relying upon the
7 operator to intervene.

8 CHAIR SHACK: Maybe we can move on,
9 because Marty is going to have to come back to address
10 this as an operator error, as part of the risk.

11 MEMBER MAYNARD: I've been patient, and
12 this is not about operator action. This is about the
13 first statement up there on the risk significant. We
14 seem to focus primarily on risk to the containment,
15 and what we're really interested in is risk to the
16 public. And one of the areas is that if you do have a
17 leak in containment, the longer you stay at a higher
18 pressure, the more risk-significant it is.

19 (Simultaneous speech.)

20 MEMBER SIEBER: When we finally come back
21 to it, I want to complain a little bit about time
22 duration not being reported. It depends on the -

23 MR. LOBEL: That's true.

24 (Simultaneous speech.)

25 MEMBER APOSTOLAKIS: That was really my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question. I don't understand -

2 (Simultaneous speech.)

3 MEMBER APOSTOLAKIS: I mean, I didn't see
4 time anywhere. Time is brought in as convenient.
5 Here are some tests. The ACRS recommended a couple of
6 hours. On the next slide, for example, where you have
7 the -

8 CHAIR SHACK: Jump to the next slide.
9 This is your cue.

10 MEMBER APOSTOLAKIS: So if I don't know
11 anything else, I look at this, so if the NPSHA is less
12 than the NPSHR -

13 MEMBER SIEBER: I'm not -

14 MEMBER APOSTOLAKIS: But if it becomes an
15 inequality, then presumably I'm in trouble.

16 MR. LOBEL: If it's less -- if A is less -

17

18 MEMBER APOSTOLAKIS: And a lot of people
19 come in and tell me oh, but it happens only for two
20 hours, you're not really in trouble.

21 MEMBER SIEBER: It depends on how much and
22 how long.

23 MEMBER APOSTOLAKIS: That's what I'm
24 trying to understand. What is the failure criteria?

25 MEMBER SIEBER: It depends on the pump.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: The problem with time and
2 pressure is that they're not really addressing a
3 physical process except maybe for the pump time
4 duration.

5 MEMBER SIEBER: Yes.

6 MR. LOBEL: The physical boundary is more
7 the required NPSH. That's what the pump vendor tells
8 the pump user, is a place where you can operate, or
9 you really should operate above that. But you can
10 operate there, and you will get a reduction from 100
11 percent flow, and 100 percent pressure. If you
12 realize that, you can operate there. And it gets into
13 the type of pump.

14 MEMBER BANERJEE: And it gets into the
15 flow rate, your pump curve.

16 MR. LOBEL: But that determines the
17 required NPSH.

18 MEMBER MAYNARD: One thing that would help
19 me in this, I don't think -- I think that it would be
20 better if we went and redefined the NPSH required.
21 And I don't care if you do it on a pump-by-pump basis,
22 or plant-by-plant, whether it's one pressure or
23 temperature for this duration, and it changes. I
24 don't think we should have a position where NPSH
25 available can be less than NPSH required. And I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the way to do that is to not just use what the pump
2 vendor comes out with NPSH required, is if you have
3 solid justification for operating at a different
4 level, let's change that to be the NPSH required.

5 MEMBER SIEBER: That's hard to do.

6 MEMBER MAYNARD: Now you're ending up with
7 okay, it's okay to violate it for a while, but there's
8 no -

9 MR. LOBEL: In a way that's what's done.
10 If you look back at the curves that the pump vendors
11 supplied to Vermont Yankee and to Brown's Ferry,
12 that's what they did, really. They went below the 3
13 percent head drop, which is the Hydraulic Institute
14 standard, and said you can operate below that for this
15 length of time, and then you have to increase it. You
16 can operate a little higher for that length of time.
17 They did that kind of thing, and they did just what
18 you're saying. They redefined the required NPSH.

19 The other thing that's done that we've
20 allowed is, we've allowed people -- their analysis
21 show that they're in cavitation for a certain amount
22 of time, we said that was okay, if you go out and test
23 your pump and show that your pump will operate for
24 that length of time with no adverse consequences. And
25 what people have done, and there's a table of people

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 who've done that kind of testing, what people have
2 done is they go out and they do a cavitation test for
3 much longer than the time they're crediting, and then
4 they take the pump apart, and they actually look at
5 the seals, and shaft, and bearings, and everything,
6 impeller, and show that there wasn't any damage, and
7 no wear for even a longer time than what they're
8 crediting. And Staff has allowed that, also.

9 MEMBER BROWN: But that's a new pump.

10 MR. LOBEL: Well, it's a new pump. These
11 pumps are tested quarterly -

12 (Simultaneous speech.)

13 MR. LOBEL: They're not cavitation tested
14 any more.

15 VICE CHAIR BONACA: What troubles me with
16 this is that all the discussion essentially is
17 attempting to make cavitation an acceptable mode of
18 operation. And, clearly, that was never intended in
19 the design of these pumps. It was never intended when
20 the original analyses were made, so I want to say that
21 when I hear this conversation and I look at all the
22 arguments, pumps are tough, they can take it,
23 whatever. Why should we allow for that to happen,
24 there is this degradation in performance, and it's
25 considered to be acceptable. I mean, that's what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really what I struggle with.

2 MEMBER APOSTOLAKIS: For voluntary -

3 VICE CHAIR BONACA: For voluntary
4 applications. I want to get power, I spend a little
5 money to uprate my plant, but I cannot invest anything
6 on these pumps.

7 MR. LOBEL: Well, the pumps don't operate
8 at this condition for the whole accident. They don't
9 operate at this condition when they're not in this
10 accident. This is just when they're calculating that
11 -- this is a criterion for calculating that they need
12 containment pressure for NPSH.

13 VICE CHAIR BONACA: I understand.

14 MEMBER APOSTOLAKIS: Is it true that this
15 is a sufficient condition, but not necessary? That's
16 really what you're arguing. It's sufficient to avoid
17 cavitation, but it's not necessary. In other words,
18 you can violate it for a while.

19 MR. LOBEL: It's more complicated than
20 that. When you're at this point, you are cavitating a
21 certain amount. You're cavitating, and you have a 3
22 percent drop in head. You're cavitating when you're
23 above the 3 percent drop in head, when you're at 1
24 percent you're cavitating. Way down the pipe
25 somewhere you could be cavitating, even when you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 not noticing that you're cavitating, you can have
2 some. And there are pump studies that show that even
3 a little bit above this criterion is actually worse.
4 You can actually get more damage to the pump than at
5 this criterion where the available is equal to the
6 required.

7 MEMBER APOSTOLAKIS: That's true.

8 MR. LOBEL: People have done testing,
9 pretty reliable testing, where they've used noise
10 measurements to show that the -

11 MEMBER SIEBER: Sometimes you're better
12 off cavitating -

13 MR. LOBEL: Yes. You're actually better
14 off cavitating the 3 percent, than to go to some
15 smaller margin above the 3 percent, because you could
16 actually be doing more damage to the pump.

17 (Simultaneous speech.)

18 MR. LOBEL: And I can give you references
19 that talk about that.

20 CHAIR SHACK: In George's terms, though,
21 this is an acceptance criterion for this analysis.

22 MR. LOBEL: It is an acceptance criterion.

23 CHAIR SHACK: So I think we can move on.
24 Now, you've made an argument why it's an acceptable
25 one, but can we -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: Yes. Let me -

2 MEMBER BANERJEE: By that argument, we
3 could suck a little air in, but you never get
4 cavitation.

5 CHAIR SHACK: As long as he's got this, he
6 can do this forever.

7 MEMBER SIEBER: Why don't we just move on.

8 CHAIR SHACK: Okay. We'll come back to
9 when this is violated, but this is the top level
10 requirement that they have, and then they make some
11 exceptions.

12 MR. LOBEL: We're running out of time.

13 (Off the record comments.)

14 MR. LOBEL: A lot of what I was going to
15 say I've said before.

16 VICE CHAIR BONACA: Special initial
17 conditions is creditable. I mean, I believe -

18 MEMBER APOSTOLAKIS: But it's also true
19 that everything that was said in the last few minutes
20 did not address your concern. Your concern is
21 different. Why should we accept even a little bit of
22 cavitation just to accommodate a voluntary change in
23 power?

24 MEMBER SIEBER: Don't we have instances
25 come up in the near future where there is no change in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 power involved, the credit for containment pressure is
2 going to be required due to 191.

3 MEMBER RAY: So that raises a question,
4 should we use the same margin more than once. Before
5 you go on to the next slide, though, I just want to
6 again say I'm not comfortable with where we are on
7 this LOCA pressure is conservatively calculated
8 question, particularly when you talk about it over a
9 long period of time. I just want to register that,
10 and then move on.

11 MR. LOBEL: Could you say -- I thought -

12 MEMBER RAY: Some up there that says this
13 is acceptable because LOCA pressure is conservatively
14 calculated.

15 MR. LOBEL: And there's a whole list of
16 conservative assumptions that are used in these -- I
17 don't understand, I guess -

18 MEMBER RAY: Why I say that?

19 MR. LOBEL: Yes. What's conserving -- I
20 mean, I'd like to answer your question, and I'm not
21 sure -

22 MEMBER RAY: Yes, but the Chairman wants
23 us to move on, and I don't disagree at the time that
24 we need to move on. You can either through
25 inadvertence, or just through misestimating end up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with more heat loss than you assume, unless you do
2 something to prove that this is a conservative
3 calculation, and I just haven't seen that. The list
4 you've got in your White Paper doesn't do it for me.
5 That's it.

6 MR. LOBEL: Well, you overestimate the
7 power, you overestimate the decay heat, you
8 overestimate -- you underestimate the capability of
9 the heat exchanger, you don't take any credit for heat
10 transfer from the torus to the outside.

11 MEMBER STETKAR: That keeps pressure high.
12 Doesn't it?

13 MR. LOBEL: Well, it keeps the pressure
14 high, but the big effect is the temperature. GE -

15 MEMBER RAY: That's fair, but we've got to
16 see it, not just have it be on the list is my point.

17 MEMBER BANERJEE: So the pressure is not -
18 - it's keeping it high, but the water temperature is
19 higher, so you've got -

20 MEMBER RAY: The argument is that they're
21 more than compensated. I just want to see numbers,
22 Sanjoy.

23 MEMBER BANERJEE: I agree. I mean, we
24 need to see a proper answer in the analysis of all the
25 -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: GE has done those types of
2 calculations where they've looked at the point of
3 minimum pressure, and the point of maximum
4 temperature, and they've shown that the available NPSH
5 is much lower at the point of maximum temperature.

6 MEMBER RAY: Well, you have a lot of
7 information that we don't get, evidently.

8 MR. LOBEL: Okay. Well, confidence in
9 containment. These are the points that I was going to
10 make for the technical basis. Let me just say the
11 containment is tested prior to operation, Appendix J
12 leak testing is done, 50.55(a) in-service inspections
13 are done, tech specs require various things to assure
14 containment integrity. Plants do checks in their
15 procedures prior to start-up to assure they have
16 containment integrity. Conservative calculations, I
17 guess we've talked about that.

18 Pump design, I think we covered a lot of
19 that under margin. I think we've already talked
20 basically about that. I think we've talked about
21 emergency operating procedures, and plant risk is
22 Marty. I'll turn it over to Marty.

23 MEMBER ARMIJO: Before you go, on pump
24 design, Chart 20 that you have, can you put that up.
25 Yes. In reading your paper, which, incidentally, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thought was very well written. I learned a lot about
2 this stuff that I didn't know about. There was a
3 table that showed that there were, in fact, more
4 cavitation resistant impellers available, aluminum
5 bronze had under the same conditions twice the
6 cavitation resistance of stainless steel. And why
7 isn't that considered to improve the margin for the
8 pumps?

9 MR. LOBEL: You have other considerations,
10 too.

11 (Simultaneous speech.)

12 MEMBER ARMIJO: -- you get in trouble.
13 That's in a severe -

14 MR. LOBEL: In a PWR you have to worry
15 about boric acid.

16 MEMBER ARMIJO: How about just the B?

17 MR. LOBEL: And in a BWR -- well, the --
18 what was I going to say? The difference isn't that
19 great, and you don't expect the pump to operate in
20 cavitation for a long time. We're talking about
21 matters of hours, we're not talking about material
22 that you want to pick for a chemical processing plant,
23 or a power plant, and other applications where that
24 pump may be running continuously for six months or a
25 year, or more.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Yes. I just -- it was a
2 very simple table. Said hey, look, here's a number of
3 hours which stainless steel operates and is damaged,
4 and you can go twice as long with this aluminum
5 bronze. And it seems like why wouldn't that be a good
6 thing to do, if you were concerned about cavitation
7 damage, whether it's short time, or long time.

8 MEMBER SIEBER: Generally, what you --
9 you're not so much concerned about wear to the
10 impeller, break the impeller, or ruining the pump
11 bearings. Vertical shaft pumps, long shafts. When
12 they cavitate, they beat the hell out of the bearings,
13 whereas, the horizontal pump with a short shaft won't
14 do that. If you run into cavitation for six hours or
15 eight hours, something like that, you're not going to
16 wear through the impeller, but if the impeller isn't
17 strong enough, you may break it.

18 MEMBER ARMIJO: So these are the best
19 pumps available. We can't do anything better.

20 (Simultaneous speech.)

21 CHAIR SHACK: In fairness, if they're
22 going to operate in the cavitating mode, they ask for
23 tests to demonstrate that they can do it. So you may
24 be able to get a better pump, but they ask for a
25 demonstration that it can be done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: Okay. We haven't talked about
2 seals. Can we spend a minute talking about seals?

3 CHAIR SHACK: Seals I think are a major
4 interest item.

5 MR. LOBEL: That question came up a couple
6 of times. I looked at the paper that Dr. Powers
7 referenced before. I looked up another paper, looked
8 up some other papers, and I talked to the people who
9 do this review. And my understanding is well, first
10 of all, that this is something that's looked at as
11 part of any review, like an EPU or something, where
12 there's a question of environmental qualification,
13 mechanical equipment qualification is part of that
14 review. That's more a programmatic review to see that
15 these things have been addressed, that the licensee
16 has actually thought about elastomer seals, air lock
17 door seals, or whatever, and that the licensee states
18 that the seal is qualified for whatever harsh
19 conditions the licensee calculates that he's going to
20 have.

21 From what I could see, the seals start to
22 not do their job for severe accident-type conditions,
23 that they seem to be okay for design-basis accident
24 conditions. And if that's not correct, I guess -

25 MR. RULAND: Rich, it's not seem to be.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Right?

2 MR. LOBEL: That seems to be the case.

3 MR. RULAND: Licensees are required to
4 have an environmental qualification program, and
5 required to demonstrate for the LOCA envelope that
6 they have assumed that the seals will withstand the
7 environmental conditions, so it's not a question of
8 seems.

9 MR. LOBEL: They make that statement, and
10 the Staff reviews that as part of EPU reviews, or
11 other LOCA analysis reviews, anything that's going to
12 affect those conditions. Do combinations, you know
13 more about that than I do. I don't know the answer
14 off-hand.

15 MEMBER POWERS: I know very little about
16 the subject, except what I've imparted to you. What I
17 know is a couple of things. I know the paper I
18 referenced to you from the Japanese, they've observed
19 an interesting phenomenon that the combination of
20 irradiation and steam was by far the harshest
21 environment, and was not replicated by doing either
22 steam alone, or nitrogen plus irradiation alone. It
23 is substantially worse.

24 The other thing I know is that elastomers
25 are subject to loss of elasticity in a radiation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 field, and it depends on the elastomer that's used.
2 And the third thing that I know is work sponsored by
3 the NRC on the degradation of organic materials found
4 a synergism between temperature and the radiation
5 field; that is, the existence of heat and radiation
6 was worse than either by itself.

7 MR. LOBEL: Was that significant in the
8 range of design-basis accidents, or more in the severe

9 -

10 MEMBER POWERS: I told you I would tell
11 you what I know, but I exhausted my inventory.

12 (Laughter.)

13 MR. LOBEL: The Japanese paper, I believe,
14 used a radiation source term for severe accidents, not
15 for design-basis accidents.

16 MEMBER POWERS: Well, I guess the question
17 I was going to pose to you, what I know is that most
18 of the environmental qualification tests presume about
19 a megarad per hour in the atmosphere, and about two
20 megarads per hour at solid surfaces. Those are fairly
21 formidable doses. There's not much difference, in
22 other words, between a dose from a severe accident and
23 a DBA.

24 MR. LOBEL: Well, if I remember right,
25 this paper was using 85 megarads for their dose.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Pretty hard to be at.

2 MR. LOBEL: Yes.

3 MEMBER POWERS: I don't know how they
4 would do that.

5 MR. LOBEL: Yes.

6 MEMBER POWERS: If you look in the COC
7 Handbook on elastomer's properties, what they look at
8 is the integrated dose. They don't look at the base
9 rate, but the integrated dose. And on a good day, I'd
10 actually be able to quote some numbers to you. I
11 hesitate to do that right now, because so far it's not
12 been a good day. It depends very much on what the
13 elastomer material is.

14 MR. LOBEL: Well, let just say again, I
15 know I talked to the people who do the reviews. They
16 showed me the reviews they're doing for the advanced
17 plants now, and they do look -- they get a list of the
18 licensee of all the seals, and the conditions that
19 they're qualified for, and the conditions to expect,
20 and they do review that.

21 MEMBER POWERS: It would be intensely
22 interesting to me to get that self same list, and an
23 example how they qualify the materials.

24 MR. LOBEL: Okay.

25 MEMBER POWERS: NRC did presume that cable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 insulation within plants would not experience an
2 embrittlement degradation, and were stunned to find
3 out that it would, and that's why they sponsored some
4 research on how elastomers and polymeric materials
5 respond to both temperature and dose rate. And they
6 saw significant degradations at integrated dose rates
7 of only 2.5 megarads, which just blew everybody away.

8 And then they found out well, it's because there's a
9 synergism between temperature and radiation.
10 Interesting, and that's all I can say. And I brought
11 it up to you because it struck me as an issue to
12 consider, when you talk about 10-minute times, and 15-
13 minute times, polymer is going to do just fine. When
14 you get up to 91 hours, that's when I start saying
15 wait, I want to know the details on the environmental
16 qualification now.

17 MR. LOBEL: Well, don't forget for this
18 long time event that we keep talking about, the
19 Appendix R event, there's no core damage for that
20 event.

21 MEMBER POWERS: Then you have a much lower
22 dose rate.

23 MEMBER BANERJEE: In this Appendix R
24 event, do you have the potential for entraining sludge
25 and stuff?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: No. The only event that had
2 the potential for doing that in what we've looked at
3 together so far was Vermont Yankee for the ATWS event.

4 They relieved pressure with a safety valve that
5 discharged into the containment, and so there was some
6 debris generated with that.

7 MEMBER BANERJEE: No, not generated. I'm
8 just saying stirring up the -

9 MR. LOBEL: Oh, turbulence?

10 MEMBER BANERJEE: Yes.

11 MR. LOBEL: Oh, as long as the RHR pumps
12 are operating, you have turbulence in the suppression
13 pool. There have been tests that show even with one
14 pump going -

15 MEMBER BANERJEE: It's sufficient
16 turbulence to -

17 MR. LOBEL: Sufficient to stir the whole -
18 to not have thermal stratification in the whole
19 suppression pool.

20 MEMBER BANERJEE: I see. That's
21 interesting. Do they take that into account in the
22 uncertainties?

23 MR. LOBEL: Where is Zeyna? Hey, Zeyna,
24 we need help.

25 MEMBER CORRADINI: So can I just -- I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looking through the slides that you skipped over
2 because of time. So the point of all of this is that
3 you still -- the Staff still feels that given that you
4 operate between what you'll call, and I'm still
5 struggling with this, a conservative value for the
6 accident pressure, and the design pressure, as long as
7 that window is large enough, you feel comfortable
8 allowing the operator to throttle back on cooling to
9 maintain a high enough pressure. That's what -

10 MR. LOBEL: Yes.

11 MEMBER CORRADINI: Okay. And how small of
12 a window does it have to be before the Staff worries
13 about the uncertainty of allowing that behavior? So
14 in other words, let's forget about NPSH, all that
15 other -

16 (Simultaneous speech.)

17 MEMBER CORRADINI: I'm just trying to
18 understand. If I'm within 1 psia, am I getting
19 uncertain about the ability to operate in that window?
20 If I'm within 10 psia? In other words, if I grant
21 you that allowable behavior, at what point does it
22 become too close to call?

23 MR. LOBEL: The pressure he has, to the
24 pressure where he has to take an action now you're
25 talking about? The operator probably -- the operator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is going to operate the plant. He's going to be
2 looking at the flow. He's going to be looking at pump
3 current. He's going to be looking at pressure,
4 discharge pressure if he has it in the control room.
5 He's going to be looking at those things, and if
6 everything is going okay, he's not going to do
7 anything.

8 CHAIR SHACK: But I think Mike's question
9 is when -

10 MR. LOBEL: He doesn't have to worry about
11 what the margin is.

12 CHAIR SHACK: -- you review the analysis,
13 when are you going to say no?

14 MEMBER CORRADINI: Yes, that's what I'm
15 asking. That's it precisely.

16 MR. LOBEL: We don't have a -- in the
17 analysis, we don't have -

18 CHAIR SHACK: You go all the way through
19 the design pressure, as long as it's there.

20 MEMBER CORRADINI: Yes, all the way to
21 design pressure.

22 MR. LOBEL: He's not going to be anywhere
23 near the design pressure.

24 MEMBER CORRADINI: We've seen analysis in
25 certain plants under certain conditions that you get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 damned close. I mean, excuse my English. Kind of
2 close.

3 MEMBER SIEBER: Accident pressure.

4 MR. LOBEL: That's a different analysis.
5 Yes, you're talking -

6 MEMBER RAY: You're not talking about
7 containment design, are you? He's talking about a
8 pump, NPSHR.

9 MEMBER CORRADINI: Right. But I saw
10 analysis with certain accidents -

11 MR. LOBEL: Oh, you're talking about the
12 curve of accident pressure -

13 MEMBER CORRADINI: Yes.

14 MR. LOBEL: -- and a curve of pressure -

15 MEMBER CORRADINI: Yes.

16 MR. LOBEL: Okay. We don't have a
17 criterion. There's no criterion for how close those
18 can be.

19 MEMBER CORRADINI: I'll stop.

20 MEMBER SIEBER: There is one case like
21 that.

22 MEMBER CORRADINI: Right. And so I'm
23 still troubled by that. That's why I'm struggling.

24 MEMBER BLEY: And when it seems there
25 might be other sources of uncertainty that haven't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 been addressed in a conservative way, or even
2 addressed.

3 CHAIR SHACK: Well, I think it becomes a
4 question of whether you think the conservatisms that
5 he knows he has overwhelm the -- or are sufficient to
6 address the uncertainties that haven't been addressed.

7 VICE CHAIR BONACA: I think the curve Mike
8 was referring to was the Appendix R.

9 MEMBER CORRADINI: Yes.

10 MR. LOBEL: Yes, for the LOCA, I feel
11 confident that there's plenty of conservatism there.

12 MEMBER CORRADINI: At least I got an
13 answer, so I'm with you, for the point. I'm fine.

14 MR. LOBEL: Okay.

15 VICE CHAIR BONACA: All right.

16 CHAIR SHACK: Before we leave, I want to
17 know what changes you're going to make in the White
18 Paper regarding the risk considerations, so I don't
19 want to run out of time.

20 MR. LOBEL: That's what we're going to
21 talk about now.

22 MR. STUTZKE: I will say a practical
23 matter, I've got to get out of here by 5:30. If I
24 don't pick up my kids, my wife will kill me, and
25 there's no uncertainty in that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Off the record comments.)

2 VICE CHAIR BONACA: We'll shoot for 5:15.

3 MR. STUTZKE: Okay. Our position is that
4 we have adequate guidance in place. We've got
5 processes that implement the guidance, and that we're
6 following it on the use of risk insights in the review
7 of license amendment requests. Okay? And we would
8 propose to continue applying that guidance to those
9 license amendment requests that contain requests for
10 containment overpressure credits. Okay?

11 I want to spend some time explaining to
12 you what -

13 CHAIR SHACK: Does this mean that you will
14 amend 1.82 to require them to submit this information
15 as -

16 MR. STUTZKE: No.

17 CHAIR SHACK: -- indicated in the White
18 Paper?

19 MR. STUTZKE: No.

20 CHAIR SHACK: Okay. What does it mean?

21 MR. STUTZKE: That's a change. Let me
22 explain what it means.

23 MEMBER STETKAR: It means if somebody
24 comes in and says I want to use a risk-basis, they
25 will consider it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: Well, that's one thing.
2 Let's back up and make certain everybody understands.
3 There's no regulation that says an operating plant
4 has to have a PRA. They're used to that in Part 52
5 space for new plants that will have to have a PRA, but
6 there's nothing now that says they have to have one.

7 CHAIR SHACK: There's nothing that says we
8 have to give them an EPU either.

9 MR. STUTZKE: Okay. So license amendments
10 fall into two categories, risk-informed and not risk-
11 informed. Basically, risk-informed license amendments
12 are ones that the licensee declares are risk-informed.
13 He's volunteered for it. He's agreed to follow Reg
14 Guide 1.174, et cetera, et cetera. In most things,
15 the risk insights are one of the principal
16 justifications to say yes or no. Okay?

17 Those are different than non-risk informed
18 license amendments where a licensee has not declared
19 that he's following Reg Guide 1.174. Okay. Here the
20 situation gets a little bit different. We refer to
21 Appendix D of SRP Section 19.2. By the way, there's a
22 couple of backup slides there to give you a chronology
23 of how this guidance evolved. It started basically
24 back in 1998. There's a couple of SECY papers and
25 SRMs. There was an ACRS briefing, CRGR Public

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 meeting, and it's been clearly vetted at that time.
2 But the notion is this, is a non-risk-informed license
3 amendment, risk insights are used to decide whether or
4 not you rebut a presumption of adequate protection
5 despite that you're meeting regulations or regulatory
6 requirements.

7 Okay. The burden is on the staff to
8 demonstrate that we have a question of adequate
9 protection. Okay? Now, we have legal authority to
10 demand the information, as Dr. Schack pointed out,
11 licensing can decline to give us the information, and
12 we can just say can't reach a decision, so you're
13 denied.

14 MEMBER APOSTOLAKIS: Can you really do
15 that?

16 MR. STUTZKE: Well -

17 CHAIR SHACK: Yes, sure.

18 MEMBER APOSTOLAKIS: What do you mean
19 "sure"? Have you done it?

20 MR. STUTZKE: We have not done it before,
21 because they always give us the information. It's a
22 couple of slides ahead, but basically to deny a non-
23 risk-informed license amendment on the basis of a risk
24 argument, that's got to go up to the Director of NRR.
25 And in order to that -- but let me -- I'm jumping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 ahead a little bit like this.

2 The other thing that's important to
3 realize is that in Reg Guide 1.174, we have five key
4 principles of risk-informed decision making. When you
5 do a risk-informed license amendment request, you're
6 supposed to meet all five of those. If you're doing a
7 non-risk-informed, those principles that are not met
8 are the ones that you drill down on, and you do more
9 analyses. But the mere fact that you don't meet one
10 out of the five, or two out of the five doesn't imply
11 a lack of adequate protection. Okay? Very simple.

12 I mean, the example is this. The first
13 requirement says you meet regulation. Well, we grant
14 exemptions to regulations, so clearly you don't meet
15 the first condition in that case.

16 VICE CHAIR BONACA: You must maintain the
17 independence of barrier.

18 MR. STUTZKE: We have to maintain defense-
19 in-depth.

20 MEMBER APOSTOLAKIS: Not an exemption,
21 that's part of the regulation.

22 MR. STUTZKE: Well, there's a regulation
23 that has the process to grant exemptions.

24 MEMBER APOSTOLAKIS: Anyway, the last sub-
25 bullet, what does it mean; "Assumes that the burden" -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. STUTZKE: The burden is on the Staff.

And, actually, George, I'm glad you brought it up, because the question came up earlier in our discussion today about how do EPU's fit into this. Well, basically, EPU's fall under Appendix D. In fact, they're culled out as one of those situations that because of synergistic effects, may create special circumstances. In fact, it says EPU's that are significantly above what the Staff has previously approved, if I remember the right words.

Now, a couple of years ago, at the Committee's suggestion, the Staff developed a so-called EPU Review Standard, the guidance on how we're going to go about reviewing EPU's. And if you look in there, you'll find a chapter that says here's the risk evaluation. Okay? And the way that I've looked at it is, the Staff at the time that the standard was developed, had decided that special circumstances may exist, and so we were asking a priori to get risk information, knowing full well that EPU's are not risk-informed, in an effort to expedite the process. Why wait for the Staff to write a bunch of RAIs if the licensees can provide the information in advance? That's the only case that I'm aware of where we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gone to that extent. Everything else would depend on
2 the Staff deciding that we needed to look at the risk-
3 information, and then we would ask questions, and it
4 would escalate that way.

5 MEMBER APOSTOLAKIS: So, basically, you
6 must show that adequate protection is not there.

7 MR. STUTZKE: Is not there.

8 CHAIR SHACK: Or is at least in question.

9 MEMBER APOSTOLAKIS: The applicant just
10 uses deterministic methods, or Appendix D. Right?

11 MR. STUTZKE: Right. Okay. Well, here
12 are the times when the guidance of Appendix D is
13 invoked, and it's an interesting language here. It
14 says, "The Staff believes that a non-risk-informed
15 license amendment may significantly change", et
16 cetera, et cetera. Okay? Staff believes. Here's how
17 it works in practice. All right.

18 A license amendment comes in, it's
19 reviewed by the Project Manager in accordance with our
20 procedures, and it's farmed out to the various
21 reviewers. So somebody like Rick will say, gee whiz,
22 I'm not comfortable with this, something is wrong.
23 Well, we have an internal office instruction that says
24 gee, go ask a Risk Analyst if you feel bad about these
25 things. Okay? All these sorts of criterion, and at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that time we would get involved and decide if we
2 wanted to do a review, and the extent of that review,
3 and so forth and so on like this, treat it more or
4 less on a case-by-case basis.

5 Realize, these situations are extremely
6 rare with the exception of EPUs, and probably the one
7 that kicked it off which had to do with electro
8 sleeving of steam generator tubes back then. They are
9 extremely rare, but these are the sorts of criteria
10 that we would use to decide whether or not we wanted
11 to pursue further risk information like this.

12 MEMBER RAY: Marty, I understand your time
13 constraint here. Just keep the answer short. This
14 starts off with, "Significantly changes", blah, blah,
15 blah, "operator action." I take it from all that's
16 been said so far that this didn't pass that gate. It
17 wasn't viewed as a significant change in operator
18 action.

19 MR. STUTZKE: Well, the fact is we've
20 reviewed two containment overpressure credit requests,
21 one at Vermont Yankee, and one at Brown's Ferry in
22 detail to see that. The question is, are there other
23 ones out in the future that may significantly change
24 operator actions or functional requirements?

25 MEMBER RAY: Well, in the case of Brown's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Ferry, it didn't meet that test. Is that right?
2 Significantly changing operator action.

3 MEMBER CORRADINI: For 5 percent.

4 MR. STUTZKE: No.

5 MEMBER RAY: We're not talking about the -
6 you're talking about the one that's already gone
7 past.

8 MR. STUTZKE: Yes.

9 MEMBER RAY: All right.

10 MEMBER APOSTOLAKIS: So the issue of
11 cavitation here would be under significantly affect
12 your basis -

13 MR. STUTZKE: That's my reading.

14 MEMBER RAY: That was my question.

15 MR. STUTZKE: That's one of the trips,
16 functional requirements, redundancy, it's this sort of
17 thing.

18 MEMBER RAY: Just a side discussion I had
19 with Mike here. I'm asking about the 20 percent
20 upgrade when I ask about significantly change operator
21 action.

22 MR. STUTZKE: Right. But remember, at
23 this point in the process, you're trying to get into
24 the process. You haven't confirmed yes or no that it
25 does significantly change it. You just think well,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there's a potential, and we need to do some
2 calculations, or get the licensee to do some
3 calculations like that.

4 Again, the numerical acceptance guidelines
5 in 1.174 aren't legally binding requirements. They're
6 not the law, they provide us a basis for reasonable
7 assurance of adequate protection, like that.

8 MEMBER APOSTOLAKIS: But I thought you
9 said that 1.174 doesn't deal with adequate protection.

10 MR. STUTZKE: Well, the point is, if you
11 can demonstrate that in fact you meet all the five
12 criteria under 174, then you have adequate protection.

13 MEMBER APOSTOLAKIS: Violate, you may
14 still have it.

15 MR. STUTZKE: You may still have it, even
16 if you violate it. And as I said before, one of the
17 things that happened when the Commission set this up
18 in their last SRM, they said we want to be notified
19 whenever you identify special circumstances. And
20 there's a variety of reasons for that. I mean, it's a
21 new process and whatever, but the implication when you
22 find special circumstances is there's something really
23 wrong. There's something wrong in your regulatory
24 guidance, or maybe your rule is not -- it has broad
25 implications like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The other thing is, in order to reject a
2 non-risk-informed license amendment on the basis of
3 risk, I've got to convince all the way up to the
4 Director of NRR. It's not done at the Branch Chief
5 level, which is where we would accept things, so that
6 would mean I have to convince my older Branch Chief,
7 then his Division Manager, then up through like this.

8 I mean, it's a serious, serious thing to reject one
9 of these things.

10 MEMBER CORRADINI: And that's because -- I
11 just want to make sure, just for clarification. And
12 that's because they've met the deterministic
13 regulations.

14 MR. STUTZKE: Yes.

15 MEMBER CORRADINI: They're a non-risk-
16 informed application, which all EPU's are.

17 MR. STUTZKE: They're in compliance with
18 all regulations -

19 MEMBER CORRADINI: Unless some bell rings
20 and a risk calculation confirms the bell, they have
21 met the letter of the law.

22 MR. STUTZKE: Right. And it's not just a
23 small delta CDF. I mean, you'd have to be way up
24 there in core damage frequency, or large early release
25 frequency, something like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: And just to drive the
2 point home back to my original question. If the
3 calculation of the overpressure credit necessary has
4 to literally intersect or cross the design pressure
5 for an alarm bell to ring on risk, maybe not even
6 then.

7 CHAIR SHACK: Containment is never going
8 to see design pressure in a risk basis.

9 MEMBER CORRADINI: Well, there was a need
10 to have a very large overpressure credit for a very
11 long period of time for the yet to be reviewed 20
12 percent EPU.

13 MR. STUTZKE: Right. And I can calculate
14 the increase in risk as a result of requiring that
15 overpressure credit, as compared to no pressure
16 required at all.

17 MR. LOBEL: We ought to be careful of the
18 nomenclature, I think. We're not talking about the
19 design pressure. I think we're talking about the
20 pressure that's calculated to be in the containment.
21 You're talking about the pressure that's there, and
22 the pressure that's needed being close together.

23 MEMBER CORRADINI: Correct. Excuse me. I
24 apologize. I apologize.

25 MEMBER BANERJEE: I guess the real risk is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that you don't get the overpressure that you say you
2 will. Then the pumps cavitate, and they don't work.

3 MEMBER CORRADINI: But as Rich said it
4 better, I misstated it as this pressure is changing
5 with time, and the overpressure that I need to make
6 this criteria, and that window narrows, unless I cross
7 that window, there's no risk-based decision that says
8 something -- an alarm bell rings.

9 MEMBER BANERJEE: The real risk is -

10 MR. LOBEL: But if you cross the window,
11 it would never get to Marty anyway, because we would
12 just tell the licensee that it's unacceptable at this
13 point.

14 MEMBER CORRADINI: Fine.

15 MEMBER BANERJEE: But this risk analysis
16 would take into account all the uncertainties and
17 everything, and then get the probability of not
18 meeting this criteria.

19 MEMBER CORRADINI: Not this one.

20 MEMBER BANERJEE: And not -- and failing
21 the pumps. Right?

22 MEMBER CORRADINI: No.

23 MEMBER APOSTOLAKIS: This risk assessment,
24 though, is based on the two basic assumptions that
25 were presented earlier. The magnitude of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 overpressure is relevant to the duration. He's not
2 quantifying any of that. He's assuming that these are
3 irrelevant. All he's looking at is whether there is
4 overpressure. Right, Marty?

5 MR. STUTZKE: That's correct.

6 MEMBER APOSTOLAKIS: Yes. So it's not
7 really a full uncertainty analysis. It's a piece of
8 it.

9 MR. STUTZKE: The uncertainty of the
10 safety margin, no.

11 MEMBER APOSTOLAKIS: Sorry?

12 MR. STUTZKE: The uncertainty of the -

13 MEMBER APOSTOLAKIS: You don't look at the
14 safety margin. That's another -

15 MR. STUTZKE: We're not looking at the
16 margin. That's a separate criteria.

17 MEMBER APOSTOLAKIS: But did you say,
18 though, that GE is doing something, the Owner's Group,
19 to quantify these uncertainties?

20 MR. LOBEL: Well, they're doing the
21 statistical analysis approach that we call it. It's
22 like, I don't know if you've been briefed on best-
23 estimate LOCA. It's the same kind of thing, where you
24 do a realistic analysis, and then you look at the
25 uncertainties. You get an uncertainty distribution

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for all the important parameters, and then you do a
2 Monte Carlo-type calculation.

3 MEMBER APOSTOLAKIS: But do they make the
4 two assumptions that Marty is making? If they make,
5 then it's not interesting. If they don't make them,
6 then it's interesting.

7 MR. LOBEL: It's not a risk-analysis.

8 MEMBER BANERJEE: Is it like the CSAU
9 methodology?

10 MR. STUTZKE: Yes.

11 MEMBER BANERJEE: All right.

12 (Simultaneous speech.)

13 CHAIR SHACK: Watch what you wish for,
14 because if you get it, they'll be able to ask for even
15 more credit.

16 MEMBER BANERJEE: Yes.

17 MEMBER APOSTOLAKIS: No, but is that what
18 they're doing? I don't know.

19 MR. STUTZKE: The downside of it is this,
20 suppose that you do a best estimate with uncertainty
21 analysis, and you buy off on a 95-95 acceptance
22 criteria. What that means is there's a 5 percent
23 chance that you don't have enough overpressure.
24 Right? So I could put that in as a basic event in the
25 PRA and propagate it through the model.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Are we going to see
2 that analysis?

3 MR. STUTZKE: The point is maybe 95-95 is
4 not good enough, maybe you want 99-99, and I've had
5 some limited discussions with other people in my new
6 office, and it becomes almost prohibitive to compute
7 it.

8 MEMBER APOSTOLAKIS: No, you have to look
9 at it in the context, the bigger context of the
10 accident.

11 MR. STUTZKE: That's right. It's tough.

12 MEMBER BANERJEE: But we do 95-95 for -

13 MEMBER CORRADINI: That's for you.

14 MEMBER BANERJEE: I mean, okay, there's a
15 5 percent chance it might be more, but it's not the
16 end of the world.

17 MR. LOBEL: The differences in the thing
18 we're talking about is that if you're talking about a
19 LOCA analysis, you're talking about a few more rods
20 exceeding the peak clad temperature. In this case,
21 you're talking about a pump not being able to -

22 (Simultaneous speech.)

23 MEMBER BANERJEE: I don't think you're
24 talking about necessarily core melt, because the
25 operator clearly can do something when he sees the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pump -

2 MR. STUTZKE: That's true. He can
3 throttle it down.

4 MEMBER SIEBER: Throttling doesn't save
5 your -

6 MEMBER BANERJEE: Can't he inject cold
7 water somewhere?

8 MEMBER APOSTOLAKIS: Are we going to see
9 the GE analysis here in this Committee?

10 MR. LOBEL: The topical report?

11 MEMBER APOSTOLAKIS: After you issue an
12 SER.

13 MR. LOBEL: Yes. We committed to come
14 back to you after we issue an SER. There was a pre-
15 brief before we started our review that GE came in and
16 gave a pre-brief. The topical report is available.
17 It's proprietary, but that's available if you want to
18 look at the topical report.

19 MEMBER APOSTOLAKIS: But this Committee
20 will actually have a chance to review it.

21 MEMBER BANERJEE: But the 99-99 is
22 prohibitive for LOCA, because it's a very elaborate
23 calculation, where this is going to be a much, much
24 smaller -

25 MR. STUTZKE: You're well outside my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 expertise.

2 MEMBER BANERJEE: Yes, this would be a
3 much simpler calculation. I don't know.

4 MR. STUTZKE: And the containment
5 computation is easy to -

6 MEMBER BANERJEE: Much easier.

7 MR. STUTZKE: The suction side, and I
8 don't know how fast.

9 MEMBER APOSTOLAKIS: Marty, if I wanted to
10 develop an event tree to consider various
11 possibilities for human intervention, if I still made
12 the two assumptions, it doesn't help me. Right? If I
13 made the assumption of magnitude and time are
14 irrelevant -

15 MR. STUTZKE: Right.

16 MEMBER APOSTOLAKIS: -- it wouldn't really
17 matter. But if I wanted to do that, I would have to
18 relax those assumptions. Correct?

19 MR. STUTZKE: Well, that's absolutely
20 right. The reason why we said time wasn't important,
21 it was a matter of looking at the fails-on-demands
22 sorts of probabilities, failure to achieve isolation,
23 as compared to the failure rate, the containment
24 leakage rates, which seem to be considerably lower,
25 even over 24 hours, 72 hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RAY: Marty, it's surely the case
2 that the uncertainty in terms of the loss of pressure
3 due to heat transfer is much greater than the loss of
4 pressure due to containment leakage. Now, the
5 argument well, that's okay, because the water you're
6 pumping is actually going to be colder at the same
7 time, that's one that I think is worth exploring, and
8 looking at. But my God Almighty, the pressure
9 uncertainty has got to be very large over a long time,
10 especially.

11 MR. STUTZKE: Well, that's true, but those
12 sorts of design-related issues aren't things that are
13 normally treated in PRA space. We worry about things
14 failing to start, or turning off, or operators doing
15 their -

16 MEMBER RAY: Okay. But I think one of our
17 jobs is to try and realize when the process fails to
18 include something that's important.

19 CHAIR SHACK: Let me just come back to the
20 question of when I'm going to get a risk analysis.
21 You made the argument when this was originally set up,
22 there was an exception for EPU's. Now you're telling
23 me that it's going to go back, and I can only get it
24 if I'm willing to go to the Director of NRR.

25 MR. LOBEL: No, what we're talking about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is non-EPU amendments that deal with overpressure.

2 MEMBER CORRADINI: Okay.

3 MR. LOBEL: EPUs are -

4 MEMBER BANERJEE: Is this topical going to
5 address EPUs then, or it's very general?

6 MR. LOBEL: Topical just talks about -

7 MEMBER BANERJEE: Methodology.

8 MR. LOBEL: -- overpressure in general.

9 And it's only for LOCA. They're not really going into
10 the Appendix R, ATWS, and Station Blackout.

11 MEMBER CORRADINI: I understand now.

12 MEMBER APOSTOLAKIS: No, but I don't.

13 There will be a risk assessment with EPU?

14 MR. STUTZKE: Yes.

15 MEMBER APOSTOLAKIS: Okay. That's what
16 you said.

17 CHAIR SHACK: Yes, but why is isn't it
18 going to say that the 1.82 will be revised to say
19 that. Oh, because that covers all requests for
20 containment overpressure, not just EPUs.

21 MEMBER SIEBER: Right.

22 MEMBER BANERJEE: For example, for PSI 191
23 you might have some requests.

24 MEMBER SIEBER: That's right.

25 MEMBER BANERJEE: You may. I don't know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Why don't we move on so
2 Marty can pick up his kids.

3 CHAIR SHACK: And just while Rich is here,
4 we've talked about meeting deterministic requirements,
5 the risk requirements. I just -- defense-in-depth is
6 where the ACRS originally started out here. And, in
7 fact, if you go all the way back to Reg Guide 1.1, it
8 was issued because of an ACRS concern about
9 independence of barriers. I mean, the whole thing was
10 up initially to preserve independence of barriers, and
11 we've given that up. And now we're ready to give it
12 up to an even greater and greater extent. And the
13 Staff agreed with us back in 1970.

14 MEMBER APOSTOLAKIS: Hopefully, not with
15 us.

16 CHAIR SHACK: Our glorious ancestors.

17 MR. STUTZKE: It's very interesting. I
18 tried over the summer to read a lot of regulatory
19 history, and I would recommend you read Dr. Okrent's
20 book on the history of the ACRS, because he mentions
21 overpressure credits, specifically mentions it.

22 CHAIR SHACK: Positively or negatively?

23 MR. STUTZKE: And he said the Committee
24 had a, "Philosophical safety concern". Okay? And I
25 read that and went wow, they knew back then. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 resolution of that was issuance of Safety Guide 1.

2 CHAIR SHACK: I have more than a
3 philosophical concern, because we've now seen events
4 where we've used up some of this margin we thought we
5 had with sump blockage and things like that. So
6 giving up independence and margin still strikes me as
7 an objectionable thing to be doing.

8 MR. STUTZKE: Well, the other thing I'll
9 point out in both Dr. Okrent's book, and the second
10 book from the NRC historian, you will not find the
11 phrase "defense-in-depth." I found that remarkable,
12 absolutely remarkable.

13 MEMBER APOSTOLAKIS: Well, it was defined
14 in 1990.

15 CHAIR SHACK: Well, we'll be talking to
16 the defense-in-depth folks tomorrow.

17 (Off the record comments.)

18 CHAIR SHACK: Do we have further comments
19 or questions?

20 MEMBER APOSTOLAKIS: Well, did you
21 conclude that all -

22 CHAIR SHACK: I want to make sure that you
23 do get -

24 MEMBER BROWN: The local dummy is speaking
25 right now, so if you go through these -- you started

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 off the initial discussion with the accident occurs.
2 The operators follow their procedures. They initiate
3 cooling, they initiate the drywell cooling, turn it
4 all on. And then they just -- the plant does what it
5 does. I'm paraphrasing, or I hope I'm paraphrasing
6 accurately. And then at some point, I presume you
7 cool, and all the analyses say that you will not
8 exceed containment pressures, you will not -- you'll
9 be able to cool the core based on the analyses done,
10 with whatever assumptions are there. Is that a
11 correct statement for the design-basis accident?

12 MR. LOBEL: There is a lot of -- there's
13 different analyses. There's analysis for peak
14 pressure, and there's an analysis for cooling the
15 plant. And then there is this NPSH analysis.

16 MEMBER BROWN: I'm assuming -- I want to
17 deal with NP.

18 MR. LOBEL: Okay.

19 MEMBER BROWN: I'm just fundamentally -- I
20 mean, if you had everything else in place, your pumps
21 would work and you would cool the plant.

22 MR. LOBEL: Right.

23 MEMBER BROWN: Now, we find we have to do
24 some things to insure that the pumps will operate
25 under this particular scenario, and there may be even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 others with the sump screens, or whatever else comes
2 up. If the operator in this circumstance here, at
3 least the one I'm aware of, the drywell turning those
4 coolers back off again, and continues to cool, the
5 pressure goes up in the containment. Will it reach
6 the design-pressure or not?

7 MR. LOBEL: I don't think so.

8 MEMBER BROWN: How far away? Is it way
9 far away?

10 MR. LOBEL: In a PWR, they get closest to
11 the design pressure at the very beginning of the
12 accident.

13 MEMBER BROWN: That's fine.

14 MR. LOBEL: You're blowing down all the
15 steam and water in the drywell, and it has to pass
16 through the vent system to get to the wetwell. It
17 can't do it all at once, because it's too small, so
18 the pressure is going up while that stuff is trying to
19 get down into the wetwell to get condensed.

20 MEMBER BROWN: I got that. I got that.

21 MR. LOBEL: Okay.

22 MEMBER BROWN: I'm going to make sure
23 Marty gets out. So that the issue -- one of my
24 concerns was we -- once we turn those off and he's --
25 the pressure doesn't exceed the containment pressure,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so it's a matter of time affect on other things. But
2 now are you setting yourself up if the operator loses
3 control of the cool down of the reactor, and the
4 temperatures go up for some reason, have you not put
5 yourself closer to a circumstance where you could
6 violate the containment?

7 MR. LOBEL: If the operator turns them
8 off, and then he has to turn them back on again?

9 MEMBER BROWN: Some type of an error --
10 yes, and all of a sudden, and they don't -- all I'm
11 worried about is moving from a regime where he doesn't
12 have to pay any attention to it, to a regime where he
13 makes - and if he made the mistake with the drywell
14 coolers on, he's got margins of having something
15 happen, whereas, if the drywell coolers are off and
16 the pressure is up so we maintain NPSH -

17 MR. LOBEL: He's got a lot of margin. The
18 peak pressure is something like 9 psig, and the design
19 pressure is 56.

20 MEMBER BROWN: I'm not talking about not
21 doing it because of NPSH, but he turns off the pumps
22 for some reason, or he loses track of the containment
23 pressure because he's -- whatever it is, because he's
24 throttled the pumps.

25 MR. DENNIG: I don't think we had concern

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about them not being turned back on again.

2 MEMBER BROWN: I just wanted to -

3 MR. DENNIG: I don't believe that that was
4 one of our concerns.

5 MR. LOBEL: Well, if he turned them back
6 on, and he went -- he could still go down below the
7 pressure.

8 MR. DENNIG: I mean, for a reason, for a
9 reason of managing the accident other than the
10 original issue.

11 MR. LOBEL: I mean, you can make that kind
12 of a statement about all the accident analysis. What
13 if the operator did something that makes things worse.

14 MEMBER BROWN: Well, the point is it's
15 required now in this circumstance to do this, in order
16 to maintain the NPSH. And we ended up, and maybe this
17 is mindless, but that finish circumstance where they
18 added the power uprates, and now they had this other
19 system that used to not be required, now it was
20 required. Not only was it required, but it required a
21 specific pump coast - some type of a coast down in
22 order to maintain accident margins, and then something
23 went wrong once they got into this, and they ended up
24 having -- they were short, and they could have the --
25 they were at low power instead of high power when the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 problem occurred. You knew you gradually you increase
2 the power rating, and you trim things off, taking
3 advantage of margins. It's similar to Bill's comment
4 about -

5 MR. LOBEL: These fan coolers are non-
6 safety equipment, if they -

7 MEMBER BROWN: Well, these other ones
8 were, too, initially.

9 MR. LOBEL: In other BWRs, they don't
10 continue into the accident. They're not loads that
11 are picked up, so they don't operate at all. In this
12 case, they do, so the operator has to turn it off. He
13 has two hours to do it, and he has three different
14 ways he can do it from the control room, and outside
15 the control room. The drywell coolers, so it's -

16 MEMBER BANERJEE: I have a quick question.
17 When is this GE report available?

18 MR. LOBEL: It's available now. It's in
19 ADAMS.

20 MEMBER BANERJEE: Would it be in time for
21 Brown's Ferry?

22 MR. LOBEL: No, it probably won't be done
23 before March. It may be, but I don't -

24 MR. RULAND: They haven't referred it in
25 their submittal. The Staff has already issued the SE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for the Brown's Ferry uprate, and it was - we did our
2 review at 120 percent. Right, Rich?

3 MR. LOBEL: We did our review at 120 -

4 MR. RULAND: Well, this isn't going to
5 affect Brown's Ferry.

6 MEMBER BANERJEE: This is just a general -

7
8 MR. LOBEL: This is a general topical
9 report.

10 MR. RULAND: Right.

11 MEMBER APOSTOLAKIS: Can you go to slide
12 6? It seems to me from what I've heard in Rich's
13 presentation and all the discussion, the real
14 principle that applies here is number 3, maintain
15 sufficient safety margins. Also, 2, but 3 is the key
16 one. All the discussion here was 3, and 3 is not
17 dealt with at all. Is that correct, Marty?

18 MR. STUTZKE: Well, all of the principles
19 are dealt with, but you're asking about how we divvy
20 up the work.

21 MEMBER APOSTOLAKIS: Well, I mean, is
22 there any calculation to demonstrate that sufficient
23 safety margins are maintained? I don't believe so,
24 because you are dealing only with the existence of
25 overpressure. You have made those two assumptions,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that the magnitude doesn't matter, and the duration
2 doesn't matter.

3 MR. STUTZKE: Okay.

4 MEMBER APOSTOLAKIS: And you have
5 eliminated 3. All the discussion is about that.

6 MEMBER SIEBER: You want actual to equal
7 required. For an actual pressure to equal required
8 pressure.

9 MEMBER APOSTOLAKIS: Yes.

10 MEMBER SIEBER: That's margin. There's
11 margin built into that.

12 MEMBER APOSTOLAKIS: But it -

13 MEMBER SIEBER: 3 percent.

14 MEMBER APOSTOLAKIS: But they don't
15 quantify that.

16 MEMBER SIEBER: 3 percent.

17 MEMBER APOSTOLAKIS: No, no, no. These
18 are not -

19 MR. STUTZKE: It's not quantified, but
20 yes, it goes back to how their work is divvied up.
21 Really, the PRA guys do number 4. And everything else
22 is a problem.

23 MEMBER APOSTOLAKIS: Is problem. But you
24 do quantify 3, or maybe GE does. Anyway, I just -

25 MR. STUTZKE: Yes. That's the intention.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: That's the intention.
2 Right.

3 MEMBER ABDEL-KHALIK: Have you at any time
4 sort of really addressed the underlying issue that
5 Howard brought up about over-cooling to the
6 containment, and the fact that as the pressure
7 increases, that the rate of change of saturation
8 pressure with saturation temperature actually
9 increases? And, therefore, small changes in
10 temperature can cause large changes in pressure.

11 MR. LOBEL: Which is why the suppression
12 pool temperature is so much more important than the
13 pressure above the water level.

14 MEMBER ABDEL-KHALIK: In the other
15 direction, meaning that if you have extra heat
16 transfer to the containment walls, for example, so
17 that the overall temperature is reduced, that will
18 cause significant changes in containment pressure so
19 that you may not have enough containment pressure to
20 give you adequate NPSH. And the problem becomes worse
21 as the temperature increases, or as the pressure
22 increases.

23 MR. LOBEL: I don't know of a calculation
24 like that, but I would guess that -

25 MEMBER ABDEL-KHALIK: Just look at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 steam table. The rate of change of saturation
2 temperature with saturation pressure.

3 MR. LOBEL: Right. That's what we were
4 talking about with why the temperature is so much more
5 important going up.

6 MEMBER RAY: But you're assuming
7 equilibrium, which I -- if we did the analysis, I
8 would -- that's exactly where I would go. That's the
9 question that Said is asking. The water stays hot,
10 but the containment atmosphere is cooled more than you
11 think, and now your assumption that well, the water
12 will always be cooled at the same time that the
13 atmosphere is being cooled and depressurized by the
14 heat transfer, that isn't necessarily a correct
15 assumption, it doesn't seem to me.

16 MEMBER SIEBER: It would probably go to
17 saturation.

18 MEMBER RAY: Well, I don't know, Jack. I
19 can imagine hot water -

20 MEMBER SIEBER: That's as hot as it can
21 get.

22 MEMBER RAY: -- and cool containment
23 temperature. Well, then let's look at the picture.

24 MR. LOBEL: Well, it can't be too cool
25 because what's heating it, the suppression pool is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hot. There's the vapor -

2 MEMBER RAY: Just cooling off is all we're
3 talking about. Look, this is just a matter of
4 quantifying something. That's all.

5 MR. LOBEL: The vapor is going to be in
6 equilibrium with water most likely.

7 MEMBER RAY: Is that enough?

8 MR. LOBEL: And the gas in the wetwell is
9 in contact with the vapor, so it's hard to see that
10 it's going to get too much -

11 MEMBER ABDEL-KHALIK: Too much time
12 constant of the containment shield wall, the thick
13 concrete. What's the time constant of that?

14 MR. LOBEL: Of the concrete?

15 MEMBER ABDEL-KHALIK: Right.

16 MR. LOBEL: Well, that the torus is metal.

17 MEMBER ABDEL-KHALIK: But there are other
18 means of heat loss to the world.

19 MEMBER RAY: It's just a matter it needs
20 to be shown rather than -

21 CHAIR SHACK: We have -- just to come back
22 to defend a little bit. Whenever we've seen
23 calculations that relax the conservative assumptions
24 that Rich has talked about, we've always found that
25 the net has gone down. I mean, I can't say that we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 looked at every possible combination -

2 MEMBER RAY: The net margin?

3 CHAIR SHACK: The net required, the
4 required NPSH has always gone down.

5 MR. LOBEL: You're saying you're going to
6 have a lot of heat transfer from the wet well
7 atmosphere, but the water is going to stay hot. I
8 don't know of a calculation like that. I have a
9 feeling it would be hard to get in that situation, but
10 I don't -

11 MEMBER RAY: I'm not trying to make an
12 argument. I'm only try to illustrate where it seems
13 to me there's uncertainty. And, to me, containment
14 leakage is a small player, containment cooling is a
15 big player by comparison. And the argument that oh,
16 well, the water will cool down more rapidly than the
17 loss of pressure due to containment cooling; well,
18 maybe so, but let's see some numbers.

19 MR. LOBEL: But the containment cooling is
20 mostly from the heat exchanger, which is in the water.

21 MEMBER RAY: I don't know that. There's
22 heat transfer that takes place over many hours here.
23 This is not something that I can intuit the way
24 perhaps you've been able to do.

25 MR. LOBEL: Well, I don't know the -- I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can't say I can point to a calculation that we've
2 done, or GE's done that way. We might be able to do
3 one.

4 MEMBER RAY: When you're down to the kind
5 of margins we're talking about here, you've got to do
6 it, it seems to me.

7 MEMBER SIEBER: Well, those kinds of
8 calculations have been done typically by designers of
9 containment where they look at the material mass,
10 thermal energy, heat transfer.

11 MEMBER RAY: Yes. I would replace the -

12 MEMBER SIEBER: That part of the
13 information is available.

14 MEMBER RAY: The pumps at my plant, and we
15 sharpened every pencil there was, but that's what
16 happened. So I've seen this done before, and I'm just
17 not that sanguine about these arguments.

18 MEMBER SIEBER: Yes, heat loss that way is
19 important.

20 CHAIR SHACK: Marty is about to get in
21 trouble here, so unless you have a burning question.

22 MEMBER SIEBER: Yes. Just stand up and
23 say goodbye.

24 MR. STUTZKE: Thank you.

25 (Simultaneous speech.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: I really appreciate the
2 discussion, and I think Rich and Marty did a good job.

3 They provided information that gives me something to
4 think about. I'm not sure it changes my overall
5 opinion, but it certainly shed light on some aspects
6 of it, and the regulatory process that I didn't know.

7 And I think they've done a good job of fielding our
8 questions and maintaining -

9 CHAIR SHACK: Well said, well said.

10 MEMBER MAYNARD: So I appreciate it.

11 MEMBER APOSTOLAKIS: Do we have any
12 conclusions from today's meeting?

13 CHAIR SHACK: Well, we get to discuss
14 that. When is -

15 MEMBER STETKAR: You mentioned you've made
16 changes to the White Paper. Are we going to -- when
17 is the Rev.1?

18 MR. RULAND: Based on -- having listened
19 to this discussion, it kind of played out the way I
20 thought it would play out. What we would very likely
21 do at this juncture is revise the White Paper, and I
22 suspect we will send a Commission paper, and the White
23 Paper will be attached to the Commission paper. And
24 that's how we likely will proceed. And the Commission
25 has directed us to send policy papers, if needed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And, like I said, I didn't hear that you were
2 overjoyed by our analysis, and we were in violent
3 agreement. I heard that you basically have viewed
4 this -- while I think we enlightened you with some
5 kind of our argument in one place, I don't hear that
6 you've moved much in your view on the matter. So once
7 we prepare a Commission paper, you'll see the White
8 Paper as an attachment, very likely.

9 Now, that's not a commitment, but that's -
10 based on what I heard today, I've got to talk to my
11 boss here, of course, Jack Rowe, who is sitting to my
12 left, and I invited Jack, and Jack wanted to come here
13 because he wanted to hear these discussions first-
14 hand. And I would -- anyway, thank you for the
15 discussions, because I think they really mirrored the
16 discussions and the debates we've had all along in
17 this matter. So we'll -- as I said in the beginning,
18 we want to drive this issue to closure.

19 We can't -- these can be entertaining, but
20 we want to really drive this -- we've got to make a
21 decision in this matter, frankly, at the Commission
22 level, and move forward. And I think you can
23 appreciate that. Just as a matter of how we conduct
24 our business. Anyway, so that's maybe -- hopefully I
25 answered your question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Yes, thanks.

2 MR. ROWE: George asked a question, and I
3 think the answer is that your position that you had
4 presented to the Commission hasn't changed.

5 CHAIR SHACK: No, I think we need to
6 discuss things.

7 MR. ROWE: Okay.

8 CHAIR SHACK: I mean, this is all -

9 MR. ROWE: I'm interested in the results
10 of these conversations.

11 CHAIR SHACK: The results of those
12 conversations -

13 MR. ROWE: How would we get those absent a
14 letter?

15 CHAIR SHACK: We'll have to discuss that.

16 MR. RULAND: And any intelligence, any
17 information you can give us just beyond us listening
18 to this meeting, would be greatly appreciated. But,
19 like I said, we're already -- my direction to our
20 staff is write the paper right now. And that's going
21 to be our direction, because we really can't wait.
22 We've got to move forward.

23 MEMBER BANERJEE: You've got a new piece
24 of information in the topical. Right? Which might
25 actually be very useful.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LOBEL: I really don't think the
2 topical is going to help with any of the issues you're
3 talking about here. It's really just one way of doing
4 the calculations. And, in fact, the way the Owner's
5 Group posed the topical is they want to use the
6 topical to justify the deterministic analysis. They
7 don't even want the statistical analysis to be the
8 licensing basis. And we're talking with them about
9 that, but -

10 MR. DENNIG: The statistical analysis is
11 just a randomization of initial conditions, and then
12 doing calculations.

13 MEMBER BANERJEE: Then it's not a CSAU.

14 MR. LOBEL: It's close to a CSAU. They
15 don't want to call it a CSAU, and they didn't do it
16 exactly like a CSAU. But the questions the members
17 have been asking here aren't answered in the topical.
18 It isn't going to help.

19 MS. ABDULLAHI: Can I make a point. This
20 is Zeyna Abdullahi. We had this topical report
21 briefing in February `08, and this is the case where
22 the Staff was saying that they have best-estimate --
23 no, that they have very conservative LOCA containment
24 calculations. And the BWROG said that, and the ACRS
25 was also saying there's not a consistency from plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to plant. And the BWROG proposed with the help of the
2 Staff a statistical approach for the LOCA containment
3 analysis with uncertainty, treatment as opposed to
4 very conservative, like Rich was saying. And we had
5 that briefing, and you will review it later on. But
6 the request in the past of having a LOCA with
7 uncertainty so you have more confidence in the
8 calculation without being overly conservative, I think
9 that's where the topical report provides some help.

10 CHAIR SHACK: Again, let me express our
11 thanks. It's been a very interesting discussion, done
12 very well, and we will be talking.

13 MR. RULAND: Rich and Marty, thank you
14 very much.

15 CHAIR SHACK: We'll take a 15-minute
16 break.

17 (Whereupon, the proceedings went off the
18 record at 5:20 p.m.)
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS


1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701


ESBWR DCD Chapter 7 DCIS Overview

Full/Subcommittee ACRS Meeting

Rich Miller
Ira Poppel
Steve Kimura
Dec 3-4, 2008



ESBWR DCIS Organization - Continued




HITACHI

Q-DCIS

- Q-DCIS organized into
 - > RTIF/NMS (reactor trip system)
 - > SSLC/ESF (ECCS and information systems)
 - > ATWS/SLC and VBIF
- Q-DCIS is deterministic
- Q-DCIS has four divisions
- Q-DCIS is N-2
- RTIF/NMS and SSLC/ESF functions implemented on diverse hardware/software platforms
- Q-DCIS is physically, electrically and data isolated between divisions and between Q-DCIS and N-DCIS



Q-DCIS Power



Note that any one battery, inverter or DCIS internal power supply can fully support divisional operation. The only effect of taking any of those components out of service is to reduce the 72 hour design basis to ~36 hours - and that only happens if offsite power is lost and both diesels fail to start. All equipment is self diagnosed/alarmed and can be maintained on line (the DCIS power supplies can be changed in less than a shift) and there is no planned requirement to ever make a division completely "black".



HITACHI

ESBWR DCIS Overall Diversity

Safety Category	Safety-Related				Nonsafety-Related						
	Q-DCIS				N-DCIS						
Platform/ Network Segment	RTIF NMS	SSLC/ESF	Independent Control platform	other	GENE		PIP A/B	BOP		PCF	
architecture	divisional	divisional	divisional	note 1	Triple Redundant (DPS)	Dual Redundant	Dual Redundant	Triple Redundant	Dual Redundant	Workstations	PLC (Deluge)

Diversity Strategy

Within Safety-Related Controls											
Q-DCIS vs DPS vs Deluge											
Q-DCIS vs N-DCIS (ESBWR DCD PRA)											

Note 1 – RSS provides operator workstations at appropriate diverse locations outside the main control room in accordance with GDC 19. See DCD section 7.1.3.2.3.2

Note 2 – Crosshatching denotes different platforms or networks



HITACHI

N-DCIS


- N-DCIS is organized into five independent dual redundant network segments
 - > GENE (contains DPS)
 - > PIP A (investment protection/RTNSS)
 - > PIP B (investment protection/RTNSS)
 - > BOP (power generation)
 - > Plant Computer Functions
- A/B N-DCIS components located in separate rooms/fire zones
- N-DCIS components dual or triply redundant powered by two or three uninterruptible power systems
- Important reactor control systems segmented
- Networks are not used for closed loop control
- N-DCIS components diverse from Q-DCIS components



ESBWR Diverse Protection System

- Provides manual and automatic
 - > Backup scram functions
 - (Rx level, Rx pressure, pool temperature, drywell pressure)
 - > Backup MSIV isolation functions
 - (Rx steam flow, Rx level)
 - > backup ADS and GDCS initiation
 - > Backup IC initiation
 - > Backup process isolation functions
 - > SLCS initiation
- Mitigates loss of feedwater heating (SRI, SCRRI)
- Initiates ARI, SRI/SCRRI, all control rod run-in
- Initiates FW runback
- Initiates level 9 FW pump trip

ESBWR Main Control Room



HITACHI

ESBWR Remote Shutdown System (RSS)

- ESBWR RSS not really a “system” – instead two auxiliary control rooms with RSS panels located in Div 1 and Div 2 quadrants of the Reactor Building
- GDC 19 RSS requirements are met by the manual scram and isolation switches on the panels
- With offsite power available, either RSS panel can operate BOP normally for plant shutdown
- With only diesel power available, either RSS panel can operate PIP A or PIP B systems for plant shutdown
- With only safety-related batteries available, either RSS panel can operate division 1 or division 2 systems for plant shutdown





Presentation to the 558th ACRS Meeting

Summary of Staff Review
of
ESBWR Design Certification Document Chapter 14 and
Tier 1

Presented by Eric Oesterle
Lead Project Manager (NRO/DNRL)
December 4, 2008

Staff Review of ESBWR Chapter 14 and Tier 1 Overview of Design Certification

Purpose

- Provide an update of the status of the staff's review of ESBWR DCD Tier 2, Chapter 14, Initial Test Program and ITAAC, and Tier 1, since the 557th ACRS Full Committee meeting

Staff Review of ESBWR Chapter 14 and Tier 1 Overview of Design Certification

Regulations:

- 10 CFR 50.34(b)(6)(iii) and 10 CFR 52.79(a)(28) - Initial Test Program
- 10 CFR 53.27(b)(1) - ITAAC

Regulatory Guidance:

- Standard Review Plan 14.2, Initial Plant Test Program
- Standard Review Plan 14.3, Inspections, Tests, Analyses and Acceptance Criteria (ITAAC)
- Reg. Guide 1.68, Initial Test Programs for Water-Cooled Nuclear Power Plants
- Reg. Guide 1.20, Comprehensive Vibration Assessment Program for Reactor Internals During Preoperational and Initial Startup Testing
- Reg. Guide 1.70, Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)
- Reg. Guide 1.206, Combined License (COL) Applications for Nuclear Power Plants

Staff Review of ESBWR Chapter 14 and Tier 1 Overview of Design Certification

Summary of Staff Review of ESBWR Chapter 14 and Tier 1:

- RAIs issued: 539
- RAI responses submitted: 509
- RAIs resolved: 476

Summary of Staff Review of ESBWR Section 14.2, Initial Test Program:

- RAIs issued: 99 (1 new RAI since 557th ACRS mtg)
- RAIs resolved: 93
- Unresolved RAIs associated with:
 - expansion, vibration and dynamic effects testing
 - testing of digital instrumentation and control system functions
 - safety system logic and control pre-operational testing
 - lead detection and isolation system pre-operational testing
 - reactor internals vibration testing
 - AC power distribution system pre-operational testing
 - incomplete description of pre-operational testing for DCIS

Staff Review of ESBWR Chapter 14 and Tier 1 Overview of Design Certification

Summary of Staff Review of ESBWR Tier 1 and Section 14.3, ITAAC:

- RAIs issued: 440 (3 new RAIs since 557th ACRS mtg)
- RAIs resolved: 383 (21 RAIs resolved since 557th ACRS mtg)
- Unresolved RAIs associated with:
 - tables of key aspects, analyses, and design features included in ITAAC
 - interface materials (offsite power and plant service water system)
 - digital instrumentation and control systems
 - human factors engineering
 - electrical systems
 - containment systems
 - reactor systems
 - format and consistency issues across similar ITAAC
 - security design features

Staff Review of ESBWR Chapter 14 and Tier 1 Overview of Design Certification

Summary

- NRO staff continues to engage with GEH to obtain satisfactory resolutions of open items associated with review of the Initial Test Program and ITAAC that are necessary to develop the staff's Final Safety Evaluation Report (FSER) for Tier 1 and Chapter 14 of the ESBWR Design Certification Document



Presentation to the ACRS Full Committee

ESBWR Design Certification Review
Chapter 7, "Instrumentation and Controls"

December 4, 2008



ACRS Full Committee Presentation ESBWR Design Certification Review Chapter 7

Purpose

- Brief the Subcommittee on the staff's continuing review of the ESBWR DCD Application Sections
 - 7.1 “Introduction”
 - Software Development Activities
 - Diversity and Defense-in-Depth Assessment
 - Setpoint Methodology
 - Data Communication Systems
 - 7.2 “Reactor Trip Systems”
 - 7.3 “Engineered Safety Features Systems”
 - 7.4 “Safe Shutdown Systems”
 - 7.5 “Information Systems Important to Safety”
 - 7.6 “Interlock Systems”
 - 7.7 “Control Systems”
 - 7.8 “Diverse Instrumentation and Control Systems”
- Answer the Committee's questions



ACRS Full Committee Presentation ESBWR Design Certification Review Chapter 7 Review Team

- Project Manager
 - Dennis Galvin
- Technical Reviewers
 - Hulbert Li, Lead
 - Leroy Hardin
 - Sang Rhow
 - Royce Beacom
 - Dinesh Taneja
 - Joseph Ashcraft
 - Kimberley Corp
 - Eugene Eagle
 - Thomas Fredette
 - Jack Zhao



ACRS Full Committee Presentation ESBWR Design Certification Review Chapter 7 Presentation

Outline of Presentation

- Applicable Regulations
- RAI Status Summary
- SER Technical Topics of Interest
 - Key I&C DAC/ITAAC Items
 - Key SER Open Items
- Discussion / Committee Questions



ACRS Full Committee Presentation ESBWR Design Certification Review Chapter 7

Key Regulations

- 10 CFR 50.55a(a)(1), 10 CFR 50.55a(h)(3), 10 CFR 50.34(f)(2), 10 CFR 50.62, and 10 CFR 52.47(b)(1)
- 10 CFR Part 50, Appendix A, GDC 1, 2, 4, 10, 13, 15, 16, 19, 20, 21, 22, 23, 24, 25, 28, 29, 33, 34, and 35

Principal Review Guidance

- SRP Section 7, including Branch Technical Positions
- SRP Sections 14.3 and 14.3.5
- Regulatory Guides 1.22, 1.47, 1.53, 1.62, 1.75, 1.97, 1.105, 1.118, 1.151, 1.152, 1.168, 1.169, 1.170, 1.171, 1.172, 1.173, 1.180, 1.189, 1.204, and 1.209
- SRM on SECY-93-087 and SECY-92-053



ACRS Full Committee Presentation ESBWR Design Certification Review Chapter 7

RAI Status Summary: SRP Chapter 7

- Original number of RAIs = 276
- Number of RAIs resolved = 206
- Number of Remaining Open Items = 70

ACRS Subcommittee Presentation

ESBWR Design Certification Review

Chapter 7 Summary

The staff followed SRP Chapters 7 & 14 Guidance to review high level functional requirements and design commitments for:

- IEEE-603 criteria compliance
- Life-cycle design process
- Setpoint methodology
- Diversity & Defense-in-Depth
- Data Communication

ACRS Full Committee Presentation

ESBWR Design Certification Review

Chapter 7 Summary

RAI open items status

- Most of the remaining open items are clarification/consistency related issues
- No safety significant technical issues that need resolution

ACRS Full Committee Presentation ESBWR Design Certification Review Committee Questions

Discussion/Committee Questions



Presentation to the ACRS Full Committee

Safety Review of the
Vogtle Electric Generating Plant
Early Site Permit Application and
Limited Work Authorization Request

December 4, 2008



Purpose

- To provide the ACRS an overview of the staff's safety review and conclusions on:
 - The Vogtle Electric Generating Plant (VEGP) Early Site Permit (ESP) Application
 - The VEGP Limited Work Authorization (LWA) Request

- Address the Full Committee's questions



Meeting Agenda

Early Site Permit Application Review:

- Remaining Schedule Milestones
- Key Review Areas / Resolution of Open Items
- Advanced Safety Evaluation Report (SER) Conclusions

Limited Work Authorization Review:

- VEGP LWA Request Summary
- Review of LWA Activities
- LWA Conclusion
- Discussion / Questions



Remaining Milestones

- ACRS Final Letter Assumed – 1/2009
- Final SER Issuance – 2/5/2009
- Mandatory Hearing – 3/23/2009
- Commission Decision Assumed – Summer/Fall 2009

Key Review Areas for ESP/LWA

- The staff completed its review of the following areas for the ESP:
 - 2.1 - Geography and Demography
 - 2.2 - Nearby Industrial, Transportation, and Military Facilities
 - **2.3 - Meteorology (1)**
 - **2.4 - Hydrology (4)**
 - **2.5 - Geology, Seismology, Geotechnical Engineering (22)**
 - 3.5.1.6 - Aircraft Hazards
 - 11 - Doses from Routine Liquid and Gaseous Effluent Releases
 - **13.3 - Emergency Planning (13)**
 - 13.6 - Physical Security
 - 15 - Accident Analyses
 - 17 - Quality Assurance
- Resolution of all Open Items (**Bold**) discussed in the Advanced SER
- The staff completed its review of the following areas for the LWA:
 - 2.5.4 – Stability of Subsurface Materials and Foundations
 - 3.8.5 – Foundations
 - 13.7 – Fitness For Duty Program
 - 17 – Quality Assurance Program




Section 2.4: Hydrology

Section 2.4 Hydrologic Hazard Analyses



- Floods induced by rain, dam break, hurricane, and tsunami.
- Low water impacts
- Ice impacts
- Water use impacts
- Groundwater flow and contamination transport analyses





2.4 Hydrology

- Section 2.4.8: Cooling Water Canals and Reservoirs (**OI 2.4-1**)
 - Issue: Do canals or reservoirs are used as any external water source for safety-related cooling water?
 - Resolution: Staff confirmed that safety-related cooling water is provided not from canals and reservoirs, but from groundwater wells. Based on aquifer characteristics, staff determined that the aquifer has sufficient capacity for initial filling and occasional makeup of two proposed water storage tanks - **Closed**

- Section 2.4.12: Groundwater (**OI 2.4-2**)
 - Issue: Predict future hydrogeological conditions to determine the safety of proposed facilities from groundwater-induced loadings.
 - Resolution: The applicant provided additional field hydrogeologic data (e.g., the unconfined aquifer characters, a refined recharge and hydraulic conductivity maps). NRC staff analyzed the groundwater regime with a post-construction setting and the provided data, and confirmed that a maximum water table elevation (165 ft msl) is far below the site grade (220 ft msl) - **Closed**



2.4 Hydrology (Con't)

2.4.13: Accidental Releases of Radionuclides In Ground Waters

■ OI 2.4-3

- Issue: Consider the potential change in flow direction within the Water Table aquifer and all feasible groundwater pathways.
- Resolution: The applicant provided additional field data; Analyses by the applicant and the NRC staff examined post-construction settings, and alternative pathways (four alternative pathways), considering an adequate number of combinations of release locations and feasible pathways - **Closed**.

■ OI 2.4-4

- Issue: Specify the nearest point along each potential pathway that may be accessible to the public and considered all alternative conceptual models for radionuclide transport analysis.
- Resolution: (1) The pathways into which these releases occur leave the site boundary before entering the Savannah River; The NRC staff completed an independent analysis of the different groundwater pathways and confirmed that releases to the accessible environment met the requirement of 10 CFR Part 20, Appendix B - **Closed**.
- COL Action Item 2.4-1: No chelating agents will be comingled with radioactive waste liquids and that such agents will not be used to mitigate an accidental release, or do the transport analysis with chelating agents.




Section 2.5: Geology, Seismology and Geotechnical Engineering

- Section 2.5.1 Site and Regional Geology
- Section 2.5.2 Vibratory Ground Motion
- Section 2.5.3 Surface Faulting
- Section 2.5.4 Stability of Subsurface Materials
- Section 2.5.5 Slope Stability




2.5.1 Basic Geologic & Seismic Information



Geology in the ESP Site Vicinity




2.5.1 Basic Geologic & Seismic Information



E-W Cross Section: Pen Branch Fault beneath VEGP site




2.5.2 – Vibratory Ground Motion



Example of EPRi Team Source Zones



2.5.2 Vibratory Ground Motion





Updated Charleston Seismic Source



Charleston Update

- Charleston update based on liquefaction features from historic and prehistoric earthquakes
- Liquefaction features occur in response to strong ground shaking





Geology and Seismology

- **3 Significant Open Items addressing:**
 - **Dames and Moore EPRI-SOG Team source model**
 - **Eastern Tennessee Seismic Source Zone model**
 - **Presence of Injected Sand Dikes in site area**



2.5.4 Stability of Subsurface Material and Foundations

- **Engineering Properties of Soils and Rocks**
- **Site Explorations**
- **Geophysical Surveys**
- **Liquefaction Potential**
- **Static Stability**



2.5.4 Stability of Subsurface Material and Foundations

- **12 Open Items addressing the adequacy of:**
 - **Field and Laboratory Testing of Subsurface Materials**
 - **Measurements of Shear Wave Velocity**
 - **Development of Soil Degradation and Damping Ratio Curves**
- **Permit Condition added to require removal of Upper Sand Layer**
- **12 COL Action Items - Resolved**



2.5.4 Stability of Subsurface Material and Foundations

Site Investigations	ESP	LWA
Borings	14	174
CPTs	10	21
Test Pits	0	8
Observation Wells	15	0
P-S Velocity Logs	5	6



SER Section 13.3: Emergency Planning

- First complete EP review under 10 CFR Part 52
- Complete & Integrated Emergency Plan (ESP)
 - Included FEMA review of State/local plans
- First-of-a-kind EP Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC) (30 ITAs/106 ACs)
- SER with Open Items (13 EP Open Items, 3 COL Action Items)
- Advanced SER (no EP Open Items, no EP COL Action Items, 7 EP Permit Conditions)



SER Section 13.3: Emergency Planning

SER Open Item 13.3-4 (EALs)

- NEI 07-01 EALs (AP1000 & ESBWR) (ongoing NRC endorsement review of NEI 07-01)
- AP1000 DCD EALs apply to Units 3 & 4
- Related Westinghouse amendments to AP1000 DCD (ongoing NRC AP1000 DCD review under docket 52-006)
- EAL resolution via 6 Permit Conditions (2 through 7)



SER Section 13.3: Emergency Planning

Permit Conditions:

- Emergency Action Levels (EALs)
 - 2 & 3 – NEI 07-01
 - 4 & 5 – AP1000 DCD Amendments (Units 3 & 4 TSC)
 - 6 & 7 – Full EAL set based on as-built plant, State/local agreed, & NRC approved (10 CFR Part 50, App. E.IV.B)
 - ITAAC 1.1.2 – EAL scheme consistent with RG 1.101
 - RG 1.101 is expected to endorse NEI-07-01
- Technical Support Center (TSC)
 - 8 – TSC location (AP1000 DCD, Tier 2* amendment)



SER Section 13.3: Emergency Planning

Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC):

- Planning Standard (10 CFR 50.47(b)(4))
 - A standard emergency classification & action level scheme, the bases of which include facility system and effluent parameters, . . .
- EP Program Element (NUREG-0654, evaluation criterion D.1)
 - An emergency classification & EAL scheme must be established . . . The specific instruments, parameters or equipment status shall be shown for establishing each emergency class, in the in-plant emergency procedures. The plan shall identify the parameter values and equipment status for each emergency class.
- Inspections, Tests, Analysis (ITA)
 - 1.1.2 – An analysis of the EAL technical bases will be performed to verify as-built, site-specific implementation of the EAL scheme.
- Acceptance Criteria (AC)
 - 1.1.2 – The EAL scheme is consistent with Regulatory Guide 1.101 [which is expected to endorse NEI 07-01 following staff review, including AP1000-related ITAAC]



Presentation to the ACRS Full Committee

Safety Review of the Vogtle Electric Generating Plant Limited Work Authorization Request

December 4, 2008



Vogtle LWA Request

Requested Activities:

- Placement of engineered backfill
- Retaining walls
- Lean concrete backfill
- Mudmats
- Waterproof membrane



2.5.4 Stability of Subsurface Materials and Foundations

LWA Key Issues

- Adequacy of borings at the site
- Geotechnical engineering properties of the subsurface materials, especially the Blue Bluff Marl and Lower Sand Stratum
- Backfill Specifications



2.5.4 Stability of Subsurface Materials and Foundation Interfaces

LWA Key Issues – Backfill ITAAC

Design Requirement	Inspections and Tests	Acceptance Criteria
Backfill material under Seismic Category 1 structures is installed to meet a minimum of 95 percent modified Proctor compaction.	Required testing will be performed during placement of the backfill materials.	A report exists that documents that the backfill material under Seismic Category 1 structures meets the minimum 95 percent modified Proctor compaction.
Backfill shear wave velocity is greater than or equal to 1,000 fps at the depth of the nuclear island foundation and below.	Field shear wave velocity measurements will be performed when backfill placement is at the elevation of the bottom of the Nuclear Island foundation and at finish grade.	A report exists and documents that the as-built backfill shear wave velocity at the nuclear island foundation depth and below is greater than or equal to 1,000 fps.



2.5.4 Stability of Subsurface Materials and Foundations

Section 2.5.4 Conclusions

- Adequacy of borings
 - Performed substantially more borings
- Geotechnical Engineering properties of subsurface materials
 - Significant additional site investigations provided sufficiently detailed information
- Backfill Specifications
 - Test Pad measurements of backfill properties
 - ITAAC to verify compaction density and shear wave velocity



Scope of Review for Chapter 3

SRP 3.7.1-Seismic Design Parameters

- Vibratory Ground Motion
- Critical Damping
- Supporting Media (pertaining to SSI modeling)

SRP 3.7.2- Seismic Systems Analysis

- Seismic Model Description
- Soil-Structure-Interaction Analysis

SRP 3.8.5-Foundations


- Foundation Stability
 - Sliding
 - Overturning



SER Section 3.7.1

Seismic Design Parameters

Comparison of Vogtle Horizontal GMRS and FIRS with AP1000 CSDRS



Source:
SSAR Appendix 2.5E, Figure 3-4



SER Section 3.7.1

Seismic Design Parameters

Technical Evaluation/Findings

Vibratory Ground Motion

- Approximate method was used for developing the FIRS. Review indicates that the method results in a conservative estimate of horizontal seismic demand.
- The FIRS defined as an outcrop motion in the free field satisfied the minimum PGA value of 0.10g (10 CFR Part 50, Appendix S)

Critical Damping

- The critical structural damping values used in SSI analysis were consistent with damping values provided in RG 1.61.

Supporting Media

- SSI modeling assumptions properly account for site characteristics such as depth of soil over bedrock, soil properties, soil layering characteristics and groundwater elevation.



SER Section 3.7.2

Seismic Systems Analysis

Technical Evaluation/Findings

Seismic Model

- The use of 2D SASSI models is acceptable for the evaluation of sliding stability and bearing pressure demands.

Soil-Structure-Interaction Analysis

- Staff compared the analysis results (e.g., ZPA values near the NI center-of-gravity) with the AP1000 DCD soft soil case and found them to be similar.
- Maximum seismic base shear forces are acceptable based on staff simplified independent calculations.



SER Section 3.8.5

Foundations

Summary of Application

- Test data of waterproofing membrane indicate a coefficient of friction of 0.7 between the membrane and the concrete mudmat.
- Test data indicate a coefficient of friction of 0.45 for soil immediately below mudmat.
- Soil test data indicate a bearing capacity of 42 ksf.



SER Section 3.8.5

Foundations

Technical Evaluation/Findings

NI Structure Stability Analysis

- Staff reviewed the maximum horizontal seismic forces and maximum friction forces below the basemat.

Maximum NI Seismic Forces

Reaction	Vogtle Lower Bound	Vogtle Best Estimate	Vogtle Upper Bound
Seismic Shear NS	78.3 E3 kips	82.5 E3 kips	89.0 E3 kips
Seismic Shear EW	88.9 E3 kips	89.8 E3 kips	95.8 E3 kips
Friction Force	117.3 E3 kips	116.7 E3 kips	116.4 E3 kips

- The NI structure will not slide during the SSE, because the frictional force is greater than the inertial force.



SER Section 3.8.5

Foundations

Technical Evaluation/Findings (Continued)

Bearing Capacity

- The maximum dynamic bearing pressure on soils for the NI, radwaste, annex, and turbine buildings are 17.95 ksf, 1.68 ksf, 7.20 ksf, and 2.54 ksf, respectively, during the SSE.
- The minimum factor of safety with respect to a failure of the dynamic soil bearing capacity during the SSE is 2.34 (42 ksf divided by 17.95).



Summary Findings

SRP Section 3.7.1 Seismic Design Parameters

- Adequately developed seismic design parameters.
- Met the applicable regulatory requirements.

SRP Section 3.7.2 Seismic Systems Analysis

- Adequately performed site-specific 2D SSI analysis for the purpose of determining the maximum seismic demands for use in the NI structure stability and maximum dynamic soil bearing evaluations.
- Staff's evaluation of in-structure response will be done as part of the SCOL review.
- Met the applicable regulatory requirements.

SRP Section 3.8.5 Foundations

- Demonstrated that the mudmat and the waterproofing membrane are adequate and that the NI foundation is stable during an SSE.
- Met the applicable regulatory requirements.




Advanced SER/LWA Conclusions

- The VEGP ESP application meets the applicable standards and requirements of the Act and the Commission's regulations.
- Site Characteristics, Design Parameters, and Terms and Conditions proposed to be included in the Permit meet the applicable requirements of Part 52.
- There is reasonable assurance that the site is in conformity with the provisions of the Act, and the Commission's regulations.
- The proposed ITAAC are necessary and sufficient, within the scope of the ESP, to provide reasonable assurance that the facility has been constructed and will be operated in conformity with the emergency plans, the provisions of the Act, and the Commission's regulations.
- Issuance of the permit will not be inimical to the common defense and security or to the health and safety of the public




BACKUP SLIDES for ESP


2.5.2 Vibratory Ground Motion




Source: Amick et al. (1990)





Source: Talwani and Schaeffer (2001)



Source: Talwani and Schaeffer (2001)




Source: modified after Talwani and Schaeffer (2001)



Distribution of Charleston Source Paleoliquefaction Features



2.5.2 Vibratory Ground Motion





Results of Staff's ETSZ Sensitivity Study

2.5.2 Vibratory Ground Motion

■ Liquefaction


- Liquefaction features occur in response to strong ground shaking
- Liquefaction susceptibility is a function of site characteristics
- Liquefaction features commonly occur in the form of sand blows





2.5.2 Vibratory Ground Motion


10-Hz Total Mean Hazard Curve





2.5.4 Stability of Subsurface Material and Foundations


Shear Wave Velocity Profile





2.5.4 Stability of Subsurface Material and Foundations


Shear Modulus Reduction Curve





2.5.4 Stability of Subsurface Material and Foundations

Damping Ratio Curves





2.5.2 Vibratory Ground Motion

- **Charleston Liquefaction Features**
 - Abundant liquefaction features from historic and prehistoric earthquakes were mapped for ~130mi. NE-SW along the South Carolina coast and >65mi. inland from coast
 - Paleoliquefaction features formed during prehistoric earthquakes



2.5.2 Vibratory Ground Motion




Illustrations of historic 1886 liquefaction features from the Charleston Area




2.5.2 Vibratory Ground Motion

- **Charleston Paleoliquefaction Features**
 - Paleoliquefaction features, documented since the 1989 EPRI study, contributed to the update of the Charleston source zone
 - Liquefaction features represent 5 similar magnitude earthquakes (in addition to 1886) during the past ~5000 years
 - Estimated repeat times for large earthquakes in the Charleston area:
 - 500-600 years, based on a complete 2,000 yr history
 - 900-1000 yrs, based on a complete 5,000 yr history



Structure Contour Map, Surface of Unit F – Trench Plan View



Mesh Perspective View
Vertical Exaggeration 2X


Explanation

- + Surveyed Elevation
- 0 Elevation Extrapolated From Bedding Attitude
- Contour Interval 1 Foot

Modified after Figure 5 (Bechtel, 1984)

BACKUP SLIDES

DETAILED VIEW OF SAND DIKE COMPLEX



Modified after Figure 3 (Bechtel, 1984)



2.5.4 Stability of Subsurface Materials and Foundations

- **Insufficient Laboratory Testing (Open Item 2.5-11)**
 - Issue: Conduct sufficient field & laboratory tests to reliably determine subsurface soil static & dynamic properties at the ESP site
 - Resolution: In support of the LWA request, the applicant performed additional field and laboratory investigations which were used to determine the static and dynamic properties of the subsurface materials



2.5.4 Stability of Subsurface Materials and Foundations

- **Blue Bluff Marl Load-bearing Properties (Open Item 2.5-12)**
 - Issue: Provide sufficient data to derive reliable site-specific engineering parameters for the Blue Bluff Marl
 - Resolution: The applicant performed SPT and split-spoon sampling in almost all ESP borings and conducted additional laboratory tests such as grain size distribution, Atterberg Limits, and carbonate content



2.5.4 Stability of Subsurface Materials and Foundations

- **Undrained Shear Strength (Open Item 2.5-13)**
 - Issue: Provide sufficient sampling and testing results to reliably derive the undrained shear strength and other related engineering parameters
 - Resolution: The applicant revised the SSAR using the additional field and laboratory investigations to provide the preconsolidation pressure calculations and overconsolidation ratios



2.5.4 Stability of Subsurface Materials and Foundations

- **Angles of Friction (Open Item 2.5-14)**
 - Issue: Provide reliable effective angles of internal friction for the subsurface soils
 - Resolution: The applicant revised the SSAR to include a description of the empirical correlation of average effective angles of internal friction which were used.



2.5.4 Stability of Subsurface Materials and Foundations

- **Blue Bluff Marl Behavior (Open Item 2.5-15)**
 - Issue: Provide information to demonstrate that the Blue Bluff Marl will behave as a hard clay or soft rock material
 - Resolution: Additional borings in support of the LWA request were used to demonstrate the behavior of the BBM



2.5.4 Stability of Subsurface Materials and Foundations

- **Elastic Modulus (Open Item 2.5-16)**
 - Issue: Provide sufficient site-specific data to justify the determination of the design parameter elastic modulus “E” for the Upper and Lower Sand Strata
 - Resolution: The applicant used representative data from the SPTs performed in support of the LWA request to determine E



2.5.4 Stability of Subsurface Materials and Foundations

- **Unit Weight Values (Open Item 2.5-17)**
 - Issue: Develop sufficient data (vs. values from previous investigations) to calculate the unit weight values for the ESP subsurface soils
 - Resolution: Additional data were included in support of the LWA request and were used to calculate the unit weight of the subsurface materials



2.5.4 Stability of Subsurface Materials and Foundations

- **SSAR Degradation Curve Revision (Open Item 2.5-20)**
 - Issue: Revise SSAR Sections 2.5.2.5.1.5, 2.5.4.7.2.1, and 2.5.4.7.2.2, along with associated tables and figures, to show the degradation curves only at a $\leq 1\%$ cyclic shear strain
 - Resolution: The SSAR was revised accordingly.



2.5.4 Stability of Subsurface Materials and Foundations

- **Liquefaction Potential of Blue Bluff Marl (Open Item 2.5-21)**
 - Issue: Provide sufficient ESP soil property data to confirm that the Blue Bluff Marl is non-liquefiable
 - Resolution: Additional borings completed in support of the LWA were used to confirm the negligible liquefaction potential of the BBM



2.5.4 Stability of Subsurface Materials and Foundations

- **Bearing Capacity (Open Item 2.5-22)**
 - Issue: Provide appropriate bearing capacity estimates
 - Resolution: Later revisions to the SSAR in support of the LWA request included the bearing capacity calculations and settlement estimates



2.5.4 Stability of Subsurface Materials and Foundations

- **Previous COL Action items**
 - 2.5-1 A COL or CP applicant will need to confirm the absence of soft materials in the load bearing layers.
 - 2.5-2 A COL or CP applicant will need to confirm the locations of the soft zones and evaluate the potential impact of the soft zones on the foundation and structures.
 - 2.5-3 A COL or CP applicant will need to provide chemical test results on the backfill.



2.5.4 Stability of Subsurface Materials and Foundations

- **Previous COL Action items**
 - 2.5-4 A COL or CP applicant will need to submit plot plans and profiles of all seismic Category I facilities for comparison with the subsurface profile and material properties.
 - 2.5-5 A COL or CP applicant will need to provide detailed excavation and backfill plans during the COL stage.
 - 2.5-6 A COL or CP applicant will need to provide sufficient information to show the backfills meet the minimum shear wave requirement.



2.5.4 Stability of Subsurface Materials and Foundations

- **Previous COL Action items**
 - 2.5-7 A COL or CP applicant will need to submit ground water condition evaluations and a detailed dewatering plan during the COL stage.
 - 2.5-8 A COL or CP applicant will need to demonstrate quantitatively whether the observed large settlement that occurred at the existing VEGP units will occur at the ESP site and have no impact on the new units.
 - 2.5-9 A COL or CP applicant will need to provide more details regarding the bearing capacity during the COL stage.



2.5.4 Stability of Subsurface Materials and Foundations

- **Previous COL Action items**
 - 2.5-10 A COL or CP applicant will need to describe the design criteria and design methods, including the factor of safety for slope stability at the COL stage.
 - 2.5-11 A COL or CP applicant will need to provide information regarding ground improvement after removal of Upper Sand Stratum for the ESP site.

Key Review Areas

Chapter 15 – Radiological Consequences of Design Basis Accidents

- Permit condition 9:
 - The permit will include the time-dependent isotropic release (source term) for each DBA
 - COL applicant referring to certified design only required to demonstrate site-specific atmospheric dispersion factor values less than used in DCD to show compliance with Part 100, 10 CFR 52.79 and GDC-19
 - Permit condition to not require holder of Vogtle ESP do anything more than any other COL applicant referring to a certified design. If ESP holder does not refer to a certified design, COLA would demonstrate that plant source term is bounded by the source term in ESP

Key Review Areas


- Applicant used AP1000, DCD Rev. 15
 - Calculated site-specific short term atmospheric dispersion factors (χ/Qs)
 - Ratio of site-specific to design reference χ/Qs applied to DCD calculated DBA dose to give estimate of site-specific DBA dose for each DBA in AP1000 DCD
 - Since each site-specific χ/Q was less than comparable design reference χ/Q , then site-specific DBA doses are less than AP1000 DCD DBA doses and therefore meet regulatory criteria
 - Can confirm by taking AP1000, Rev. 15 source term release rates for each DBA and calculating site-specific DBA dose using site-specific χ/Qs



Backup Slides (3.7 and 3.8)



Nuclear Island Supporting Media




Source:
SSAR Appendix 2.5E, Figure 5.0-2



SER Section 3.7.1

Seismic Design Parameters


Comparison of Vogtle Vertical GMRS and FIRS with AP1000 CSDRS



Source:
SSAR Appendix 2.5E, Figure 3-4




SSI Model




Source:
SSAR Appendix 2.5E, Figure 4.1-2

Source:
SSAR Appendix 2.5E, Figure 4.1-1





Lateral Extent of Backfill






Source:
SSAR Appendix 2.5E, Figures A-1



2D Model Results

Reactor Vessel Support; EL 99 ft, Node 4041






Source:
SSAR Appendix 2.5E, Figures 5.1-1,2,3



2D Model Results

Shield Building Roof; EL 327 ft, Node 4310



Source:
SSAR Appendix 2.5E, Figures 5.1-10,11,12



Tables

Nodes	AP 1000 Generic Plant Elevation (ft)	Description
4041	99.00	NI at Reactor Vessel Support Elevation
4061	116.5	Auxiliary Shield Building at Control Room Floor
4120	179.56	ASB Auxiliary Building Roof Area
4310	327.41	ASB Shield Building Roof Area
4412	224	Steel Containment Vessel near Polar Crane
4535	134.25	Containment Internal Structure at Operating Deck


Source:
SSAR Appendix 2.5E, Table 5.1-1

Tank and Seismic Response Direction	Frequency Hertz
Fuel Area	
Fuel Pool, EW	0.39
Fuel Pool, NS	0.26
Fuel Transfer Canal, EW	0.68
Fuel Transfer Canal, NS	0.26
Cask Loading Pit, EW	0.39
Cask Loading Pit, NS	0.37
Cask Washdown Pit, EW	0.39
Cask Washdown Pit, NS	0.36
IRWST Tank	
Steel Wall, EW	0.41
Steel Wall, NS	0.25
NE Wall, EW	0.36
North Wall Pressurizer, NS	0.29
West Wall, EW	0.29
South Wall, NS	0.29
<u>Shielding Building</u>	
<u>PCCS Tank</u>	<u>0.136</u>

Source:
SSAR Appendix 2.5E, Table 5.1-2



AP1000 DCD




Source:
TR-3, Figure 4.4.1-1



AP1000 DCD


2D SASSI FRS Comparison Node 41 Y





AP1000 DCD


2D SASSI FRS Comparison Node 310 Y



Source:
TR-3, Figure D-6



COL Power Block – Cooling Tower Boring Locations





Southern Nuclear
Vogtle 3 & 4 ACRS Meeting
December 3-4, 2008

Early Site Permit

Jim Davis
ESP Project Engineer
Southern Nuclear

Agenda

- Introduction
- Schedule
- Early Site Permit (ESP) Overview
- Limited Work Authorization (LWA) Overview



Introduction

- Southern Nuclear is pursuing an Early Site Permit (ESP) in accordance with 10 CFR 52 Subpart A-Early Site Permits
- In addition Southern Nuclear is seeking a Limited Work Authorization (LWA) in accordance with 10 CFR 50.10


Introduction

- An ESP grants approval of a site for one or more nuclear power facilities separate from the filing of an application for a construction permit or combined license for the facility
- The requested LWA will allow a limited scope of safety-related construction activities to proceed at applicants risk as long as a site redress plan is included.

VEGP ESP Level of Detail


Example	Other ESPs	VEGP ESP
Reactor Type Power Output	Options Listed	Two Westinghouse AP1000's at 1117 MWe Each
Plant Layout Cooling Water Design Intake Design	General Information Provided	Detailed Conceptual Design and Layouts Provided
Water Consumption And Discharge Flow	Envelope Approach	Plant-Specific Numbers Provided
Normal Effluents and Accident Doses	Envelope Approach	Plant-Specific Numbers Provided
Emergency Plan	Major Features	Complete & Integrated Plan
Limited Work Authorization	None	Requested for specific activities


Vogtle 3&4 Schedule




Vogtle Site Location

The, 3,169-acre existing 2 Unit site is located on a Coastal Plain bluff on the southwest side of the Savannah River in eastern Burke County Georgia. The site is directly across the river from the Department of Energy's Savannah River Site (Barnwell County, South Carolina). It is about 150 river miles from the mouth of the Savannah River and approximately 26 miles southeast of Augusta, Georgia.






	Plant Site		Railroads
	Interstates		Urban Areas
	Highways		Counties
	Major Roads		Major Waters





Early Site Permit (ESP) Contents







Part 2 Site Safety Analysis Report

Chapter numbering follows FSAR format and addressed selected chapters:

- 1 Introduction and General Description
- 2 Site Characteristics
 - 2.1 Geography and Demography
 - 2.2 Potential Hazards
 - 2.3 Meteorology
 - 2.4 Hydrology
 - 2.5 Geology and Seismic
- 3 Design of Structures, Components, Equipment, & Systems
 - 3.5.1.6 Aircraft Hazards
 - 3.8 Design of Category I Structures
- 11 Radioactive Waste Management
 - 11.2.3 Liquid Radioactive Releases
 - 11.3.3 Gaseous Radioactive Releases
- 13 Conduct of Operations
 - 13.3 Emergency Planning
 - 13.6 Industrial Security
 - 13.7 Fitness for Duty
- 15 Accident Analyses
- 17 Quality Assurance

Vogle Site Layout





Site Soil/Rock Profile with Backfill

ESP Requests for Additional Information (RAIs)

Section	Subject	RAIs
2.1	Geography and Demography	12
2.2	Potential Hazards	18
2.3	Meteorology	16
2.4	Hydrology	10
2.5	Geology and Seismic	64
3.5.1.6	Aircraft Hazards	1
11	Liquid and Gaseous Releases	16
13	Emergency Planning	48
15	Accident Analysis	1
17	Quality Assurance	3

RAIs

14

189

SOUTHERN
COMPANY



SER Open Items

Section	Subject	OIs
2.3	Meteorology	1
2.4	Hydrology	4
2.5	Geology and Seismic	22
13	Emergency Planning	13
	Total	<hr/> 40

LWA RAIs

The addition of the LWA request resulted in an additional 26 RAIs for the following subject areas:

- Site Investigation Information
- Engineering properties of subsurface materials
- Backfill requirements and engineering criteria

LWA and Preconstruction Overview

- Overview
- Pre-Construction Activities
- LWA Construction Activities
- LWA Schedule

Application Submittal - LWA

- Initial LWA-1 Request – ESP Revision 0, August 2006
- LWA-2 was included in ESP Revision 2, Supplement 1, August 2007
- Updated LWA Request to new rule 10 CFR 50.10 - ESP Revision 3, November 2007

Preconstruction Activities

Construction Does Not Include:

- Changes for temporary use of the land for public recreational purposes
- Site exploration
- Preparation of a site for construction of a facility
 - Clearing of the site
 - Grading
 - installation of drainage
 - Erosion and other environmental mitigation measures
 - Construction of temporary roads and borrow areas
- Erection of fences and other access control measures
- Excavation

Preconstruction Activities


Construction Does Not Include (Continued):

- Erection of support buildings for use in connection with the construction of the facility (Construction equipment storage sheds, Warehouse and shop facilities, Utilities, Concrete mixing plants, Docking and unloading facilities, Office buildings)
- Building of service facilities
- Paved roads
- Parking lots
- Railroad spurs
- Exterior utility and lighting systems
- Potable water systems
- Sanitary sewerage treatment facilities
- Transmission lines;
- Procurement or fabrication of components or portions of the proposed facility occurring at other than the final, in-place location at the facility

LWA Construction Activities

- The SNC LWA request is for the full extent of activities allowed by regulation and the site redress plan encompasses all such activities. Examples of VEGP LWA activities that SNC has identified include the following:
 - Engineered Backfill
 - Retaining Walls (mechanically stabilized earth walls)
 - Lean concrete backfill
 - Mud Mats
 - Waterproof membrane
 - FFD
 - QA
 - PI&R

Vogtle Site 2018 Conceptual Layout



Augusta Newsprint
Goshen

River Intake Road

Intake Structure

Cemetery

Intake Structure

Barge Slip

Unit 1-2 Discharge
Unit 3-4 Discharge

Savannah River

230kV Substation

Mallard Pond

Haul Road

Scherer Transmission Line

McIntosh Reroute

500kV Switchyard

ISFSI

Unit 4

Unit 3

U2 U1

Common Support Buildings

Construction Entrance

PA Expansion

PAP

Warehouse

Construction Laydown Area

Cooling Towers


Security Pavilion

Plant Wilson (CTs)

Main Plant


McIntosh

Preconstruction Activities - Dewatering and Excavation



12/11/2006

LWA Activities - Placement of Engineered Fill for Nuclear Island



Upper Sands

Utley Limestone

Engineered Fill


Blue Bluff Marl (Bearing Layer)

Lower Sands


~86'

~63'


~900'



VOGTLE UNITS 3 & 4
POWERBLOCK EXCAVATION PLAN
FIGURE 1



SECTION A



SECTION B


VOGTLE UNITS 3 & 4
POWERBLOCK EXCAVATION SECTIONS
FIGURE 2

MSE Wall Test Section - July 2008



12/17/2008

Example MSE Wall near Atlanta Airport



Waterproof Membrane

stirling lloyd
THE TECHNOLOGY OF PROTECTION




Above. Application of the 1st coat of Integritank (yellow) on to the geotextile. The walls are sprayed first, followed by the slab, particularly at smaller sites, to ensure the material is cured at the applicators' entrance and exit points.

Installation

Below. Completion of 1st coat of Integritank.



MSE Wall for Nuclear Island
In Place Prior to COL



Nuclear Island Foundation at Receipt of COL

Questions



ELECTRIC POWER
RESEARCH INSTITUTE

Industry Position Overview

On the Technical Basis for Revision of Embrittlement Criteria in 10CFR50.46

ACRS Committee Meeting
December 4, 2008
Rockville, MD

Industry Presentation Overview

Industry Collaboration with NRC

- The industry is supportive of NRC's overall objective with regards to revision of 10 CFR 50.46(b) to a performance based rule
- The Industry's Fuel Reliability Program (FRP) has been actively participating in the LOCA tests at ANL



Industry Position Overview

- Safety significance
- Industry position on hydrogen as a surrogate for irradiation
- Data gaps
- Estimate of implementation cost
- Summary

Safety Significance

- Evaluation indicates no significant safety concerns with respect to current design basis (based on typical Zircaloy-4 H pickup)


Typical 3-Loop PWR
Achievable Pin Power vs. Burnup



Industry Position on Hydrogen Pre-Charging

Pre-hydridding

- Zircaloy-4, ZIRLO and M5 PQD ductile-to-brittle transition ECR



- Sample from multiple vendors fit on the same trend line

Pre-hydridding appears to be a good surrogate for irradiation

Data Gaps

- More post-quench ductility data needed at lower temperatures with hydrogen effects
 - Industry is conducting complementary LOCA oxidation and PQD testing
- Requirement in RIL-0801 to use 2-sided oxidation away from the ballooned region is not supported by ANL data
 - Industry is planning to conduct tests to investigate potential influence of internal oxygen sources
- Periodic testing on breakaway oxidation is driven by observed short E110 breakaway time
 - Industry believes QA programs will be sufficient to keep process in control

Implications of Proposed Change - Cost Estimate

- Current LOCA evaluation models will likely require re-licensing
 - All operating reactors will need to demonstrate compliance
 - Expanded hot-cell campaigns to license corrosion-hydrogen correlations
- Costs to vendors and licensees to comply with anticipated new rule is estimated at several hundred million dollars
- Implementation will require multiple vendor/licensee/NRC interactions
 - Phased implementation a must if rulemaking proceeds

Summary


- Evaluation indicates no significant safety concerns with respect to current design basis, no need to rush through rule making
- Industry supports flexibility in rule
 - Use lower level documents for details
- Industry supports qualification testing, but not rule-mandated periodic testing
- Pre-hydridding appears to be a good surrogate for irradiation

Together...Shaping the Future of Electricity

Industry Position Overview


Incomplete database

- NRC-RES efforts focuses only on testing at 1200°C but high burnup fuel is not capable reaching this temperature




A bounding approach will have a significant negative impact on the industry with little or no safety benefit

Industry Test Plans – LOCA Oxidation & POD



Preliminary evaluation example


- Effect of hydrogen on oxygen content – actual ANL samples



- Hydrogen appears to enhance oxygen diffusion
- Hydrogen does not appear to increase oxygen solubility
- Other preliminary results indicate small increases in oxygen contents with increasing oxidation temperature

Industry Test Plans

- Oxygen content as a function of oxidation temperature




Integral LOCA Experiments on High-Burnup Limerick Fuel Do Not Show Significant ID Oxygen Pickup at 57 GWd/MTU Burnup

NUREG Interpretation

(A): This inner-surface region does not have an alpha layer even though in close proximity to fuel material. More typical of what is observed for most of the inner surface at this axial location.

(B): Evidence of some local inner surface oxygen-stabilized alpha



Limerick fuel at 57-60 GWd/MTu

From Figure 175 : for ICL#2 sample at 50 mm above the burst midplane


Industry Test Plans – LOCA Oxidation & PQD

Test Apparatus

- Electric resistance furnace
 - Center core quartz tube
 - Heat furnace up to set temperature and then insert samples
 - Initial inert gas atmosphere is possible
 - Excellent temperature repeatability
 - Cooling scenarios
 - Slow cool – turn off power and let furnace cool
 - Intermediate cool – remove quartz tube from furnace
 - Fast cool - remove quartz tube from furnace and forced cooling with fan
 - Quench – drop sample into a water tank
- Sample evaluation
 - RCT, Metallography, WDX and EDS with oxygen standards

Industry Test Plans – LOCA Oxidation & PQD

- Data indicates ECR accumulated at lower temperatures not as detrimental to ductility for Zircaloy-4
- Attempted to demonstrate ECR is not reduced to zero at elevated hydrogen contents
- Test details
 - Entire range of relevant oxidation temperatures and hydrogen content
 - Full characterization of samples in addition to RCT
- Generate sufficient test data to propose alternative PQD criteria not tied to 1200°C
- Determine feasibility of developing an embrittlement model



Industry Test Plans – ID Oxidation

ID Oxidation Test Matrix

- Sealed BWR cladding capsules with pellets
 - No or little contact pressure
 - Fresh/pre-oxidized cladding
 - Standard pellets, capsule pressure equal to atmosphere at temperature
 - Contact pressure
 - Fresh/pre-oxidized cladding
 - Oversized pellets, capsule evacuated
- Sealed BWR cladding capsule without pellet
 - Evaluate pre-existing ID oxide effect
 - Determine extent of ID oxygen stabilized alpha formation
 - Evaluate clad mechanical property at LOCA temperatures
 - Needed to evaluate contact pressure



Strategy for Revising 50.46(b) Fuel Performance Criteria

ACRS Full Committee Meeting
December 4, 2008

Paul M. Clifford
Division of Safety Systems
Nuclear Reactor Regulation

Rulemaking Objectives

- Following Commission directive, develop a performance-based rule which enables licensees to use advanced cladding materials without needing an exemption.
 - Replace prescriptive criteria with performance-based regulatory requirements.
 - Expand applicability beyond “zircaloy or ZIRLO”.
- Capture results of High Burnup LOCA Research Program.
 - Research identified new embrittlement mechanisms which necessitate rule changes.

Applicability of Rule

Current Regulation:

- Paragraph (a)(1)(i) limits applicability to “zircaloy or ZIRLO”.

Research Finding:

- Empirical database includes wide range of zirconium alloys.

Plant Safety:

- No impact.

Strategy for Revising Regulation:

- Replace “zircaloy or ZIRLO” with less specific terminology (e.g., approved zirconium-alloy).
- Applicability to new alloys will need to be demonstrated by testing.

Peak Cladding Temperature

Current Regulation:

- Paragraph (b)(1) limits PCT to 2200°F.

Research Finding:

- Post quench ductility (PQD) decreases dramatically in samples oxidized beyond 2200°F.
- Confirms current regulatory criterion.

Plant Safety:

- No impact.

Strategy for Revising Regulation:

- No change.

Local Oxidation

Current Regulation:

- Paragraph (b)(2) limits local oxidation to 17% ECR.


Research Finding:

- New cladding embrittlement mechanism identified.
 - PQD sensitive to pre-transient cladding hydrogen concentration.
- A constant 17% ECR limit does not always ensure PQD.
- Information Notice 98-29 adjustment (subtract initial oxide layer from 17% ECR limit) may not always ensure PQD.

Local Oxidation (cont.)

Plant Safety:


- Modern alloys exhibit unirradiated brittle transition at or above 17% ECR.



Local Oxidation (cont.)

Plant Safety:


- Highest power fuel rods challenge 2200°F and 17% ECR limits.
- Corrosion build-up coincident with U^{235} depletion (diminishing rod power).
- Lower power fuel rods experience more benign transient.



Strategy for Revising Regulation:

Alternative Regulations:

1. Generic PQD criteria specified within rule.



2. Optional test program for defining alloy-specific or temperature-specific PQD criteria.

ID Oxygen Diffusion

Current Regulation:

- None.

Research Finding:

- Oxygen from fuel bonding layer (on cladding ID) diffuses into the base metal and exacerbates cladding embrittlement.

Plant Safety:

- Current methods require double sided oxidation within the balloon region.
- Higher burnup fuel rods operating at lower power will experience more benign transient.

Strategy for Revising Regulation:

- New requirement within rule.

Breakaway Oxidation

Current Regulation:

- None.

Research Finding:

- New cladding embrittlement mechanism identified.
 - Protective tetragonal oxide transforms to monoclinic structure.
 - Hydrogen uptake promotes cladding embrittlement.
- Timing of transformation sensitive to manufacturing process.

Plant Safety:

- Measured breakaway time for domestic alloys exceed 3000 seconds.
- SBLOCA analysis coupled with reasonable operator actions show that the duration at elevated temperatures remains below breakaway time.

Breakaway Oxidation (cont)

Strategy for Revising Regulation:

- New performance requirement within rule.
 - Required testing to establish measured break-away time.
- Required periodic testing.

Regulatory Challenge

- Developing a performance-based rule which meets the objectives of the rulemaking plan (e.g., optional testing program) while satisfying legal requirements (e.g., specific enforceable requirements).
 - Performance-based rule more difficult to script.
 - Specifying optional test protocols within rule versus regulatory guidance document.

Optional Test Program

- Regulations within 50.46(b)(2) specify general requirements for optional testing:
 - Criterion for the ductility test would be 1% plastic strain using ring-compression tests.
 - Criterion for the breakaway oxidation test would be 200 wppm hydrogen uptake.
- Acceptable experimental protocols for establishing cladding ductility criteria and breakaway oxidation limits would be provided within a comprehensive test procedure.




Implementing Alternative PQD Criteria


Implementing PQD Curve

(initial hydrogen content converted to burnup)

Post-Quench Ductility Limit



Added Flexibility



Added Flexibility (cont.)





Path Forward

Ongoing Research Activities

1. Development and validation of a comprehensive, performance-based test procedure.
2. Additional PQD tests at intermediate hydrogen levels.
3. Additional breakaway tests to investigate whether the timing of breakaway oxidation is sensitive to variations in temperature profile or thermal cycling.



Advance Notice of Proposed Rulemaking

- ANPR process designed to enhance public participation during significant rulemaking campaigns. Benefits include:
 - Public response to rule concept and/or staff requests for additional information factored into the rulemaking proceeding and language of proposed rule language
 - Facilitates formal stakeholder interaction on the rulemaking while further research is acquired.

Staff White Paper Concerning Containment Overpressure Credits: Risk Considerations

Marty Stutzke, RES/DRA

ACRS Presentation
December 4, 2008

Staff Position

- The staff will continue to consider risk insights in its reviews of license amendment request (LARs) that contain requests for containment overpressure (COP) credits in accordance with its existing processes, which implement Commission-approved guidance.

Use of Risk Insights to Support Regulatory Decisionmaking

- NRR Office Instruction LIC-101 describes the staff's process for reviewing LARs.
- Risk-informed LARs
 - Guidance: RG 1.174 and SRP Section 19.2.
 - Risk insights provide one of the primary justifications for acceptability of the LAR.
 - All five key principles of risk-informed decisionmaking stated in RG 1.174 should be met.
 - Licensees voluntarily submit risk informed LARs.
- Non-risk-informed LARs
 - Guidance: SRP Section 19.2, Appendix D.
 - Risk insights may be used to determine whether or not a proposed plant change rebuts the presumption of adequate protection despite the fact that the proposed change meets currently specified regulatory requirements.
 - If one or more of the five key principles are not met, then a more complete assessment (deterministic and/or probabilistic) should be performed.
 - The fact that one or more of the five key principles is not met does not automatically imply a lack of adequate protection (i.e., the five key principles do not define “adequate protection”).
 - Staff assumes the burden of demonstrating that the presumption of adequate protection is not supported.


Invoking SRP Section 19.2, Appendix D

- SRP Section 19.2, Appendix D is invoked when the staff believes that a non-risk-informed LAR:
 - Significantly changes allowed outage time, initiator probability, mitigation probability, recovery time, or operator action,
 - Significantly changes functional requirements or redundancy,
 - Significantly affects the basis for successful safety function, or
 - Creates “special circumstances:”
 - Substantially increases the likelihood or consequences of accidents that are risk significant, but beyond the design and licensing basis of the plant,
 - Degrades multiple levels of defense or Reactor Oversight Process cornerstones,
 - Significantly reduces availability/reliability of systems, structures and components that are risk significant, but not required by regulations, or
 - Synergistic or cumulative effects that significantly impact risk.

Using SRP Section 19.2, Appendix D

- The numerical risk acceptance guidelines and safety principles in RG 1.174 are intended to provide a basis for finding that there is reasonable assurance of adequate protection.
 - The guidelines and safety principles serve as a point of reference for gauging risk impact, but are not legally binding requirements.
 - SRP Section 19.2, Appendix D emphasizes the need to differentiate between the concept of adequate protection and the numerical risk acceptance guidelines.
- The staff must notify the Commission whenever “special circumstances” are identified.
- The decision to reject a non-risk-informed LAR on the basis of risk will be made by the Director, NRR.

Five Key Principles of Risk-Informed Decisionmaking



Application of the Five Key Principles to COP Credits

- Principle #1: Compliance with regulation
 - There is no regulation that prohibits use of a COP credit.
- Principle #2: Defense-in-depth
 - RG 1.174 focuses on understanding how a proposed change affects the physical barriers that provide defense-in-depth.
 - A COP credit reduces defense-in-depth because it introduces a dependency between the containment and fuel cladding barriers.
 - SRP Section 19.2 also discusses the need to consider programmatic elements that provide defense-in-depth.
 - In and of itself, a COP credit does not eliminate or alter any programmatic element (i.e., containment leakage testing) that provides defense-in-depth.
 - Licensees and staff should consider possible synergistic effects that may arise when various programmatic elements are modified (perhaps through a series of LARs).

Application of the Five Key Principles to COP Credits (Con't.)

- Principle #3: Safety margins
 - Discussed elsewhere in the staff's presentation.
- Principle #4: Small changes in risk
 - Current estimates indicate that the change in internal events CDF due to a COP credit is less than $10^{-6}/y$.
 - The staff's white paper describes how PRA elements should be modified to reflect a COP credit.
 - RG 1.174 allows the use of qualitative risk evaluations (e.g., seismic margins analysis).
 - The final acceptability of a proposed COP credit is based on consideration of current regulatory requirements and adherence to the five key principles, and not solely on a comparison of quantitative PRA results to the numerical risk acceptance guidelines.
- Principle #5: Performance measurement
 - The staff's white paper lists many performance measurement strategies relevant to COP credits.

Backup Viewgraphs

Acronyms and Initialisms

COP	containment overpressure
LAR	license amendment request
NRR	The Office of Nuclear Reactor Regulation
RG	Regulatory Guide
SRP	Standard Review Plan (NUREG-0800)

The Evolution of SRP Section 19.2, Appendix D

- 8/25/1997, COMSAJ-97-008: Discussion of compliance and safety; staff has the responsibility to consider risk during review of LARs.
- 4/12/1998: Union Electric submitted LAR to electrosleeve SG tubes at Calloway (not risk-informed); staff concerned about behavior of electrosleeve material during severe accidents.
- 12/23/1998, SECY-98-300: Options to risk-inform 10 CFR 50; staff identified policy issue to get clarification of its authority to apply risk-informed decisionmaking in areas beyond those associated with licensee-initiated risk-informed LARs.
- 5/24/1999: Staff approved Calloway electrosleeve LAR.
- 6/8/1999, SRM on SECY-98-300: Commission agreed that additional guidance was needed.
- 10/12/1999, SECY-99-246: Transmitted interim guidance on applying risk-informed decisionmaking in LARs.
- 1/5/2000, SRM on SECY-99-246: Commission approved interim guidance.
- 3/28/2000, RIS 00-007: Advised licensees about interim guidance on the use of risk information by the staff during its reviews of LARs.

The Evolution of SRP Section 19.2, Appendix D (Con't.)

- 4/10/2000: Draft appendix to SRP Chapter 19 published in the Federal Register.
- 5/11/2000: ACRS meeting on draft appendix to SRP Chapter 19.
- 5/16/2000: Public workshop on draft appendix to SRP Chapter 19.
- 5/30/2000: CRGR meeting on draft appendix to SRP Chapter 19.
- 9/26/2000: Staff forwarded the final appendix to SRP Chapter 19 to the Commission.
- 11/12/2000, COMSECY-00-0038: Commission approved final appendix to SRP, Chapter 19; directed the staff to notify the Commission of the first few LARs that create special circumstances.
- 1/18/2001, RIS 01-002: Advised licensees of final guidance on the use of risk information by the staff during its reviews of LARs.
- June 2007: Former SRP Chapter 19 redesignated as SRP Section 19.2; Appendix D retained without modification.

Use of Containment Accident Pressure in Determining Available NPSH of ECCS and Containment Heat Removal Pumps

R. Lobel, NRR/DSS
M. Stutzke, RES/DRA

December 4, 2008

PURPOSE

- To discuss the NRC staff position on the use of containment accident pressure in determining the available NPSH of ECCS and containment heat removal pumps
- Staff position and discussion provided to ACRS in a memorandum to the ACRS Executive Director, dated November 4, 2008

TOPICS

- INTRODUCTION
- REGULATORY BACKGROUND
- REGULATORY BASIS
- TECHNICAL BASIS
- RISK CONSIDERATIONS
- FUTURE ACTIONS
- CONCLUSIONS

INTRODUCTION-1

- Changes to November 4, 2008 position paper:
 - Position paper states that RG 1.1 will be withdrawn. It will not. (Executive Summary and Page 11)
 - For non-EPU submittals, risk procedure will follow SRP 19.2 Appendix D (Executive Summary and Page 28)
 - Discussion of uncertainty in NPSHR will be revised (Page 4)

INTRODUCTION-2

- ECCS AND CONTAINMENT HEAT REMOVAL PUMPS IN BWRs AND PWRs ARE CENTRIFUGAL PUMPS
 - Capable of operation over a wide range of flow rates and pressures
 - Operation well understood
 - Used in wide variety of applications
 - Subject to cavitation

REGULATORY BACKGROUND-1

- Regulations allow use of containment accident pressure in determining the available NPSH of safety related pumps

REGULATORY BACKGROUND-2

- RG 1.1 November 1970
- RG 1.82 Rev 0
 - 50% Blockage
- RG 1.82 Rev 1 November 1985
 - Incorporates findings of USI A-43
 - Uniform coverage of sump screens by loca generated debris
 - RG 1.1 cited as guidance for use of containment accident pressure

REGULATORY BACKGROUND-3

- RG 1.82 Revision 2 May 1996
 - Incorporates guidance supporting NRC Bulletin 96-03
- GL 97-04 October 1997
- RG 1.82 Revision 3 November 2003
 - Incorporates guidance supporting NRC Bulletin 2003-01
- DRAFT RG 1.82 Revision 4
 - Revises guidance on calculating available NPSH
 - September 20, 2005 ACRS letter recommended revisions and further restrictions on use of containment accident pressure prior to issuing

NRC POSITION

- The NRC allows use of containment accident pressure in determining available NPSH in the following cases:
 - Analyses using conservative assumptions have demonstrated that this pressure will be available for postulated design basis accidents
 - When examined from a broader perspective (i.e., beyond design basis accidents), an acceptable level of safety is maintained

NRC POSITION-2

- Duration of use of containment accident pressure is not risk significant.
- Significant contributors to loss of containment integrity occur at start of postulated accident:
 - Pre-existing leak
 - Failure of containment isolation
 - Possible exception for App R fire (associated circuits). Examined during staff reviews.

NRC POSITION-3

- The magnitude of pressure needed is not risk significant.
- A calculation of peak LOCA containment pressure demonstrates that the pressure is less than the design pressure.
- Pressure at the time of peak sump or suppression pool temperature is much less than containment design pressure.

NPSH MARGIN

- Some authorities specify a margin between NPSHR and NPSHA of 30% or more
- Nuclear industry practice is $NPSHA = NPSHR$
- This is acceptable because:
 - LOCA pressure is conservatively calculated
 - Margin is important to ensure continuous long-term pump operation. Not one time operation for period of hours.
 - Tests have shown that damage rate is highest at some point between 3% and incipient cavitation. (Pump dependent.)

TECHNICAL BASIS

- Considerations for acceptability of using containment accident pressure:
 - High confidence in containment integrity
 - Conservative calculations
 - Pump design
 - Emergency operating procedures
 - Minimal impact on plant risk

CONTAINMENT-1

- RG 1.1: One rationale for not using containment accident pressure is the possibility of “impaired containment integrity”
 - Structural integrity test prior to licensing
 - 10 CFR 50.54(o) and Appendix J require leak testing of containment and individual penetrations
- 10 CFR 50.55a requires periodic inspections of the containment.
- TS control containment integrity.
- Stringent plant procedures.
- Good experience

CONTAINMENT-2

- Majority of plants using containment accident pressure to determine available NPSH are BWRs with Mark I containments
 - inerted
 - O₂ monitors
 - Drywell-wetwell ΔP restricted by technical specifications

CONTAINMENT-3

- 4 plants subatmospheric. 3 more operate as sub- atmospheric
- 4 PWRs with large dry containments

CONTAINMENT-4

- Other safety analyses assume containment integrity:
 - Containment integrity is assumed in calculating offsite dose (10 CFR 50.67 or 10 CFR Part 100)
 - Accident pressure is assumed in calculating peak cladding temperature (10 CFR Appendix K)

EQ CONSIDERATIONS

- SRP 3.11 covers all items of equipment important to safety (mechanical, electrical, I&C)
- SRP 3.11:
 - *For mechanical equipment located in a harsh environment, compliance with the environmental design provisions of GDC 4 are generally achieved by demonstrating that the nonmetallic parts/components are suitable for the postulated design basis environment conditions.*
 - *For mechanical equipment, the staff concentrates its review on materials that are sensitive to environmental effects (e.g., seals, gaskets, lubricants, fluids for hydraulic systems and diaphragms*

CONSERVATISM-1

- Calculation for LOCA underestimates containment pressure and overestimates suppression pool or sump temperature
- Calculations for ATWS, station blackout and Appendix R fire are realistic
 - some conservatism is typically present
- NRC staff November 4, 2008, white paper provides lists of typical conservative assumptions used in BWR and PWR LOCA calculations.

PUMP DESIGN-1

- All pumps of interest share certain characteristics with respect to cavitation:
 - robust construction
 - mechanical seals
 - stainless steel (cavitation-resistant) impellers
- ECCS pumps of later plants have lower required NPSH than those used in earlier plants

PUMP DESIGN-2

- NRC staff has approved pump operation in cavitation below the required NPSH
- Based on testing and subsequent inspection of pumps
- These tests of prototypical pumps in cavitation have not shown damage or more than very minor wear (scratches)

PUMP DESIGN-3

SUMMMARY OF NUCLEAR POWER PLANT SAFETY RELATED PUMP CAVITATION TESTING

PLANT	PUMP	COMMENTS
Browns Ferry	RHR	<ul style="list-style-type: none"> • Tests performed at 8000 and 10000 gpm • Severe audible cavitation but acceptable motor vibration • Tests terminated before “breakout” point (complete loss of head) • Discharge head drop 10-12% • Manufacturer’s NPSHR curves may be reduced an additional 9 ft • Operated for 10 minutes below manufacturer’s recommended design NPSH conditions
Browns Ferry	RHR and Core Spray	<ul style="list-style-type: none"> • Pump vendor provided curves showing acceptable operation for limited times at up to 6% head loss • Based on total operation time of 8000 hrs at various NPSHR values.
Dresden	Core Spray	<ul style="list-style-type: none"> • Witness and NPSH testing. Pump disassembled and examined. All parts in excellent condition. • Cavitation tested 4000 to 6000 gpm. Time not specified. Pump disassembled and examined. No damage or wear. • Pump again tested below previous cavitation point for one hour. No damage or wear. • Pump cavitation tested again for one hour. Suction pressure lowered and tested further for 30 minutes. Pump again disassembled and examined. No damage or wear. Several scratches.
Vermont Yankee		<ul style="list-style-type: none"> • Pump vendor provided curves showing acceptable operation for limited times at up to 6% head loss • Based on total operation time of 8000 hrs at various NPSHR values.
Monticello	Core Spray	Cavitation test performed by pump vendor. Pump went through “extensive cavitation” for several hours “without visible damage to the impeller.”
Beaver Valley (North Anna Unit 2 pump)	Recirculation Spray	Closed loop test. NPSHA lowered by water temperature increase and tank level decrease Initial NPSHA = 15.1 ft. NPSHA lowered to 5 ft (well into the breakdown region) for ½ hour. After testing pump Total Dynamic Head/Capacity curve regenerated. No degradation noted.
Crystal River	Building Spray	Pump vendor provided justification for a required NPSH based on a 5% head drop

OPERATIONAL CONSIDERATIONS-1

- BWR EOPs consider containment pressure in assessing adequate available NPSH
- BWR NPSH analyses consider operation of containment spray for the duration of the event

OPERATIONAL CONSIDERATIONS-3

- Operator indications of cavitation (from control room)
 - Erratic or decreasing pump motor current
 - Erratic flow or flow less than expected
 - Frequent adjustments to ECCS pump discharge valves to maintain constant flow rate (BWRs)
- Operator response to cavitation
 - throttle pump
 - remove pump from service
 - consider other water sources

EFFECT OF THROTTLING

Dresden 2/3 calculation DRE97-0002 Rev 0 Attachment A

RHR/CS	RHR Pump Flow/Pump (gpm)	Suction Loss (ft)	NPSHR (ft)	NPSH margin (ft)
4/2	5000	10.7	30	-11.1
4/2	3750	6.5	25.5	-0.7
4/2	2500	3.4	25	4.3

FUTURE ACTIONS

- Revise RG 1.82 Revision 3
 - Clarify and add more detail to NPSH discussion
 - Revise positions
 - Remove material not relevant to current status of the issue (e.g., sump design descriptions)
 - Update references
 - Revise RG 1.1 to state that RG 1.82 provides the current guidance.
- Revise white paper
- Make white paper publicly available.

CONCLUSIONS

- High confidence in containment integrity
- Prototypical pumps have been cavitation tested for periods up to several hours with no damage
- Need for credit for containment accident pressure for BWRs is limited to older plants
- Where examined, the risk of using containment accident pressure in determining available NPSH is negligible
- For some plants, reliance on containment accident pressure is a result of conservative analysis

BACKUP SLIDES

STATISTICAL APPROACH

- A statistical estimate of the uncertainty in the pressure needed for adequate NPSH is added to a realistic value
- BWROG has submitted NEDC-33347 for review and approval.
- Approach used in several other areas of reactor safety analysis:
 - Realistic LOCA
 - Departure from Nucleate Boiling Ratio (DNBR)
 - BWR Anticipated operational Occurrences (AOO's)

PENETRATION SEALS

- “Both Viton and EPR/EPDM O-rings appear undamaged when exposed directly to a steam environment with temperatures up to about 600 F at a pressure of 155 psia for 4 to 6 hours...”
- “Silicon rubber O-rings appear undamaged up to 500 F at a pressure of 155 psia when exposed directly in a steam environment for about 4 hours...”

8th SMIRT Conference 1985

“Integrity of Containment Penetrations under Severe Accident Conditions,” C.V. Subramanian

