

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

RECEIVED
JUN 13 2008

Location: Rockville, Maryland

Date: Friday, June 6, 2008

Work Order No.: NRC-2223

Pages 1-147

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

June 6, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on June 6, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

553RD MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

+ + + + +

FRIDAY,

JUNE 6, 2008

The Advisory Committee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B3, 11545 Rockville Pike, Rockville, Maryland, at 8:30 a.m., WILLIAM J. SHACK, Ph.D., Chair, presiding.

MEMBERS PRESENT:

WILLIAM J. SHACK, Chair

MARIO V. BONACA, Vice Chair

JOHN D. SIEBER, Member-at-Large

SANJOY BANERJEE

J. SAM ARMIJO

DANA A. POWERS

SAID ABDEL-KHALIK

OTTO L. MAYNARD

JOHN W. STETKAR

DENNIS C. BLEY

MICHAEL L. CORRADINI

GEORGE E. APOSTOLAKIS

NEAL R. GROSSCOURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT:

2 JEFF CIOCCO

3 MICHAEL SCOTT

4 BILL RULAND

5 PAUL KLEIN

6 JOHN GROBE

7 ALSO PRESENT:

8 KIYOSHI YAMAUCHI

9 KEITH PAULSON

10 SHINJI KAWANAGO

11 HIROSHI HAMAMOTO

12 MASAYA HOSHI

13 TADASHI SHIRAIISHI

14 MUTSUMI ISHIDA

15 KATSUNORI KAWAI

16 MAKOTO TAKASHIMA

17
18
19
20
21
22
23
24
25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

I-N-D-E-X

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

AGENDA ITEM

PAGE

| | |
|---|----|
| 14) Opening Remarks by the ACRS Chairman | 4 |
| 15) Overview of the US-Advanced Pressurized Water Reactor Design | 5 |
| 15.1) Remarks by the Subcommittee Chairman | 5 |
| 15.2) Briefing by and discussions with representatives of the NRC staff and Mitsubishi Heavy Industries | 7 |
| 16) Status of NRC Staff Activities Associated with the Resolution of Generic Safety Issue (GSI)-191 | 99 |
| 16.1) Briefing by and discussions with representatives of the NRC staff | |
| Adjourn | |

P-R-O-C-E-E-D-I-N-G-S

14) OPENING REMARKS BY THE ACRS CHAIRMAN

CHAIRMAN SHACK: The meeting will now come to order. This is the third day of the 553rd meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: an overview of the U.S. advanced pressurized water reactor design and the status of NRC activities associated with the resolution of generic safety issue 191, "Assessment of Debris Accumulation on Pressurized-Water Reactor Sump Performance."

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Tanny Santos is the designated federal official for the initial portion of the meeting.

We have received no written comments or requests for time to make oral statements from members of the public regarding today's session. We have representatives of the State of Vermont on the phone bridge line listening for discussion of the topics scheduled for today's meeting.

To preclude interruption of the meeting, the phone line will be placed in a listen-in mode during the presentations and Committee discussions.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 A transcript of portions of the meeting is
2 being kept. And it is requested that speakers use one
3 of the microphones, identify themselves, and speak
4 with sufficient clarity and volume so that they can be
5 readily heard.

6 I would remind the members that we are
7 scheduled to interview another candidate today at the
8 end of the presentations. And so don't disappear.

9 With that, I will turn the meeting over to
10 Otto, who will lead us through the first
11 presentations.

12 MEMBER MAYNARD: Thank you, Mr. Chairman.

13 15) OVERVIEW OF THE US-ADVANCED PRESSURIZED WATER

14 REACTOR DESIGN

15 15.1) REMARKS BY THE SUBCOMMITTEE CHAIRMAN

16 MEMBER MAYNARD: As you said, this is a
17 brief overview of the U.S. APWR. It's an
18 informational meeting. We are not expected to write
19 a letter or to make any decisions. So we don't need
20 to get into the level of detail that we might need to
21 thoroughly examine every aspect of this.

22 So we have a lot of material to cover. I
23 think you are going to find that this is a very
24 complete package on the information. It covers
25 comparisons to U.S. current plants. It provides

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 numbers, good diagrams, fuel design. It identifies
2 the various codes and methods that they're using for
3 various parts of the analysis, safety analysis; fuel
4 design containment. It provides some of their
5 information relative to GSI-191.

6 It also provides some good information on
7 some of the unique aspects of this. It has an
8 advanced accumulator that is a little different than
9 what we have seen. It has digital I&C control room
10 systems that I think some really good information is
11 going to provide about that.

12 The reason I am identifying all of this is
13 that we will hold most of our questions toward the
14 end. I think that we will find that the presentation
15 will cover the items and then maybe have a little bit
16 of time at the end for some discussion on some of the
17 items. So I will be trying to control that as we go
18 through.

19 (Laughter.)

20 MEMBER POWERS: Good luck.

21 MEMBER MAYNARD: I know. This plant, one
22 of the plants that they're comparing it to, it looks
23 to me from the numbers, is one of the later models.
24 Westinghouse PWR is a SNUPS design. It looks like
25 some of the Calloway/Wolf Creek numbers that I see in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there as part of the comparison there. So it's kind
2 of near and dear to my heart there.

3 With that, I want to turn it over to Jeff
4 Ciocco, the staff. He will lead the presentation.
5 And then I think Mr. Kiyoshi Yamauchi will be leading
6 the Mitsubishi presentation. So I will turn it over
7 to Jeff to get started.

8 MR. CIOCCO: Okay. Thank you.

9 15.2) BRIEFING BY AND DISCUSSIONS WITH
10 REPRESENTATIVES OF THE NRC STAFF AND
11 MITSUBISHI HEAVY INDUSTRIES

12 MR. CIOCCO: My name is Joe Ciocco. I am
13 the lead project manager for the U.S. APWR standard
14 design certification. I am going to give you a brief
15 project overview this morning before Mitsubishi gets
16 into their technical presentation on their reactor
17 design technology.

18 So the purpose of this morning's briefing
19 is to provide information to you to familiarize you
20 with the U.S. APWR design certification application,
21 the licensing review process, and the current status
22 of our licensing review and to address any questions
23 that you have.

24 So the agenda is going to be short. I
25 will talk about the application status, the review

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 schedule, and the information provided in the design
2 control document that we have, as well as the topical
3 reports.

4 The U.S. APWR application status. We
5 began interactions with Mitsubishi back in July of
6 2006. These were called the pre-application review
7 meetings. We had ten meetings with Mitsubishi. They
8 came to us in early 2006 with their intent to apply
9 for a standard design certification.

10 So we had ten public meetings,
11 pre-application review meetings. And most of these
12 were meetings. They were pre-submittal meetings of
13 topical reports that Mitsubishi came to us and said
14 they had 12 areas that they wanted to supply topical
15 reports. And prior to those topical report
16 submissions, they wanted to have a public meeting with
17 us.

18 They chose the areas of the topical
19 reports, the accident analysis, digital I&C, the
20 advanced accumulator, thermal design methodology, and
21 fuel design methodology, as well as the quality
22 assurance program description.

23 So from July 2006 until the tendering of
24 the application on December 31st, 2007, we had
25 pre-application review meetings with Mitsubishi.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Their application was tendered to us on December 31st,
2 New Year's Eve, of last year. We completed a 60-day
3 acceptance review and docketed the application on
4 February 29th. We have a docket number.

5 So right now we are about three months
6 into our phase 1 licensing review. The staff is
7 writing RAIs, requests for additional information; as
8 well as writing the preliminary safety evaluation
9 report. So we are really in the early stages right
10 now of phase 1 of six phases to produce the final
11 safety evaluation report. And I will show you a
12 schedule in a few slides.

13 I wanted to put on here as far as our --
14 you've heard DCWG, design-centered review groups,
15 where we have the design technology and the utility
16 who selected that. In this case we have Luminant
17 Power, which selected the U.S. APWR technology for
18 their units 3 and 4 at the Comanche Peak site.

19 MEMBER SIEBER: It would be good if you
20 could provide us with a disk with the DC as submitted
21 on it.

22 MR. CIOCCO: I certainly will. It's also

23 --

24 MEMBER SIEBER: Give us a head's up and
25 ability to familiarize ourselves with the plant before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we start on the iterations.

2 MR. CIOCCO: Certainly will. We also have
3 it on our public Web site as well.

4 MEMBER SIEBER: I would prefer a disk.
5 (Laughter.).

6 MR. CIOCCO: We can do that. I have them
7 at my desk.

8 MEMBER SIEBER: I know it's on the Web
9 site.

10 MR. CIOCCO: Okay. A little bit on the
11 review schedule background. This is very important
12 for us in building our schedule for the licensing
13 review.

14 Like I said, we received the design
15 control document. It defines a very specific approach
16 where there is design criteria and there is a process
17 for Mitsubishi submitting technical reports to us
18 through its what they call a design timeline or very
19 particular areas, for instance, in chapter 3 in their
20 piping and components and the digital I&C.

21 The application references the 13 topical
22 reports. One of those is completed now where the
23 staff has written the safety evaluation report. And
24 that's on the quality assurance program description.

25 We have 12 topical reports currently under

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff review. And they are all referenced in the
2 design control document. And there are 15 technical
3 reports, which aren't stand-alone documents, but they
4 are a supplement to the design control document that
5 the staff is reviewing along with a particular chapter
6 of the DCD.

7 And of these 50 technical reports, about
8 25 have been tendered to the NRC. And there are about
9 25 more to come in. The last ones come in -- right
10 now the schedule is -- mid 2009. A lot of them are
11 the stress analysis results of the piping and
12 components and I think a seismic analysis of the fuel
13 design.

14 So we are well on our way over. I would
15 say 25 or 30 of the technical reports have been
16 submitted to the NRC. MHI had a goal that was to
17 minimize the scope, a number of the open items, if you
18 will, at the end of phase 2. That is really our draft
19 safety evaluation report. We call it the SE with open
20 items.

21 So whenever we built our schedule, we
22 looked at, when was the staff going to complete its
23 review of the topical reports and when are we going to
24 have all the technical reports in for review so the
25 staff can make an evaluation finding?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If necessary, at the end, we are going to
2 re-base on our schedule at the completion of phase 2
3 in the ACRS when we know the number and complexity of
4 the open items that we're going to have. We will
5 certainly coordinate with the ACRS staff your review
6 twice, what we call phases 3 and 5. Three is the SE
7 with open items. And then phase 5 is the draft final
8 safety evaluation report.

9 MEMBER MAYNARD: And, for the Committee's
10 information, I talked with Jeff a little bit. We're
11 going to need to be taking a look at the list of
12 topical reports and identifying what items that we may
13 want to review before we see the SER with open items
14 and stuff, too.

15 MEMBER ARMIJO: Will this list of topical
16 reports include the various analytical codes used in
17 the safety evaluation? Are you going to review these
18 on a generic basis or is it going to be kind of mixed
19 in with the licensing or certification of the plant?

20 MR. CIOCCO: The topical reports do
21 include computer codes and the thermal hydraulics for
22 the advanced accumulator and the accident analysis.
23 So the staff is currently reviewing those in the
24 topical reports.

25 MEMBER ARMIJO: For example, fuel design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methods?

2 MR. CIOCCO: Yes.

3 MEMBER ARMIJO: That will be included if
4 it isn't already?

5 MR. CIOCCO: It is in a topical report.
6 And you will see in Mitsubishi's presentation where
7 they are going to talk about a particular area in the
8 topical report and the staff, where we are doing the
9 review.

10 Our last topical report came in I think in
11 March of this year. It's on a particular code. It's
12 a Mitsubishi code called FINDS, F-I-N-D-S, which is
13 used in their fuel design. So that's currently under
14 staff review.

15 MEMBER SIEBER: So are we going to get the
16 opportunity to review the topical reports along with
17 the application?

18 MR. CIOCCO: Yes. The HRS has each and
19 every topical report that's been tendered to the NRC.
20 And I'm going to show you a slide shortly which is
21 going to show the expected completion date of the NRC
22 review. And you will see that those dates are
23 actually very close to the end of the staff's review
24 for a particular chapter.

25 So you will be able to look at the staff's

1 safety evaluation report on that topical as well as
2 the staff's safety evaluation report on the chapter of
3 the DCD which references that topical report.

4 MEMBER MAYNARD: I'm going to say probably
5 at our next meeting, we need to go over a list,
6 identify what things we have an interest in, and make
7 sure that we get involved at a time that it will do
8 some good.

9 MR. CIOCCO: Okay. Next I show this is
10 the overall review schedule. We put this in a letter
11 to Mitsubishi on May 9th. It shows about a 42-month
12 review schedule from the phase I.

13 The application was tendered, like I said,
14 on December 31st. We docketed in February. Our start
15 date was around the middle of March. So it's going to
16 take us about 24 months to get to our safety
17 evaluation report with open items.

18 At that point -- and this is the last date
19 of a chapter completion. There are 19 chapters of a
20 design control document. So we have a schedule
21 leading down to March 10th, when all of these chapters
22 are going to be completed. We will look at
23 interacting with the ACRS subcommittee on where they
24 are going to receive those chapters.

25 The overall schedule down through the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 final safety evaluation report with no open items is
2 about a 42-month schedule. This will be followed
3 through a rulemaking process, like we did for all
4 other standard design certification.

5 MEMBER CORRADINI: Let me ask you a
6 question at this point. What did you learn from the
7 ESBWR and the AP1000 that has improved this schedule
8 or made it better for the staff's interaction with
9 ACRS and with the applicant? Is anything different
10 here than the ESBWR schedule, for example?

11 MEMBER CORRADINI: Well, from a scheduling
12 standpoint. I am trying to understand the differences
13 or is it following the ESBWR schedule?

14 MR. BURKHART: I am Larry Burkhardt of the
15 U.S. APWR, projects branch chief.

16 We have learned a lot from ESBWR, and we
17 think it is an advantage for them to come to you with
18 specific chapters. I hope you think that is an
19 advantage, too. And I see some mixed looks.

20 We are open to discussing how we do that,
21 but we are starting, Jeff and I are starting, to
22 discuss how and when we are going to come to you.
23 And, of course, we will work with your staff on when
24 that might be, the best time to do with SER with open
25 items.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And it looks like the chapters may be
2 finishing up in two waves, and they make sense once we
3 get into the scheduling and come to you with specific
4 --

5 MEMBER POWERS: Let me say that you choose
6 your waves, at least with respect to the EPR, where I
7 know what the waves will look like, is curious. You
8 bring a wave forward and say, "Okay. We're going to
9 look at the i&c systems before we look at the plant
10 layout and whatnot. That is not going to work.

11 MR. BURKHART: We would definitely take
12 your input on that and do it in a way that makes
13 sense.

14 MEMBER MAYNARD: I think it's fair to say
15 that the ACRS has learned some lessons from the ESBWR
16 review. And we will have some interactions and coming
17 up with what we think the optimum --

18 MR. BURKHART: Absolutely. And we have
19 been working with Tanny. And we will take your input
20 and try to make that more efficient.

21 Also, we may want to come to you on
22 particular issues as you discuss like unique design
23 features of the advanced accumulator before the SER
24 with open items. And we are definitely open to doing
25 that. I think that's a good idea.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER CORRADINI: So I had a second
2 question, which is let's take the March 2010 date.
3 That's the end of the 20-19 chapters with SER open
4 items or that's when the staff will start feeding it
5 in some fashion to the ACRS?

6 MR. CIOCCO: This is the end date of the
7 total completion of the compilation of the safety
8 evaluation report of all 19 chapters into the final
9 document, if you will, of an SE with open items.
10 There are individual completion dates leading down to
11 this. If you were to look at a game chart, as we
12 heard --

13 MEMBER CORRADINI: I don't want to, but I
14 think I've got you now. So that's the end game. So
15 is it your anticipation that with some sort of wave
16 structure, that a subcommittee of ACRS will see
17 groupings of the chapters before March 10th?

18 MR. CIOCCO: Yes, sir.

19 MEMBER CORRADINI: Okay.

20 MR. CIOCCO: Yes.

21 MR. BURKHART: Yes. Those are
22 not-to-exceed dates. And as we were thinking of how
23 phase 2 is going to wind up, we hope to come to you
24 with some chapters, whatever makes sense, before that
25 March 2010 date exactly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Thank you.

2 MR. BURKHART: You are welcome.

3 MR. CIOCCO: Okay. Next I have two slides
4 which show the 19 chapters of the application that we
5 have in each of our -- we have a project team in the
6 Office of Nuclear Reactors as well as the topical
7 reports.

8 As I said, there were 13 topical reports.
9 And in parentheses, I put the completion date of these
10 topical reports. And, like I said, I think the ACRS
11 has each of these. We can always provide them again
12 and then the expected dates.

13 And the topical reports are the areas that
14 Mitsubishi has chosen to work with the staff. In the
15 area of the reactor, chapter 4, you have the fuel
16 design, thermal design methodology. And this was our
17 latest topical report. The May 2009 is the completion
18 date for the fuel assembly.

19 In chapter 6, we have the advanced
20 accumulator you're going to hear about as well as the
21 LOCA mass and energy. Chapter 7, digital I&C has
22 three topical reports. As you said, each of these
23 chapters has a particular completion date leading up
24 to that March 2010 date.

25 We have the accident analysis,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 large-break, small-break, and non-LOCA analysis. This
2 one is completed on the quality assurance program
3 description. And, then, finally, we have the human
4 factors and HSI system description.

5 So that is really how we laid out our
6 project assignments and topical report assignments
7 because these will be stand-alone safety evaluation
8 reports. And in many of these, Mitsubishi has asked
9 that these topical reports be applied to the operating
10 fleet as well as the new reactor fleet.

11 MEMBER BLEY: Question on that last item
12 you have. Chapter 19 doesn't seem to have any
13 associated reports with it. Is there a PRA done yet?

14 MR. CIOCCO: Oh, yes, sir, there is. Yes.
15 They have actually submitted a PRA level 3.

16 MEMBER BLEY: So you do have --

17 MR. CIOCCO: Yes. They just don't have a
18 topical report. But it was totally addressed in the
19 chapter 19 document.

20 MEMBER STETKAR: Do they have the actual
21 PRA?

22 MR. CIOCCO: Yes, sir.

23 MEMBER BLEY: You have it?

24 MR. CIOCCO: We do. Yes, sir, we do.
25 Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: So do you have a
2 schedule for when you complete the SERs for the
3 topical reports?

4 MR. CIOCCO: Yes, sir. These are the
5 completion dates in parentheses.

6 MEMBER BANERJEE: Oh, okay.

7 MR. CIOCCO: Most of them, they were
8 tendered beginning in January of 2007, the advanced
9 accumulator, and the quality assurance program
10 description. So they have been coming in in kind of
11 a steady stream beginning in early 2007 through the
12 last and final receipt was in March of this year.
13 These are the completion dates that I put in
14 parentheses.

15 MEMBER BANERJEE: So we should actually
16 schedule some subcommittee meetings if you wish to
17 review these? And those dates are the ones when you
18 finish your SER?

19 MR. CIOCCO: This is when the staff is
20 going to have its position on those topical reports.

21 MEMBER MAYNARD: I think we are going to
22 have to get -- let's not SER with open items. Let's
23 --

24 MR. CIOCCO: These are stand-alone safety
25 evaluation reports on the top row.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: We need to get involved
2 or that's what we need to be identifying.

3 MEMBER BANERJEE: We need to identify
4 which ones and have the appropriate subcommittee --

5 MEMBER APOSTOLAKIS: So we get involved
6 after these dates, right?

7 MEMBER MAYNARD: No. For the topical
8 reports, we're going to need to get involved before or
9 the ones that we choose to take a look at.

10 MEMBER APOSTOLAKIS: Okay.

11 MR. BURKHART: Just to make a comment.
12 Because we have less time in pre-application with this
13 applicant than some others, a lot of the topical
14 reports, which are generally their approaches to
15 design, are simultaneous now with the chapters for the
16 DCD.

17 So whether or not the timing is good to
18 separate those, we're open to hearing that from you,
19 but it's a good opportunity I think to wrap them
20 almost together. But we can talk about that because
21 we can see the advantage of how we're proceeding here
22 is we see that approach and we see how they're
23 implementing their approach.

24 MEMBER MAYNARD: The situation we don't
25 want to get into is to be reviewing a chapter and a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conclusion is drawn on a topical report we didn't get
2 a chance to take a look at that, all of a sudden, that
3 leaves us with nothing that we can really comment on
4 or do.

5 MR. BURKHART: And we'll definitely --

6 MEMBER MAYNARD: We'll take a look that
7 for - we need to move on here.

8 MEMBER CORRADINI: Mr. Chairman, may I ask
9 one clarification? So you made a comment in the
10 middle of this. Besides new plants, these topical
11 reports are for, and I didn't get your -- so what
12 plants, currently operating plants, are these topical
13 reports going to be applicable to? That's what I
14 thought you were implying. Maybe I misunderstood.

15 MR. CIOCCO: Whenever they tendered the
16 topical reports, they asked if these could be applied
17 and used by the operating fleet as well as the new
18 reactor fleet.

19 MEMBER ARMIJO: And that is for approval
20 of the topical report, --

21 MR. CIOCCO: Yes, sir.

22 MEMBER ARMIJO: -- not just for the APWR?

23 MR. CIOCCO: Not just for the APWR.

24 MEMBER ARMIJO: All right. Thank you.

25 MR. CIOCCO: Yes. You're welcome.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BURKHART: And that is a good point
2 because NRR -- we would like them to review it with
3 us. And they're coming back to us and saying, "Well,
4 no one has referenced this in the license amendment,"
5 et cetera. So they don't know how to prioritize that.

6 But the bottom line is we, NRO, are
7 looking at the review. We are coordinating it with
8 NRR.

9 MEMBER ARMIJO: Well, so --

10 MEMBER MAYNARD: We do need to move on.

11 MR. CIOCCO: Yes.

12 MEMBER MAYNARD: We have a lot of
13 information. This is --

14 MR. CIOCCO: Okay. Thank you. And that
15 concludes my presentation. I wanted to give you an
16 idea of the application, let you know that the phase
17 1 is underway with the topical, technicals, and the
18 application and that we look forward to working with
19 the ACRS as we complete our safety review.

20 MEMBER MAYNARD: Okay. Thank you.

21 I think, Mr. Yamauchi, we will get your
22 slides up here on the --

23 MEMBER BLEY: While we are getting ready
24 here, will this talk tell us about what makes this the
25 U.S., as opposed to others? We think you are building

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 one of these in Japan already.

2 MEMBER MAYNARD: That is covered, yes.

3 MR. YAMAUCHI: So, good morning, ladies
4 and gentlemen. My name is Kiyoshi Yamauchi, Executive
5 Officer of Mitsubishi Heavy Industries. This is a
6 great honor for us to have this opportunity to talk
7 with our U.S. APWR, with the ACRS Chairman, and the
8 members. We have many colleagues. Half of them are
9 working in Arlington, half of them from Japan.

10 I would like to explain very briefly what
11 is MHI. I will talk about experience, technologies,
12 and commitment.

13 Next, please. Our history in the nuclear
14 world is quite long. And we have been operating
15 already 26 old PWR plants in Japan, including one
16 nuclear ship, MUTSU, at the very beginning. There are
17 23 plants now in operation, and one is under
18 construction. This is the Tomari unit, this one. And
19 here we will install all digital I&C systems. And
20 they are already there.

21 We have two plants under licensing, these
22 two. This is APWR plants. So this is the best plant
23 over U.S. APWR and now is under licensing stage.

24 Even in the stagnation period in the
25 world, we have been continuing to build or replace

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plants. And that is why we can develop our own
2 technologies as core competence. And also we can keep
3 our engineers and infrastructures.

4 Next, please. And also we have extensive
5 experiences of components exports. These are for the
6 fourth, steam generators on the vessel head. And if
7 you stop over at Kobayashi shipyard in Japan, you can
8 see a steam generator for San Onofre, big one, and
9 steam generator for EDF in Belgium. And also you can
10 see a big vessel for Okiluoto, EPR, in Finland.
11 Please be visiting there.

12 Next, please. And the other talk about
13 our technologies. We are not only a
14 manufacturer/vendor. We are a total plant maker. We
15 are a single point responsibility, single turnkey work
16 from the R&D design and engineering, manufacturing,
17 construction, maintenance, and fuel supply.

18 And also we have established our global
19 assurance during the export phase of components. And
20 this is why we have decided to have the DCD of our own
21 plant. This is why we are here.

22 Next, please. And one of our core
23 competencies is nuclear safety analysis and with the
24 core designs. We use state-of-the-art technologies.
25 And also we have our own test facilities. And also we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will do licensing support to the governments.

2 MEMBER BANERJEE: Is that in Takasago or
3 where is that?

4 MR. YAMAUCHI: Yes, yes. Sure.

5 Next, please.

6 MEMBER BANERJEE: Full height?

7 MR. YAMAUCHI: It depends on the -- if
8 full height is needed, we will do that.

9 Next, please. And also we have a plant
10 engineering and the purchase procurement capability.
11 We will make our 3D-CAD, which integrates common
12 database from design to purchase and construction.
13 It's a once-through system.

14 Next page, please. And also we have a
15 capability of manufacturing. This is a picture of
16 Super Miller reactor vessel. We can make reactor
17 vessels, steam generators, c1DM. We have internals or
18 turbines or all components. We can do that.

19 Next, please. And also we will do plant
20 constructions ourselves. And the most important issue
21 at this stage is how to shorten the construction
22 period. And the left one is the latest plant in the
23 Hokkaido area. We will use super wash, cranes. And
24 share portion and the dome portion are welded at the
25 site. And they can fix it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And also we can use a modular utilization
2 effort. And that can enable to reduce the
3 construction period. And we would like to use such
4 experience in U.S., too.

5 Next page, please. And also we have been
6 supplying fuel assemblies. And so far we have
7 supplied around 18,000 fuel assemblies to Japan PWR
8 plants.

9 Next, please. And we think, MHI thinks,
10 safety is the most key important issue for the nuclear
11 facilities to develop, to construct, and to operate.
12 So our U.S. APWR is totally in compliance with the
13 U.S. requirements.

14 And also our U.S. APWR design is very
15 evolutionary type, not revolutionary, not surprising
16 for you. And it's quite similar to this type. But
17 capacity is larger because we can use larger turbines
18 and larger steam generators, which we can make.

19 And also the systems are quite similar to
20 the conventional ones. And we will use some unique
21 systems. They are all already proven or accepted
22 technologies having used.

23 The last, please. And there is a
24 conclusion. We are committed to provide the highest
25 quality global nuclear products and services and also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 our infrastructure, having developed and maintained
2 throughout our long history. And the U.S. APWR
3 demonstrates the commitment to quality and safety
4 worldwide.

5 This is my short statement. Thank you
6 very much.

7 MEMBER MAYNARD: Thank you.

8 MR. YAMAUCHI: Also we have many people.
9 So please do not hesitate to ask many questions.

10 (Laughter.)

11 MR. YAMAUCHI: Thank you very much.

12 MEMBER MAYNARD: We are going to be
13 discussing more on fuel and stuff here when they go
14 through the specific design. This is not the end of
15 the presentation. We need to be moving along here.
16 Keith, are you going to be --

17 MR. PAULSON: Yes, yes.

18 MEMBER MAYNARD: -- now going through the
19 design features. And that is where we are going to
20 talk more about some of the specifics on the fuel and
21 stuff. So go ahead.

22 MR. PAULSON: What I am going to try to do
23 is to supplement some of the things that Mr. Yamauchi
24 started with to give you an identification of how the
25 design looks compared to designs you have seen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 already.

2 As he mentioned, you will see very quickly
3 that this is not a revolutionary design but an
4 evolutionary design. It's consistent with designs
5 that have been implemented in the U.S. in many cases
6 and also consistent with the APWR and Japanese designs
7 because of the consistency of the designs manufactured
8 by Mitsubishi with designs that you have seen from the
9 U.S.

10 So you will see a few new things, which
11 hopefully you will ask some questions on at the
12 appropriate time. And I'll leave that up to Mr.
13 Maynard to make that decision when the appropriate
14 time is. But, in any case, I will move forward.

15 I am going to have to go through things
16 very quickly because I know you want to leave some
17 time at the end for questions. I have a lot of
18 material. I am not going to go over things you have
19 seen already with a lot of detail. I am just going to
20 point to the fact that it is consistent with something
21 you have already seen.

22 If there's a question about that, fine.
23 But I am going to try and spend most of the time on
24 those things that you have either asked questions on
25 already or things that may be somewhat new or more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 advanced that you have seen to date. So that's going
2 to be my philosophy.

3 These are the issues we're dealing with.
4 And I'm going to deal with what the U.S. APWR is, core
5 and fuel design, systems design. We will talk a
6 little bit about the I&C architecture and also just
7 some conclusions at the end very briefly.

8 This is going to be really the world's
9 largest, at least we think the world's largest, PWR
10 based on the fact that we'll be getting about 1,700
11 megawatts electric out of the plant.

12 One of the reasons that this plant can
13 meet that high objective is because of the high
14 thermal efficiency. And that comes about because of
15 the design of the turbine that we're using, which will
16 have about a 39 percent efficiency, as opposed to
17 typical plants today, which are more in the range of
18 35 percent.

19 So we also have a very high -- and this
20 may be of some interest when you look at the steam
21 generator design if you're so inclined to see the high
22 performance of the separators on this design, very,
23 very high-level efficiency on the separators. We are
24 developing the capability to utilize a 70-inch class
25 blade for the turbine, which allows us to get the 39

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent thermal efficiency.

2 And the U.S. APWR does meet what we
3 believe to be the U.S. utility requirements that have
4 been specified years ago in the utilities requirements
5 document.

6 MEMBER BANERJEE: Is there any reheat or
7 is it --

8 MR. PAULSON: Yes.

9 MEMBER BANERJEE: There is reheat?

10 MR. PAULSON: Yes. Some of the URD areas
11 that we hit upon specifically and some that are
12 specifically focused on safety, first of all, we have
13 eliminated the penetrations of the vessel on the
14 bottom.

15 We have implemented full four-train
16 safety, both in terms of the mechanical and electrical
17 components. We are utilizing 14-foot fuel. We have
18 a fully digital I&C.

19 And I am going to spend more time,
20 obviously, on all of these issues, but this is just
21 some highlights up front.

22 And due consideration against protection
23 against airplane crash and long-term containment
24 integrity have been built into the design or are being
25 built into the design based on evaluations of things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like the airplane crash.

2 You had some questions about the APWR.
3 This is a generation, more or less the next generation
4 of the APWR, which is going into the Tsuruga 3 and 4
5 units in Japan. There have been developments that
6 have gone beyond that, and I will talk about those.
7 And you will see those in the comparison tables.

8 Here shows you some of the testing that
9 went on and the key areas that were identified
10 specifically to demonstrate the acceptability and
11 adequacy of the APWR design. That is in the area of
12 reactor internals and the neutron reflector.

13 By the way, we have done some confirmatory
14 testing on those again, in addition to what we had
15 done for the APWR. And that was done last year and
16 early into this year.

17 The compact steam generator design. This
18 looks at a triangular pitch, where we have been able
19 to reduce the pitch on the steam generator tubes and
20 actually reduce the size.

21 As I mentioned already, the separator
22 performs extremely well for the steam generators and
23 has demonstrated a very low moisture carryover.

24 The reactor coolant pumps are the same
25 reactor coolant pumps that we would be using for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 APWR design, will be used in the U.S. APWR design.
2 The i&c is an architecture that utilizes complete
3 digital I&C for both the control and protection system
4 and has a history that I will go through later on to
5 show where we started out with respect to this design
6 to show that we just didn't jump right into a design
7 that we plan on implementing here in the United States
8 that is one that has been sequentially developed as
9 backfits for the U.S. or in Japan and will be put in
10 also to the U.S. APWR but has been installed already,
11 by the way, at the Tomari site.

12 MEMBER SIEBER: What kind of tube support
13 plates do you have in the steam generator?

14 MR. PAULSON: Tube support plates are
15 stainless steel broached.

16 MEMBER SIEBER: Broached? Thank you.

17 MR. PAULSON: And the turbine I mentioned,
18 we are looking at turbine performance. We also will
19 do some additional testing on the new turbine blade.

20 A quick comparison here. This is one of
21 the things you asked for early on to get to where
22 we're at. We like to look at the U.S. design of the
23 current four-loop plant. This is very similar to the
24 SNUPS design.

25 This is the APWR as configured in the one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that will go in at Tsuruga 3 and 4. And this last
2 slide shows the comparison with the U.S. APWR.

3 There is one critical key point here, and
4 that is that notice that the thermal output for the
5 U.S. APWR is no larger than that already in the APWR.
6 The only way that the additional megawatts electric
7 were able to get to that is with the higher
8 efficiencies that are identified as part of the
9 design.

10 So we're not bumping this thing up in
11 power, thermal power, just to get additional megawatts
12 out. We are actually using the performance of the
13 turbine to get those additional megawatts.

14 MEMBER CORRADINI: And that is all due to
15 the final low-stage blade that we're --

16 MR. PAULSON: Primarily, yes, you're
17 right. That's the --

18 MEMBER BANERJEE: Is there any 70-inch
19 blade in operation?

20 MR. PAULSON: No. That's why I said there
21 will be some additional testing.

22 MEMBER BANERJEE: And you are doing
23 testing of erosion and all that sort of stuff?

24 MR. PAULSON: Right. That will be
25 correct. We are doing testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Do you have a full-scale
2 model?

3 MR. PAULSON: Yes. We will, yes.

4 MEMBER BANERJEE: It has to be close to
5 Mach 1, the blade tip velocities. Is it 1,800 rpm
6 turbine?

7 MR. PAULSON: Eighteen hundred rpm.

8 MEMBER SIEBER: And these are add-on blade
9 rows, as opposed to --

10 MR. PAULSON: Longer blades, right.

11 MEMBER SIEBER: So same number of --

12 MR. PAULSON: Same number of blade rows.
13 I think that's correct. Same number of blade rows.
14 Just the blade is longer.

15 MEMBER SIEBER: Or more blades?

16 MR. PAULSON: No. I think it's the longer
17 blade. It goes from 54 to 70 inches, roughly 70
18 inches.

19 MEMBER ABDEL-KHALIK: You refer to the
20 steam generators as compact. How does the water
21 inventory in the steam generator compare to that in
22 the 54F model?

23 MR. PAULSON: There is more. There is
24 more in the steam generator than in the 54. And you
25 can see also just you could guess at that just by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 -- well, let me go to this. This is more or less the
2 square foot area of each of the steam generators. So
3 the 54 by 54 thousand, this has about 91 thousand.

4 MEMBER ABDEL-KHALIK: Well, I'm not
5 concerned about --

6 MR. PAULSON: I know, but you asked
7 additional water. Yes, it has more water volume also.

8 MEMBER BANERJEE: But it is on a
9 triangular pitch, right?

10 MR. PAULSON: It is on a triangular pitch,
11 right.

12 MEMBER BLEY: Why do you call it compact?

13 MR. PAULSON: We call it compact because
14 we reduced the tube size and were able to reduce the
15 size based on what we had used in other designs.

16 MEMBER BANERJEE: Is the tube sheet the
17 same size as the 70F or is it larger?

18 MR. PAULSON: No. This is a bigger steam
19 generator.

20 MEMBER MAYNARD: We will have an
21 opportunity to go into more detail when we go through
22 our other reviews. We need to move on. If we have
23 time at the end, we can have additional discussion on
24 this.

25 MR. PAULSON: Okay. I have covered most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of these points, I think. The bigger output is not
2 due to additional core power. It's due to just
3 thermal power or the capability of the turbines. And
4 the high-performance turbine is key to getting those
5 additional megawatts.

6 A few more comparisons. Notice about 193
7 assemblies, 17 by 17. It's a 17 by 17 you have known
8 and loved in the past or known and hated depending on
9 whether you like it or not. But 17 by 17 is the
10 standard fuel design.

11 And it's consistent among all three
12 plants. The only difference between the U.S. APWR and
13 the current design is that the U.S. APWR will be a
14 14-foot core, as opposed to a 12-foot core.

15 The reactor vessel internals is slightly
16 different because we are not using this baffle/former
17 design. We are using a neutron reflector.

18 If you remember, I did show a number of
19 tests that went on back in the 1990s on the neutron
20 reflector. We have also done some testing this year
21 that went into this year on the neutron reflector to
22 validate some of the test information that we had.

23 This is very simple, by the way. And I
24 will get into it a little more later on, this neutron
25 reflector.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The in-core instrumentation was
2 bottom-mounted in the current U.S. designs. was going
3 to be and will be bottom-mounted in the APWR, but we
4 have gone to a top mount for the U.S. APWR.

5 MEMBER SIEBER: That slows down your
6 fueling a lot, right?

7 MR. PAULSON: Pardon?

8 MEMBER SIEBER: Top mount slows refueling?

9 MR. PAULSON: A little bit, yes. You have
10 more there but not much. But it does allow you to go
11 to 24 months. This design goes to 24 months. So that
12 helps cut the --

13 MEMBER BANERJEE: That is why you made 14
14 foot, right?

15 MR. PAULSON: Right.

16 MEMBER BANERJEE: So it's not a local
17 limit or a DND limit.

18 MR. PAULSON: The power stays the same.
19 And what you are going to see --

20 MEMBER BANERJEE: It has more fuel?

21 MR. PAULSON: Well, more fuel, yes.
22 Longer fuel, the same number of assemblies, though, as
23 the APWR.

24 MEMBER BANERJEE: Just to give you a
25 little summary of the types of systems that we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 using, we're using, rather than the two-train design
2 for the electrical design for its standard in the
3 U.S., four-loop design and that would be in the APWR,
4 we have gone to four electrical trains. And as we are
5 going in the APWR, we are going to four trains,
6 mechanical. We will have four mechanical trains also
7 in the U.S. APWR.

8 From a systems point of view, one of the
9 changes we are making here is we are going to --
10 rather than using two high-head pumps and two low-head
11 pumps, we are going to using four high-head pumps plus
12 the utilization of the advanced accumulator in the
13 U.S. APWR. I will have some more slides on that later
14 on. It's just what the advanced accumulator looks
15 like and how it performs. But, in any case, what it
16 does basically, it allows us to eliminate the low-head
17 pumps on the ECCS design.

18 Rather than using an outside containment
19 or an outside pit for refueling water storage, we go
20 to the -- that pit is located on the inside for both
21 the APWR and the U.S. APWR. Containment vessel in
22 each case is pre-stressed concrete. And the I&C here,
23 as you can see, will be full digital in the APWR and
24 the U.S. APWR. And, as I mentioned before, that
25 design has already gone into Tomari, which is not an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 APWR.

2 MEMBER MAYNARD: Make sure everybody
3 caught one of the key things here. Instead of 2 100
4 percent trains for a number of these, there are 4 50
5 percent trains.

6 MEMBER STETKAR: I wanted to ask about
7 that key thing. Is that 4 50 percent in licensing
8 space or in functional space? In other words, do I
9 really need two high-head safety injection pumps to
10 meet the thermal hydraulic requirements for, let's
11 say, a small or medium LOCA?

12 MR. PAULSON: No. You have the capability
13 here of since you have four of them, you can have a
14 single failure and you can have one out of service and
15 still meet LOCA.

16 MEMBER STETKAR: That's licensing space.

17 MR. PAULSON: Right.

18 MEMBER STETKAR: I'm asking, will one pump
19 deliver enough flow? In the 2 by 100, obviously one
20 pump will deliver enough flow for any accident
21 conditions.

22 MR. PAULSON: Right.

23 MEMBER STETKAR: Will one of these pumps
24 also deliver enough flow for those same accident
25 conditions?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: For a small to moderate
2 break size, yes.

3 MEMBER STETKAR: I am asking --

4 MR. PAULSON: For certain break sizes,
5 yes. I think for the limiting break, maybe not. I
6 don't know if we --

7 MEMBER MAYNARD: We will have an
8 opportunity to explore that in far more depth. I want
9 to make sure everybody caught that.

10 MEMBER BANERJEE: What about long-term
11 cooling? How do you do that?

12 MR. PAULSON: Long-term cooling? Well,
13 long-term cooling is done with the high-head pumps.
14 And, of course, we have RHR pumps available, too,
15 later on.

16 The RHR pumps are now used jointly as
17 containment spray. You will see that in some of our
18 slides. But just as a forerunner of that comment, the
19 RHR system is used as a dual function.

20 MEMBER ABDEL-KHALIK: What is the shutoff
21 head of the high-head pumps?

22 MR. HAMAMOTO: This is Hiroshi Hamamoto.
23 It depends on the sheet. After LOCA, only
24 the higher --

25 MR. PAULSON: Just the high-end.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ABDEL-KHALIK: This is a specific
2 question about the pump. What is the shutoff head of
3 the pump?

4 MR. HAMAMOTO: About 4,000 feet for the
5 high-end pump.

6 MEMBER ABDEL-KHALIK: Four thousand feet.
7 Translate that to psi.

8 MEMBER BANERJEE: Thirty feet is 15 psi.

9 MEMBER ABDEL-KHALIK: So that is really an
10 intermediate pressure pump.

11 MR. PAULSON: Right. What is it, about
12 1,300?

13 MEMBER BANERJEE: It is below saturation
14 for the system or is it above saturation for the
15 system?

16 MEMBER ABDEL-KHALIK: It doesn't make
17 sense.

18 MEMBER BANERJEE: Yes. We need some
19 numbers.

20 MEMBER ABDEL-KHALIK: That doesn't make
21 sense.

22 MEMBER MAYNARD: Maybe we can get that
23 later.

24 MEMBER BANERJEE: Can we make a list of
25 things --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: We will certainly make a
2 -- yes.

3 MR. PAULSON: The analysis and the
4 description of all of the systems are part of the
5 design that was submitted. I&C, fully digital in both
6 cases.

7 We will move on. Fuel assembly. Fuel
8 assembly is fairly standard. We're using a 14-foot
9 with 11 grid. The difference here is that there are
10 11 grids, as opposed to 9 in some of the current
11 designs. And so, therefore, the distance between them
12 is less than or equal to what you are seeing in
13 current designs.

14 I think that is the only big difference
15 between other 14-foot 17 by 17s that you have seen
16 using Zirlo for the fuel, zircalloy for certain
17 aspects of the design also.

18 MEMBER BANERJEE: Did you have full-scale
19 critical heat flux on this testing?

20 MR. PAULSON: I'll ask. Was there
21 full-scale critical heat flux?

22 MR. HOSHI: Yes.

23 MEMBER MAYNARD: You need to come to a
24 microphone and identify yourself, please.

25 MR. HOSHI: My name is Masaya Hoshi, MHI.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have conducted a generic test three
2 years ago in the Columbia University. It's a
3 full-scale test.

4 MEMBER BANERJEE: Full-scale?

5 MR. HOSHI: Yes. Full-scale means five by
6 five grid spacing using the length of heat and length
7 of throughput.

8 MEMBER BANERJEE: Not 17 by 17?

9 MR. HOSHI: Not 17 by 17.

10 MEMBER BANERJEE: Five by five?

11 MR. HOSHI: Five by five. I believe that
12 those are the testing authorities used in this
13 industry

14 MEMBER ARMIJO: Now, just an observation.
15 You are going to 97 percent theoretical density on
16 pellets and probably the highest gadolinia. Later
17 when we get into the details, we want to understand
18 how that is affecting the stress on the cladding, even
19 though it's operating at pretty standard powers.

20 MR. PAULSON: Okay. We will keep a note
21 of that.

22 MEMBER SIEBER: It takes a lot of detail
23 to answer that question.

24 MEMBER ARMIJO: Yes. That's why I just
25 said we would do it later.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAULSON: Just to look at the standard
2 designs, I think. I don't think that there is
3 anything particularly new here. So I am not going to
4 go through it. But it's to give you a little
5 information on the specific design of the fuel
6 assemblies. We'll just move on because we are running
7 short on time here.

8 This slide, it's fortunately simple and I
9 think critical in terms of how you look at safety in
10 the place because I think the key parameter here if
11 you want to consider a key parameter is the change in
12 the kilowatts per foot in the design from the standard
13 design, the four-loop that we had, where we improved
14 it in the APWR and improve it once again even in the
15 U.S. APWR. And that's one of the reasons for the
16 improvement in safety in this plant design.

17 Core design is a low-power density core
18 with flexible operation. We're planning on this core
19 going to 24 months. It uses two batch cycles.
20 Uranium enrichment stays below five percent. Burnups
21 we believe can go to 62 gigawatts, gigawatt-days per
22 ton. Thermal design margins are high in this plant.
23 And, therefore, the peaking factors can go up higher.

24 Negative reactivity feedback is pretty
25 standard, where their negative feedback for Doppler

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and moderator coefficient, temperature coefficient, is
2 also negative.

3 And the neutron steel reflector is added
4 to the design and has two major benefits. First of
5 all, it reduces slightly the enrichment requirements.
6 And, secondly, it reduces the fluence on the vessel.

7 So it has two significant benefits, very
8 simple design. You will see it a little later on.
9 But it also has both a safety and an economic benefit.
10 That's kind of unusual in safety space.

11 I mentioned the neutron reflector. This
12 is a series of, it is a build-up series of, pieces
13 that are stacked on one another. There is a
14 significant reduction in the number of bolts
15 associated with the design. If you look at the number
16 of bolts in the baffle/former design, it's like 2,000
17 that says maybe 50 bolts in.

18 So in terms of the number of components,
19 it's significantly different. It's very simple.
20 There's no magic about this. It's just basically a
21 block with holes in it. And so the thermal hydraulic
22 characterization, characteristics on this are very
23 simple, but it has we think a significant benefit to
24 the overall design, both in terms of economics and
25 safety.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You have asked from a computer code point
2 of view what we are doing different than what you have
3 seen in the past. What you are going to hear is an
4 answer to that. There are two codes that are
5 specifically Mitsubishi codes, both in fuel. Jeff
6 mentioned the FINDS code as one of them. We also have
7 the FINE code, which provides some of the fuel
8 parameters and characteristics.

9 We have provided topical reports for
10 these. And so you will have a lot of information to
11 review.

12 MEMBER ARMIJO: And, in particular, those
13 codes you are applying for a generic approval by the
14 --

15 MEMBER SIEBER: Yes.

16 MR. PAULSON: Yes.

17 MEMBER ARMIJO: Okay. We will definitely
18 want to look at those.

19 MR. PAULSON: In terms of the
20 methodologies that are used for a nuclear design, we
21 used PARAGON, which is a 2-D lattice physics code. I
22 think you have seen that already. Thermal hydraulics,
23 we're using VIPRE and WRB-2 correlations. And those
24 are familiar also and --

25 MEMBER BANERJEE: Those already you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 using approved codes or --

2 MR. PAULSON: Yes.

3 MEMBER BANERJEE: -- VIPRE? Okay. So
4 that's a Westinghouse code, right?

5 MR. PAULSON: Right. And the RTDP code
6 also thermal design procedures, statistical evaluation
7 I think has been something you have reviewed also.

8 MEMBER SIEBER: Right.

9 MEMBER BANERJEE: You are not using
10 NOTRUMP and things like that, just VIPRE?

11 MR. PAULSON: No. Just VIPRE.

12 MEMBER BANERJEE: Okay.

13 MR. PAULSON: The reactor coolant system.
14 Going through the key parts of the reactor coolant
15 system, they are slightly different. One is the
16 larger diameter and larger height of the reactor
17 vessel from a standard four-loop plant. It's the
18 same, by the way, as the APWR. So it's not something
19 that has not been evaluated for many years already in
20 Japan.

21 MEMBER SIEBER: Does that have the same
22 number of welds as the current plants?

23 MR. PAULSON: Roughly, yes. It doesn't
24 have any -- well, it doesn't have a weld in the
25 beltline. So it's --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Thank you.

2 MR. PAULSON: I haven't counted them, but
3 I know that there is no significant difference.

4 MEMBER SIEBER: Okay.

5 MR. PAULSON: Yamauchi-san, do any of the
6 Mitsubishi know? I think it's about the same number
7 of weld as a standard four-loop design, but I don't
8 want to say that.

9 MR. YAMAUCHI: I think so.

10 MR. PAULSON: Yes. Okay.

11 MEMBER ABDEL-KHALIK: The power-to-flow
12 ratio is higher than the current four-loop plant. How
13 does that affect the propensity for axial offset?

14 MR. PAULSON: Would one of the fuel people
15 address that? Oshi-san? There was a question on the
16 power-to-flow ratio being higher. And how does that
17 influence the axial offset? Do you know?

18 MR. HOSHI: My name is Masaya Hoshi, MHI.

19 The U.S. APWR flow rate is part of the
20 flow ratio. I mean, the flow ratio is a little bit
21 higher than the other standard plants. It grows to
22 some margin to some margin. And that's the only thing
23 that we can think of on the -- there are almost no
24 differences between those two.

25 MR. PAULSON: No difference in axial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 offset?

2 MR. HOSHI: No differences.

3 MEMBER ABDEL-KHALIK: The ratio between
4 power and flow is higher in the U.S. APWR than it is
5 for the current loop, for the current four-loop. Even
6 though the flow is higher, the power is higher --

7 MR. PAULSON: The ratio is higher by --

8 MEMBER ABDEL-KHALIK: Yes.

9 MR. PAULSON: He's saying it's close, but
10 he doesn't think there is an impact on --

11 MEMBER MAYNARD: I think we need to be
12 careful about drawing conclusions right now. And we
13 will have a chance to talk about that in more detail.
14 You can give some thoughts now, but I don't take that
15 as an official --

16 MR. PAULSON: Right. We reserve the right
17 to change our mind.

18 MEMBER MAYNARD: Right. And I think it's
19 something that we're going to be interested in when we
20 get into the fuel design and the fuel operation.

21 MR. PAULSON: Right. Any questions we can
22 handle in a more detailed meeting like that. That's
23 a fairly detailed question. But just off the top of
24 our heads, we can't think of a reason why it should.
25 But it shouldn't be major in any case.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Let's see. I think that's about it. I
2 did mention that there is a difference in this
3 difference in flow. This is the model 100 pump. This
4 is the model 93A pump. And pressurizer volume, there
5 is an additional margin in the pressurizer, which
6 provides a little additional comfort level with
7 respect to events that look at over-pressurization.
8 It's nice to have a little additional margin. And
9 that is built into the pressurizer volume.

10 MEMBER SIEBER: And trips, too. You don't
11 want to lose the level.

12 MR. PAULSON: Yes. Good point. This is
13 a little complicated, but I think there are just a few
14 points here. As we mentioned, this is a 4 by 50
15 percent. For large-break LOCA, this is the high-head
16 pumps. The high-head pumps have direct vessel
17 injection.

18 Advanced accumulator injects into the cold
19 leg. So if you can follow through on that, it's a
20 little hard in here to see the safety injection pumps
21 pumping here into the vessel, but you can see on the
22 green lines and coming in directly to the vessel. And
23 you can see the advanced accumulators, which are the
24 red dots here going directly into the cold leg.

25 You can see also that all of the pumps are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 outside containment but take suction from the
2 refueling water storage pit inside containment. So
3 that's the suction coming in each of the lines. You
4 can see that they're --

5 MEMBER BANERJEE: So the high-head pumps
6 are going into the hot leg or what?

7 MR. PAULSON: No, no. The high-head pumps
8 go into the vessel.

9 MEMBER SIEBER: Right.

10 MEMBER BANERJEE: Into the vessel?

11 MR. PAULSON: Direct vessel injection,
12 yes.

13 PARTICIPANT: Yes. After the injector, we
14 have change, right? That is under two after the
15 separation.

16 MEMBER BANERJEE: So it automatically
17 switches, right?

18 PARTICIPANT: No. Manual.

19 MEMBER BANERJEE: Manual switches. Okay.
20 What time is that?

21 PARTICIPANT: About four hours later.

22 MEMBER BANERJEE: Okay. Makes sense.

23 MR. PAULSON: This is your first
24 introduction to see what the advanced accumulator
25 unless you've peeked at some of our previous

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 literature, what it looks like with respect to
2 performance.

3 The advanced accumulator is identified as
4 advanced only because it uses a system where flow can
5 be changed in the design. So there's a time period at
6 which there is a high flow once the injection starts
7 and which continues to a point here, at which time it
8 switches to lower flow. And this is accomplished by
9 using a standpipe, which I will show you in some
10 additional slides what this specifically looks like.

11 But it is an early injection of a lot of
12 water into the vessel. It is intended to fill the
13 lower plenum and the downcomer so that immediately
14 with as high flow level from the advanced accumulator
15 performs that function and then later on performs a
16 function of supplying additional flow to maintain the
17 water level above what is necessary for the LOCA
18 evaluations. And then at some point in time, you can
19 see that most of the; in fact, all of the, flow comes
20 from the high-head pumps.

21 MEMBER STETKAR: What is the accumulator
22 injection setpoint, the accumulator injection
23 pressure?

24 MR. PAULSON: Well, the pressure is
25 proprietary information, but it's a nitrogen blanket.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I can say that. But it is in our documentation.

2 MEMBER STETKAR: Okay. Thanks.

3 MR. PAULSON: So, in any case, you can see
4 that what the accumulator does, this is how the U.S.
5 APWR performs with respect to what would have occurred
6 in the old design because this has both the low-head
7 pump and the high-head pumps. Here you have no
8 low-head pumps but only the safety injection,
9 high-head safety injection, and the accumulator.

10 The question is, why did we go to this
11 arrangement? We went to this arrangement because we
12 wanted to use -- and you will see this later on. We
13 wanted to use turbines, rather than diesel generators,
14 a little longer start time but highly efficient for
15 the plant. And it provides us the margin that we
16 needed early on to get additional water into the
17 system for LOCA evaluations.

18 MEMBER CORRADINI: Instead of making a
19 bigger accumulator? It is a bigger accumulator.

20 MR. PAULSON: Well, this is simpler
21 because you can control the flow that you need when
22 you need it.

23 These are the features of the advanced
24 accumulator. And, by the way, there has been a fair
25 amount of scale testing that has gone on for this,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 went on back in the mid 1990s because this was going
2 to apply and is applied as a part of the APWR design
3 in Japan.

4 But, in any case, the major components are
5 the anti-vortex cap, which if you had a chance to see
6 some of the testing that went on, which was visual
7 testing, you could see how this performs with respect
8 to maintaining the flow as the flow shifts.

9 The flow shifts, as you can see in this
10 chart. The flow shifts once the level of the
11 accumulator goes below the standpipe. Once it goes
12 below the standpipe, I will show you in a little later
13 slide, but you get only flow in one direction. When
14 you have flow through the standpipe, you actually get
15 it in two directions because you are seeing flow
16 coming in through the small flow pipe and from the
17 standpipe.

18 Once the level of the fluid in the
19 accumulator goes below the level of the standpipe, you
20 only get flow through the small flow pipe. That is
21 the one that actually uses the vortex chamber that
22 provides flow to the primary system but regulates that
23 flow using the vortex.

24 An example of what I just said, water
25 level is reduced. Water level is injected, both two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 different ways. It comes in. You can see it here.
2 This is a side entrance, which provides an angular
3 momentum to the fluid coming in through the small
4 inlet. This is coming in through the main pipe.

5 The sum of these two, then, becomes the
6 initial water that goes into the vessel. What this
7 does, basically by having two flows this way, there is
8 no angular momentum assigned to the water once it gets
9 into the pipe. So it flows directly into the primary
10 system.

11 Once you get to the point where the level
12 drops below the standpipe, you get flow only coming in
13 the side inlet. And it utilizes the vortex to provide
14 flow into the primary system.

15 MEMBER ABDEL-KHALIK: So gas can actually
16 enter the primary system before the accumulator is
17 fully discharged?

18 MR. PAULSON: No. Well, we've looked at
19 that. Part of the testing we have looked at is if gas
20 can injure. We haven't found any, but we did look to
21 see if we used saturated fluid, saturated with
22 nitrogen, to see if there was any impact.

23 And the impact was very small, but the
24 arrangement is such that there is no significant
25 amount of gas that can get into the primary system.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And there is a topical report that discusses it
2 specifically.

3 By the way, this was high interest by the
4 NRC also. So we turned in our advanced accumulator
5 topical as one of the earliest topicals. It went in
6 about the time of our QA.

7 MEMBER BANERJEE: So the level can never
8 fall below the side inlet, right?

9 MR. PAULSON: That is right.

10 MEMBER BANERJEE: How do you ensure it
11 never falls below the side inlet?

12 MR. PAULSON: Well, the available flow
13 that you have is such that it continues to -- well,
14 when you say, "never falls below the side inlet,"
15 eventually the side inlet goes to zero, but there is
16 always a head of water in the pipe which prevents gas
17 from going into the primary system.

18 MEMBER BANERJEE: So how do you ensure
19 that head of water?

20 MR. PAULSON: With the arrangement of the
21 pipe that is connected to the primary system.

22 MEMBER ARMIJO: Is there only one or are
23 there several of these accumulators?

24 MR. PAULSON: Four.

25 MEMBER ARMIJO: Four?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAULSON: There's one for every loop.

2 MEMBER BANERJEE: So let's say that the
3 nitrogen pushes out all the water and the side inlet
4 is uncovered. Now, is there no way that nitrogen can
5 then bubble up into that line?

6 MR. PAULSON: I'll let the expert handle
7 that.

8 MR. SHIRAIISHI: My name is Tadashi
9 Shiraishi. And I am the inventor of the advanced
10 accumulator.

11 Well, you know, the standpipe prevents the
12 nitrogen gas entrance into the injection pipe. So
13 there is no gas entrance if that is my --

14 MEMBER CORRADINI: Can I ask the question
15 differently? And then we can stop.

16 (Laughter.)

17 MEMBER CORRADINI: If I have a continual
18 loss of pressure in the primary system, I can't
19 understand how eventually I'm not going to have gas
20 flow-through.

21 I mean, if you equalize it, then I
22 understand. But if I have continual loss of pressure
23 in the vessel, eventually that nitrogen is going to
24 make it in. Okay? All right. Then we're on the same
25 page.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: I think it's obvious to
2 say that this will be an item of interest to the ACRS
3 review, also the topical report. And I think we will
4 have a chance to review some things in more detail.

5 Let's go ahead. Let's go ahead and move
6 on, yes.

7 MR. PAULSON: Okay. We can move on from
8 there. So in terms of the design features of the
9 high-head injection system, it's four independent
10 trains. And sufficient capacity for safety injection
11 meets safety injection requirement for the core
12 reflooding stage.

13 The difference between it I think we've
14 talked about already. It's the difference between two
15 trains and four trains, 2 100 versus 4 50 percent.
16 The design is such in all of these that we believe
17 that we will be able to operate with a single failure
18 and one pump out of service. And that's part of the
19 evaluation that we've put into our DCD. And it's
20 being evaluated by the NRC.

21 There's one additional feature of the
22 plant. And it's one of those additional things that
23 we don't utilize as part of the chapter 15 analysis,
24 but it's a feed-and-bleed capability that utilizes the
25 safety injection pump as a way of providing long-term

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 cooling, if necessary, without using other systems.

2 This just shows the arrangement of the
3 in-containment refueling water storage pit. As I
4 mentioned, the refueling water storage pit for both
5 the RHR pumps and --

6 MEMBER ABDEL-KHALIK: Can we go back to
7 the previous slide, please? You used natural boron.
8 Is it natural boron or enriched boron?

9 MS. ISHIDA: Natural boron.

10 MEMBER ABDEL-KHALIK: Okay. So what is
11 the critical boron concentration for a fresh core?

12 MS. ISHIDA: Mutsumi Ishida from MHI.

13 The boron concentration at the fresh core,
14 at the first cycle, is the most highest one. And it
15 is more or less 1,000 ppm.

16 MEMBER ABDEL-KHALIK: A thousand ppm?

17 MS. ISHIDA: Yes. It is because of the
18 use of -- it is because we use a lot of bundle
19 observer.

20 MEMBER ABDEL-KHALIK: Okay. Thank you.

21 MR. PAULSON: Okay? All right. Move on.
22 As I mentioned, the refueling water storage pit, both
23 the RHR system, which also is the core spray system as
24 part of the LOCA analysis, and the safety injection
25 pumps take suction from the refueling water storage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pit. These pumps are all outside the containment but
2 inside the reactor building, which is the protected
3 building for safety systems.

4 One of the important parts of this design
5 is that it's segmented into four designs. So most of
6 the systems, electrical and most of the mechanical
7 systems, are partitioned in such a way so that they
8 are in one quadrant of the reactor building.

9 We have conservative countermeasures. We
10 think for 191, it was interesting that we're coming on
11 the same day as you are dealing with this. We have
12 had numerous discussions with the NRC on this subject.

13 We think we have a very robust design for
14 the system. We have four redundant passive strainers,
15 sufficient surface area available for that strainer
16 design. We're going to use very low-debris type
17 material. We're not going to use -- we're going to
18 minimize the amount of fibrous insulation and utilize
19 primarily metal insulation and also to avoid
20 problematic chemicals. We're doing some chemical
21 testing this fall. NRC is planning on coming to view
22 those tests to confirm that the strainer design is
23 adequate.

24 MEMBER ARMIJO: What is that buffer,
25 sodium TB, on your chart? I'm just trying --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAULSON: Yes, I know. I know.
2 Sodium TB?

3 MEMBER CORRADINI: You have to identify
4 yourself and say it louder. I'm sorry.

5 MR. HAMAMOTO: This is Hiroshi Hamamoto
6 from Mitsubishi.

7 MEMBER CORRADINI: And louder. I don't
8 think the recorder got it. Repeat it, please.

9 MR. PAULSON: Repeat your name.

10 MR. HAMAMOTO: Hiroshi Hamamoto.

11 MEMBER CORRADINI: And the answer?

12 MR. HAMAMOTO: Sodium hydrate tetraborate.

13 MR. PAULSON: Emergency feedwater system
14 has four pumps. There are two turbine-driven, two
15 motor-driven pumps. They're each dedicated to one
16 steam generator unless one of them is out of service.

17 Then there are cross-links for those.
18 There are two separate pools from which the water can
19 be drawn, each 50 percent pools. They also are
20 connected so that any of the pumps can get water from
21 either of the sumps.

22 MEMBER SIEBER: In four separate fire
23 areas.

24 MR. PAULSON: Four separate fire areas.
25 Well, they are separated, but they are not separated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 into quadrants. You can look at that when you see the
2 reactor building.

3 MEMBER SIEBER: If one catches fire, will
4 it set another one on fire?

5 MR. PAULSON: No. I think they are fire
6 barriers.

7 MEMBER SIEBER: It's walls, as opposed to
8 --

9 MR. PAULSON: Correct. Quadrants, right.
10 The emergency feedwater system is a 4-train
11 configuration, as I mentioned, 2 motor-driven, 2
12 turbine-driven, each 50 percent. Two safety-grade
13 independent feedwater sources are available. Those
14 two pits are both 50 percent pits, as I mentioned. So
15 I think I have covered most of the material on this
16 slide already.

17 MEMBER STETKAR: Does the water capacity
18 in the pits combined have enough for 24-hour decay
19 heat removal?

20 MR. PAULSON: Yes. It's designed for
21 2,400, I think, at out standby.

22 MEMBER STETKAR: Thank you.

23 MR. PAULSON: I mentioned the gas turbine
24 earlier. This is always an interesting subject
25 because it's somewhat new for the United States. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 approach is a little bit differently normally.

2 We have gone to this for a number of
3 reasons. We think that these turbines are highly
4 reliable. They haven't been used for nuclear
5 applications, but they have been used for other
6 applications.

7 And we have gone through a series of tests
8 that we're providing a technical report on that will
9 be used by the NRC to evaluate this type of pumping
10 system.

11 But we use it because of the reliability
12 that we have and the ease of maintenance. They are
13 very simple pumps compared to normal pumps. So there
14 are advantages to this. We know it's a subject that
15 may be of interest to you also, and it is being
16 reviewed closely by the NRC also.

17 We have also, by the way, had a training
18 seminar for the NRC on these pumps that we completed
19 a month or so ago.

20 MEMBER BLEY: They are turbine generators?

21 MEMBER STETKAR: Turbine generators,
22 right?

23 MR. PAULSON: Turbine generators. I'm
24 sorry.

25 MEMBER STETKAR: I understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Does that information have
2 extensive testing? I'm familiar with some other
3 previously used emergency gas turbine generators whose
4 reliability to start wasn't so great.

5 MR. PAULSON: We're aware of that data,
6 actually. And I think we have data that supports that
7 this is high-performance --

8 MEMBER BLEY: Docket.

9 MR. PAULSON: Right.

10 MR. KAWANAGO: This is Shinji Kawanago
11 from MHI.

12 We have already submitted one technical
13 record, which included our reliability data and
14 especially other emergency gas turbine system.

15 MEMBER ARMIJO: Have you used such turbine
16 generators in your Japanese plants?

17 MR. KAWANAGO: I am again Shinji Kawanago.

18 In Japan, we have one experience, only the
19 one experience, to supply the gas turbine engineering
20 to the other emergency system for the nuclear
21 background.

22 MEMBER ARMIJO: It has operated with
23 license in Japan?

24 MR. KAWANAGO: Yes, but it is not a
25 commercial nuclear power plant. It is a test nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power plant.

2 MEMBER SIEBER: We will all ponder
3 reliability where applied.

4 VICE CHAIRMAN BONACA: How many gas
5 turbines do you have? Four?

6 MR. KAWANAGO: Four, yes. Other emergency
7 --

8 VICE CHAIRMAN BONACA: Or emergency.

9 MR. KAWANAGO: In addition, two of the --

10 MEMBER MAYNARD: Where is the fuel supply
11 for this kept? Is it big tanks or --

12 MR. PAULSON: Tanks.

13 CHAIRMAN SHACK: This is seismically
14 qualified?

15 MR. PAULSON: It has to be. It will be in
16 part of the building that is considered an extension
17 of the reactor building.

18 MEMBER MAYNARD: By gas, I take it you're
19 talking either natural gas or propane?

20 MR. KAWANAGO: In a few areas, we use the
21 same fuel, diesel generator. That means that --

22 MEMBER MAYNARD: Okay.

23 MR. KAWANAGO: We use this gas turbine,
24 but a few areas of --

25 MEMBER MAYNARD: Like an airplane engine.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: It gets into the
2 combustion chamber.

3 MR. PAULSON: Let's hope.

4 MR. KAWANAGO: Kerosene or diesel.

5 MEMBER MAYNARD: Right, yes.

6 MR. PAULSON: Just some of the benefits of
7 using the gas turbine. I think I have identified most
8 of these already, but there is a space benefit, no
9 cooling required, it's easily maintained.

10 It's a very simple system. We don't think
11 that that is true of the diesel generator and the
12 performance and reliability and start time now. The
13 start time is the issue we're dealing with
14 specifically with the advanced accumulator. Okay?

15 Forty seconds is typical, but in the
16 analysis that we perform for LOCA, we use 100 seconds
17 so that there is significant margin between the 40
18 seconds we think is the right number for this start
19 time, as opposed to what we used in the safety
20 analysis.

21 There is not too much significant I think
22 about this. You have probably seen that slide a
23 number of times already with respect to the design of
24 the containment. This is a pre-stress concrete
25 vessel. And the design is very standard, I think. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 does have a liner.

2 And it's a fairly large containment. I
3 think it operates under a slightly negative pressure,
4 if I'm not mistaken.

5 MEMBER SIEBER: Yes.

6 MR. PAULSON: And the size of the
7 containment is indicative of the size of the
8 components and so forth that we're using for the
9 plant. Just, by the way, the design pressure for the
10 containment, since you'll see it later on in any case,
11 is 68 psi, psig.

12 The methodologies. You asked about
13 computer codes and are interested in them. I think
14 that this has been addressed already by the NRC in
15 their presentation, but just to mention the fact that
16 these are not computer codes that you have -- you have
17 seen these computer codes already I think is the best
18 way to say it.

19 WCOBRA/TRAC I think and ASTRUM are known
20 to the NRC and approved by the NRC for large-break,
21 for small-break MRELAP. Now, M means that Mitsubishi
22 has made slight changes in the code to account for,
23 for example, the advanced accumulator and for direct
24 vessel injection.

25 Those are the only changes that we have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 made to it from what you have already reviewed. So
2 that the only significant differences from what you
3 would see would be for the modeling of those systems
4 that are slightly different from what has been used
5 past in the those codes.

6 Mass energy release, the same comment
7 applies for SATAN or WREFLOOD and GOTHIC. The only
8 modifications are relative to the design changes that
9 we have used. Containment pressure, GOTHIC once again
10 is a widely known code and I think one that has been
11 well-reviewed already by the NRC.

12 For the non-LOCA codes, we are using
13 MARVEL, which is a code a lot like LOFTRAN, actually.
14 It has many similarities. The modifications that have
15 been made to that code from the versions that have
16 been reviewed by the NRC, which goes back, by the way,
17 quite a ways, goes back into the mid 1970s, in any
18 case, the modifications have been to take it from a
19 single loop or two-loop configuration to a four-loop
20 configuration as somewhat similar to what LOFTRAN has
21 done going from one loop to four loops. Other than
22 that, it's basically the only change. TWINKLE I think
23 has been reviewed on numerous occasions and VIPRE
24 also. The sump channel analysis are all codes that
25 have been reviewed by the NRC. RADTRAD, PWR-GALE I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 think are widely used in the industry also for dose
2 evaluation.

3 Severe accidents. The U.S. APWR achieves
4 a high level of safety comprehensively addressing
5 severe accidents and mitigate the consequences,
6 demonstrate compliance with the NRC regulations,
7 including TMI requirements. We also can demonstrate
8 resolution with respect to unresolved safety issues
9 and high-priority generic items also.

10 A little complicated design, but it shows
11 some of the features associated with protection for
12 severe accidents. Specifically there is a reactor
13 cavity area under the reactor vessel that can be
14 flooded if there are events that are of concern with
15 respect to penetration of the vessel. So that
16 provides for. There are redundant sources of water
17 for that, for that area.

18 And evaluations are performed -- I think
19 it's part of chapter 19 -- with respect to performance
20 of this under a number of circumstances, which are
21 listed here: hydrogen generator, core debris, steam
22 explosion, high-pressure melt ejection because of the
23 no penetrations in the bottom and steam generator tube
24 ruptures as temperature-induced tube rupture and
25 molten core-concrete interactions, long-term

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 containment over-pressure. All of these have been
2 addressed as part of our evaluation.

3 MEMBER CORRADINI: So may I ask just one
4 clarifying question? So the way you have the colors
5 and the cartoon, is it the accident management plan to
6 flood up to the vessel for in-vessel retention or is
7 that just the way it's cartoon-colored?

8 MR. PAULSON: No. It would be flooded up
9 to that level. This is the level that it would be
10 flooded up to.

11 MEMBER CORRADINI: So for the purposes of
12 trying to keep the core inside the vessel or just
13 because that is the way the geometry --

14 MR. PAULSON: It depends on the accident.
15 There are some accidents that you could probably
16 identify that you could penetrate the vessel first
17 possibly.

18 MEMBER CORRADINI: Okay. So that's more
19 a matter of geometry than a matter of plan?

20 MR. PAULSON: No.

21 MEMBER CORRADINI: I'll stop asking.

22 MR. PAULSON: In any case, we have looked
23 at both cases, where there is a debris that hits the
24 floor before there is any water in there. So the
25 water is not in there to start out with and then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 floods.

2 MEMBER CORRADINI: So I will ask my
3 question in general and just leave it there.

4 MEMBER POWERS: I thought you said you
5 were going to stop.

6 MEMBER CORRADINI: I didn't say when.

7 (Laughter.)

8 MEMBER CORRADINI: The reason I ask that
9 is because in other design certifications we have
10 seen, certain applicants intentionally flood above for
11 in-vessel retention and others intentionally keep it
12 as dry as possible. So I'm trying to ask you, are you
13 either or potentially both? So what is your intent
14 from a design for accident management standpoint?

15 MR. PAULSON: Kawai-san?

16 MR. KAWAI: This is Katsunori Kawai of
17 MNES.

18 We think in-vessel retention has much
19 uncertainty. So we don't expect in-vessel retention
20 to merit.

21 MEMBER CORRADINI: Okay. And your water
22 management? If I might just ask you to finish your
23 thought process? So your water management depends on
24 the accident sequence or do you want to keep the
25 cavity region dry? What is the thinking process?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KAWAI: Recirculating storage water
2 coming into safety injection pump and spray pump. At
3 first this water goes into the cavity. In case of
4 failure of this water input, we use fire water. This
5 is manual operation. Fire water will be inputted
6 going to the cavity.

7 MEMBER CORRADINI: Okay. Thank you.

8 MEMBER BANERJEE: Just a question. It's
9 not a severe accident question. Where are you putting
10 your sump screens for long-term recirculation?

11 MR. PAULSON: They are right here. Do you
12 see this? That is one of them right there, would be
13 right there. There are sumps so that the --

14 MEMBER BANERJEE: They are actually the
15 screens within the sump?

16 MR. PAULSON: Over the sump.

17 MEMBER BANERJEE: Over the sumps?

18 MR. PAULSON: Right.

19 MEMBER BANERJEE: All around? How large
20 are the --

21 MR. PAULSON: Just over the sumps. There
22 are four sumps that the pumps take suction on. It's
23 overload.

24 MEMBER MAYNARD: Are they fairly large
25 sumps? That's okay. That's some detail we can get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 into --

2 MR. PAULSON: I don't know. I can't
3 define. I don't know the exact volume.

4 MEMBER BANERJEE: Just one more question.
5 Your insulation is RMI, I hope, and not caliceal or
6 Nukon?

7 MR. PAULSON: Right. Well, we are going
8 as much as possible to metal insulation, as opposed to
9 fibrous. You would only use fibrous if there were
10 some unique reason for it.

11 MEMBER MAYNARD: Sanjoy, you were out.
12 There's a specific slide where he covered that. And
13 he cut what materials they're trying to avoid and what
14 materials they're trying to use there.

15 MEMBER BANERJEE: And you have a buffer.

16 MR. PAULSON: Yes. You thought the last
17 slide was complicated.

18 (Laughter.)

19 MEMBER MAYNARD: Digital I&C folks need to
20 wake up now.

21 MR. PAULSON: Right. That's right. There
22 it is. It's all right there. I'm not the expert on
23 I&C. I'll give you just a quick review. And if you
24 are interested in specifics, we have an expert here.

25 There are three separate areas to look at.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 One is DAS, which is the Diverse Actuation System,
2 which is part of the protection for common mode. We
3 have the protection area, which is this area. And
4 here is the controlled area.

5 You can see that there are four separate
6 systems with direct lines up through each of the
7 protection cabinets and then into the control room,
8 which is identified here. And there are also direct
9 lines of information coming down to the remote
10 shutdown panel, which is identified here.

11 There are, like I said, three basic
12 systems we're looking at: DAS; the protection system;
13 and the control system, which is this area over here.

14 MEMBER BLEY: A question, but it's kind of
15 related to what Jeff showed us earlier. From what you
16 have told us, this I&C system is now installed in the
17 new plant. And it's funding the same one here.

18 Jeff's package talked about the topical
19 report on the I&C design process, which is what we
20 usually see for plants. Is the actual I&C system
21 submitted as part of the design cert?

22 MR. PAULSON: Yes.

23 MEMBER BLEY: Okay. So the actual system
24 is part of that?

25 MR. PAULSON: Right. And, in fact, one of

1 the things if you get interested enough, we actually
2 have a simulator of the control room now in the U.S.

3 MEMBER SIEBER: In Pittsburgh.

4 MR. PAULSON: In Pittsburgh that was
5 looked at by -- well, NRC looked at it this week.
6 Yes.

7 MEMBER BLEY: And it's this one?

8 MR. PAULSON: Yes.

9 MEMBER BLEY: Oh, cool.

10 (Laughter.)

11 MR. PAULSON: Larry, would you like to --

12 MR. BURKHART: We went to visit this week.

13 MEMBER BLEY: This week?

14 MR. BURKHART: Yes, just a couple of days
15 ago. It's not exactly 100 percent the same. And I'll
16 let that up to MHI to discuss. It's we were told very
17 similar. It's the simulator for the plant that has
18 the system now. But it's not a four-loop redundant
19 plant, the simulator. So there are some differences,
20 although we've been told it's very, very similar. So
21 it's not exactly U.S. APWR.

22 MEMBER MAYNARD: It would be interesting.
23 I think it would add some value.

24 MR. PAULSON: Pardon?

25 MEMBER MAYNARD: I was just saying it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something I think at least part of the Committee would
2 be interested in. And perhaps at some point we would
3 like to go take a look at it, too. But we will talk
4 about that later. That's --

5 MEMBER SIEBER: You'll like Cranberry.

6 (Laughter.)

7 MR. BURKHART: I would just second that.
8 It is well worth the visit to see it.

9 MEMBER BLEY: One last related question.
10 Is this I&C system analyzed in your PRA?

11 MR. PAULSON: This I&C system?

12 MEMBER BLEY: Yes.

13 MR. PAULSON: As far as I know.

14 Takashima?

15 MR. TAKASHIMA: My name is Makoto
16 Takashima.

17 This I&C system is considered in the PRA,
18 including some kind of factors, including. Our PRA is
19 best on these systems.

20 MEMBER BLEY: And the topical data report
21 you told us about includes the data --

22 MR. TAKASHIMA: Yes, topical data is
23 included in PRA report.

24 MEMBER BLEY: Thank you.

25 MR. PAULSON: This is the control room

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that you would see in the mock-up of the control room
2 and the simulator that you would see up in Cranberry.
3 I think we've talked about it enough, but it shows the
4 different locations and supervisor panel, the operator
5 panel, and the large display panels and the location
6 of where the diverse panel will go in the future.

7 Just a couple of the features.
8 Microprocessor-based digital technology for I&C, no
9 mechanical relays, complete FORTRAN redundancy,
10 distributed architecture, fully multiplexed and
11 duplicated signal transmission for I&C equipment rooms
12 and main control room, and between the I&C systems,
13 common digital platform.

14 We actually have a submittal to the NRC on
15 the platform, which is called MELTAC, that you can
16 look at. It's a topical report that has been
17 submitted and a fully computerized main control room,
18 touch screen, by the way. The design is touch screen.

19 MEMBER SIEBER: Thank you.

20 MEMBER BLEY: Is there anywhere in
21 operating plants where the kind of displays and touch
22 screen facilities you are talking about are currently
23 in use?

24 MEMBER SIEBER: Yes.

25 MR. PAULSON: Do you want to answer that,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Takashima-san?

2 MR. TAKASHIMA: No. We operate this all
3 the same numerus in new plants. No. We have no
4 operating plants.

5 MR. KAWANAGO: Now we have a plant.

6 MR. TAKASHIMA: Actual plant we will
7 present later, operating plants.

8 MR. KAWANAGO: He wants to show on our
9 next slide.

10 MEMBER BLEY: Okay.

11 (Laughter.)

12 MR. KAWANAGO: Thank you.

13 MR. PAULSON: Okay. The non-safety
14 applications are the following. Do you want to get
15 into this, Takashima-san, as to the history? You
16 mentioned that it came on the next slide, and there
17 were certain things maybe you could mention.

18 MR. TAKASHIMA: I'm sorry. It's on the
19 next slide.

20 MR. PAULSON: This shows, as I mentioned
21 early on, we were going to show the development
22 history to show that we weren't just shoving this into
23 the U.S. APWR, that there has been a history over the
24 course of roughly the last 20 years of developing the
25 design and also implementing it, primarily in the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 non-safety systems.

2 But now later on we're moving very, very
3 swiftly into the safety systems. And the first
4 installation of the design has been completed. The
5 installation has been completed in the Tomari design.

6 I mentioned the MELTAC platform. This is
7 developed by a sister part of Mitsubishi called MELCO,
8 Mitsubishi Electric Company, and is currently under
9 review by the NRC. The application in Japan has been
10 for emergency safeguard features that will be at
11 Tomari. Another application will be at Tsuruga. This
12 is the APWR design.

13 Ikata 1 and 2 in 2009, Takahama units over
14 a period of time, and Ohi also, where there will be
15 upgrades to the package well prior to the use of this
16 in the first U.S. APWR.

17 MR. BURKHART: And, Keith, just to make a
18 clarification on the simulator in Warrendale, we were
19 told that the simulator is the Ohi simulator. Is that
20 correct?

21 MR. TAKASHIMA: It's based on Ohi 1 and 2.

22 MR. BURKHART: Okay. Thanks.

23 MR. TAKASHIMA: Three and 4. Excuse me.

24 MR. KAWANAGO: And the other question,
25 basically the unit 3 -- my name is Shinji Kawanago.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 These are from the bottom three: the Ikata, the
2 Takahama, and the Ohi. This one is actual operation
3 up front. And we have the plant to upgrade by using
4 this same platform.

5 MR. PAULSON: A significant amount of V&V
6 testing went on for the development in Japan. This
7 outlines some of that. The development began in '97,
8 the V&V testing, three times the Japanese utility ship
9 operators from 12 sites, full-scale simulator.

10 MEMBER BLEY: Is there a technical or
11 topical report on the operator performance in these
12 tests?

13 MR. TAKASHIMA: All together describes
14 these kinds of experiences.

15 MEMBER BLEY: I didn't understand.

16 MR. TAKASHIMA: Yes.

17 MR. PAULSON: And we plan on doing
18 basically the same thing. As we said, the first
19 application was in Tomari, Tsuruga, and Ikata for
20 modernization. Let's move on to the next slide. We
21 plan on doing something very similar in the U.S.,
22 where we are going to do the human interface,
23 human-systems interface, verification, and validation
24 with U.S. operators.

25 We will do a dynamic evaluation will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 performed for full-scale for eight U.S. operating
2 crews in the following areas. We will establish a
3 design specification and, with those results, will
4 provide a technical report this year. The NRC staff
5 will visit into the mapping site. We put down that
6 they visited it two days ago and demonstrated plant
7 operation for that simulator.

8 Well, conclusions are similar. The U.S.
9 APWR is based on the APWR. The reason that is
10 important is because of the amount of testing that
11 went on on the APWR that I mentioned earlier. The
12 U.S. APWR, 1,700 megawatts, which is primarily due to
13 the improved performance of the turbine. It's using
14 known technology that we will do some additional
15 testing on to validate the performance of the turbine.

16 And the U.S. APWR has been designed to
17 meet all U.S. utility requirements and all U.S. safety
18 requirements, as indicated in reg guide 1.206.

19 MEMBER MAYNARD: I would like to go back.
20 Now we have a little bit of time if anybody has any
21 questions on what we have gone over, a little more
22 discussion. Sam?

23 MEMBER ARMIJO: Yes. I may have missed
24 it, but when you had your comparisons of the current
25 U.S. four-loop plants with the APWR and the U.S. APWR,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 could you tell us the temperatures and pressures of
2 the APWR compared to, let's say, the conventional
3 U.S.? Specifically, have you increased T-hot and
4 pressure in order to get more efficiency?

5 MR. PAULSON: The pressure is the same,
6 2,250. Temperatures are comparable, right.

7 MEMBER ARMIJO: Right.

8 MR. PAULSON: I'm trying to think what the
9 hot leg temperature is. The inlet temperature is
10 around 555 Fahrenheit.

11 MEMBER ARMIJO: And T-hot?

12 MR. PAULSON: I think T-average in the
13 core is 587. So just take that ratio. It's 32
14 degrees. It puts it right in the range of known
15 operating plants.

16 MEMBER ARMIJO: Thank you.

17 MR. PAULSON: Yes?

18 MEMBER STETKAR: Did you mean T-ave is
19 587? That is a little high.

20 MR. PAULSON: That is in the core. That
21 is not exit.

22 MEMBER STETKAR: You said T-ave. Did you
23 mean T-ave?

24 MEMBER SIEBER: That is what he meant.

25 MR. HOSHI: My name is Masaya Hoshi.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I am talking about that the temperature
2 temperature. We are keeping the T-hot as 325 DUC.
3 That is our common design. So APWR and the U.S. APWR,
4 those two plants are the same T-hot designs. The flow
5 rate is different. So the T-operation, T-inlet might
6 be different, but T-hot is the same.

7 MEMBER MAYNARD: That makes it very
8 comparable to what the current U.S. --

9 MEMBER SIEBER: Yes, that's what he said.

10 MEMBER MAYNARD: -- 555, 585 to T-ave and
11 about 617 or so for T-hot.

12 MR. PAULSON: It's about the same. I
13 think that was the question, was the pressure and the
14 temperature about the same.

15 MEMBER MAYNARD: Right, right.

16 MR. PAULSON: And the answer to that is
17 yes.

18 MEMBER SIEBER: It's within a degree of
19 the upgraded Millstone plant.

20 MEMBER BANERJEE: I have a question on
21 your slide where you showed ECCS and CSS/RHRS if you
22 can go back to that.

23 MR. PAULSON: Do you have the number on
24 it?

25 MEMBER BANERJEE: I can't see number.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PAULSON: It's a little number in the
2 lower right-hand corner, that last number.

3 MEMBER BANERJEE: Seventeen. If you look
4 at that, it seems -- since there is no scale, it is
5 hard to say, but it seems that you have lower amount
6 of flow in the long term anyway that is your current
7 strategy than when you had a low-head injection pump
8 with the control flow loop design. Is that true or is
9 that just an optical illusion based on not having --

10 MR. PAULSON: How is the flow compared to
11 the standard four-loop design long term compared to
12 what we have?

13 MEMBER BANERJEE: Not even long term, even
14 relatively in the short term. Since there is no
15 scale, it is hard to know. Yes. It goes from about,
16 you know, wherever that green thing takes over on the
17 left-hand side.

18 MR. PAULSON: We can get an answer to that
19 question. I think there was much different. It had
20 to meet cool-down requirements.

21 MEMBER BANERJEE: Yes. So I don't know
22 what. Since there is no scale, it is impossible to
23 tell, but qualitatively it seems that you are going to
24 have less flow.

25 MR. PAULSON: Well, some of the scales on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this are proprietary, but they're in the report.

2 MEMBER MAYNARD: I would think it would be
3 lower until long term, when you end up putting RHR on
4 for the longer-term cooling because compared to the
5 current, you've got RHR and your is pumps. And on the
6 U.S. APWR, you only have the safety injection pump.
7 You don't have the RHR at that point. So I would
8 think the flow would be --

9 MEMBER SIEBER: The available flow is
10 lower, but it meets the requirement.

11 MEMBER BANERJEE: It may meet the
12 requirement, but, nonetheless, I mean, if we could see
13 quantitative. At some point we are going to see some
14 quantitative numbers --

15 MEMBER SIEBER: Right.

16 MEMBER BANERJEE: -- on pressure,
17 injection pressures, all these things.

18 MEMBER SIEBER: Right. Get that in closed
19 session.

20 MEMBER BANERJEE: When is that going to
21 be? I mean, hopefully not too far down the line so we
22 are apprised of what is really different about this
23 design because this is very different not having a
24 low-pressure injection system. We're seeing this in
25 another design, where we don't have a high-pressure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 injection system.

2 MEMBER MAYNARD: Every one of the
3 revolutionary designs is going to have something that
4 we're not --

5 MEMBER BANERJEE: Is it safe, though? I
6 always feel that the more water you can get in, the
7 better.

8 MEMBER SIEBER: Yes, until --

9 MEMBER MAYNARD: We want everything.

10 MEMBER SIEBER: It depends on what the
11 cost is.

12 MEMBER MAYNARD: We will be looking at
13 schedules on what time we look. You know, some of
14 this, as far as the chapter review stuff, that is
15 going to be quite a ways down the road.

16 Some of the topical reports, some of the
17 specific topics, we're going to be looking at what do
18 we need to be looking at sooner with various
19 subcommittees and things there.

20 MEMBER ABDEL-KHALIK: What codes do you
21 use to analyze subcooled boiling, crud deposition, and
22 boron deposition in the hot channels?

23 MR. PAULSON: Who would be the best to
24 answer that?

25 MR. KIKOTA: Excuse me? Could you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: What codes do you
2 use to analyze subcooled boiling, crud deposition, and
3 boron deposition in the hot channels?

4 MR. PAULSON: Computer codes.

5 MR. KIKOTA: My name is Michitaka Kikota,
6 MHI.

7 Boron, we use an input calculation code
8 which is made for following the NRC requirement. What
9 is the question? I cannot understand.

10 MEMBER ABDEL-KHALIK: I am trying to
11 figure out, how do you determine how much boron
12 actually or how much crud deposits in the upper part
13 of the core and how much axial offset do you get?

14 MR. PAULSON: How do we calculate crud
15 deposition and how much is it? Do we know? Do we
16 have a --

17 MR. TESHIMA: I am Hideyouki Teshima from
18 MHI.

19 With regard to axial offsets, I think
20 there are three factors for the AOA. The first one is
21 the solution of the crud.

22 MEMBER ABDEL-KHALIK: I understand. I am
23 asking what codes do you analyze that.

24 MR. TESHIMA: In the FIND codes, the raw
25 design code, we assume some of the crud deposition in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the calculation.

2 MR. PAULSON: That is one of the unique
3 codes. And it's one that we have written a topical
4 on. That is available.

5 MEMBER APOSTOLAKIS: Can we go to slide
6 40? Could you explain a little bit what you mean by
7 HSI verification and validation has been conducted and
8 then the second bullet as well?

9 MR. PAULSON: Bullet 1 and bullet 2, what
10 we're planning on doing --

11 MEMBER APOSTOLAKIS: Briefly what --

12 MR. TESHIMA: We are now planning
13 verification and validation of our standard HSI design
14 and standard human considerations by U.S. operators
15 from Luminant.

16 MEMBER APOSTOLAKIS: What does it mean to
17 verify and validate?

18 MR. TESHIMA: Now we plan to do six
19 actions: CTR events, heat-up and cool-down of the
20 operation, these kinds of simulated operations. We
21 operate by U.S. operator and we validate/verification.
22 We provide verification and validation of our design.

23 MR. KAWANAGO: In addition to verification
24 --

25 MR. TESHIMA: Oh, verification and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 validation of our standard design of the HSI systems.

2 MR. KAWANAGO: Validation and
3 verification.

4 MR. TESHIMA: Oh, verification and
5 validation. Okay. I think verification and
6 validation means U.S. operator using our simulator to
7 treat after the accident. Okay? By using the actual
8 simulator and touch our display and using our system
9 on those, using our main control board.

10 MEMBER APOSTOLAKIS: That sounds more like
11 a training.

12 MR. TESHIMA: Yes, yes. No, not training.

13 MEMBER APOSTOLAKIS: How is it
14 verification? I don't understand what verification
15 means.

16 MR. TESHIMA: On each step operator using
17 our display. And our display, also scheme, total
18 design of our main control board is enough to apply
19 U.S. operating plant by verify by U.S. operator.

20 MR. KAWANAGO: This is Shinji Kawanago.

21 I will try to explain a little bit. Now,
22 as we have explained, we already have the actual
23 design of a system. We have already applied to the
24 Japanese nuclear power plant. And so we already have
25 the actual display and also procedure how to use the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 main control board, feature private computer,
2 computerized system.

3 However, -- and we know to apply that to
4 the design. And to the U.S. operator and U.S.
5 operator have some preference and also some specific
6 request for us.

7 So maybe the culture between the Japan and
8 United States, there is some difference. And so we
9 need to verify that our actual design is applicable to
10 the U.S. operator or not. And maybe there is some
11 modification we need.

12 And so we call that one verification and
13 validation by U.S. operator.

14 MEMBER APOSTOLAKIS: Now, if we go to the
15 fourth sub-bullet under the second bullet, "Normal and
16 degraded HSI conditions" --

17 MR. TESHIMA: This meaning the -- we have
18 two types HSI systems. One is non-safety systems,
19 normally operator using non-safety systems. That's
20 non-safety systems can operate non-safety and also
21 safety equipment. But this is a non-safety system.

22 And if we assume a total failure of the
23 non-safety system, we still have safety, safety-grade
24 HSI. So the safety can keep the safety I&C. We want
25 to demonstrate these kinds of situations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: And there will be
2 some report of this?

3 MR. TESHIMA: Yes. And also we provided
4 the actual report of the result of these kinds of
5 operations by the end of this year.

6 MEMBER APOSTOLAKIS: Thank you.

7 MEMBER ABDEL-KHALIK: Can I follow up on
8 George's question? What kind of data are you going to
9 collect during this verification and validation
10 process?

11 MR. TESHIMA: I think the data, first is
12 operator comment. We gather the operator comment for
13 our design. And also we measure the actual operator
14 performance, time, touching time, and the operator
15 performance we measure.

16 MR. PAULSON: If you look at the
17 information that's supplied on the board, you will see
18 that the procedures are there. So you can see if the
19 procedures are there, you could compare that with what
20 the procedures indicate the operator to do. And you
21 can look at the times.

22 That is one thing that Takashima is
23 focusing on, is how well can a U.S. operator perform
24 functions associated with the procedures as
25 identified? That is a key measure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 The other issue I think that Mr. Kawanago
2 mentioned is to look specifically at the differences
3 between U.S. performance and what U.S. operators are
4 looking for in terms of information that they need to
5 perform certain functions that are in the procedures?

6 Those types of things will be recorded
7 also and factored into the final design.

8 MEMBER ABDEL-KHALIK: So the emergency
9 operating procedures for this plant have already been
10 developed?

11 MR. PAULSON: There are procedures for
12 operation of the plant that have been developed in
13 Japan.

14 MR. TESHIMA: Excuse me. On this
15 verification and validation, it would be current,
16 based on current plant. And we also we already have
17 the emergency operating procedures for this plant. So
18 by using these operating procedures, we will have this
19 kind of verification and validation.

20 This verification and validation process
21 is to check our standard HSI design for operating
22 plant and U.S. APWR. The actual validation and
23 verification for U.S. APWR will be performed later by
24 using actual U.S. APWR simulator and actual U.S. APWR
25 displays and actual U.S. APWR EOP. These kinds of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 activities will be performed next week. This is based
2 on the standard.

3 MR. KAWANAGO: This is Shinji Kawanago.

4 I want to expand a little bit. As we
5 explained to you, we have already had huge experiment
6 data, which was conducted in Japan, to make sure on
7 this human-system interface.

8 For example, the Japanese operators have
9 already used this one. And we check the monitor, the
10 actual time, during the accident. And so through
11 those processes, we developed this human-system
12 interface.

13 And so we have already furnished the
14 simulator in the United States. And we want to
15 compare the previous data in Japan and test the data,
16 which is conducted by the American operator. We want
17 to compare.

18 And if there is no significant difference,
19 that means this human-system interface is good. But
20 if there is some difference, we need to modify our
21 standard design for this U.S. APWR.

22 After that and, actually, it is we develop
23 the actual design for the U.S. APWR again. But,
24 anyway, of course, we need to do the actual standard
25 design for the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER APOSTOLAKIS: It sounds to me like,
2 instead of verification and validation, the
3 appropriate word is "adaptation."

4 MR. KAWANAGO: Adaptation.

5 MEMBER APOSTOLAKIS: Verification and
6 validation is --

7 MEMBER SIEBER: It has another meaning.

8 MEMBER APOSTOLAKIS: You are adapting it
9 to American --

10 MEMBER BLEY: Will those U.S. tests be
11 done as part of this design certification or will that
12 come later?

13 MR. KAWANAGO: Yes. It is part of the
14 DCD.

15 MR. TESHIMA: This test is part of the
16 DCD.

17 MEMBER BLEY: Okay.

18 MR. TESHIMA: So we will provide the
19 report in the DCD.

20 MR. BURKHART: Well, I recommend when you
21 go to your visit to the simulator that -- we had a
22 very good presentation on what MHI proposes to be
23 submitted and what is going to be done when, although
24 -- correct me if I am wrong, Mr. Kaneda -- I believe
25 the HSI task analysis for the U.S. APWR isn't going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 be done until 2012.

2 So just take away from this I recommend
3 going on that visit because it is well worth it. And
4 MHI can lay out what they expect to submit when. Now,
5 I will tell you that based on our visit, we have some
6 questions.

7 But I think that would be very revealing
8 on what their intentions are in this area.

9 MEMBER MAYNARD: One more question, and we
10 will be done.

11 MEMBER ARMIJO: I presume the fuel for
12 this plant will be manufactured in Japan.

13 MR. KAWANAGO: Yes.

14 MEMBER ARMIJO: And I guess the question
15 I have to the staff is, what is the NRC's involvement
16 regarding the fabrication facilities in Japan? Is it
17 hands-off? Is there some sort of an audit or review?

18 MR. BURKHART: We are already inspecting.
19 We have vendor inspections going on already over in
20 these facilities.

21 MEMBER ARMIJO: Is it the same thing you
22 would do, for example, from a fuel supply from a U.S.

23 --

24 MR. BURKHART: I imagine the answer is
25 yes. I don't know if anybody from the QA, NRO's QA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Branch, is here, but we have been actively going out
2 to all of the facilities overseas to conduct vendor
3 inspections. We can provide a separate briefing on
4 that if you'd like.

5 MEMBER ARMIJO: I just wanted to know what
6 your practice was.

7 MR. BURKHART: Yes. I can definitely tell
8 you that there's a lot of folks who have been overseas
9 looking at all of these facilities. And we'll
10 continue to look at them.

11 MR. PAULSON: We have had U.S. audits for
12 replacement components already in Japan. So it's --

13 MEMBER ARMIJO: From the NRC?

14 MR. PAULSON: Yes.

15 MR. BURKHART: We are also looking at --

16 MEMBER MAYNARD: I see a potential need
17 for ACRS to conduct some visits on our own.

18 (Laughter.)

19 MEMBER MAYNARD: I would like to go ahead
20 and bring this to a close. This was an informational
21 briefing. So we'll have opportunity later to go into
22 more detail on a number of these.

23 I would like to congratulate MHI and also
24 the staff. I think the presentation hit the points
25 that I thought were important to the Committee,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 identifying the codes and going through the design,
2 very thorough presentation.

3 I also compliment the ACRS for actually
4 letting them get completely through their presentation
5 and have time at the end for some questions.

6 (Laughter.)

7 CHAIR SHACK: It's just because people
8 fear you.

9 (Laughter.)

10 MEMBER MAYNARD: I think a couple of
11 obvious things that have come out of this, you know,
12 there are a few of the topical or technical reports
13 that we're going to want to take a look at. I'm sure
14 that the two fuel topicals is something we will want
15 to take a look at here and also the accumulator. I
16 know the staff has had interest in that. That's a
17 topical report I think we're going to want to take a
18 look at.

19 At our next meeting in July during the
20 planning session, I'm going to try to identify or make
21 sure everybody has a copy of the list. At that time
22 we can talk about what things do we maybe want to take
23 a look at before we start getting the chapter reviews
24 and stuff on that.

25 Also I think getting a copy of the DCD

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will allow us to take a look at -- you know, it may
2 answer a lot of questions that we have. If we see
3 areas where it doesn't really have the detail then we
4 may need to set some different meetings up to take a
5 look at that ahead of time.

6 MEMBER BANERJEE: And when can we get the
7 DCD and the list of topical?

8 MR. PAULSON: Five minutes.

9 MEMBER BANERJEE: I don't want paper, CD
10 or I prefer it on a memory stick.

11 MEMBER MAYNARD: Okay. I would like to
12 bring the meeting to a close. Again I would like to
13 thank everyone for an outstanding presentation and an
14 overview. And I turn it back to you, Mr. Chairman.

15 CHAIRMAN SHACK: Okay. Right on time. I
16 think it's time for a 15-minute break. We will resume
17 at 10:45.

18 (Whereupon, the foregoing matter went off
19 the record at 10:27 a.m. and went back on
20 the record at 10:46 a.m.)

21 CHAIRMAN SHACK: I would like to come back
22 into session.

23 Our next topic is one of our favorite
24 GSIs, 191, pressurized water reactor sump performance.
25 And Sanjoy will be leading us through that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Okay, I think we all
2 know what the issue is which is that the Generic
3 Letter in 2004, Generic Letter 2004-402, potential
4 impact of debris blockage in emergency recirculation
5 during design basis accidents at pressurized water
6 reactors. And this Generic Letter required PWR
7 licensees to do certain things which I won't go into
8 detail.

9 Anyway, the end process of all of this is
10 that we have our licensees right now putting in much
11 larger sumps to make sure that we don't get too much
12 pressure drop or sump screen slurry.

13 Mike Scott is going to update us on these
14 activities and we hope that this matter will
15 eventually be closed out as quickly as possible. ACRS
16 is also getting fatigue on it.

17 (Laughter.)

18 Okay, go ahead, Mike.

19 MR. SCOTT: Okay, thank you. As Dr. Shack
20 referred to as one of your favorite GSIs, it's
21 absolutely my favorite to the point that I won't work
22 on anything else.

23 (Laughter.)

24 I am more than pleased to be back to talk
25 to you about this issue. And before I get started, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this supposed to project up here?

2 CHAIRMAN SHACK: Yes.

3 MR. SCOTT: What do I do to do that?

4 MEMBER BANERJEE: Somebody will help you.

5 (Pause.)

6 MR. SCOTT: I'll get started. Before I
7 get into the slide show, I'd just like to make a
8 couple of introductory remarks. First of all, we are
9 pleased, I am pleased to present this subject to you
10 again and pleased to provide you some good news.

11 Substantial progress has been made with
12 regard to GSI 191 since our last talk to the full
13 Committee which was about a year ago. We believe that
14 resolution of the issue -- as Sanjoy referred to, we
15 are closer than we were. We think we're significantly
16 closer than we were a year ago. For example, as was
17 mentioned, effectively all of the PWRs now have
18 significantly larger strainers installed by one to two
19 orders of magnitude. They're larger than what they
20 were when Generic Letter 04-02 was written.

21 A number of plants have changed their sump
22 buffers typically to sodium tetraborate, although
23 sometimes other buffers, depending on the plant
24 specific conditions which has also reduced
25 vulnerability. Some plants have removed problem

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 insulation. All of these actions have significantly,
2 we believe, enhanced safety in the PWR fleet.

3 Meanwhile, the staff has, through many
4 interactions, generally accepted most of the vendor
5 test protocols. As you know, we came to you a year
6 ago. There were significant concerns with the test
7 protocols. We have worked through most of that now
8 with some exceptions. There are some second order
9 issues that remain with some of the protocols, but by
10 and large, we believe that the vendors have gotten to
11 the point where they have tests that we believe show
12 conservatively whether a strainer performs adequately
13 or not.

14 And a number of licensees have reported
15 completion of all corrective actions and they believe
16 that they have satisfactorily addressed Generic Letter
17 04-02. We are in the process of verifying whether we
18 agree with that.

19 So that's the good news. On the other
20 side of the ledger, we're still not quite as close to
21 the finish line as we predicted we would be, and as we
22 would like to be at this time. We had an original
23 target date for closing the generic issue in 2007.
24 That didn't happen. And I'm going to talk to you in
25 the presentation about some of the reasons why.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 A few significant issues remain, as I
2 mentioned, with a couple of the test protocols. We
3 have to work through that. And even when we work
4 through that, many of the licensees tested with old
5 protocols and those protocols we had issues with and
6 those plants are likely to get requests for additional
7 information from us.

8 As I believe you all are aware, the
9 downstream in-vessel issue is not fully resolved and
10 I'll talk some about that today.

11 Some high-fiber plants, we believe, will
12 likely struggle to show success with a test protocol
13 that is clearly conservative. And so it may be that at
14 the end of the day some plants need to take additional
15 measures to reduce their vulnerability to this issue.
16 We don't know that at this point, but we have seen
17 some test indications that show that a -- so to speak,
18 a little bit of debris can go a long way.

19 I believe that Dr. Graham Wallace referred
20 to this issue very appropriately in our last
21 Subcommittee meeting. It's like a hydra. You cut off
22 a head and two more grow back. And that's been a
23 frustrating part of GSI-191. So it's good news, bad
24 news and today I'm here today to talk to you about
25 both and give you a picture of where we're going and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 when we plan to come back to the Committee.

2 Slide 2 refers to things that Dr. Banerjee
3 already talked about. Generic Letter 04-02 is our
4 primary regulatory vehicle for seeing correction of
5 the issues posted by Generic Safety Issue 191. And
6 basically, what that Generic Letter said was by the
7 end of 2007, each PWR licensee should determine what
8 its plant-specific debris generation transport are,
9 make needed modifications to show compliance with the
10 regulations and the presence of that plant-specific
11 debris loading and update the licensing bases for the
12 plant to reflect those corrective actions made. That
13 was what was supposed to happen by the end of 2007.
14 We didn't quite get there.

15 So where are? I talked about the fact
16 that we have much larger strainers and a number of
17 other modifications have been done. You may or may
18 not be aware that the Fort Calhoun plant implemented
19 what we called a water management initiative. That
20 is, they revised their licensing basis such that the
21 containment spray would not be used in the event of a
22 LOCA. It was not needed to be used. And if
23 containment spray is not used, that has several
24 beneficial effects for strainer performance. It cuts
25 significantly on the flow rate of the water that goes

1 into the sump and impinges on the strainer and it also
2 means that a lot less debris is washed down by the
3 containment spray system into the sump. So a plant
4 that chooses to do this can make its burden a lot
5 easier on showing that strainer performance is
6 adequate. And Fort Calhoun, as I understand it, has
7 implemented that change.

8 We don't know whether other plants plant
9 to do that. We certainly do not have any other
10 submittals from plants, but this was an initiative
11 that the NRC, specifically the Commission encouraged.
12 And at least one plant took.

13 Staff and industry both believe that the
14 risk of clogging is significantly lower than it was
15 when the Generic Safety Issue was initiated and when
16 the Generic Letter was initiated. And we believe that
17 plants can continue to operate safely for the same
18 reasons that were stated in Generic Letter 04-02
19 while we work through the remaining issues associated
20 with closing out Generic Safety Issue 191.

21 Integrated head loss testing including
22 chemical effects is on-going. You may recall that we
23 talked to you a year ago about what the kind of
24 chemical effects testing was going on. We mentioned
25 to you at the time that we had concerns with some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the aspects of the test protocols and as I mentioned
2 to you in my introduction, we have largely worked
3 through those with the vendors and with a couple of
4 exceptions and the staff is observing and commenting
5 on representative tests intended to show function. So
6 we believe we're approaching the end of that process.

7 Now then the question becomes is those who
8 tested and took credit for earlier testing which
9 didn't pass muster with the NRC, how we will deal with
10 those.

11 MEMBER MAYNARD: Do we know why more
12 plants haven't used the water management option? Is
13 it more of a regulatory burden or more of a physical
14 design that causes problems?

15 MR. SCOTT: I honestly don't know.
16 Clearly, Fort Calhoun came in and they got approval
17 for it. It may be that -- and I'm sure this is the
18 case, as with everything else with GSI 191, it's
19 extremely plant-specific. So if your particular --
20 let's say you're a low-fiber plant. You probably
21 don't much issue here and you don't have motivation to
22 try to pursue a water management change. You might
23 have a particular combination of debris and chemicals
24 such that it's just not worth your trouble to go to.
25 Maybe a particular plant needs containment spray to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 get through a LOCA. This plant was able to show that
2 they didn't. It may not work for everyone.

3 Bill wants to comment.

4 MR. RULAND: As I understand it, Fort
5 Calhoun has a -- for the size of its plant, has a
6 rather large containment and their containment cooler
7 capacity is also a large containment cooling capacity.
8 So coupled those two features coupled together
9 enabled them to go forward with this initiative and
10 the staff did a review of this including the debris
11 generation and how that would affect the containment
12 coolers. But again --

13 MEMBER MAYNARD: And I understand for some
14 of the plants, plant-specific issues.

15 MR. RULAND: That's correct.

16 MEMBER MAYNARD: I would have thought
17 there would have been a few more.

18 MR. RULAND: And so did we.

19 MR. SCOTT: And let's think about it in
20 these terms. It is not necessarily the end game yet.
21 A particular plant may have difficulty showing that
22 they've adequately addressed the issue to the staff's
23 satisfaction and they may find themselves in the mode
24 of making additional changes. And this would
25 potentially be on their menu for doing that. But it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is accurate to state that so far we only have one.

2 I indicated that our goal was to be done
3 by the end of 2007. That did not happen because of
4 various issues, downstream effects analyses were and
5 are on-going. The head loss testing was not done, is
6 still not done.

7 Most of the plant modifications were
8 completed by the end of 2007, but there were a few
9 that remain, particularly with regard to a piece of
10 equipment that would be problematic to get to during
11 a normal operation and which is not likely to cause a
12 problem for a plant.

13 An example is Diablo Canyon received an
14 extension to January 2009 to remove certain insulation
15 that is difficult to access on their steam generators.
16 They're replacing the steam generators in January 2009
17 anyhow. This insulation would only be affected by a
18 very few LOCAs and so you look at the risk of it, it's
19 very small and the dose is very large and so it did
20 not seem to be an intelligent thing to do to try to
21 push that to be done before the steam generator
22 replacement. So it's that kind of thing.

23 One of the plants received additional time
24 to make a number of small modifications to their pumps
25 to reduce their risk posed by downstream effects,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 blockage of the lines to the pumps or damage to pump
2 seals.

3 CHAIRMAN SHACK: Let me just come back to
4 that water management initiative again. That
5 presumably is all done in design basis space, right?

6 MR. SCOTT: Yes.

7 CHAIRMAN SHACK: Nobody looks at what that
8 does to the PRA.

9 MR. SCOTT: I don't know the answer to
10 that, how it was processed and whether it was risk-
11 informed or not. I don't.

12 CHAIRMAN SHACK: We normally encourage
13 plants to have containment sprays for various reasons.

14 MR. SCOTT: Well, and it's not like they
15 have removed the system. The system is available, but
16 -- and there may be -- and I'll be honest with you
17 here, I'm not familiar with the details of this. They
18 may have some gates that say well under certain
19 circumstances I am going to use it. I just don't have
20 that information in front of me. We can get you, if
21 you would find it helpful, a copy of the license
22 amendment application and the staff's review of it.

23 CHAIRMAN SHACK: I'd be interested in
24 seeing that.

25 MEMBER BLEY: Something like SAMGs might

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pick this up as a later action.

2 CHAIRMAN SHACK: Right. I mean you might
3 not need it right now, but some time along the way.

4 MEMBER BLEY: In some bad scenario you
5 might.

6 CHAIRMAN SHACK: In some bad scenario.

7 MEMBER MAYNARD: If you are taking it out
8 of the automatic actuation.

9 CHAIRMAN SHACK: Right, but I'm not sure
10 that just because I take it out of the automatic
11 actuation that's really solved my problem. When I
12 need to use it --

13 MEMBER BLEY: Once it's out of automatic
14 operation, is there any requirement that it be there
15 at all? Maybe not any more.

16 MEMBER APOSTOLAKIS: Even the automatic
17 actuation. You can't just say I will remove the
18 automatic actuation and do it manually. I think it's
19 tied to the diesel, isn't it?

20 CHAIRMAN SHACK: Yes, but that's all
21 addressed in licensing space.

22 MEMBER APOSTOLAKIS: But still.

23 CHAIRMAN SHACK: I'm interested in what it
24 does in a wider range of accident management.

25 MEMBER BLEY: The PRA says there's a lot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of cases where it's really nice not having it because
2 you conserve water and get a lot longer. Later on,
3 you might really want to have it.

4 MEMBER BANERJEE: If you will provide
5 this, let's take a look and let's move on.

6 MR. SCOTT: Okay, right, and we're not
7 prepared to address that subject in detail today.

8 MR. KLEIN: One clarification, Mike. This
9 is Paul Klein from NRR. They will not take the system
10 out of service because it's still being used for a
11 main steam line break. It's just the auto start on a
12 LOCA, the logic was changed so that you would not have
13 an auto start on a LOCA.

14 MR. SCOTT: For the record, that was Paul
15 Klein, NRR.

16 MEMBER APOSTOLAKIS: But these decisions
17 to give them more time are essentially the result of
18 judgment, right? NRC monitored judgment taking into
19 account the facts as you said, the risk is low and
20 they're going to do this anyway? That is basically
21 somebody's job?

22 MR. SCOTT: That is correct. We actually
23 sent a SECY paper to the Commission in 2006 that
24 specified the criteria the staff planned to use to
25 evaluate extension requests. And it was along the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 lines of what you're talking about. What are the
2 mitigative measures you have taken. If you want a
3 lengthy extension, tell us about the risk association
4 with it. We believe that a short-term extension of a
5 couple of months or a few months would show up very
6 low in risk base any how. But if you want a lengthy
7 extension, then tell us why it's okay.

8 There were specific criteria for it, but
9 it's -- you're correct, it is a judgment call on the
10 staff's part. And the other part of the picture was
11 mitigative -- modifications that have been made.
12 Everybody has a larger strainer. They've addressed a
13 lot of the issues. Everyone essentially has addressed
14 most of the issues associated with this now and so
15 we're cleaning up the remaining issues. Typically, an
16 extension would be for one particular mod or to
17 complete the analysis. You know, the way we did this
18 which is very different is do the mods now on the
19 assumption that the old strainers were too small, then
20 follow it up with the analysis that shows that the
21 modification is adequate to address the issue fully
22 with full knowledge going into that that we might find
23 that additional actions were needed.

24 So now what they're doing, most of them,
25 the mods are done and now they are doing the analyses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and these analyses are complex and tricky and
2 sometimes it's difficult to have a demonstrably
3 conservative test that still passes the criteria. So
4 that's what's being struggled with.

5. MEMBER APOSTOLAKIS: Okay.

6 MR. SCOTT: We talked about extensions.
7 All plants have now given us a supplemental response
8 to the Generic Letter. We asked for those in February
9 and we received it from all the plants. Some of those
10 responses were incomplete because the plants had
11 received extensions to do additional actions.

12 Chemical effects. For some time, we
13 considered chemical effects to be the most challenging
14 issue associated with GSI 191. We believe that the
15 test vendors at this point most of them have a handle
16 on how to test for chemical effects and the plants are
17 conducting tests. As noted here, they didn't get done
18 by the end of 2007 for various reasons. The industry,
19 we believe, was a bit slow in recognizing the
20 significance of the issue. The ICET round of testing
21 and the follow-on testing certainly indicated some
22 surprising results that helped motivate action in this
23 area. Once the action was begun, there were only so
24 many test vendors and so the licensees queued up with
25 the test vendors to get their testing done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 As I mentioned to you, the staff posed
2 challenges along the way by raising issues with the
3 prototypicality or conservatism of the test protocols.
4 That slowed them down further as they resolve the
5 staff's issues. And so we ended up not getting done
6 by the end of 2007.

7 We did issue a safety evaluation on the
8 chemical effects topical report, WCAP-16530, in
9 December 2007. Licensees can choose that report to
10 help them to go through their chemical effects
11 evaluations or as with all these issues that they
12 don't choose to use topical report they can use their
13 own plant-specific method if appropriately justified.

14 So we believe that the licensees are
15 moving forward on chemical effects and have a path
16 forward to show a successful test of chemical effects
17 issues.

18 You've heard about the chemical effects
19 peer review. The Office of Research commissioned a
20 peer review in 2006 that identified 100 or so
21 questions regarding chemical effects that they thought
22 had not been answered yet. The staff has gone through
23 a multi-tiered process to screen those peer-review
24 questions to identify those warranting further
25 evaluation and we have and Office of Research has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 briefed the Committee some time back on the type of
2 questions that were asked and our plans to review
3 them.

4 We are now reviewing the study results
5 from the staff-supported work intended to screen those
6 issues. The likely result is that there could be a
7 need for additional consideration of some of these
8 effects and the number currently being bandied about
9 is four, four particular effects that might need
10 additional work. However, the staff has not completed
11 its effort in screening those effects. We do expect
12 to finish that work in the next few months and plan to
13 report to the Committee on this along with a number of
14 other subjects later in 2008.

15 Downstream effects. We divide that into
16 two parts: ex-vessel and in-vessel. We did issue a
17 safety evaluation on an ex-vessel proprietary
18 downstream effects topical report, proprietary ex-
19 vessel downstream topical report. Issued that in
20 December 2007. Some licensees are still working
21 through having to do these type of tests as a result
22 of the fact that that SE came out in late 2007. So
23 some plants had extensions to perform this work.

24 And then there is the other issue and I
25 mentioned a few minutes ago the chemical effects were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 thought to be the most challenging issue associated
2 with 191 and 191 always surprises us and now we've had
3 a surprise with regard to in-vessel downstream effects
4 which refers to the potential for blockage of flow in
5 the core and/or local effects in the core.

6 We did receive a topical report, WCAP-
7 16793 in middle of last year. We issued a draft
8 safety evaluation in March of this year which we
9 provided to the ACRS Thermal Hydraulic Subcommittee.
10 We met with the Subcommittee in March and the
11 Subcommittee had a number of questions and concerns.
12 The staff and the PWR Owners Group are now working to
13 address those concerns and the Owners Group has
14 concluded that it needs to do additional testing.

15 We are attempting to work with the Owners
16 Group to get them to identify a test protocol that we
17 would view as adequately conservative. There had been
18 on-going discussions about that which is why we have
19 not been able to come back to the Subcommittee and say
20 here is the plan to address your issues. So we do
21 plan to do that, obviously, to get back to the
22 Subcommittee as soon as we have a clear path forward
23 and as soon as we have some information to provide
24 you. We anticipate that will be in the near future.
25 But this -- some issue has sometimes, as I mentioned,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 surprised us.

2 So we have, by the way, as a separate data
3 point one licensee who has chosen to test themselves
4 rather than test an association with the Owners Group.
5 They performed a test at CDI facility in New Jersey
6 which the staff observed a week or two back. And the
7 staff found that that test protocol appeared to be
8 adequately conservative. We will be happy to talk to
9 you in some detail about what we observed at that test
10 and hopefully test results from the Owners Group work
11 in the near future. But the lesson we took away from
12 that is that there is a protocol that we believe is
13 defensible. Whether the Owners Group will use it is
14 unknown and the question arises okay, that was with
15 one type of fuel and we have a number of different
16 fuel designs and to what extent does the Owners Group
17 work bound all the fuel that's out there. And we
18 don't know that yet. We have asked them questions
19 about that. We know that the different designs of
20 fuel have a very different geometry at the inlet, all
21 intended to discourage intrusion of debris during
22 normal operation into the fuel. And this is one of
23 those situations where it could actually encourage a
24 debris bed at the inlet. So that all has to be sorted
25 out. It's being sorted out as a high priority now and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we will update you all on it when we have more
2 information.

3 MEMBER ARMIJO: Michael, I have a real
4 quick question. I didn't attend the ACRS Subcommittee
5 on this subject, but in the questions that are being
6 addressed, obviously the temperature and the flow and
7 everything in the assemblies, the fuel assemblies are
8 being considered, but will these chemical change due
9 to radiolysis? Is that being addressed, that
10 question?

11 MR. SCOTT: Paul Klein can correct me if
12 I'm wrong here, but I believe that radiolysis effects
13 is one of the four peer-review questions that's being
14 addressed. Is that right, Paul, or -- set me
15 straight.

16 MR. KLEIN: That's correct. One of the
17 questions raised by the Peer Review Committee was the
18 effect of radiation not only on the precipitate, but
19 on metallic corrosion rates. So that is one of the
20 topics of the four that remain.

21 MR. SCOTT: So those remain on our plate
22 to deal with. Did that answer your question?

23 MEMBER ARMIJO: Yes, thank you.

24 MR. RULAND: This is Bill Ruland.
25 However, regarding the in-vessel topical report, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 radiolysis is not part of our analysis, is that
2 correct?

3 The radiolysis is not part of the analysis
4 for the in-vessel topical report. Rather, it's a peer
5 review issue that is subject to further research.

6 MR. SCOTT: I believe that is accurate,
7 yes.

8 MEMBER MAYNARD: For the plant that's
9 doing the plant-specific testing, is that just for a
10 very specific fuel -- if they make design changes in
11 the future, they basically have to redo testing?

12 MR. SCOTT: Well, you could ask that
13 question about any aspect about GSI-191, if you think
14 about it.

15 I've got like 12 review areas to show
16 adequacy in this issue: coatings and chemicals and
17 downstream and upstream and so on and so on. And
18 there will be a licensing basis for the plant in every
19 one of those areas. And if the plant changes that
20 licensing basis, then we have regulations that, of
21 course, call for them to evaluate that. So if they
22 change fuel types to a different fuel than what has
23 been certified, so to speak for GSI-191, then they're
24 going to have to evaluate that change. That might
25 take evaluation. It might take testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: What I was really getting
2 at -- I know the approach of the WCAP was to provide
3 a method for evaluating and we're still going to have
4 a plant-specific, design-specific review against that,
5 and I didn't know if this testing provided data for a
6 methodology or whether it would just for what they had
7 in the core right now.

8 MR. KLEIN: Mike, if I can jump in here.
9 That particular licensee looked at the configuration
10 that they have in the existing core and then they also
11 looked at another configuration that they were
12 considering switching to in the future and they saw
13 that that did make some differences in the pressure
14 drop that was observed.

15 MR. SCOTT: Which is also information for
16 us when interacting with the Owners Group because we
17 are concerned that if there is more than one type out
18 there, which there clearly is, and if it has a
19 significant impact on head loss, which it clearly
20 does, then how many tests do you have to do to bound
21 all that? That's why this is not trivially easy to do
22 and get right back in to talk to you all. That's kind
23 of where we are.

24 MR. RULAND: And more generically, you've
25 raised a question that we have also considered, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maintaining the licensing basis for GSI 191 is going
2 to be non-trivial. So the staff is already
3 considering a document, probably a regulatory issue
4 summary that is going to come out that is going to try
5 to provide guidance to the licensees about how to
6 maintain that. Basically tell them, describe how we
7 did the review and provide them guidance on how to
8 maintain the licensing basis.

9 MEMBER BANERJEE: I have a question about
10 this. I'm aware of the test that you are talking
11 about, but were there any chemical effects there?

12 MR. SCOTT: The test that we're talking
13 about did include chemical effects.

14 The last sub-bullet on here refers to the
15 fact that I initially in this presentation had some
16 more discussion on the draft WCAP and some of the
17 staff's conclusions, which actually the Subcommittee
18 has seen before. Because of the time constraints
19 associated with this presentation, I went ahead and
20 moved them back to the backup slides. But that
21 information is there if you are interested in seeing
22 it.

23 This is a summary of our understanding of
24 the Subcommittee's questions and concerns regarding
25 WCAP 16793. And we did send, I sent Dr. Banerjee and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 email on that and he actually added a couple of items
2 which are reflected in here. So we believe this is an
3 accurate summary of the questions asked by the
4 Subcommittee and that we need to address and plan to
5 address going forward.

6 So where do we go from here on 16793? The
7 staff has provided additional information to the
8 Subcommittee on a couple of the aspects of the
9 questions that were asked. There were some documents
10 that we provided to the ACRS staff. There seems to
11 have been based on some email traffic some questions
12 as to whether the Subcommittee has actually seen a
13 document that we provided. I asked the staff, ACRS
14 staff --

15 MEMBER BANERJEE: To the Owners Group?

16 MR. SCOTT: There was an industry test
17 document that you requested.

18 Paul, what was the name of that document,
19 please?

20 MR. KLEIN: It was a paper, Mike. It was
21 an industry document. It was requested on a
22 Subcommittee and we provided it.

23 MR. SCOTT: Do you remember what it was?

24 MR. KLEIN: It was related to, I think,
25 fouling, but I -- it was an old report.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: Do you have that?

2 MR. KLEIN: Yes.

3 MR. SCOTT: Okay. So that we have
4 provided some additional information, but we have not
5 addressed with you most of the questions that you
6 asked. We mentioned the fact that the Owners Group
7 plans additional testing and we need to evaluate what
8 they tell us in response to the questions that you
9 raised.

10 And the staff, as we talked about, and the
11 Owners Group, will return to brief the Subcommittee in
12 due course, depending on when we sort out the testing
13 with them.

14 MEMBER BANERJEE: You know, the Commission
15 has an interest in this and the question came up in
16 our meeting yesterday, and we sort of promised them a
17 letter. They're anxious to get the letter --

18 MR. SCOTT: A letter on that particular
19 issue or 191 in general?

20 MEMBER BANERJEE: Well, it was a general
21 question, but sort of the answer I gave was that most
22 of the issues on the way to resolution and the issue
23 which still requires some attention is this downstream
24 effect. So I mean I'm not sure what sort of a letter
25 we're going to give them. But they want a letter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's clear.

2 And after the meeting, Commissioner Jaczko
3 talked to me and said we're looking to hear from ACRS.
4 So obviously, we owe them a letter. Now exactly what
5 we cover in that letter, I don't know, but suddenly
6 the downstream effect being important, we need to
7 write a letter on this WCAP or whatever the equivalent
8 is or the full subject of downstream effects, however
9 you guys want to treat it.

10 It maybe end up having to write a couple
11 of letters, but --

12 MR. GROVE: This is Jack Grove. Bill and
13 I were at the meeting yesterday, listening to the
14 dialogue and it's pretty clear even though the last
15 time we updated, Commissioner Jaczko, was just
16 several months ago. GSI-191 is a project that rapidly
17 evolves and we concluded it was clear that it was time
18 to rebrief the Commissioner TAs on the status of 191
19 as well as the status of BWR strainers.

20 So we're scheduling that briefing now to
21 bring all the Commissioners up to speed on the latest
22 information. I don't know if that helps you with when
23 you made forward letters or not --

24 MEMBER BANERJEE: I think it would help
25 that you brief them, of course, but I think we owe

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 them a letter. That's more or less the situation.

2 Exactly what the letter should be on, I
3 think we should discuss as a Committee and decide how
4 wide that letter should be or whether it should focus
5 on a specific issue like downstream effect.

6 MR. SCOTT: If I might make a suggestion,
7 you might want to table that until we talk towards the
8 end of this presentation about what we plan to tell
9 you and when we plan to tell it to you.

10 MEMBER BANERJEE: Let's go on.

11 MR. SCOTT: We may be in a better position
12 to do that.

13 Head loss testing. The staff has
14 questioned whether various aspect of the vendor for
15 foreign testing is conservative and prototypical. For
16 example, we have had concerns, as you see here in
17 debris preparation and introduction how is the debris
18 added to test loop and in what order is it added? Do
19 you put the particles in first? Do you put the fibers
20 in first? Do you throw them all in together? And you
21 may not be surprised to find out that it matters what
22 order you put them in.

23 And it turns out that particles go in
24 first, followed by fibers debris, fine fibers debris,
25 tends to be the worst case situation based on our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 observations when testing is done.

2 If the particles set up the fibers for an
3 adherent thin bed and a potentially problematic thin
4 bed and by thin I mean quite thin. Less than the one-
5 eighth inch that we used to think of as the cut off of
6 what a thin bed would be. It doesn't take much of the
7 right kind of debris and the right order to cause a
8 significant head loss.

9 So we have had questions about that with
10 the vendors as we have observed the testing. Some of
11 them put the fiber in first which we used to think was
12 an appropriate way to do it. Now we're not so sure.
13 Of course, the burden is on the licensees and their
14 vendors to show us that they have a conservative
15 protocol for their plant-specific conditions and this
16 issue, and I can't emphasize this enough is extremely
17 plant specific. Some plants have a little problem.
18 Others have a significant problem.

19 So we have gone round and round on this.
20 I do think that we are approaching the point, as I
21 mentioned to you, where we're okay with the test
22 protocols and now the licensees need to run the tests
23 and validate that their strainer can withstand this
24 situation.

25 MEMBER APOSTOLAKIS: Mike, why do some

1 plants have big problem and others don't?

2 MR. SCOTT: It has to do with how much
3 fibrous and particulate insulation they have. Some
4 plants and actually the NRC encouraged the industry to
5 do this two decades ago. They said when you're going
6 to do a modification that causes you to pull
7 insulation out of your inside container, consider
8 whether it makes sense to replace it with reflective
9 metal insulation.

10 And reflective metal is good in some
11 applications, maybe not so good in others, but there
12 are plants that either started that way or have gone
13 that way to where they have very little fiber in their
14 plant. And some of these plants the only fibrous
15 insulation, fibrous debris source term is what we
16 refer to as latent debris, stuff on the floor.
17 There's no fibrous insulation still in the plants.
18 Those plants, we are prepared largely at this point,
19 based on the information that's been provided to us,
20 to conclude they have reasonable assurance that they
21 will not experience this phenomenon.

22 MEMBER APOSTOLAKIS: The plant
23 variabilities is due to the fact that some plants
24 don't have fibrous --

25 MR. SCOTT: That's a major impact also.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There's a variation in what kind of buffer they use,
2 what kind of sump buffer they use. So there are
3 various things. But I would say --

4 MEMBER BANERJEE: Pump geometry --

5 MR. SCOTT: Yes, near-field settling
6 refers to -- let's say -- remember that these are test
7 rigs that are in a warehouse somewhere. They're not
8 testing in the plant. So what they do is, is they put
9 the debris and observe as it goes to the strainer.

10 Well, okay, so let's say that some of the
11 debris settles on to the floor in front of the
12 strainer. That's fine, and they can take credit for
13 that if that would happen in the plant. But they have
14 to show that. They have to show that any settling in
15 the test rig is representative of what would happen in
16 the plant. So that's what that refers to.

17 MEMBER BANERJEE: It depends on how
18 stirred-up the flow would be in the plant compared to
19 in the test rig.

20 MR. SCOTT: Well, -- and they have to make
21 sure that their flow rate is prototypical is not
22 trivially easy --

23 MEMBER BANERJEE: No, not at all. In
24 fact, last May when we first had a very interesting
25 meeting, the Subcommittee with industry, four or five

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plants came and there were quite a lot of questions
2 about the prototypicality of the tests.

3 MR. SCOTT: Yes.

4 MEMBER BANERJEE: And I think they've been
5 trying to respond to a lot of these questions and I
6 think very good progress has been made in that
7 direction.

8 MR. SCOTT: Yes, we believe so. But it's
9 been a struggle. It's been a struggle. And what we
10 ended up with is a number of plants had already tested
11 under these problematic protocols from our perspective
12 and so now we're in the mode of asking them to justify
13 why their previously done work is adequate. That
14 could cause additional testing, for example. So
15 that's why we want to cleanly wrap this thing up, but
16 it's just not clean.

17 MEMBER BANERJEE: And then there's only a
18 limited number of places where you can do the testing,
19 so the full thing is --

20 MR. SCOTT: That's right. There are about
21 a half dozen vendors. The tests are significant
22 expense for the licensees, so obviously, they don't
23 enjoy having to retest, but at the same time they have
24 to show that they've adequately addressed this and
25 that their strainers will pass muster.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER BANERJEE: It's a massive job. I
2 mean each plant is different.

3 MR. SCOTT: There's a lot of evaluations.
4 There are many aspects to the evaluations. Each one
5 is backed up by its own type of test of analysis.
6 Yes, it's extremely off-scale high, complex issue.
7 Yes, it is.

8 I think I've talked about this. I guess
9 the last bullet, the licensees, of course, can use any
10 approach. We don't dictate the approach. We can say
11 okay, here's what we have observed, for example, we
12 have observed that a thin bed composed of particles
13 going in first, followed by fine debris, fine fiber
14 only, is likely the most problematic situation for
15 head loss. And then so a plant needs to consider
16 whether that applies to their specific conditions.

17 Another protocol might be okay, but we'd
18 ask questions to state that. Why? Well, one reason
19 test that we observed. I mean I already mentioned
20 this to you was particles followed by fine fiber and
21 notice I put the word only in parens there. It turns
22 out if you add more coarse fiber, that turns out to be
23 better, lower head loss. Because there's more paths
24 for the water to get through the coarser debris that
25 sits on the strainer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Unfortunately, for the plant though,
2 typically, their transport analysis may show that only
3 the fine fiber really transports. And if that's the
4 case, then you cant' dump the big stuff on there. And
5 so that's been a subject of some angst.

6 I think I've talked about the other points
7 here. Likely to be challenging for high fiber and
8 maybe even medium fiber plants to use this test
9 protocol to show that they don't have a problem and
10 that sort of case, there may come a point here in the
11 near future where that plant needs to conclude and
12 needs to take additional action such as additional
13 modifications to fully address this issue.

14 Supplemental reviews. We are reviewing
15 the supplemental responses that we got in February.
16 That is our top priority right now. There will be
17 supplements to the supplements, so to speak, for the
18 many plants that were not done the first time through.

19 And we're likely to send requests for
20 additional information to most plants. What we're
21 trying to sort out now is how do we carry a request
22 for additional information regarding the in-vessel
23 issue which is, of course, still under review by the
24 staff.

25 For low fiber plants, those that have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mostly RMI, as I talked about, reflected metal
2 insulation. They are likely to see few RAIs. We are
3 prepared to accept for several of those plants right
4 now, that they're not going to experience a
5 problematic thin bed, a build up of debris, on the
6 ECCS strainer. Those plants are close to being done
7 and that's good. Because we would rather focus our
8 resources on the plants that are not so close to being
9 done and so we are -- we're trying to get at the last
10 couple of things here, notably WCAP 16793 in order to
11 close the issue for the low-fiber plants. We're not
12 quite there, but we're getting close.

13 We anticipate and I will not raise my
14 right hand on this and swear to it, but we anticipate
15 that we will close this thing in 2009. The last time
16 I came and talked to you, we anticipated we will close
17 it in '08, so this is a very, pardon the pun, fluid
18 problem, and I warned you in advance. I warned you
19 I was going to do that. And so while we have a goal.
20 We just have to see what develops here.

21 MEMBER APOSTOLAKIS: You are consistent.

22 (Laughter.)

23 MR. SCOTT: That's not the kind of
24 consistency I'm proud of.

25 MEMBER BANERJEE: It's like every

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 President that has said about oil independence --

2 (Laughter.)

3 It's a mirage that fades.

4 MR. SCOTT: To give it its due though, (a)
5 it's a very complex issue; and (b) both the industry
6 and the NRC has devoted huge resources to addressing
7 this issue and enormous improvements have occurred.
8 But to try to get to the finish line and get past the
9 past few of these things is a real problem. And to
10 say otherwise, I wouldn't be frank with you.

11 So what are we going to do?

12 We plan to close these issues for each
13 plant and because it is plant specific, we're going to
14 close it one plant at a time. And then generically.
15 Based on what? Review of the supplemental responses
16 which may involve supplements to the supplements.
17 Review of region inspections of the licensee
18 corrective actions and what I mean by that is is we
19 have asked the regions through a temporary instruction
20 to go validate that the licensees have done what they
21 said they were going to do. If they said we're going
22 to put in a certain amount of strainer, they did. If
23 they said they were going to change a certain amount
24 of insulation, they did. The regions are not involved
25 directly with the review of the analyses and testing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's our job here. But we do take their input to
2 have additional confidence that the licensees did what
3 they said they were going to do.

4 And as we've told you in past meetings, we
5 did a number of comprehensive audits which are
6 actually the results of which are visible on our
7 website. And we are looking at their responses to the
8 audit open items.

9 The open items were -- the audits were a
10 way for us to take a detailed look at certain plants
11 representative of the various types of strainers and
12 testing out there to increase our confidence that the
13 issue is being addressed. Obviously, we don't have
14 the capability to audit every plant in that way. It
15 sends a team of eight or ten people to a plant for a
16 week. We can't do everybody, but we did nine of them.
17 And so those plants to be representative of, for
18 example, one particular vendor's test protocol. And
19 so we expect the licensees who use that vendor to have
20 paid attention to the audit results that occurred at
21 the other plants and we are to a limited extent
22 validating that by going through the Generic Letter
23 responses that have been provided to us although I
24 would candidly say that the Generic Letter response
25 reviews cannot be at a level of detail the same as an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 audit.

2 We will -- we'll get to the point here in
3 all likelihood where a plant has not done all its
4 mods. You remember I mentioned that one piece of
5 insulation at Diablo Canyon that won't be replaced
6 until '09. But they will have done their testing and
7 their testing will be based on the plant configuration
8 after the last mod goes in. There will likely come a
9 point where we'll say that plant is done pending this
10 particular action which we will track to completion.
11 We don't want to drop the ball and have the plants not
12 make the corrective actions that they plan to make.
13 So we will track them. NRR will track them until
14 they're all done. But we may at some point close the
15 generic safety issue and close the Generic Letter for
16 a given plant based on the fact that the test results
17 are good and the mod commitments are there. So just
18 to let you know about that. Otherwise, we couldn't
19 close this issue until the last mod is made at the
20 last plant and we don't currently think that's a
21 useful way to go into this.

22 At the same time we have to accept the
23 burden that we don't drop the ball after we do close
24 it, so we're going to have a process in place to
25 ensure that occurs, that it doesn't occur.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 I mentioned to you that we talked about
2 what we want to come back to the Committee with. We,
3 of course, need to come back to the Subcommittee to
4 talk about the in-vessel downstream effects. The
5 owners group has intentions of doing their testing
6 this month or next. Before that really occurs, at
7 least final testing from the staff's perspective we
8 have to agree basically buy into what they're planning
9 to do and we haven't gotten to that point yet.

10 We might be in a position, we should -- I
11 have a reasonable amount of confidence that we will be
12 in a position in the fall, perhaps the early fall, to
13 come in and tell you a good deal more additional
14 information. For example, we can talk about the
15 Diablo Canyon testing. Hopefully, the Owners Group
16 will have already done their testing and the staff
17 will have a view on that. I don't think in the early
18 fall we will have a revised SE for you to look at
19 because only at that time will we have, if the Owners
20 Group meets their present plan, only in September
21 will we have their revised topical report.

22 So there is still some months out here to
23 do that, but I think there might be value in the fall,
24 given the Subcommittee and potentially full Committee
25 an update on this in-vessel downstream which currently

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 is the last issue to be fully addressed by the staff.

2 We can come in and talk to you about the
3 testing protocols and results. Of course, you got a
4 briefing a year ago on what type of protocols were out
5 there. We can update you on what was agreed on or
6 what the staff reviewed and the changes that the
7 licensees and the vendors made in order to address our
8 concerns with those protocols so we can give you some
9 discussion of that.

10 We can come in and talk to you about where
11 we stand on review of the licensee supplemental
12 responses. We are early in that process. You had, as
13 I mentioned, I've already given you one top level
14 result that we think for the low fiber plant several
15 of them are basically done. But we're going to get
16 into the higher fiber plants and we will come back and
17 tell you how we're doing with that.

18 We will tell you, hopefully, in the fall,
19 the final results of the chemical effects peer-review
20 scoping analyses. I mentioned there were four issues
21 that the Office of Research is proposing. Might need
22 additional work. NRR plans to review that and we'll
23 reach a conclusion on that and tell you what that
24 conclusion was and the basis for it.

25 And the staff would also plan to report to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you the -- some results of additional confirmatory
2 chemical effects testing that the staff has sponsored
3 at Argonne National Laboratory.

4 MEMBER ARMIJO: Could you just briefly say
5 what kind of tests those are?

6 MR. SCOTT: No, I can't, but Paul Klein
7 can.

8 MEMBER ARMIJO: Okay.

9 MR. KLEIN: Paul Klein with NRR. We had
10 asked ANL to look at some specific things to help us
11 in our review, the GL supplements. In particular, we
12 asked them to do some tests with the WCAP surrogate.
13 We asked them to look at chemical injection and how
14 head loss with the one vendor approach would compare
15 to head loss with the WCAP surrogate and then we also
16 asked them to corrode aluminum in their test loop in
17 a sodium hydroxide environment and then try to
18 benchmark that head loss from the corrosion product in
19 subsequent precipitation to the other two processes.

20 MEMBER ARMIJO: Thank you.

21 MR. SCOTT: So that, to answer you
22 question earlier is what we would propose to brief you
23 on in the fall some time. That may not be timely from
24 the perspective of the letter that you're being asked
25 to write. I don't know. But this was our thoughts as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to what and when, in the fall, September, October,
2 something in that nature.

3 MEMBER BANERJEE: I think what we need to
4 do after your presentation is have a brief discussion
5 as a Committee to see what sort of a letter we could
6 write based on the information that we would have at
7 that time.

8 We've noted the things that you can supply
9 us by the all.

10 It seems to me that everything except
11 downstream effects could be in a state where we can
12 write something about. You can give us a status
13 report on most things, right.

14 MR. SCOTT: In the fall, you're speaking
15 of.

16 MEMBER ARMIJO: Yes.

17 MR. SCOTT: We'll have a much better idea
18 about how the Generic Letter reviews are shaping up.
19 How many plants are needing to do additional work,
20 that kind of thing. What we decide and what they
21 decide to do about the case where they tested under a
22 protocol that we didn't buy into.

23 MEMBER ARMIJO: I think considerable
24 progress has been made since our last letter to the
25 Commission.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: I think so too.

2 MEMBER ARMIJO: So I think we should
3 document that in some way.

4 MR. SCOTT: Obviously, whatever we can do
5 to support that documentation, we'd be happy to do.

6 MEMBER ARMIJO: Right. I mean -- I mean
7 I wouldn't mind waiting until everything was closed.
8 I don't know about the rest of the Committee, but I
9 think from what we heard yesterday, we do owe them a
10 letter and they want the letter.

11 They probably will get a letter.

12 MR. SCOTT: Okay, that concludes my
13 remarks for GSI-191, but I'm going to throw in one
14 more item here.

15 MEMBER ARMIJO: Which also arose
16 yesterday, Jaczko asked me about this, so --

17 MR. SCOTT: The long and sordid history of
18 sump issues goes back to the 1980s, at least, probably
19 goes back before that --

20 MEMBER CORRADINI: Seventies.

21 MR. SCOTT: Seventies, okay. As far back
22 as I'm aware of it. The PWRs were resolved in the
23 1980s as a result of the information obtained from the
24 PWRs and as a result of certain events that occurred
25 at BWRS, both in the United States and abroad, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Agency initiated regulatory actions in the mid-1990s.
2 The industry took corrective actions for BWRs that
3 made your strainers bigger. And we closed the issue
4 for BWRs in the '90s.

5 As a result of the information obtained in
6 the look at the BWRs, additional questions arose
7 regarding PWRs and so in -- yes, one of those -- and
8 so in 1996, GSI-191 was initiated. We have spent the
9 last decade ironing out the issues for PWRs and we
10 have gotten much, much smarter than we were as an
11 agency when the BWR work was done. So that leads to
12 the obvious question, do we need to evaluate the BWRs
13 again?

14 We would like at the end of this process
15 to achieve a consistent regulatory basis that doesn't
16 require further rounds of Bs, Ps, Bs and Ps. So one
17 of our objectives in looking back at the BWRs is to
18 achieve appropriate regulatory consistency.
19 Hopefully, we are getting to a high-enough state of
20 knowledge on these complex issues now that it will not
21 make sense from a cost-benefit basis, a safety basis
22 to further pursue second and third order effects
23 indefinitely.

24 Okay, so we really want to be -- we want
25 to get a consistent regulatory basis that shows that

1 safety is being achieved and that we can move on
2 beyond these issues.

3 Why are we at different places for the
4 BWRs and PWRs? This is probably fairly obvious to
5 you, but just to state it, obviously, we have a
6 different strainer design. We have a different
7 configuration. The Bs have the suppression pools
8 versus the sumps and the Ps. Different conditions
9 chemical-wise. The BWRs, by and large, do not have --
10 they don't have chemical buffers. The PWRs do. The
11 way the ECCS is operated obviously varies between the
12 two reactor designs. So there are all sorts of
13 reasons why it might be appropriate to have a
14 different treatment for Bs and Ps. So just the fact
15 that they're different doesn't necessarily mean that's
16 a problem.

17 But at the same time we are smarter now.
18 There are additional issues that have arisen, for
19 example, chemical effects. That really was not
20 necessarily addressed back in the '90s. I say
21 necessarily because some work was done regarding
22 impact of corrosion products from the suppression pool
23 back when the BWRs were addressed. Were they
24 adequately addressed, we don't know.

25 So we're going to go back and look at it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 again.

2 We are asking the Office of Research to
3 evaluate the differences and recommend additional
4 actions, if warranted, a scoping study. Research has
5 begun that work. They just started it. Their
6 objective is to provide us the results of that scoping
7 study by the end of 2008. That information will help
8 inform NRR as to whether additional regulatory actions
9 are needed to address BWRs. However, we are not
10 standing on that work alone. We have been encouraging
11 the BWR Owners Group to take the initiative to address
12 the issues themselves rather than waiting on us to
13 come out with a multi-plan action that might be
14 painful for the industry. We are not prepared to do
15 that at this point, but we are encouraging the BWR
16 Owners Group to take actions to avoid us having to get
17 to that point.

18 We will consider further regulatory
19 actions based on the results of that work. I will say
20 that I met with the BWR Owners Group just yesterday
21 and we received a very encouraging picture from them
22 that they recognize that there were questions to be
23 answered and they largely signed on to answer those.
24 Of course, they said we don't have funding for this
25 yet and we have to get the funding and we don't know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the schedule, but we recognize additional questions
2 needs to be answered from which the staff had sent
3 them by the way.

4 We sent them a paper that said here are
5 some specific treatment disparities that we think need
6 to be looked at further, for example, chemical
7 effects, in-vessel downstream effects for BRWs may be
8 more problematic than for PWRs because of the channels
9 that inhibit cross flow between the assemblies.

10 As the Subcommittee Members may recall,
11 when we came and briefed you, it doesn't take a whole
12 lot of flow coming into the core of the PWR to provide
13 adequate flow because of the cross flow between the
14 assemblies. It's a small amount of flow. For BWRs,
15 that might be more challenging and so that's one of
16 the points that we think they need to look into. And
17 they agreed to look into it.

18 So we are encouraged, based on yesterday's
19 meeting, it was actually a change in their position
20 from a previous meeting we had with them in November
21 where they didn't think certain issues needed to be
22 addressed. I think their perception of the scope is
23 broadened and so we were pleased with that.

24 So we have a plan that we are working to
25 address the issue for BWRs and to attempt to achieve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 an appropriately consistent licensing basis for the
2 two reactor types.

3 So we're early in that process yet and
4 we're not prepared at this point, obviously, to talk
5 about industry results on this, but we're embarked on
6 the process.

7 MEMBER CORRADINI: Mike, we should
8 conclude, I think.

9 MR. SCOTT: We will conclude with this
10 slide. It says as you already know, as several of you
11 have referred to, GSI-191 is a real complex issue. We
12 are working hard to resolve it. Just for the sake of
13 argument, would every member of the staff who has been
14 involved in this issue, please raise his hand.

15 (Laughter.)

16 Tom Hafera, ex-member of the staff. Chen
17 Lai Lui, NASA. They're all over the place. We have
18 committed enormous resources for one issue to address
19 this issue, so we are working hard to get done with it
20 and we have had challenges and surprises throughout.

21 It is possible that when we're done with
22 the testing and the analysis and we've validated the
23 testing and analysis is okay, additional mods may be
24 needed and that will be up to the plants to do and we
25 will have to deal with that at that time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As I mentioned to you, our current plan is
2 to resolve the issue in 2009 and we are doing our
3 utmost to get that done.

4 Subject to your questions.

5 MEMBER BANERJEE: Questions?

6 MEMBER MAYNARD: I don't have a question,
7 but just to get it on the record for this meeting, I
8 think you should identify that you, Dennis, and I went
9 to the Salem plant and actually observed a screen that
10 went into containment and saw the design. At least
11 that plant had been receptive to comments made at
12 previous meetings and it incorporated some of those.
13 So just for the record get that on there.

14 MEMBER BANERJEE: right.

15 MR. SCOTT: Coincidentally, that was also
16 a plant we did an audit on. So they have a number of
17 issues to address from our audit.

18 MEMBER BANERJEE: So I think we've got a
19 good update. We have to discuss at some point what we
20 want to do.

21 VICE CHAIRMAN BONACA: So the BWR, it's an
22 interesting point. Yesterday, we raised the issue of
23 back-pressure credit for power uprates with the
24 Commission and we're still granting back-pressure
25 credit when this issue is still open.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCOTT: I'm sorry, say that again?

2 VICE CHAIRMAN BONACA: I'm saying we're
3 still granting back-pressure credit, and yet now the
4 issue of recirculation for BWR is reopening.

5 MR. SCOTT: You mean containment over-
6 pressure? Oh, okay.

7 There are some PWRs that have -- some of
8 them have quite low margins, net positive suction head
9 margins and they have asked us not to much for post-
10 accident pressure but for atmospheric pressure credit
11 which we have granted. But that's an on-going
12 discussion as well.

13 VICE CHAIRMAN BONACA: That's an on-going
14 discussion.

15 MEMBER BANERJEE: So I think with that,
16 I'll turn it back to you.

17 Thanks, Mike. Very nice update.

18 MR. SCOTT: You're welcome.

19 MEMBER BANERJEE: Very good presentation.

20 CHAIRMAN SHACK: Don't run away,
21 gentlemen. That is the end of the meeting. We can go
22 off record now. So the meeting is adjourned.

23 (Whereupon, at 11:44 a.m., the meeting
24 was concluded.)

25

CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.


Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com



U.S.NRC

United States Nuclear Regulatory Commission

Protecting People and the Environment

US-APWR Standard Design Certification Project Overview

To:

Advisory Committee on Reactor Safeguards

By:

Jeff Ciocco, Senior Project Manager
U.S. Nuclear Regulatory Commission

June 6, 2008

US-APWR Application Status


- Pre-application review meetings began July 2006.
- Topical Report submittals began January 2007.
- Received Mitsubishi Heavy Industries (MHI), LTD, US-APWR standard design certification (DC) application on December 31, 2007.
- Acceptance review completed and docketed application on February 29, 2008. (Docket Number is 52-021).
- Phase 1 licensing review underway, preparing Preliminary Safety Evaluation Report and issuing RAIs.
- Luminant selected the US-APWR technology for Comanche Peak Nuclear Power Plant Units 3 & 4.
 - COL application expected September 2008.

US-APWR Design Certification Review Schedule

| <u>Phase</u> | <u>Name</u> | <u>End date</u> |
|--------------|---|-----------------|
| Phase 1 | Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI) | June 2009 |
| Phase 2 | SER with Open Items | March 2010 |
| Phase 3 | ACRS Review of SER with Open Items | June 2010 |
| Phase 4 | Advanced SER with No Open Items | May 2011 |
| Phase 5 | ACRS Review of Advanced SER with No Open Items | August 2011 |
| Phase 6 | Final SER with No Open Items | September 2011 |

DCD Chapters and Topical Reports

| <u>Chapter Project Manager</u> | <u>DCD Chapter</u> | <u>Topical Reports (SER Dates)</u> |
|--------------------------------|---|---|
| Mike Takacs | Ch 10 – Steam & Power | |
| Ngola Otto | Ch 11 – Radioactive Waste Management Systems | |
| Ngola Otto | Ch 12 – Radiation Protection | |
| Mike Takacs | Ch 13 – Conduct of Operations | |
| Ngola Otto | Ch 14 – Initial Test Programs | |
| Mike Takacs | Ch 15 – Transient & Accident Analyses | <ul style="list-style-type: none"> - Non-LOCA Methodology (05/2009) - Large Break LOCA Code Applicability (05/2009) - Small Break LOCA Methodology (04/2009) |
| Peter Hearn | Ch 16 – Instrumentation & Controls | |
| Jeff Ciocco | Ch 17 Quality Assurance & Reliability Assurance | <ul style="list-style-type: none"> - Quality Assurance Program (QAP) Description for Design Certification (01/2008) |
| Steve Monarque | Ch 18 – Human Factors Engineering | <ul style="list-style-type: none"> - HFE Process & HSI System Design (09/2008) |
| Jin Chung | Ch 19 – PRA & Severe Accidents | |



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

Status and Path Forward for Generic Safety Issue 191, Pressurized Water Reactor Sump Performance

Presented by:

Michael Scott

Office of Nuclear Reactor Regulation

Presented to:

Advisory Committee on Reactor Safeguards

June 6, 2008



Background

- Generic Safety Issue 191 involves performance of PWR emergency core cooling and containment spray systems in recirculation mode in the presence of debris after a loss-of-coolant accident/high-energy line break
- Generic Letter 2004-02 requested licensees, by end of 2007, to:
 - Determine plant-specific debris generation and transport
 - Make needed modifications to show compliance with regulations in presence of plant-specific debris loading



Current Status of GSI-191

- Essentially all PWRs have installed much larger sump strainers
- Many have done other modifications (e.g., removed insulation or replaced sump buffer)
- Fort Calhoun implementing water management initiative
- Staff and industry believe risk of strainer clogging reduced significantly
 - Significant uncertainties remain
 - Plants can continue to operate safely for same reasons as stated in GL 2004-02
- Integrated head loss testing (including chemicals) ongoing
 - Staff reviewing and commenting on protocols
 - Staff observing and commenting on representative tests intended to show adequate strainer function



Current Status (Continued)

- Most licensees received additional time beyond 12/31/07 to complete certain corrective actions
 - Downstream effects analyses
 - Integrated head loss testing
 - Plant modifications
- Most extensions for a few months; a few into 2009
- All plants submitted supplemental responses to GL 2004-02 in February/March 2008 (incomplete responses for plants with extensions)



Chemical Effects

- Many plants did not complete integrated head loss testing with chemical effects by end of 2007
- Completion delayed by:
 - Late recognition by industry of difficulty of the issue
 - Limited number of testing vendors, requiring queuing
 - Challenges resolving staff issues with chemical effects topical report
 - Staff issues with testing methods used or planned by test vendors
- Staff issued safety evaluation (SE) on chemical effects topical report in December 2007



Chemical Effects Peer Review

- Staff screened peer review issues in 2007 to identify those warranting further evaluation
- Office of Nuclear Regulatory Research commissioned study of aspects that earlier staff review could not disposition
- Staff currently reviewing study results
- Likely result is need for additional consideration of some of these effects
- Will report to Committee on this later in 2008



Downstream Effects

- Ex-vessel (pumps, valves, etc.)
 - SE on ex-vessel downstream effects topical report issued December 2007
 - Some licensees have requested extensions to complete these analyses
- In-vessel (core flow blockage)
 - Received topical report WCAP-16793-NP June 2007
 - Draft SE issued in March 2008
 - Met with ACRS Thermal-Hydraulics Subcommittee March 19
 - Subcommittee had questions and concerns
 - Staff and PWR Owners Group working to address issues
 - Will return to Subcommittee as soon as issues resolved
 - Description of method in draft WCAP and some preliminary NRC staff conclusions discussed in backup slides



ACRS T/H Subcommittee Questions and Concerns

- Flow resistance at the core inlet or first spacer grid as a consequence of deposits (maximum loss permitted and whether that could occur)
- Temperature at the screen vs. that at the core inlet and its effect of solubility of chemical compounds
- More information on local subchannel blockage and its potential for temperature hot spots
- Bypass testing and assumptions
- Driving head for flow into the core
- Potential for and consequences of debris inhibiting boric acid mixing



Path Forward on WCAP-16793

- Staff has provided additional information to the subcommittee that may address some aspects of these questions
- PWR Owners Group plans additional testing to reduce uncertainty regarding potential for blockage at core inlet
- Staff needs to evaluate responses being developed by PWR Owners Group
- Staff and PWR Owners Group plan to return to brief subcommittee
- Timeline dependent on completion of adequate Owners Group-sponsored testing and/or evaluation



Head Loss Testing

- Staff has questioned whether various aspects of the licensee-sponsored vendor-performed head loss testing are conservative or prototypical
 - Debris preparation and introduction
 - Near-field settling
 - Thin bed testing
- Staff's questions and concerns have had impacts on licensee test schedules
- Staff has found that most vendors now have conservative protocols – though some licensees completed testing under previous protocols with which staff has had concerns
- Licensees can use any approach that they can show to be conservative or prototypical



Head Loss Testing (Cont'd)

- One recent test of a uniform flow strainer conducted by adding full particulate load followed by sufficient fine fiber (only) to create a thin debris bed resulted in high head loss without chemicals
- Challenge for licensees is to develop conservative or prototypical, but not excessively conservative, test protocol
- Potentially challenging for high-fiber and maybe for medium-fiber plants



GL Supplemental Response Reviews

- Staff has begun review of supplemental GL responses
- Because of extensions, many licensees will need to submit an additional response
- Likely to send requests for additional information (RAIs) to most plants
 - For low-fiber plants, few RAIs – maybe limited to in-vessel downstream effects
- Result is final closure in 2009



Closing GL 2004-02 and GSI-191

- Staff plans to close these issues for each plant based on:
 - Review of licensee supplemental responses
 - Results of Region inspections of licensee corrective actions
 - Review of licensee responses to audit open items (as applicable)
- If a plant has not completed all modifications but has a satisfactory strainer evaluation in place and a specific plan for completing remaining modifications, staff plans to close the GL and GSI for that plant
- Staff will track all corrective actions to completion at all plants



Subjects Proposed for Future ACRS Review

- In-vessel downstream effects
- Integrated head loss testing protocols and results
- Results of staff review of licensee supplemental responses
- Results of chemical effects peer review scoping analyses
- Results of additional confirmatory chemical effects testing at Argonne National Laboratory



Disparities in Treatment for PWRs and BWRs

- BWR strainer issues resolved in 1990s
- For various reasons, treatment of debris-induced clogging issues has varied for PWRs and BWRs
 - Different strainer, ECCS, and core designs
 - Issues addressed at different times and based on different states of knowledge
- Learned a lot from PWR work – applicable to BWRs?
- NRR has sent User Need to ask RES to evaluate differences and recommend additional actions if warranted – RES has begun work
- Encouraging BWR Owners Group to take initiative to address potential issues
- Will consider further regulatory actions based on BWROG and RES activities



Conclusions

- GSI-191 remains an extraordinary complex and difficult issue to resolve
- Licensees have made substantial progress in reducing vulnerability to strainer clogging and related issues
- Additional modifications may be needed (e.g., remove problem materials from containment) if licensees cannot show success in the near future with conservative testing and evaluation
- Staff expects issue resolution in 2009



Backup Slides



WCAP-16793 Approach to In-vessel Effects

- Limit on the maximum temperature of fuel clad is established based upon a conservative value that prevents fuel damage (in accordance with 10 CFR 50.46)
- Industry-recognized models for deposition of solids and calculation of temperature increases based on heat transfer coefficients are used
- Flow simulation code (WCOBRA/TRAC) is used to assess limit on flow reduction and still achieve adequate core cooling
- Entire chemical effects source term from topical report WCAP-16530 assumed to be available for deposit on core surfaces



Approach to In-vessel Effects (Cont'd)

- Size and quantity of fibrous material entering the lower core region is estimated from the containment sump screen dimensions and plant fiber bypass tests
- Deposition of this material on the lower core plate, leading to flow blockage, is assessed
- Particulate and fibrous matter that passes through the lower core plate is evaluated for local flow blockage and deposition effects
- Thickness of fuel deposits (oxide + crud + chemical deposit) formed is calculated using LOCADM based on fuel decay heat, the mass of materials present, and the core surface area



Licensee Use of WCAP-16793

- Licensees are likely to take credit for WCAP-16793-NP as bounding for their plants in showing that in-vessel downstream effects will not cause unacceptable impacts on the fuel
- Application of WCAP-16793-NP is to be in accordance with conditions and limitations contained in the NRC SE (when published)
- Licensees are expected to verify that the assumptions in the WCAP-16793-NP methods are conservative with respect to their individual plants
- Licensees may choose to develop and substitute plant-specific data, such as debris content, chemicals, strainer efficiency, etc.



Staff Review of WCAP-16793


- Staff noted a number of conservatisms in WCAP-16793
 - Most of core entrance assumed blocked with debris – flow still adequate
 - Assumed buildup of debris on core surfaces conservative
 - Thermal conductivity value conservative
 - Worst-case local heating well below limit
 - Chemical source term assumptions conservative
 - Large margin between the chemical deposit predicted for a high-fiber plant with large amounts of calcium silicate insulation and the amount of deposit that would cause the maximum peak clad temperature to exceed the acceptance criteria

MITSUBISHI

US-APWR



Opening Remarks What is MHI and MHI Commitment



June 6, 2008

Kiyoshi Yamauchi
Executive Officer, Senior Vice President,
Nuclear Energy Systems Headquarters

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08101

Contents



- 1. MHI Experience**
- 2. MHI Technologies**
- 3. MHI Commitment to Nuclear Safety**
- 4. Conclusions**

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.


553rd ACRS MEETING
UAP-HF-08101-1

2. MHI Technologies (1/6) -Total Plant Capability-





➤ Total Plant Capability with "Single Point Responsibility"

- ✓ R&D, design and engineering, manufacturing, construction, maintenance services, and fuel supply



➤ Globalized Quality Assurance

- ✓ Supporting export of nuclear components, e.g., steam generators, reactor vessels, reactor vessel heads or turbines ...



MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.


553rd ACRS MEETING
UAP-HF-08101-4

2. MHI Technologies (2/6) -Reactor Core Design & Safety Analysis-




➤ State-of-the-Art Reactor Core Design and Safety Analysis

- ✓ Advanced analytical program
- ✓ Verification using demonstration test facilities
- ✓ Licensing support



Power distribution after the rod ejection from 3-D calculation



A demonstration test facility for the LOCA analysis methodology

MITSUBISHI HEAVY INDUSTRIES, LTD.


Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08101-5


2. MHI Technologies (5/6) -Plant Construction-



➤ Various On-Site Work Reduction Techniques



- ✓ Super large-capacity cranes
 - On-site containment
 - Welding and formation
- ✓ Comprehensive coordination of civil & construction work



➤ Module Utilization

- ✓ Internal structures using SC (-Left)
(Steel plate reinforced concrete)
- ✓ Large prefabricated blocks (-Right)

Typical achievements
(1st Concrete to fuel loading)


| | |
|--------|---------------|
| 2 loop | : 34.5 months |
| 3 loop | : 37.5 months |
| 4 loop | : 40.0 months |

2. MHI Technologies (6/6) -PWR Fuel Supply-



➤ Leading edge technology based on abundant manufacturing / irradiation experience


as of February 2008





MITSUBISHI **US-APWR**

DESIGN FEATURES



June 6, 2008

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102

Contents



- 1. What is the US-APWR**
- 2. Fuel and Core Design**
- 3. System Design & Safety Features**
- 4. I&C System Architecture**
- 5. Conclusions**




MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102-1

Proven, Fully Tested Technologies

Verification of Advanced Features for APWR

| | 1995 | 2000 | 2005 | |
|---|----------------------------------|------|------|--|
| • Reactor Internals and Neutron Reflector | Flow Tests | | |  Reactor Flow Test |
| • Compact SG and Improved Separator | Performance, Flow, Seismic Tests | | |  SG Separator Test |
| • Advanced Accumulator | Performance Tests | | | |
| • High-performance RCP | Performance and Flow Tests | | | |
| • Advanced I&C System | Operability Tests with Simulator | | | |
| • Turbine | Performance and Vibration Tests | | |  LP Turbine Test |

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102-4

Comparison of Output & Main Components

| | | US Current 4 Loop | APWR | US-APWR |
|----------------------|---------------------|----------------------|-----------|-----------------|
| Electric Output | | 1,180 MWe | 1,538 MWe | 1,700 MWe Class |
| Core Thermal Output | | 3,411MWt | 4,451 MWt | 4,451 MWt |
| Steam Generator | Model | 54F | 70F-1 | 91TT-1 |
| | Tube size | 7/8 in. | 3/4 in. | 3/4 in. |
| Reactor Coolant Pump | Model | 93A-1 | 100A | 100A |
| Turbine | LP last-stage blade | 44 in. | 54 in. | 70 in. class |

➤ APWR

- ✓ 1,538 MWe output is achieved by large capacity core and large capacity main components such as SG, RCP, turbine, etc.

➤ US-APWR

- ✓ 1,700 MWe class output is achieved by a 10% higher efficiency than APWR.
 - Same core thermal output as APWR
 - High-performance, large capacity steam generator
 - High-performance turbine

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.


553rd ACRS MEETING
UAP-HF-08102-5

2. Fuel and Core Design

Fuel Assembly

- Flexible Operation
- Enhanced Economy
- Improved Reliability

17x17 Fuel rod array
 14 ft Fuel active length ●
 In-core instrumentation guide tube
 Control rod guide thimble
 Bottom grid spacer
 Bottom nozzle ●
 Anti-debris design with built-in filter



Top nozzle
 Top grid spacer
 Intermediate grid spacer
 High DNB performance design ●
 Shorter grid spacing with 11 grids ●●
 Fretting resistant spring ●
 Zircaloy-4 ●
 Fuel rod
 Higher density pellet (97%TD) ●
 Corrosion resistant cladding Material (ZIRLO™) ●
 Higher gadolinia content pellet (10wt%) ●
 Large plenum volume ●
 Lower power density ●

Fuel Design


| | US Current | APWR | US-APWR |
|--|---------------|--------------|-------------|
| Fuel Assembly | | | |
| Fuel Rods Array in Fuel Assembly | 17 x 17 | 17 x 17 | 17 x 17 |
| Number of Fuel Rods per Fuel Assembly | 264 | 264 | 264 |
| Number of Control Rod Guide Thimbles | 24 | 24 | 24 |
| Number of in-core Instrumentation guide tube | 1 | 1 | 1 |
| Number of Spacer Grids | 8 / 10 | 9 | 11 |
| Fuel Rod | | | |
| Outside Diameter | 0.374 in. | 0.374 in. | 0.374 in. |
| Cladding Thickness | 0.022 in. | 0.022 in. | 0.022 in. |
| Active Fuel Length | 12 ft / 14 ft | 12 ft | 14 ft |
| Enrichment | Max. 5 wt% | Max. 5 wt% | Max. 5 wt% |
| Gadolinia Content | Max. 8 wt% | Max. 10 wt% | Max. 10 wt% |
| Pellet Density | 95 % TD | 97 % TD | 97 %TD |
| Material | | | |
| Cladding | ZIRLO™ | MDA / ZIRLO™ | ZIRLO™ |

Neutron Reflector

Improved reliability

● Significantly simplified and reliable structure


- Number of bolts reduced significantly and located only at out of core region
- No welds



Enhanced performance

● Reduced neutron exposure rate

- 1/3 of current 4 loop design without neutron shield



Methodology and Codes

➤ Fuel Design


✓ FINE

- Fuel rod design code developed by MHI
- Significant post irradiation examinations and out-of-pile test
- Topical report on verification and applicability to US-APWR fuel is under NRC review

✓ FINDS

- Fuel assembly seismic analysis code developed by MHI
- Topical report on verification and applicability to US-APWR fuel is under NRC review

ECCS and CSS/RHRS



➤ High Reliability

- ✓ 4 train configuration
(50% x 4 for large break LOCA)
- ✓ In-containment RWSP
(eliminate recirculation switchover)

➤ Simplification


- ✓ Advanced accumulators (ACC)
(Integrated function of low head injection system)
- ✓ ECCS train includes an accumulator and high head injection system
- ✓ Direct vessel injection
(no inter-connection between trains)
- ✓ Common use of CSS and RHRS

ECCS and CSS/RHRS (cont.)


Advanced Accumulator

- ✓ Passive switching of injection flow rate
- ✓ Integrated function of low head injection system
- ✓ Long accumulator injection time allows more time for safety injection pump to start (allows use of gas turbine generator for EPS)
- ✓ Topical report on Advanced Accumulator is under NRC review

Current 4 Loop




US-APWR



ECCS and CSS/RHRS (cont.)

Design feature of high head injection system

- 4 independent trains without interconnections between trains
- Sufficient capacity of safety injection pumps
 - ✓ Meets the safety injection requirement for core reflooding stage



| Item | US Current 4 Loop | US-APWR | Reason and/or Advantage |
|-----------------------------|------------------------------------|--------------|--|
| Trains | 2 trains | 4 trains | <ul style="list-style-type: none"> • Enhanced reliability • Achieve OLM under single failure |
| High head Injection | Loop injection 2 SIP + 2 CH/SIP | DVI 4 SIP | <ul style="list-style-type: none"> • No interconnection between trains |
| Refueling Water Storage Pit | Outside CV | Inside CV | <ul style="list-style-type: none"> • Eliminate recirculation switchover |

MITSUBISHI HEAVY INDUSTRIES, LTD.


Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102-20

ECCS and CSS/RHRS (cont.)

Feed & Bleed for Boration to Achieve Safe Shutdown

➤ Design Features



- ✓ Emergency Letdown Lines are installed from H/L to RWSP
- ✓ In Safe Shutdown operation, emergency boration source is RWSP
- ✓ The borated water is injected by Safety Injection pump
- ✓ The volume control of RCS is achieved by Feed & Bleed with SIP and Emergency Letdown Line

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102-21


Emergency Feedwater System

➤ Design concept of the EFWS

- ✓ Achieve high reliability with simplified systems
- ✓ Allow On-Line Maintenance assuming single failure

➤ Feature of the EFWS

- ✓ Independent 4 train system
- ✓ 2 safety grade water sources
- ✓ Diverse power sources for the pumps
- ✓ Cross connections in the inlet and outlet of the pumps (normally isolated)



Emergency Feedwater System (cont.)

➤ 4 train configuration

- ✓ 4 pumps with diverse power sources
 - 2 motor-driven emergency feedwater pumps (50% x 2)
 - 2 turbine-driven emergency feedwater pumps (50% x 2)
- ✓ Cross connected discharge of the pumps allows On-Line Maintenance (OLM)


➤ 2 safety grade independent feedwater sources

- ✓ Two emergency feedwater pits (50% x 2)
- ✓ Cross connected inlet of the pumps backs up each feedwater source

| Item | US Current 4 Loop | US-APWR | Reason and/or Advantage |
|----------------------------|----------------------------|----------------------------|--|
| System Configuration | 2 trains | 4 trains | A pump is allowed OLM under the single failure |
| Emergency Feedwater Pump | M/D EFWP: 2 T/D EFWP: 1 | M/D EFWP: 2 T/D EFWP: 2 | Diverse power sources |
| Emergency Feedwater Source | 1 | 2 | 2 independent pits (backup available) |

PCCV

- Robust and reliable Pre-Stressed Concrete Containment Vessel with steel liner is used in US-APWR



MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.

553rd ACRS MEETING
UAP-HF-08102-28

Methodology and Codes for Safety Analysis

➤ Large Break LOCA

- ✓ WCOBRA/TRAC code and ASTRUM methodology
- ✓ Approved by NRC
- ✓ US-APWR design features modeled:
 - Advanced Accumulator
 - Direct Vessel Injection
- ✓ Topical report on applicability to US-APWR is under NRC review

➤ Small Break LOCA

- ✓ Appendix-K version of M-RELAP5 code
- ✓ Equivalent to RELAP5/MOD3.2 widely used in US
- ✓ US-APWR design features modeled:
 - Advanced Accumulator
 - Direct Vessel Injection
- ✓ Topical report on applicability to US-APWR is under NRC review

MITSUBISHI HEAVY INDUSTRIES, LTD.

Copyright© 2008 MITSUBISHI HEAVY INDUSTRIES, LTD.


553rd ACRS MEETING
UAP-HF-08102-29

Countermeasures for Severe Accident

- **US-APWR achieves higher safety to comprehensively address severe accident and mitigate consequences**
 - ✓ Demonstrate compliance with current NRC regulations including TMI requirements for new plants
 - ✓ Demonstrate technical resolution of the applicable unresolved safety issues (USI), and the medium and high-priority generic safety issues (GSI) discussed in NUREG-0933

Countermeasures for Severe Accident (cont.)

➤ Severe Accident Mitigation Features



Addressed severe accident issues

- (1) Hydrogen generation and control
- (2) Core debris coolability
- (3) Steam explosion
- (4) HPME
- (5) TISGTR
- (6) MCCI
- (7) Long-term containment overpressure
- (8) Equipment survivability

Overall I&C System Architecture

- **Microprocessor based digital technology for most plant I&C (no electro-mechanical relays)**
- **Complete four train redundancy for safety I&C with each division in separate fire zone**
- **Distributed architecture for non-safety I&C with redundancy**
- **Fully multiplexed and duplicated signal transmission networks from local areas to I&C equipment rooms and Main Control Room, and between I&C systems**
- **Common digital platform for safety and non-safety I&C**
- **Diverse Actuation System based on analog technology**
- **Fully computerized Main Control Room**

History of MHI Digital Application

- **Non-safety Application History**
 - ✓ **Development began in 1985 with initial goal of non-safety applications and long term goal of safety applications**
 - ✓ **Platform originally developed in compliance with US standards, including communications independence (cyber security)**
 - ✓ **First installation for non-safety systems / components**
 - ✓ **Average 10 years operation for five operating plants**
 - ✓ **Applied to all non-safety I&C, 50 applications per plant**
 - ✓ **Over 20 million hours total operating experience**
 - ✓ **No unexpected shutdown caused by I&C**
 - ✓ **No system malfunction caused by S/W or H/W failure**

HSI Verification & Validation

- **HSI Verification & Validation is being conducted with U.S. operators**
- **Dynamic validation will be performed using Full-Scale Simulator with 8 U.S. operating crews**
 - Performance Check
 - Review and Comment
 - Normal and accident scenarios
 - Normal and degraded HSI conditions
- ✓ **Established Standard Design Specification**
- ✓ **Results will be issued as a technical report this year.**
- **NRC Staff visited MEPPI on June 4th.**
Demonstrated plant operation using the simulator.

5. Conclusions

- **US-APWR design is similar to the Japanese APWR currently in the stages of licensing review**
- **US-APWR is 1,700 MWe class large NPP based on MHI proven, advanced technology to improve reliability and enhance safety**
- **US-APWR meets U.S. utility's requirements and provides enhanced safety with features that address R.G. 1.206**