

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

July 10, 2008

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on July 10, 2008, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

554TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARD
(ACRS)

+ + + + +

THURSDAY

JULY 10, 2008

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the
Nuclear Regulatory Commission, Two White Flint
North, Room T2B3, 11545 Rockville Pike, at 8:30
a.m., William J. Shack, Chairman, presiding.

COMMITTEE MEMBERS:

WILLIAM J. SHACK, Chairman

MARIO V. BONACA, Vice Chairman

GEORGE APOSTOLAKIS, Member

J. SAM ARMIJO, Member

SANJOY BANERJEE, Member

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR., Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

COMMITTEE MEMBERS: (CONT.)

MICHAEL L. CORRADINI, Member

OTTO L. MAYNARD, Member

DANA A. POWERS, Member

HAROLD B. RAY, Member

JOHN D. SIEBER, Member

JOHN W. STETKAR, Member

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A G E N D A

INTRODUCTION: 4

Objective of Briefing 4

Regulatory Requirement 5

Containment Integrity Acceptance

 Requirements 105

Containment Overpressure Acceptance

 Criteria 131

Adjourn

P-R-O-C-E-E-D-I-N-G-S

(8:29 a.m.)

CHAIRMAN SHACK: The meeting will now come to order. This is the second day of the 554th Meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following; status of NRC activities associated with seismic design issues at nuclear power plants, containment overpressure credit, future ACRS activities, and report of the Planning and Procedures Subcommittee, reconciliation of ACRS comments and recommendation, and preparation of ACRS reports.

A portion of the session on containment overpressure credit may be closed to protect proprietary information applicable to this matter. This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Tanny Santos is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or requests for time to make oral statements from members of the public regarding today's session. We have Mr. Royceman from National Legal Scholars law firm on the phone bridge line to listen to the discussion regarding the status of seismic design issues at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 nuclear power plants. To preclude interruption of the
2 meeting, the phone line will be placed in a listen-in
3 mode during the presentations and Committee
4 discussion.

5 A transcript of portions of the meeting is
6 being kept, and it is requested that speakers use one
7 of the microphones, identify themselves, and speak
8 with sufficient clarity and volume so that they can be
9 readily heard.

10 And our first item of business this
11 morning is the status of NRC activities associated
12 with seismic design issues, and Dr. Powers will be
13 leading that discussion.

14 MEMBER POWERS: As the members are aware,
15 the seismic issues have emerged in connection with
16 early site permits and designs in the reactors. And
17 there has been a substantial evolution in the overall
18 assessment of the seismic hazard posed in Central and
19 Eastern United States, so there's a lot of activities
20 going on in connection with the seismic issue. And we
21 were -- had the benefit of a little tutorial on some
22 of the quantitative aspects of seismic hazard
23 analysis.

24 (Off the record comments.)

25 MEMBER POWERS: At any rate, today we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to get a little more formal assessment of what
2 the Staff's activities are. We have the benefit of a
3 consultant, Bill Hinze, behind me, to assist us. He
4 is actually an expert in this field, and will provide
5 us some expert consultation to this discussion of a
6 variety of different activities. I'm not exactly sure
7 who's going to lead us off. Annie is going to lead us
8 off.

9 Annie, the Committee is new, you're a bit
10 new, and it is traditional when new people come and
11 talk to us that they give some background for why
12 they're qualified to talk before this esteemed body.

13 (Laughter.)

14 MEMBER POWERS: So if you would be kind
15 enough to give us a little bit of your background.

16 MS. KAMMERER: Okay. Well, my name is
17 Annie Kammerer. I'm, obviously, in the Office of
18 Research.

19 (Off the record comments.)

20 MS. KAMMERER: Thank you. My name is
21 Annie Kammerer, and I've been with the Agency for
22 about a year and a half now. I came from an
23 international design firm, Urban Partners
24 International. It's based in London, and I worked for
25 the London office, as well as San Francisco. I was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 working principally in liquified natural gas projects
2 as a seismic hazard specialist, seismic engineer. My
3 Ph.D. is actually in earthquake engineering from
4 Berkeley, where I continued to do research, as well as
5 the consulting before I came here. So I'm fairly new
6 to the Agency.

7 When I came on, I was heavily involved in
8 1.208, the guide on seismic hazard, and was asked to
9 sort of help develop and implement a research program
10 on seismic, because at that time, the Agency was
11 dealing with a lot of issues related to seismic as the
12 ESPs were in-house, and Staff was grappling with a lot
13 of different questions.

14 Okay. So I want to say thank you so much
15 for having me here this morning. I really welcome the
16 opportunity to show you all of the great things that
17 we have been doing. You notice that my name is not on
18 this slide, and that's because really this is
19 collaborative. It's a collaborative project. The
20 work is being done collaboratively. And, in fact,
21 right now even the funding has been collaborative,
22 with not only tremendous support from the management
23 and the Office of Research, but also support from the
24 Office of New Reactors in getting some of this work
25 funded, because this is a new program. It basically

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got kicked off in 2007, and as you can see, we've
2 developed the program really starting from 2008 and
3 beyond. So a lot of times I'll be talking about the
4 program plan, and this is what it is.

5 Okay. Great. Because there's so much in
6 this program that we're getting going, it's really
7 challenging to talk about it in 45 minutes too much,
8 so I'm going to talk a lot about the philosophy and
9 the approach that we're taking, as well as the items
10 related to seismic hazard, which follows from what
11 many of you heard on Tuesday. And, in fact, I've even
12 taken some of the figures on Tuesday, and replaced my
13 figures for the same item so that they'll look a
14 little bit more familiar. So, hopefully, all of this
15 will follow on.

16 So, again, we developed a research plan,
17 and made it publicly available. And the reason for
18 that was that there were so many different items.
19 Those were all interrelated, which really needed a
20 comprehensive, thoughtful process, that rather than
21 doing each user need by user need, or research request
22 by research request, we tried to put together a plan
23 that would really give us a roadmap for moving forward
24 so that it was clear what we were doing, where we were
25 going, not only to us in-house, but also to industry,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and to members of the seismic community who are very
2 interested. And so this has now been published as of,
3 I think, in January, but it is a living document. And
4 as additional needs come up, we will do a periodic re-
5 evaluation and republication of this document,
6 probably about annually.

7 We targeted the program specifically on
8 the regulatory needs of the Agency, of course. It's
9 very important to understand RES is a service
10 organization to the Agency, and what we need to do is
11 to make sure that the needs of our folks in New
12 Reactors, and NMSS, and NRR have the tools that they
13 need, and the information that they need to undertake
14 the regulatory activities. So this, as I mentioned,
15 has been developed, really a lot of input, a lot of
16 collaboration with the other offices, particularly
17 NRO.

18 We presented the plan at a public meeting
19 in December, where it was an industry meeting, and
20 we've gotten really, really positive feedback from
21 that. And, in fact, you'll see that actually EPRI has
22 come in to collaborate with us on several projects,
23 and I'll show you. So the NRC funding, and as well as
24 DOE, so NRC funding is really being heavily leveraged
25 in this program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We are looking at both pushing forward the
2 science, and really bringing the NRC's seismic
3 research program to the cutting edge, as well as
4 really looking at the items that will lead to long-
5 term regulatory stability. So where are the big
6 questions? We heard a lot on Tuesday about the
7 uncertainties in a lot of these areas, and we really
8 tried to target those areas in which uncertainty is
9 the greatest in a very thoughtful way.

10 And, lastly, as you also heard, there's a
11 movement towards performance state-based approaches,
12 so this program deals with that a lot in relation to
13 the design elements, which I'm not going to talk about
14 today, but the engineering side of the program is very
15 heavily based on the performance-based approaches in
16 developing the technical basis for new regulatory
17 guidance in that area. That's something that's really
18 just getting in place now, and something that perhaps
19 I can present to you in the future.

20 So we undertook this philosophy when
21 developing the program. We wanted to look at both
22 short and long-term research topics. We wanted to
23 both address the critical needs that the Agency had in
24 the short-term, but also look forward in a very
25 thoughtful way to, again, reducing uncertainty, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increasing long-term regulatory stability, and to
2 really getting us to the place where in five years we
3 would want to be in five years, so that we didn't end
4 up saying gosh, if only we would have done this back
5 in 2009. We've really taken -

6 MEMBER POWERS: You're always going to do
7 that.

8 (Laughter.)

9 MS. KAMMERER: That's probably true.
10 Hopefully, we'll minimize the sleepless nights. I
11 wish that I'd done different things last week, so
12 that's very true.

13 We're looking at really a systematic and
14 integrated program, and I hope that you'll see that as
15 I present some of the specific topics. We're really
16 trying to move the seismic research from a topic-by-
17 topic approach to an integrated approach. And that's
18 not only true within the Agency, that's true within
19 the seismic hazard assessment community, but
20 essentially Eastern U.S., in general. It's been more
21 that people have been doing their particular topics as
22 they could, and we're looking with other agencies to
23 really bring an integrated approach.

24 We're focused on the highest
25 uncertainties, and we're really trying to make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 everything that we're doing risk-informed, and fill in
2 some gaps.

3 MEMBER CORRADINI: Just for my
4 information. So what are other some key agencies that
5 have been historically doing this? Are there one or
6 two that stand out that you'd want to partner with so
7 you can get information from them, and not duplicate
8 what they're -

9 MS. KAMMERER: Absolutely. Well, the
10 principal one with regard to seismic hazard is the
11 USGS. Of course, they're responsible for the National
12 Hazard Maps. They're also -- their core competency is
13 going out and getting information on seismic sources,
14 and so we're doing a lot of work. We're also, of
15 course, leveraging DOE dollars quite a bit.

16 I'll show you one of the projects MJ East.
17 We've actually managed to bring in partners also from
18 the NEHRP program. The NEHRP Consortium is going to
19 be partnering with us on that, and that's a group of
20 USGS, NIST, FEMA, I'm forgetting an agency. Sorry if
21 there's anyone here from the other NEHRP agency,
22 there's four of them. So they're actually coming in
23 and sponsoring with us. So I'll talk about a little
24 bit about how we are actually bringing in other
25 groups, because I think that is really critical to how

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we've been able to go from zero to 60, just even
2 within a year, and fairly limited funding, of course,
3 because this is a new program.

4 And we're trying to do a lot of things
5 cost-effectively, and so that means piggy-backing on
6 work that's been done that's very similar. There's
7 been a lot of work out in California, doesn't
8 necessarily apply to the CE U.S., but with a little
9 bit of targeted funding, we can go to those people and
10 say how about doing this small additional program.
11 It's extremely cost-effective for us.

12 We're really trying to bring in
13 universities. Grad students are cheap, they're much
14 cheaper than lab folks on many occasions, and so we're
15 -

16 MEMBER POWERS: But not nearly as good.

17 (Off the record comments.)

18 MS. KAMMERER: And in some cases, they're
19 actually partnering together. We're just implementing
20 some work now with Lawrence Berkeley Lab from some
21 folks that moved from Lawrence Livermore.

22 MEMBER CORRADINI: I was hoping you were
23 going to say labs are not allowed.

24 MS. KAMMERER: No, absolutely not. We
25 definitely value the input from labs. So LBL is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually working with the University of California and
2 bringing us a lot of great talent there.

3 MEMBER POWERS: Can we turn his microphone
4 off? Go ahead, Annie.

5 MS. KAMMERER: You know, one of the
6 things, too, is we're really trying to focus the work
7 in universities in a way that is also looking at our
8 future workforce, and trying to support the university
9 work in an intelligent way to support some grad
10 students, some post docs, and to really try to make
11 sure that we have a staff, as well, and that they
12 would love to come and work for the NRC, of course.

13 One of the things that we're also doing is
14 what we call next generation approaches, and I'll talk
15 about that in more detail. But it's sort of a new
16 concept over the last few years within the seismic
17 community, and so far it's been very successful in
18 applying these types of approaches for our program.
19 And, of course, we're always striving for the highest
20 quality, and the best technical information.

21 So, hopefully, you'll recognize a few of
22 these slides from Tuesday. And this is sort of an
23 overview of the different elements within the program.
24 So we're looking at all of the elements that go into
25 the probabilistic seismic hazard assessment, so you'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 recognize the sources, the information on how often
2 the sources for these different types of earthquakes,
3 the ground motion prediction equations which was okay,
4 if there's this earthquake there, what does that mean
5 for my site? We talked about that through this
6 figure. Hopefully, it looks familiar. Again, getting
7 a hazard curve. And then, ultimately, turning that
8 into a response spectra, which becomes that blue curve
9 if it's rock, or sometimes looking at site response,
10 if that's important, in which case that comes from the
11 blue curve.

12 We're also looking at the design and the
13 engineering side of it, so it's really a two-part
14 program. So we're also looking at seismic behavior,
15 and degradation, and things like that for systems,
16 structures, and components, as well as the full SSI,
17 and support of some of the work ongoing with the
18 certified design.

19 MEMBER CORRADINI: So not to go through it
20 again, but just an overview question. If I were a
21 chemical plant trying to site -- doing a hazard
22 analysis for a chemical plant, or a biological
23 facility that might have hazards, is the methodology
24 identical?

25 MS. KAMMERER: Yes, absolutely. As I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioned, I come from liquified natural gas. And
2 that was actually -- even though I hadn't worked in
3 nuclear at all, it was really -- it's the same set of
4 tools, and it's the same knowledge that you need to
5 bring in.

6 I think the thing that really comes into
7 play with nuclear is the very long return periods that
8 we look at. In LNG, you tend to look at the 5,000-
9 year event. Here we're looking all the way up to much
10 longer return periods, and ultimately looking at core
11 damage frequency, but the tools are the same. You
12 would do this if it were a California hospital, or if
13 it were an LNG facility. It's really just a matter of
14 what your risk target is.

15 MEMBER CORRADINI: And the years that you
16 go out, that's more regulatory policy versus -

17 MS. KAMMERER: Exactly. It comes down to
18 acceptable risk, what is acceptable risk? That's sort
19 of the beauty of a risk-informed performance-based
20 approach, is you can make your decisions based on
21 comparative risk. And even for things like multiple
22 external events, it has to balance the design elements
23 and where you put your money in the design of the
24 plant.

25 MEMBER BANERJEE: So for the very long

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 term, do you have something that -- geological record
2 that allows you to go out beyond 5,000 years?

3 MS. KAMMERER: Yes. On Tuesday, there was
4 some presentation of that. And, actually, we're
5 looking at some -- undertaking more in this project,
6 as well. Like paleoliquefaction studies, paleoseismic
7 studies, where you do the fault trenching, and you go
8 through, and you can see where these different events
9 occurred within time. There is some extrapolation, of
10 course.

11 One of the challenges we have in the
12 Central Eastern U.S. is that when you go to very long
13 return periods, you have natural erosion processes,
14 which will smear out the evidence of some of these
15 events. And that's a challenge for us, and so we're
16 having to really work with the USGS, as well as
17 several universities that have been focused on this.
18 Virginia Tech being one that we've just implemented a
19 project with to look at exactly these types of
20 questions. And certainly, Yucca Mountain -

21 MEMBER BANERJEE: The Ice Age must have
22 made a difference. Right?

23 MS. KAMMERER: Of course. Of course.
24 Especially to our tsunami program. Actually, that's
25 where we're really building Ice Age issues. And we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 also looking at supporting small pieces of funding or
2 some peripheral concept studies for what we call
3 naturally occurring seismoscope. Some of you through
4 the Yucca Mountain work might be familiar with these
5 precarious rocks, which you have this rock and it's
6 sitting on this little tiny pedestal still, and so you
7 can get some information about what could -- like an
8 upper bound on the shaking because that rock is still
9 there over a certain time period. So we're looking at
10 actually doing a little bit of funding for some of
11 these other ideas that people have that have been used
12 in other parts of the world.

13 MEMBER CORRADINI: So let me just ask my
14 question again, because I thought I understood, and I
15 asked George, and maybe I've got it wrong. So when
16 you say the return period in the chemical industry is
17 5,000 years, and in our's it's longer.

18 MS. KAMMERER: In LNG.

19 MEMBER CORRADINI: In LNG, it's 5,000
20 years. And now our's is longer. Is that because the
21 risk here is lower, and I must look longer to
22 accumulate my worry, or is it a policy issue, or is it
23 the risk is higher, therefore, I have to look for
24 longer periods. I want to understand the logic of the
25 return period being different.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. KAMMERER: The difference is the
2 criticality of the facility, and it is a question of
3 what kind of risk is acceptable for different types of
4 facilities.

5 MEMBER CORRADINI: So it's a value
6 judgment and a policy. It's not a calculation. I
7 don't come to a return period based on a calculation.

8 MS. KAMMERER: No.

9 MEMBER CORRADINI: I come to it based on
10 judgment.

11 MS. KAMMERER: The hazard is what the
12 hazard is. The earthquakes occur regardless of what's
13 sitting there.

14 MR. AKE: This is John Ake. I'm also one
15 of Annie's colleagues at the Office of Research. It's
16 probably easier if we just table the discussion of
17 return period. Think in terms of annual probability
18 of exceedance, or annual frequency of exceedance. It
19 makes it easier, because it doesn't imply -

20 UNIDENTIFIED SPEAKER: That doesn't change
21 the question.

22 MEMBER POWERS: And there's a very simple
23 answer to that. You take the consequences of an
24 event -

25 MEMBER CORRADINI: That's right. You're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 right.

2 MEMBER POWERS: -- by the return period to
3 get to a value that has a figure of merit. And that
4 should be roughly constant among all industrial
5 activity.

6 MEMBER CORRADINI: Actually, you're -

7 MS. KAMMERER: But the design is
8 different.

9 MEMBER POWERS: I bet you on a roughly
10 based area, it's pretty darned constant.

11 MS. EWELL: Excuse me. Jennifer Ewell
12 from Office of Research. Actually, Dr. Powers, can we
13 let John go through the whole -

14 MEMBER POWERS: No.

15 MS. EWELL: -- history, because I think
16 we're talking passed each other.

17 MEMBER POWERS: If he's going to deliver
18 a presentation here, I want to get through Annie's.

19 MS. EWELL: No, no, no. He's going to
20 answer the question briefly, but I think just if you
21 give him 30 seconds, I think it will be clear.

22 MR. AKE: I just think it's easier to
23 think in terms of annual frequency of exceedance
24 rather than probability, because that is actually --
25 you're correct that that is what you multiply times

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the consequences -

2 MS. KAMMERER: Right. Right.

3 MR. AKE: But it's actually -- people
4 think in terms of when they talk about return periods,
5 they think well, I must need to wait 5,000 years to
6 see that. It's actually annual, you have a one in
7 five thousand chance -

8 MEMBER POWERS: You cannot tell me that
9 you believe this Committee is so foolish that they
10 will make that kind of a mistake.

11 MS. EWELL: Actually, we were just trying
12 to answer the question, not meaning to insult
13 anybody's intelligence. But it is a public meeting,
14 and it's on record, so we thought that it would be
15 nice to just get -

16 MR. AKE: Thank you.

17 MEMBER POWERS: Okay.

18 MS. KAMMERER: I apologize because
19 sometimes I simplify things. At my last job, I was
20 often the person who was trying to explain to the
21 public in New York why they were spending their hard-
22 earned tax dollars to seismically upgrade that Tappan
23 Zee Bridge, for example, and so sometimes I do make
24 some simplifications.

25 CHAIRMAN SHACK: We just like frequency of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 exceedance better than a time period.

2 MS. KAMMERER: Okay. Thank you. Also,
3 there is, of course, the design. The design -

4 MEMBER POWERS: It's really complicated to
5 make the conversion.

6 MS. KAMMERER: That's true. The design
7 also plays into the risk, and that's a key element of
8 performance-based engineering, and the thing that
9 we're looking at in the design portion, which we're
10 not going to be talking about.

11 MEMBER BANERJEE: So as you go out to very
12 low frequencies, the uncertainties increase
13 enormously, don't they?

14 MS. KAMMERER: Yes.

15 MEMBER BANERJEE: So how does one band
16 that uncertainty?

17 MS. KAMMERER: Well, a little bit later
18 when I'll talk about the SSHAC methodology, I'll
19 explain how we're looking at quantifying that in the
20 program. Okay.

21 UNIDENTIFIED SPEAKER: What happened to
22 the tutorial, Sanjoy?

23 MEMBER BANERJEE: I did come to the first
24 part, and then I had to go away.

25 MS. EWELL: Can we just try to focus on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the presentation, as we go through the presentation.

2 MEMBER POWERS: Jennifer, I'll tell you
3 what, why don't you let me control the session?

4 MS. EWELL: I was just trying to -

5 MEMBER POWERS: Yes. Let me try to
6 control the session.

7 MS. EWELL: Well, I don't mean to be a
8 problem. I was just trying to help Annie get through
9 the next slide, because I think some of the questions
10 will come out in the presentation. I apologize, Dr.
11 Powers.

12 MS. KAMMERER: And, of course, you all
13 know where I work, so if you have any questions, I'm
14 very happy to come back, and any of you are also
15 welcome. I have an open cube policy for ACRS. So I
16 think this is the way that I sort of use to explain
17 that. Again, we tried to really develop a very strong
18 integrative program, but we also -- so we separate it
19 out in the different chapters, and so you can really
20 think of our Earth Science and National Hazard section
21 as being Chapter 2, again in the public document.
22 Earthquake in Chapter 3. Chapter 4 is International
23 Activities. We have a lot of stuff going on there.
24 It's really too much to get into today, key things, of
25 course, being the Kashiwazaki Lessons Learned project

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we're undertaking through IAEA.

2 I've been to the plant twice now, and it's
3 been extremely useful to be working on that program,
4 as well as some tsunami work we're also doing with the
5 Japanese, which will really help to inform our
6 program. And the regulatory guides. Of course, all
7 of this has to feed back into the next generation of
8 regulatory guides, they're ongoing.

9 Just to give you an idea, this really is
10 an integrated multi-disciplinary project. Each of
11 these are one of the sections, and one of the topics
12 of interest within the plan, and so you can see that
13 they're really all over. And a lot of times we do
14 have this cross-disciplinary work that we're focusing
15 on.

16 We also are looking at, again, short and
17 long-term planning. This shows some of the active
18 projects that we have ongoing. As I mentioned to you,
19 this is a very new program, but we've had tremendous
20 support from the Office of Research to get this going.
21 I mean, coming from the outside, I'm just amazed at
22 the leadership and the vision, as well as the
23 tremendous support from NRO in getting some of these
24 implemented in 2008, which is really, really
25 important. So we also have some that we're getting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 started. A few of these are awaiting some outputs of
2 other things, so it's really critical that we try and
3 keep this program on track. Research has been
4 ongoing.

5 MEMBER APOSTOLAKIS: Yes. I mean, this
6 issue has been very popular with this Agency for
7 several years.

8 MS. KAMMERER: That's true.

9 MEMBER APOSTOLAKIS: Some of this stuff
10 was developed with -

11 MS. KAMMERER: Absolutely. I think that
12 there was -- this is really a way to take what has
13 been done, because there were a few projects which
14 were ongoing, to try and identify the gaps, and try to
15 identify how it all would really fit together in a
16 comprehensive way. So there were individual projects
17 which were ongoing, that was true. I think what we've
18 really tried to do - and, again, this is really --
19 there was a lot of vision in management across the
20 Agency, that they wanted something where there was
21 really a clear path forward, and a clear program. And
22 the funding has actually gone up significantly over
23 the last year, from about -- well, too little to a lot
24 more.

25 (Simultaneous speech.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. KAMMERER: It's gone from way too
2 little to halfway to where I would actually really
3 love to be.

4 MEMBER CORRADINI: You're eventually going
5 to give us those numbers?

6 MS. KAMMERER: I don't know if I can in a
7 public meeting.

8 MEMBER POWERS: And we have no need for
9 those numbers.

10 MS. KAMMERER: I'd be happy to tell you in
11 private, any of you, how much I really would actually
12 love to have.

13 (Laughter.)

14 MS. KAMMERER: I'm not shy about asking
15 for money, as many people know. Okay. So one of the
16 things that we were trying to do is really to bring in
17 this idea of these next generation approaches into the
18 seismic hazard work, in particular. This is something
19 that's been happening very -- it happened very
20 effectively on a couple of projects, and we're trying
21 to bring in the idea. And so far, it's been really,
22 really effective for us.

23 As you mentioned, NRC has initiated a lot
24 of the early seismic hazard work. When I was going to
25 Berkeley, NRC was sort of spoken of with such love and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 nostalgia, I cannot even tell you. It's part of the
2 reason I came, was because so much of the really key
3 work came from this Agency.

4 Really, different methods and tools kind
5 of took off. A lot of different databases were
6 developed. A lot, unfortunately, ended up in gray
7 literature, proprietary reports and proprietary
8 software. So now that the field is maturing, there's
9 a real push to bring it all back together and to
10 integrate it, not only in this Agency, but within the
11 community, and so we've really, I think, been able to
12 inspire a lot of the community to get on board with us
13 as we're trying to do this. And the way to do it is
14 through common databases. Get everyone in the room to
15 bring their data for the benefit of all, community
16 consensus, documentation of thought process is very,
17 very important for letting everyone understand exactly
18 how people came to these decisions.

19 That leads to long-term regulatory
20 stability. If you understand what went into their
21 decision making, when new information comes up, you
22 can put it in some sort of framework. Does this fit
23 with the technical ideas and the framework people had
24 when they made these decisions, or is this really
25 something new? And, of course, it helps us to better

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 quantify uncertainties, particularly epistemic
2 uncertainties, and better understand where they lie.

3 MEMBER POWERS: Is your perception the
4 same as mine, that when we were looking at the seismic
5 sources to Vogtle, that a lot of that was just because
6 of confusion over databases, and sources, and things
7 like that?

8 MS. KAMMERER: I don't -- I think that
9 that's really -- questions on Vogtle really should be
10 addressed to NRO. I was not in -

11 MEMBER POWERS: I asked you. (Laughter.)

12 MS. KAMMERER: I think that in general,
13 one of the things that we're trying to do - and you'll
14 see this especially in the Central Eastern CEUS SSC
15 project, which many NRC staff are involved with. EPRI
16 and DOE are funding it. Dr. Shack is - excuse me -
17 Dr. Hinze is helping us to work on this program,
18 because a lot of what we had was possibly out of date.
19 The databases that we had were out of date. There was
20 this mix of things that were still completely
21 appropriate, and things that were out of date. And I
22 think it's just -- it was a challenge. You had a lot
23 of different vintages of information, so call that
24 confusion. I'm not sure. I think our staff has done
25 a tremendous job.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNIDENTIFIED SPEAKER: Maybe you could
2 rephrase -- I wasn't sure I understood your -

3 MEMBER POWERS: I'm not sure that's a real
4 important point.

5 UNIDENTIFIED SPEAKER: I mean, what Annie
6 is talking about, a lot of these source models for the
7 Central Eastern U.S. were developed in the mid-1980s,
8 but they have updated with the ESPs and the cause,
9 they have updated several key source zones. And you
10 saw that with Vogtle, and our ongoing work is to do a
11 complete update of the whole Central Eastern U.S.,
12 which is what Annie is going to talk about.

13 MS. KAMMERER: Right.

14 MEMBER CORRADINI: So, again, for a
15 novice, as you look harder do you find that the source
16 frequency magnitudes are growing in terms of what was
17 there, and now as you look harder, you find more, or
18 are you finding that you just are getting smarter on
19 how you analyze it? I'm trying to understand.

20 MS. KAMMERER: Mostly, it's the -- I think
21 we're getting a lot smarter, certainly. And a lot of
22 work has been done in the interim 20 years. In some
23 cases, yes, we have found new information, and we have
24 looked harder. When I talked about the CEUS SSC
25 project, that is based on all of the data as it exists

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 now. Just really pulling together everything that's
2 there, including information from the application.
3 But also, in conjunction with that, we really want to
4 start doing some of this work that will help us to
5 identify when we might have missed things, or where we
6 could better characterize sources, for example, is
7 Tennessee.

8 MEMBER POWERS: And one of the problems
9 you suffer from is, of course, you're an active
10 researcher in this area, and so you're very up-to-
11 date.

12 MS. KAMMERER: Yes.

13 MEMBER POWERS: Some of the Committee are
14 probably not as up-to-date. It might be useful to
15 comment on changes that have occurred in USGS
16 assessment on the return frequencies. For instance,
17 at the New Madrid site, and some of the other major
18 seismic centers, where they're probably not -- are
19 very familiar with the pre-1989, maybe not so much
20 familiar with the post 1989.

21 MS. KAMMERER: Right. Well, we do have
22 National Hazard Map, which is ongoing, the work is
23 ongoing. So they redo this map every six years.
24 There are, of course, changes. I guess over the last
25 20 years I would say that a lot of it's gone up. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 most recent maps of several areas have actually gone
2 down, and the reason for that is because of the new
3 ground motion prediction equations. We have more
4 data, and I'll talk about that a little bit.

5 One of the key -- all of this plays
6 together, so it's -

7 MEMBER APOSTOLAKIS: In the same school.
8 When you use acronyms, explain what they are, CEUS?

9 MS. KAMMERER: Okay. Central Eastern U.S.
10 It's actually on some of my later slides.

11 (Off the record comment.)

12 MEMBER APOSTOLAKIS: Are you going to tell
13 us exactly what that means?

14 MS. KAMMERER: Yes, well I hope to. I've
15 only got 10:00, so -

16 MEMBER POWERS: Yes, we could let her go.

17 MEMBER APOSTOLAKIS: If we don't
18 understand what she's saying, that doesn't help.

19 MS. KAMMERER: No, I know, but I think it
20 will be clear when we look at the -- when we look at
21 the actual projects, I think it will be clear.

22 MEMBER APOSTOLAKIS: Okay.

23 MS. KAMMERER: Because where that term
24 comes from, the next generation attenuation
25 relationships, which we're piggybacking on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: On the information -

2 MS. KAMMERER: Yes. Well, it doesn't
3 apply to next generation. The approach is considered
4 next generation, but it's been applied to attenuation
5 relationships in particular with great success, but it
6 really implies a fundamental redevelopment of these
7 tools, not just this incremental change, not where
8 we're going to take what already exists and just
9 weight it differently. We're talking about developing
10 new tools, really take it to the next level, and
11 bringing the work in the Central Eastern U.S. and the
12 hazards, the understanding of hazard in the Central
13 Eastern U.S. to the same level as the west, where a
14 lot of this work has been focused.

15 MEMBER APOSTOLAKIS: You are taking for
16 granted that plants should follow a probabilistic
17 approach, and from what little I have read, there are
18 some people especially to do it, who object.

19 MS. KAMMERER: That's true.

20 MEMBER APOSTOLAKIS: Are we going to
21 understand at some point, today or maybe some other
22 time, what the objections are, and why this Agency
23 decided to go -

24 MS. KAMMERER: Well, I'm not sure that --
25 I don't know that that's within this, but I will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actually talk about what we're doing to address that
2 discrepancy with Europe.

3 MEMBER APOSTOLAKIS: Okay.

4 MS. KAMMERER: So it's more of a
5 technique, rather than getting into the nitty-gritty
6 of the details. But you'll see, we actually have some
7 ideas on that, and so we'll talk about that. And,
8 certainly, the international program that we're doing
9 is something. In addition, IAEA is about to update
10 their seismic hazard guide, and that is, in large
11 part, to members of the international community in
12 different countries saying that they want our 1.208
13 incorporated more, and also some of this information
14 that's coming out of our project, the guidelines.
15 People are really asking for this, so I think that the
16 tide is turning with regard to the disagreement.

17 MEMBER APOSTOLAKIS: But we should
18 understand the disagreement. I mean, as a Committee
19 we should understand it.

20 MS. KAMMERER: We can that in a separate -
21 - that's really a large -

22 MEMBER POWERS: I think it's fair to say,
23 George, that this is not a -

24 MEMBER APOSTOLAKIS: Not for today.

25 MS. KAMMERER: Right. That's certainly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something that we can talk about.

2 MR. CHOKSHI: This is Nilesh Chokshi. I
3 think, George, there was a recent meeting with IAEA
4 about bringing different countries and use of the
5 probabilistic methods, and at some point in time we
6 can tell you what is the outcome of that.

7 MS. KAMMERER: Yes.

8 MEMBER APOSTOLAKIS: Yes, I'd like to hear
9 that. I don't know if the other members want to.

10 (Chorus of yeses.)

11 MS. KAMMERER: I think it would be very
12 useful. And we have a lot of activity going to try
13 and bridge that gap with the rest of the -- not bridge
14 the gap, actually, because many people -- most
15 countries want to move towards probabilistic risk-
16 informed techniques, and they would like our
17 leadership on that, which is great.

18 So I'm going to talk about some of the
19 stuff again that we have with regard to the hazards
20 portion of it, not get into, unfortunately, design.
21 We just really can't get to that today, but some of
22 the things we have going, maximum magnitude of the
23 CESSSE project. I'll talk about all these, and we do
24 have a small study with the USGS to look at the
25 National Hazard Map, so you go look at a variety of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different assumptions, and to try to understand the
2 sensitivity of their map to some of the things that we
3 would maybe do differently, or we aren't really sure
4 about. And we're looking at uncertainties that will
5 help us prioritize some of our research needs. Again,
6 I'll talk about Next Generation East project, and the
7 project of the application of the SSHAC guidelines.

8 So just to remind you of this figure from
9 a couple of days ago, what I'm going to talk about
10 next is these curves, which say for this earthquake of
11 magnitude and distance, this is what it means to my
12 site. This is how much the shaking is. And just to
13 remind you what was said, these are empirical
14 relationship principally, and in the East there's
15 going to be some modeling, as well, but there is some
16 scatter here. So what we're looking at is really not
17 only trying to get the best estimate, but also
18 understand the expert -- so just to remind you of that
19 slide.

20 So the way that we're doing that is
21 through a project called NGA-East. This is a follow-
22 up project to a very successful project called the
23 Next Generation Attenuation project for the West,
24 which significantly reduced the scatter in the
25 different relationships. It took all of these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 different attenuation relationships, our ground motion
2 prediction equations, the terminology has changed.
3 They're the same thing. So it went really from all of
4 these different separate relationships that everybody
5 had to bring a unified to approach, and that was
6 because they had mutually agreed upon databases.
7 Everyone brought their data together and agreed upon
8 it, and did baseline correcting, things like that.

9 They agreed upon the technical bases.
10 They worked together to figure out what the
11 appropriate assumptions would be in some of the work.
12 The upshot is the epistemic uncertainties, the
13 modeling uncertainties were really reduced, and they
14 were characterized. And, as a result, there has been
15 broad community consensus in the West. I mean, really
16 overnight these became the standard of practice. So
17 you'll notice that this is sort of before, and then
18 after. And you'll notice that actually in many cases
19 the numbers actually came down. And that was due to
20 finally getting some near-field large earthquake data.
21 Before it was simply extrapolated out, now we actually
22 have more data, and the same is true with the East.

23 MEMBER APOSTOLAKIS: These curves don't
24 display uncertainty.

25 MS. KAMMERER: These curves do not. No,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these are all just the medium curves. However, again,
2 it's that curve, it's a curve, it's not a single
3 value.

4 MEMBER BLEY: Did any of this work, and
5 I'm trying to account for things in the modeling,
6 actually reduce the uncertainty or scatter?

7 MS. KAMMERER: Well, the -

8 MEMBER BLEY: That's strictly, that's the
9 measured data.

10 MS. KAMMERER: It's the measured data.
11 What they did was they were able to really pull
12 together a much larger database.

13 MEMBER BLEY: Okay.

14 MS. KAMMERER: They pulled in data from
15 Japan, as well, to look at that. It reduced some of
16 the scatter in the models, and that some of the
17 assumptions that you have to make which are tied to
18 that data were -- they developed a technical basis for
19 deciding what those assumptions should be.

20 So we saw this, while I was in California
21 working at the time, and saw just overnight that all
22 of these disagreements on so many projects I was
23 working on evaporated. All of a sudden everyone said
24 we believe in this process. It had broad community
25 support. And, again, the approaches they took, agreed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 upon assumptions, a common database at very high
2 levels, everyone's data was pulled together. And for
3 the East we're doing the same thing.

4 The way that we approached this, because
5 we felt that this was of benefit to so many different
6 agencies, that if we put a small development program
7 in place to develop the scope, the schedule, the
8 budget, and maybe to do a little bit of PR, that we
9 could leverage NRC funds significantly. We're now at
10 the end of this process. We've had three workshops,
11 and we're getting to kick off the main project, and
12 it's been very, very successful. So, in total, it's
13 a five year, \$4.3 million project. We're looking at
14 coming in with a million and a half of that. DOE is
15 going to match our funds. EPRI is coming in hopefully
16 with about a half a million, possibly. And also, the
17 other NEHRP agencies are also partnering with us so
18 that's a consortium again of FEMA, USGS, NIST. And
19 NIST even hosted our second workshop which was a
20 stakeholders workshop here in D.C.

21 MEMBER APOSTOLAKIS: What is NEHRP?

22 MS. KAMMERER: NEHRP is the National
23 Earthquake Hazards Reduction Program. It's a program
24 that's been set in place, and it's a way for different
25 agencies that are involved in that to all work

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 together. And, in addition, we're even seeing small
2 pots of private funding from Risk Management Solutions
3 and other groups.

4 This is being run through the Pacific
5 Earthquake Engineering Research Center at Berkeley,
6 which is where the original program was done. They
7 had all the contracts in place. They had the
8 experience, and it's just worked really, really nice.
9 USGS is also coming in with in-kind participation, and
10 this will be used for the next generation of National
11 Hazard Maps.

12 Okay. So that's the ground motion
13 prediction portion of the problem. Then there's also
14 the sort of broad guidelines of how do you undertake
15 these studies? And, of course, many of you are very
16 familiar. In fact, some of you are even involved in
17 writing the guidelines which are commonly now known as
18 the SSHAC Guideline, the Senior Seismic Hazard
19 Analysis Committee developed a NUREG. This is
20 internationally. I was really quite surprised when I
21 started doing some work. This has sort of become the
22 constitution at PSHA. And really now, it's sort of
23 this framework, and now they're saying we want to use
24 this. There have been a few of these projects
25 undertaken with these guidelines. Give us some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 practical laws to sort of help us work through.

2 MEMBER APOSTOLAKIS: We've had a problem
3 with this agency, and I'm glad you're saying these
4 things. We're doing better outside than inside.

5 (Simultaneous speech.)

6 MEMBER APOSTOLAKIS: One of those letters
7 recommended that some effort be undertaken to make
8 sure that various groups within the Agency use more or
9 less the same approach to the expert opinion and
10 dissertation.

11 MS. KAMMERER: Yes.

12 MEMBER APOSTOLAKIS: You are working with
13 all these other agencies. Is it harder to work with
14 our own people here?

15 (Off mic comment.)

16 MS. KAMMERER: There have been some
17 challenges. I think it depends on who you work with.
18 I mean, I think that -

19 MEMBER APOSTOLAKIS: But it shouldn't.
20 That's my point.

21 MS. KAMMERER: Yes, I know. The seismic
22 group I think has been -- I mean, we really think of
23 ourselves as the seismic team, and we meet for
24 lunches, we talk, we have share point sites that we
25 communicate constantly. So I think that we have been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- I feel like I've just been incredibly fortunate to
2 have such great people across the Agency to work with.

3 You know, there are definitely some
4 challenges. I'm also the Chair of the Flood Technical
5 Advisory Group, but there are challenges. But, boy,
6 you're right. I mean, the international community
7 love the NRC. I can't tell you. You walk into the
8 room as the NRC person, and it's taken for granted
9 that you're doing good technical work, which is just -
10 - it's amazing.

11 So getting back to this, the general
12 framework works very well. Everyone agrees on that.
13 No one wants to touch the SSHAC Guidelines. What
14 people want is more details. How are you going to do
15 this? So we put together this set of workshops that
16 bring in people who have actually tried to use the
17 guidelines to say what worked, what didn't work. And,
18 particularly, we've brought in people from the Swiss
19 program, SSHAC Level 4, which has been the cause of a
20 lot of international consternation. And, as well,
21 people that worked on the Yucca Mountain project.

22 This was an NRC-funded project, but
23 actually to bring in the international participants,
24 which was challenging for us, the DOE Extreme Ground
25 Motions program actually sponsored their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 participation, as well, because they felt it was
2 important.

3 MEMBER BANERJEE: What do you mean by
4 Level 4?

5 MS. KAMMERER: The SSHAC Guidelines
6 describe a series of levels of complexity that you can
7 undertake, coming from like the single individual
8 trying to characterize the community, the breadth of
9 community opinion, all the way up to where you develop
10 a Level 4, which is individual teams of experts coming
11 to their own decision trees, and then trying to bring
12 it together, so it's sort of these levels of
13 complexity, Level 4 being the top level. The Swiss
14 said well, NRC Level 4, that's what we want, and so
15 that's what they did.

16 We are actually using this process for the
17 Central Eastern U.S., and we're doing a Level 3,
18 because it's cheaper, it's faster. We felt that we
19 have the understanding to really get the same product
20 at the end. It's just going to be a lot more work for
21 the people involved, so it's a series of levels in
22 complexity.

23 MR. CHOKSHI: This is Nilesh Chokshi,
24 again. Just to answer your question, the four level -
25 - the levels you decide based on the nature of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 facility, how critical facility is, like the nuclear
2 facilities, things like this. What state setting you
3 are talking about really is called seismotechtron, it
4 can warn into -- in a very active area, so depending
5 on the nature of the questions, the scope of the
6 study, the particular aspects, you decide what level.

7 MS. KAMMERER: What you need.

8 MR. CHOKSHI: For nuclear presently, this
9 is generally three and four.

10 MS. KAMMERER: Yes.

11 MEMBER APOSTOLAKIS: Yes. The issue,
12 Sanjoy, was that typically researchers working on
13 these things, they try to do the best job they can,
14 and they scare the hell out of people who don't have
15 such a major project. And they say you're telling me
16 I have to invite international experts and train them
17 and so on. All I have to do is pick up the phone and
18 ask a couple of guys, and I get an idea, and I solve
19 my problem. If the problem is not of major
20 significance, the nation, for example, like Yucca
21 Mountain is, maybe that's good enough. It's not very
22 controversial, so they were very careful to say here
23 are four categories, and under these circumstances you
24 really don't have to try to do this Cadillac, so to
25 speak, approach, which is very expensive. Because

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there have been other projects, in fact, PGME, one of
2 the guys who was on the committee said look, I had
3 these problems, and I didn't go through all this. I
4 invited some of the good people I know, we exchanged
5 ideas and so on, and it worked. So that was a -

6 MEMBER BANERJEE: But this guidance has
7 formalized this work -

8 MS. KAMMERER: Yes. And we're trying to
9 fill in the details as to how do you achieve these
10 different levels.

11 MEMBER BANERJEE: I've got the picture.
12 I think we can move on.

13 MEMBER CORRADINI: So just so I
14 understand. If you look at NUREG-1150, what level
15 would it be similar to?

16 MR. CHOKSHI: I think it will depend under
17 which part of the 1150 you're looking at.

18 MEMBER APOSTOLAKIS: I mean, the severe
19 accidents, they invited people to Albuquerque, they
20 trained them, they spent time making sure they
21 understand. They went back home, they come back. I
22 mean, that's as expensive as it gets.

23 MS. KAMMERER: Well, hopefully these
24 things will be done -

25 UNIDENTIFIED SPEAKER: We have to keep

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 moving.

2 MS. KAMMERER: Yes. Okay. So what we did
3 is we had a series of workshops which were facilitated
4 by the USGS, and we focused on three areas; the first
5 one, Lessons Learned, what went right, what went
6 wrong, what can we learn of it? What are your
7 thoughts? All of these people who had participated,
8 and it was focused on process, only process.

9 The second question, which was key to, of
10 course, how long do you update these things? How old
11 does the old EPRI site have to be before it really
12 needs to be updated? This was a question that not
13 only we're grappling with now, but by looking at it,
14 it helps us to set the ground rules for what happens
15 once the CEUS SSC project is completed, and we have a
16 replacement. And then, also, understanding and
17 characterizing uncertainties is something that we want
18 to do in the future, in an additional -

19 MEMBER BANERJEE: My question originally,
20 how do you go about doing that?

21 MS. KAMMERER: Well, there's a variety -
22 I'll talk about that in the CEUS SSC project.

23 MEMBER BANERJEE: Okay. If you're going
24 to talk about it later, fine.

25 MS. KAMMERER: Yes. I'll get there one.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 One more product, and then we'll get there. So the
2 goal of this is in the short-term, we're going to have
3 USGS open file report summarizing all of the
4 discussions. At the last workshop, we basically came
5 through with a series of concrete recommendations that
6 everyone that was in this workshop agreed upon,
7 mutually agreed upon by sort of many of the best and
8 the brightest.

9 And, by the way, ACRS sent staffers to the
10 second workshop on how and when to update, and we
11 really appreciate that. NRO has also sent staff, as
12 well, so we've had good representation across the
13 agency. Ultimately, we'll turn this into a NUREG
14 document which will be a companion to the SSHAC
15 Guidelines.

16 MEMBER APOSTOLAKIS: Is it just -- or the
17 meetings are when the ACRS meeting here?

18 MS. KAMMERER: Yes.

19 MEMBER APOSTOLAKIS: Some of us cannot go
20 to places -

21 (Laughter.)

22 UNIDENTIFIED SPEAKER: It's very
23 deliberately done, George.

24 MS. KAMMERER: Yes. Trying to get the
25 girth of people that we were trying to get in the room

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was just painful, but I don't have to tell you guys.
2 I'm sure you know.

3 Okay. So this Central Eastern U.S.
4 Seismic Source Characterization project for nuclear
5 facilities, the CEUS SSC. This is a major study of
6 participation from NRC, being principally led by EPRI.
7 It's a complete replacement of the EPRI SOG database,
8 if that makes sense. So it's being half funded by
9 EPRI, and half funded by government.

10 USGS is also participating under
11 sponsorship from NRC, specifically. Some of the
12 funding NRO sent over is supporting that
13 participation. Other U.S. specialists, Dr. Hinze, is
14 on the participatory peer review panel, as well as two
15 of us in RES. We have participation from NRO in
16 several different overview, so that the idea is that
17 we have oversight and participation all the way
18 through this project, so that what we get at the end
19 we feel is really as good as we could get it. And
20 we're happy with the project that comes out at the
21 end. USGS also has people on the peer review, as well
22 as bringing in a lot of technical expertise for this.

23 MEMBER ARMIJO: Who is the Project
24 Manager? Is it EPRI, project managing?

25 MS. KAMMERER: EPRI is project managing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Right. Right.

2 MS. KAMMERER: That's right. And this was
3 something that staff really kind of pushed for, and
4 we're thrilled that they've taken this on. And I was
5 a little skeptical at first, I think many of you, we
6 talked off-line, in really how much of a say the NRC
7 was going to have going along, but so far I think it's
8 going very, very well. I feel very positive about the
9 way that it's headed.

10 MR. HINZE: Annie, I don't -- if I may
11 interrupt for just a moment. I think Lawrence
12 Salimony from Savannah River is a major project
13 manager of this.

14 MS. KAMMERER: That's true.

15 MR. HINZE: From a technical standpoint,
16 and I think that may be what you're getting at.

17 MEMBER ARMIJO: Yes. Who is going to make
18 sure that this thing meets its goals, gets --
19 somebody's got to be in charge.

20 MS. KAMMERER: Well, yes, that's true.
21 And programmatically, that's true. With regard to
22 making sure technically that it meets its goals,
23 that's really, I think, a key role of the
24 participatory peer review panel, where we have
25 participation from three folks, USGS, as well as Jeff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Kimble.

2 MEMBER APOSTOLAKIS: Directed the term
3 participatory peer review also from SSHAC.

4 MS. KAMMERER: That's right. This is
5 based on -- this follows the SSHAC Guidelines very,
6 very closely. And, by the way, EPRI has produced a
7 report describing exactly how this is going to happen.
8 There's a document which is now publicly available, I
9 think just a few days ago, forms the basis of their
10 proposal to DOE, and their agreement with DOE. It
11 literally just came out, and so you can all see
12 exactly how this is going to work. And it really,
13 though, has to be tied with the SSHAC Guidelines, so
14 the way that -- the goal of any SSHAC process is to
15 try to bring in the breadth of community opinion to
16 look at all of the possible hypothetical alternate
17 models, to have workshops that bring in the proponents
18 of these different models, to listen to them, and to
19 develop in the end a database or a decision tree which
20 takes all of these viable alternate hypotheses into
21 account and appropriately weights them. And that's
22 done by an integration, but there's this participatory
23 peer review panel which really tries to hold that team
24 to the fire, and say I don't think that you've
25 appropriately given this enough thought, and ask a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question of the expert. So this really is a very
2 formalized process.

3 So as this project is undertaken, one of
4 the first things to do is develop a massive database
5 of all of the existing information that could be
6 brought to bear to answer the question of what is
7 going on tectonically in the Central and Eastern U.S.,
8 and what are the capabilities of these different
9 sources? That's a key part of all of this. And so
10 that provides some information on the aleatory
11 variability of the different sources, so what is the
12 variability of how these sources behave?

13 As you go through and you look at all of
14 these different alternate hypotheses and you weight
15 them, that gives you a quantification of the modeling
16 uncertainty, the epistemic. And so, it's a very
17 rigorous formalized process that gets you quantitative
18 realizations of these different types of
19 uncertainties, which represent the community, the
20 breadth of community opinion at the time the study is
21 done.

22 MEMBER APOSTOLAKIS: Ultimately, the
23 quantification of uncertainty comes from experts using
24 -- it's not just this is what I think. I mean, you
25 have to document it. And it's important, too. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mean, it is not a coincidence that the title of the
2 report, Guidance on Uncertainty and Use of Experts.
3 The Committee deliberately put these words up there to
4 point out that -- because at that time the big
5 question was why are the EPRI curves different from
6 the Livermore curves? And the Committee decided it
7 was not really something fundamentally technical, but
8 it was how things were interpreted, judgments were
9 elicited, so the title itself included the words "Use
10 of Experts". Because it's model uncertainty, any time
11 you have model uncertainty, you've to actually go to
12 experts to interpret the uncertainty. It's not a
13 statistical kind of thing where you collect data, and
14 you -

15 MS. KAMMERER: Right.

16 MEMBER BANERJEE: They just don't have
17 enough data, I guess.

18 MEMBER APOSTOLAKIS: Especially at that
19 time, I don't know what it is now.

20 MEMBER POWERS: Annie, I do not know how
21 you and the Staff plans to break down its activities,
22 but I've got lots of view graphs on lots of topics, so
23 I don't know how long you're supposed to go.

24 MS. KAMMERER: Well, I was supposed to
25 stop 15 minutes ago, so let me get to one really, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think, key -- oh, let just mention -- give me two
2 minutes, and as long as there's no more questions, I
3 think I can just summarize everything.

4 With this, one of the things that has come
5 out is people want to go to the probabilistic method,
6 but they don't really quite understand how they go
7 about that. One of the things that came up at the
8 first meeting that we are now implementing is an
9 international observer's program. We're basically
10 inviting people who want to be involved, or are
11 seismic hazard specialists in the other parts of the
12 world that might not think that they want to go
13 probabilistic, to come and watch us go through this
14 process, and see that it does, indeed, have a very
15 strong technical basis, and to see how they can
16 implement it in their country. So we have a number of
17 participants from different countries coming to these
18 workshops as observers. And we're also the day before
19 doing sort of an orientation training session on what
20 is going to happen. And we really hope that that will
21 allay a lot of the discussions and the concerns which
22 are not always necessarily based directly. So, as I
23 mentioned, we want to do some work. We're just
24 getting some work started, and getting new information
25 in the Central Eastern U.S., this is being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 coordinated. We're looking at maximum magnitude again
2 through a workshop, a community consensus approach,
3 trying to bring everybody in, bring everybody's data
4 together, and work from a community approach.

5 So I guess, let me just say that we really
6 feel very strongly that we're really headed in the
7 right direction. And I'm just amazed at how much
8 we've been able to get going within a year. So
9 between the CEUS SSC, which is going to give us new
10 sorts of characterization for the Central Eastern
11 U.S., and ongoing work to continue to dig into some of
12 these regions.

13 The Ground Motion Prediction Equations
14 which say okay, for those sources visit means my site,
15 which is being addressed through NGA-East, and all
16 this within the process, again, of the SSHAC
17 Guidelines. This is really bringing us to the next
18 generation of seismic hazard characterization for the
19 Central Eastern U.S., and we believe will bring us to
20 a place where we're going to have long-term regulatory
21 stability, and an approach that everyone understands,
22 and buys into, and is really not only NRC, and
23 industry, and DOE, but really a community consensus.

24 So I think I'm just going to go ahead and
25 skip that. Mentioned that tsunami is also part of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 program, very close to my heart.

2 MEMBER POWERS: And you notice the
3 Committee gave you a big attaboy for that.

4 MS. KAMMERER: Thank you. I really
5 appreciate that. I really, really appreciate that. I
6 think we have tremendous -- we've had a lot of really
7 great interaction within the Agency, and also with the
8 other agencies that were partnering with the USGS
9 Woods Hole group, and NOAA.

10 MEMBER POWERS: I think what you did there
11 was very well done, and we brought it up in our
12 research report.

13 MS. KAMMERER: Thank you. Yes, I really
14 appreciate that. And I've got to hand it to RES
15 Management. They have been incredibly supportive in
16 getting this done. And those -

17 MEMBER POWERS: Must be merit of you
18 telling us -

19 MS. KAMMERER: No, I mean, I feel like as
20 a researcher, I feel like I've died and gone to heaven
21 having all of this great -- it's like a really smart
22 thing we should be doing. Okay, go do it.

23 MEMBER APOSTOLAKIS: One of the
24 controversial issues in the elicitation and
25 utilization of expert opinions is how do you handle

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the different views of, in the old days, the different
2 experts, and the issue of relative weight. And, of
3 course, the NRC had directed Livermore to give equal
4 weight, which shocked the Committee. Then we came up
5 with this approach of having multiple workshops, and
6 bringing everybody to the same level, and then you
7 don't need outside -

8 MS. KAMMERER: Right. Right.

9 MEMBER APOSTOLAKIS: However, there are
10 still people who believe that this is an assumption,
11 really. I mean, you can't prove, but since you have
12 these workshops, eventually everybody will be the
13 same.

14 MS. KAMMERER: That's right. And,
15 certainly, people are -

16 MEMBER APOSTOLAKIS: Are you guys
17 addressing this issue?

18 MS. KAMMERER: Yes, absolutely. That's
19 one of the key questions that have come up in these
20 workshops. Absolutely. And a lot of times they
21 actually have ended up with equal weight. And, by the
22 way, one of the things we're trying to do in all this
23 is avoid another EPRI-Livermore disagreement. That's
24 why we're trying so hard to work together, and to
25 bring USGS in, because, of course, they do have the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 national model, as well, so we're really trying to
2 bring this all together. What we're trying to do is
3 be smart from the very beginning, so we don't end up
4 in an uncomfortable place at the end.

5 I think what we're trying to do very hard
6 is to really -- of course, people are all going to
7 disagree. One of the two things that came up -
8 actually, three things came up - one is that bringing
9 people back together to discuss why they're making the
10 decisions they're making, and what their assumptions
11 are. These are the experts. One of the things that
12 we found in the past is they tried to keep them all
13 separate and keep them pure, but, actually, that
14 assumes that experts can't learn by talking to each
15 other. And, so, one of the things that has come out
16 is we need to bring everybody back together, after
17 there's all of these different weights of things, and
18 say why are you doing this? Why are you doing that?
19 Having to question each other, and, hopefully, that
20 will lead to better consensus about how the weighting
21 should be.

22 Of course, everybody is going to think
23 that their approach deserves the higher weight with
24 regard to the experts, but really that comes down to
25 technical integration. And for this Level 3, it's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 real strong need to have the participatory peer review
2 panel really hold the integrator's feet to the fire,
3 and ask them why they're doing that, and why they're
4 weighting certain people. It all has to be tied back
5 to that database, the technical information which is
6 available.

7 MEMBER APOSTOLAKIS: So it is being
8 addressed, and we don't have to -

9 MS. KAMMERER: Yes. Yes.

10 MR. CHOKSHI: George, I think the SSHAC
11 concept of the expert is they're both as evaluator and
12 expert for the -

13 MS. KAMMERER: That's right. And peer
14 review.

15 MEMBER APOSTOLAKIS: I agree. I mean, the
16 group proposed an approach. That doesn't mean that
17 they are closer to scientific theory, proven thing.

18 MS. KAMMERER: Right.

19 MEMBER APOSTOLAKIS: And the point is that
20 other groups - and, again, it comes back to why are
21 people in groups within the NRC doing different things
22 - but, as you know, there was a major study in the
23 European Union regarding whatever - I don't care what
24 they - but, anyway, they applied this approach of
25 having numerical evaluations of the credibility of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experts. You asked a guy how high do you think the
2 Eiffel Tower is, and then depending on that. And this
3 minor controversy is still there. All I am asking is
4 that you guys are addressing it, you don't have to
5 discuss it now.

6 MS. KAMMERER: Yes. And I think you'll
7 probably find the USGS open-file report very
8 interesting. And I apologize that I -- because, of
9 course, we did offer an invitation to come, but
10 apparently it was -- all of our workshops are poorly
11 timed.

12 MEMBER APOSTOLAKIS: It was the first week
13 of the month. That's when we meet.

14 MEMBER POWERS: It seems to me, George,
15 that -- I mean, Annie is a breath of fresh air here,
16 and she -- I can listen to her for hours. We don't
17 have hours.

18 MS. KAMMERER: Oh, thank you.

19 MEMBER POWERS: But it seems to me that
20 there is an excellent opportunity for us to have a
21 Subcommittee meeting.

22 MEMBER APOSTOLAKIS: Agreed.

23 MEMBER POWERS: Which we could go over
24 this research program in some depth. And it seems to
25 me the vehicle for that would be when you produce this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NUREG on the SSHAC Guidelines, that that would be an
2 opportunity both look at the specifics, but also to
3 look at the overall research program in some greater
4 detail. And we could schedule that when George has
5 classes, and -

6 MS. KAMMERER: (Laughing.) I would really
7 welcome that opportunity.

8 MEMBER APOSTOLAKIS: I think probably we'd
9 need a series of Subcommittees.

10 MEMBER POWERS: It is, indeed, and it's --
11 I mean, as we noted in the Research program, this
12 whole area is being revitalized, justifiably so,
13 because it's going to be -- seismic is going to be the
14 risk-limiting factor, and so when we see people coming
15 in with new reactors and telling us they have 10 to
16 the minus 8 CDFs, we know that's just not true, when
17 you locate them at any real site. We have major
18 things, but that's my proposal, is that, Annie, once
19 you get your SSHAC Guideline NUREG in shape where you
20 think it can benefit from an examination by the
21 Committee, that we would do that, but we would expand
22 to look at the entire seismic -

23 MS. KAMMERER: That would be great. That
24 would be great.

25 MEMBER APOSTOLAKIS: When do you think you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 may have it, roughly?

2 MS. KAMMERER: Oh, we're going to have
3 them within the next couple of months. Right?

4 MR. AKE: The draft, I believe, is due in
5 October -

6 THE REPORTER: Please come to a
7 microphone.

8 MEMBER BANERJEE: You have to come to a
9 mic.

10 MR. AKE: I believe the draft open-file
11 report is due in October to us, is deliverable to us.

12 MEMBER APOSTOLAKIS: Our review can be
13 participatory, too.

14 MS. KAMMERER: Absolutely. Absolutely.
15 And, again, there's the open-file report, but in
16 addition, we'd like to turn this into a NUREG, as
17 well, because that -- and so really to take -- because
18 we wouldn't want to hamper the community from saying
19 what they wanted to say feeling like it's going into
20 some sort of NRC document.

21 MEMBER APOSTOLAKIS: Oh, this is not the
22 NUREG then.

23 MS. KAMMERER: It's a U.S. -- the draft
24 that we're getting -- the product that we're getting
25 from the USGS, as a result of these workshops is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 USGS open-file report. And that was done because we
2 wanted people to feel like they could take away sort
3 of the whole regulatory element of it, and really talk
4 about the peer sides and the process. Although,
5 obviously, the regulatory arm is everywhere.

6 MEMBER APOSTOLAKIS: We should meet before
7 the NUREG.

8 MS. KAMMERER: Yes.

9 MEMBER APOSTOLAKIS: We can meet you as
10 NUREGs, we cannot meet you as U.S. geological survey.

11 MS. EWELL: Oh, I would like to ask,
12 though, that we have a little bit of time to just make
13 sure we have a staff consensus, agency consensus
14 before -

15 MEMBER POWERS: I mean, it's up to you
16 guys when you do it, but that would be my proposal.

17 MEMBER APOSTOLAKIS: I think that's an
18 excellent proposal, but we carry two -

19 MS. KAMMERER: Okay.

20 MEMBER APOSTOLAKIS: Don't give me three
21 volumes and ask me to come in a week.

22 MS. KAMMERER: Hopefully, it's going to be
23 nowhere near three volumes. I mean, we really wanted
24 to be very focused on the recommendations.

25 MEMBER APOSTOLAKIS: Very good. Very

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 good.

2 MS. KAMMERER: Thank you so much for
3 inviting me.

4 MEMBER POWERS: Thank you, Annie. There's
5 more to come.

6 (Off the record comments.)

7 MR. STUTZKE: We're here to talk about
8 Generic Issue 199, and I'll explain briefly what that
9 issue is. I'm Marty Stutzke, the Senior Technical
10 Advisor for Probabilistic Risk Assessment
11 Technologies. I work in the Division of Risk Analysis
12 in the Office of Research. Sitting next to me is Dr.
13 John Ake, who's in the Division of Engineering, and
14 also in the Office of Research. Sitting over at the
15 side table is Lauren Killian, who's the Project
16 Manager for Generic Issue 199.

17 And to anticipate one of George's
18 comments, if you flip to the last page of my
19 presentation, all of my acronyms are spelled out.

20 CHAIRMAN SHACK: Actually, we forgot a
21 couple.

22 MR. STUTZKE: Well, I did notice that NRC
23 was not on there.

24 MEMBER APOSTOLAKIS: What's the difference
25 between a GSI and a GI?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNIDENTIFIED SPEAKER: One is a -

2 MEMBER APOSTOLAKIS: Oh, come on. The
3 other is what, a scientific issue? Oh, I'm glad you
4 do not know. I thought it was -

5 MR. STUTZKE: John Kaufman should probably
6 answer that.

7 (Off the record comments.)

8 MR. KAUFMAN: John Kaufman, Branch Chief
9 for the Generic Issues Program, acting today for Jack
10 Foster. There's really no difference.

11 MEMBER APOSTOLAKIS: Oh, okay.

12 MR. KAUFMAN: They're the same.

13 MEMBER APOSTOLAKIS: Oh, so you just
14 decided to go -

15 MEMBER POWERS: Now, that's something I
16 would never want on the record, be a member of the
17 Agency list and say drop safety, which is a good idea.

18 (Off the record comments.)

19 MEMBER APOSTOLAKIS: Shall we start,
20 Marty?

21 MR. STUTZKE: Yes, please. Okay.
22 Briefly, the issue is as follows. The Staff has
23 identified the estimated seismic hazard levels at
24 some plants in the Central and Eastern United States
25 may be higher than we previously thought. We know

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this because we've looked at the Early Site Permit
2 applications, and made some comparisons to the IPEEE.
3 We also have the benefit of looking at U.S. geological
4 survey seismic hazards, too.

5 The next slide gives you an idea of our
6 problem. These are respond spectras, the safe
7 shutdown earthquake being in black, at a low ground
8 motion response spectra you'll see that your envelope
9 is bounded, which implies everything is okay. Some of
10 the more recent seismic estimates more like a solid
11 red line, and you can see the high frequency portion
12 exceeds the design spec. Okay? So it's not just that
13 the frequency or the exceedance frequencies of
14 earthquakes may be increasing, but it's the spectral
15 composition is also changing. And the problem we're
16 faced with is what does it mean?

17 MEMBER APOSTOLAKIS: What's GMRS again?

18 MR. STUTZKE: Ground Motion Response
19 Spectra.

20 MEMBER CORRADINI: That is what the plant
21 base will see.

22 MR. STUTZKE: Right.

23 MEMBER CORRADINI: That's after point
24 source manipulated to get to the final point of what's
25 wiggling.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: That's right.

2 MEMBER CORRADINI: So what's wiggling the
3 base. Got it.

4 MR. STUTZKE: So the low frequency is
5 going down.

6 MEMBER ARMIJO: What you just said was a
7 different thing. Right?

8 MEMBER CORRADINI: It's what the plant
9 foundation would see.

10 MEMBER RAY: Well, that means you're
11 taking into account soil structure interaction. Is
12 this free field, or is this basement -

13 MR. AKE: This does not include the
14 effects of soil structure interaction.

15 MEMBER RAY: Exactly.

16 MEMBER CORRADINI: Okay.

17 MR. AKE: It's the input and all -

18 MR. STUTZKE: This is free field.

19 MR. AKE: Right, but would drive the use
20 as the input.

21 MR. STUTZKE: Yes.

22 MEMBER CORRADINI: So the soil around the
23 plant still is not taken into account.

24 MR. STUTZKE: If the plant weren't there.

25 MEMBER CORRADINI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: You said it the other way.
2 This is a comparison of seismic hazard estimates.
3 These are -- you see on the Y-axis, it's the
4 exceedance frequency. It's the frequency of
5 earthquakes that exceed a particular ground
6 acceleration. And I have them from a variety of
7 sources, the EPRI 1989 study, the revised Livermore
8 study done in '94, a couple of USGS curves, including
9 the one that was issued about two months ago, and the
10 Early Site Permit. And you can see that both the ESP
11 curves, and the USGS curves indicate higher
12 frequencies when you get to the half G ranges.

13 MEMBER STETKAR: Marty, do you see that
14 for a lot of sites? I'm just curious, because I've
15 seen USGS consistently higher.

16 MR. STUTZKE: Yes.

17 MEMBER STETKAR: At the high G range.

18 MR. STUTZKE: It's generally true.

19 MEMBER STETKAR: Is there some
20 understanding of why that is?

21 MR. AKE: I think the -- if I could jump
22 in on that one, the biggest change that you see
23 reflected in these curves that Donna changed is as
24 Annie alluded to earlier, is the change in the ground
25 motion prediction equations, and the newer ground

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 motion prediction equations tend to predict slightly
2 higher ground motion values, and they also tend to
3 yield slightly flatter hazard, because, you see, the
4 other thing that has changed in these curves is the
5 slopes of the curves change, which is also something
6 that affects where we'll end up with our estimates.

7 MEMBER BANERJEE: So if that's true, why
8 is the ESP 2003, if it's an evolution of the model
9 does that mean that the ESP 2003 is a very different
10 model from the USGS 2003?

11 MR. AKE: The ESP model used a different
12 set of -- a different attenuation function than was
13 used by the USGS, slightly different. And I think
14 there are a couple of other minor differences between
15 the models.

16 MEMBER BANERJEE: But there's a
17 significant difference in the peak ground acceleration
18 around 1G.

19 MEMBER APOSTOLAKIS: But we never go
20 there. Where are we usually, we're in .17. The SSC's
21 where are they?

22 UNIDENTIFIED SPEAKER: They've been
23 reading around .3.

24 UNIDENTIFIED SPEAKER: The SSCs are
25 typically -- .3 would be on the high end of the SSCs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: The .3 is more typical of
2 the high confidence, low probability -

3 (Simultaneous speech.)

4 MEMBER APOSTOLAKIS: So these curves are
5 medium curves. What are they?

6 MR. STUTZKE: These are mean hazard
7 curves.

8 MEMBER APOSTOLAKIS: Mean hazard, so if I
9 go into about .2G, are there really significant --
10 where is it?

11 (Simultaneous speech.)

12 MEMBER APOSTOLAKIS: Somewhere there, and
13 it's not that bad. The ESP, it's about the same as
14 all -- I mean, all three of them .7 really.

15 MEMBER CORRADINI: If this is off base,
16 Dan, you stop me, but I just got the -- I want you to
17 kind of restate what you said about the model. So
18 this is -- there's no plant involved, but I'm sitting
19 on the ground where the plant might be, and I'm
20 coupling the point source to that location, and the
21 model of coupling is different between the yellow
22 curve and the pink curve, and the light blue curve.

23 MEMBER APOSTOLAKIS: Coupling what?

24 MEMBER CORRADINI: Coupling the point
25 source.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: The power point source,
2 necessarily, can be -

3 (Simultaneous speech.)

4 MEMBER CORRADINI: And I'm standing on the
5 ground, and the way I model that propagation of the
6 waves is different.

7 UNIDENTIFIED SPEAKER: There's more than
8 one source. There's several sources that we're
9 modeling here. We have several sources that we're
10 modeling, we're compiling all those together to come
11 up with this hazard curve. So the source models are
12 different, the ground motion models are different
13 between these different groups. There's similar
14 parameters. Obviously, there's some agreement on
15 magnitude and how often earthquakes occur in the
16 ground motion models, but -

17 MEMBER APOSTOLAKIS: The combination, in
18 other words.

19 UNIDENTIFIED SPEAKER: Yes.

20 MEMBER APOSTOLAKIS: But still, my
21 question is what difference does it make? I mean, for
22 the region -

23 MEMBER POWERS: George, why don't we let
24 him go through it, and that's what he's trying to tell
25 you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: And my quick and dirty
2 answer is when you do the seismic risk estimate,
3 you're integrating over the all acceleration range.
4 You integrate over the entire ranges of acceleration,
5 you're not just picking one point off of the curve, so
6 the slope of the curve, it all makes a big difference.
7 It's not at all obvious how it affects, it's highly
8 non-linear.

9 So a background on the generic history,
10 the concern was identified in May of 2005 by NRR.
11 This was, of course, before NRO was created. It's the
12 same body of people. They raised the issue, but still
13 have concluded that they thought there was adequate
14 protection to the plants. The Office of Research
15 opened up the issue in June of '05. There was various
16 activities went on culminating in February of this
17 year with a screening panel that concluded it's a real
18 generic issue, and we need to proceed to the safety
19 and risk assessment phase of our process.

20 We had held a public meeting that was well
21 attended in early February of this year to talk about
22 our plans to resolve this. The last bullet is
23 something I'll remind you. When I was briefing you
24 last month on our RASP program, I mentioned that we
25 have an MOU between NRC and EPRI, and we've added a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 task to share seismic research information.

2 The Generic Issues program is laid out in
3 Management Directive 6.4. It's basically our marching
4 orders of how to proceed in resolving it. When we did
5 the safety and risk assessment piece, they gave us
6 these guidelines, these criteria up here to decide.
7 And you'll see that it's laid out very much like
8 Regulatory Guide 1.174, where we have a baseline core
9 damage frequency, and we look at the change of core
10 damage frequency, and the notion is if you're in the
11 shaded area, we can stop work on the Generic Issue.
12 If you're outside, then we need to continue to do some
13 more work like this.

14 Now, there's a number of problems
15 associated with this, and challenges.
16 Philosophically, what does the change in core damage
17 frequency mean? Normally, when we talk about it,
18 we're talking about modifying the power plant, we're
19 trying to fix something. We want to measure the
20 benefit of that sort of shift. Here what we have is
21 a change in our perception of the seismic hazard. The
22 hazard probably hasn't changed, we just are
23 interpreting the data different ways, so delta-CDF,
24 in my mind, is with respect to what? What do you we
25 use as the baseline frequency here? So that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something we've been puzzling over for some time.

2 More specifically, the process, what it
3 tells us to do is to pick a surrogate plant and go
4 forward. And the idea is that the surrogate would in
5 some sense be a bounding plant, so if you're trying to
6 show that all the plants in the country fall within
7 this shaded area.

8 MEMBER ABDEL-KHALIK: Why is this any
9 different than uncertainty in the performance of a
10 piece of hardware?

11 MR. STUTZKE: It's not really. It's a
12 manifestation to some extent of modeling uncertainty
13 with all the different assumptions, and things like
14 this. The other thing is that it's difficult for us
15 to let alone deal with the uncertainty, whenever we
16 apply a screening criteria like you see here, the
17 comparison is always done on mean values, so I'm not
18 quite certain what the mean means in this case?
19 That's the question I'm asking. But, anyway, let me
20 go forward. We're still wrestling with it. It's not
21 resolved, I think in my mind, to an acceptable level.

22 But the problem we have is, it's real hard
23 to pick a surrogate plant. Site hazard is site-
24 specific, the seismic is site-specific like this, even
25 the fragility within the site can be different, so I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 can have different fragility levels, HCLPF values for
2 Unit 1 than I have for Unit 2. So it's really
3 difficult to claim that you could find a bounding
4 plant. And, of course, we want to pick a process that
5 we can defend like this. It's applicable, we can
6 implement it easily, so forth and so on.

7 Under the IPEEE program, about one-third
8 of the licensees did full seismic PRAs. The rest of
9 them all did seismic margins PRAs. And there are
10 substantial differences between them. Notably, the
11 seismic margin to PRA tends to ignore all the random
12 failures, human actions, these sorts of things.
13 They're strictly looking at the hardware, and it
14 builds up to a plant level HCLPF value like this. And
15 as you can probably guess, you know from your
16 experience, seismic PRAs are tremendously expensive.
17 These are multi-million dollar projects to implement,
18 so I'd be perfectly happy to go to my boss, Dr.
19 Shearon, and say look, I've got to do 104 seismic
20 PRAs, and each one is \$2 million, pony up.

21 MEMBER STETKAR: What's your basis for
22 that cost, because seismic PRAs, given a good Level 1
23 internal event model of a plant, have been done
24 reasonably well for a couple of hundred thousand
25 dollars, or less. So I'm not sure why you say it's \$2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 million to do a seismic PRA. What's the basis for that
2 estimate, if cost is, in fact, the driving factor
3 behind why you need to take kind of a generic
4 approach?

5 MR. STUTZKE: Granted, the simple answer
6 is I have to go through laboratories. I have
7 expenses.

8 UNIDENTIFIED SPEAKER: Why?

9 MEMBER BANERJEE: To an MIT grad student.

10 MEMBER CORRADINI: No, but I guess I
11 wanted to ask -- forget about the money, because we're
12 not here to talk about money. I guess I wanted to
13 understand the process. Is the difference between the
14 two is the individuals involved in all the front end
15 work in terms of effort elicitation, because of the
16 site-specifics, or is it simply because of -

17 MR. STUTZKE: Okay. The expensive part of
18 the seismic PRA are the plant walk-downs, getting hold
19 of the experts.

20 MR. CHOKSHI: Excuse me. Let me clarify.
21 This is Nilesh Chokshi. Cost aspect depends on the
22 level of details that we have to go to. PRAs are
23 iterative-type things, you figure out what the level
24 of detail you have to go through. The fundamental
25 difference between the PRA and margin is margin is,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 essentially, very simplified. It is the element sub-
2 PRA. It does not count core damage frequency, it just
3 estimates plant capacity. And it was derived from the
4 PRA insights. And, in fact, it was an ACRS-driven
5 question that is there a lift beyond the SSC. Is
6 there margin from the design points, and that's what
7 the seismic margin was designed to answer, rather than
8 calculating core damage frequency.

9 MEMBER BLEY: Niles, to do the margins,
10 don't you have to essentially do the fragility
11 analysis to come up with the HCLPFs?

12 MR. CHOKSHI: Yes, what you do is there
13 are two approaches. You can do the fragility or there
14 is called conservative deterministic margin approach,
15 but you have to do the calculations. The only thing
16 is that because you are not doing full scope and point
17 to all the other seismic condition initiators, like
18 large LOCA, your scope is smaller, and you can use
19 historical experience base to pin things. But, again,
20 the PRA depends on how far you need to go to answer
21 the question, so it's not that PRAs are always going
22 to cost tremendous more, margin approach.
23 Particularly, as mentioned, if you have a very
24 detailed Level 1 PRA model, you have to modify it.

25 MEMBER BLEY: Okay. Thanks. I was just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curious where the \$2 million came from.

2 MS. EWELL: Can I also add, as far as
3 either using a bounding approach, the Generic Issue
4 program is supposed to be just that, taking a look at
5 an issue and determining whether or not it rises to
6 the level of interest for the NRC to take action, as
7 well as then perhaps engage the industry. And, of
8 course, the fact that considerations come into play,
9 so the concept of doing 104 plant-specific analyses is
10 just not part of the GI approach, because what we're
11 trying to do here is get an estimate, and enough
12 technical basis to say yes, industry, you need to
13 answer this question for us, because we are not coming
14 up with the industry's answer for them. We're just
15 determining whether or not we have a technical basis
16 to ask the question. So I don't want everyone to walk
17 away thinking that the Agency is cheap and is trying
18 to cut corners.

19 MEMBER APOSTOLAKIS: If you convince them
20 to do that, maybe to do two or three Level 2 PRAs.

21 (Laughter.)

22 MR. STUTZKE: The other thing I'd point
23 out is there's a matter of resources. There aren't
24 that many seismic PRA people around any more. I mean,
25 two of them are sitting right here. Okay. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ones that are available all seem to be off doing new
2 plant stuff, so it's a complicated problem.

3 So we came up with this process that says
4 it's basically following some work done by Dr.
5 Kennedy. It's referenced in Appendix D of the ANS
6 Standard on External Event PRA. And the process works
7 like this; it's that you fit the hazard curves to a
8 power log, so they are linear in log-log space. Then
9 you develop a plant level fragility curve, so it's
10 like a super component for the entire plant like this,
11 and it's log normal. And you can do that if a seismic
12 PRA was actually done for the IPEEE, you already have
13 the curve. You can pick the points. If seismic
14 margins was done, you use the reported high confidence
15 low probability of failure that's equal to a 1 percent
16 probability of failure. You assume a composite log
17 standard deviation of .4, could be at .3, so .4 is the
18 recommended number. And the point is with that,
19 seismic CDF now has an analytic form, I'll show you.
20 It's simple. There's an equation for it. I mean, it's
21 easy to implement.

22 MEMBER BLEY: Do we know, or have a good
23 feeling what that invented fragility curve kind of
24 means with respect to the plant? Where the .4 comes
25 from.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. STUTZKE: Well, I can defend it like
2 this. First of all, I don't need to know the risk
3 contributors that you would get out of a PRA. I don't
4 need to know it's this component or this structure.
5 What I'm trying to do is come up with a simple way to
6 compare the differences in the hazards, and suppress
7 the plant response sort of thing like that.

8 The other thing is that we've done a lot
9 of testing in the last couple of months where instead
10 of fitting up to a power log, we fit it to other
11 curves. We do a point-to-point convolution, so I've
12 looked at the numerical details like that. This
13 method reproduces the known seismic PRA results in a
14 large number of plants.

15 MEMBER BLEY: That's helpful.

16 MR. STUTZKE: Yes.

17 MEMBER APOSTOLAKIS: I don't understand
18 something that says if an SPRA was done, pick the
19 plant level fragility to log-normal distribution.
20 Where does that -- I mean the seismic PRA normally
21 does not produce this super fragility.

22 (Simultaneous speech.)

23 MEMBER APOSTOLAKIS: I'm sure that is the
24 case, but how do you that?

25 MR. STUTZKE: What I was able to find in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 every IPEEE submittal or in a response to a staff
2 request for information, this curve -

3 MEMBER APOSTOLAKIS: Exists?

4 MR. STUTZKE: Acceleration, probability of
5 failure.

6 MR. CHOKSHI: You can control from the
7 different sequences a plant level fragility -

8 MEMBER APOSTOLAKIS: I suspect that's how
9 it's done. My question is, is it actually done? Why
10 should an SPRA do that?

11 MEMBER BLEY: I don't think they do.

12 MR. STUTZKE: Every single one.

13 MR. CHOKSHI: Then you can see any -- if
14 you walk through the hazard sensitivity -

15 (Simultaneous speech.)

16 MR. CHOKSHI: And it's a much simpler way
17 to do it.

18 MEMBER STETKAR: They back it out of the
19 results. They don't produce it for the
20 quantification. They do the quantification, and then
21 infer an effective plant level fragility curve.

22 MR. CHOKSHI: It helps for the sensitivity
23 then, changing the hazard -- and, in fact, that's here
24 what Marty is doing, is changing the hazard. That's
25 why this approach. See, the plant fragility stays

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 constantly. He's looking at changing the hazard.

2 MR. STUTZKE: Okay. This is my, I guess,
3 viewgraph that's in color and it has equations on it.
4 It's just to let you know why I'm a Senior Technical
5 person.

6 (Laughter.)

7 UNIDENTIFIED SPEAKER: It's got log scales
8 and log linears. I mean, this is great.

9 MR. STUTZKE: Okay. So the hazard curve
10 looks roughly like on the left-hand side here. It's
11 the exceedance frequency. This is the power log fit,
12 case of IA to the minus case of H. You'll hear the
13 seismic people will talk about the slope of the hazard
14 curve, they're talking about case of H like this. And
15 you can see the linear fit. It's not unreasonable. Of
16 course, a real hazard curve dives off at high
17 accelerations. You can get infinite accelerations.
18 Similarly, with the power log, what it actually
19 predicts mathematically is the frequency of very small
20 earthquakes approaches infinity. That doesn't make a
21 lot of sense either, but it's certainly bounding.

22 This is the equation for an example,
23 fragility curve, the mean value, which is what we're
24 convolving the mean hazard against the mean fragility.

25 CHAIRMAN SHACK: In very small earthquakes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's pretty high, so it doesn't make much difference.

2 MEMBER STETKAR: Yes. The good news is it
3 exists in plants, the change in the relation to the
4 hazard -

5 (Simultaneous speech.)

6 MEMBER STETKAR: -- doesn't make much
7 difference.

8 MEMBER APOSTOLAKIS: Now you tell us that
9 this is a research issue?

10 MR. STUTZKE: It is.

11 MEMBER APOSTOLAKIS: Is your approach
12 sensitive to that?

13 MR. STUTZKE: Well, right now because
14 we're using the hazard curve - remember, the
15 motivation for the power log fit is to be able to get
16 an analytic form to the integral here. That's what
17 makes it easy. Normally, when people do seismic PRAs,
18 in fact, in NUREG-1407, we told them to truncate at
19 1.5G.

20 MEMBER APOSTOLAKIS: So you're picking
21 one.

22 MR. STUTZKE: Yes. We're just picking
23 one.

24 MEMBER APOSTOLAKIS: All right.

25 MR. STUTZKE: And it actually turns out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with this power log you don't have to go to infinity.
2 You can integrate over any two fixed acceleration
3 ranges like that, as well.

4 Of course, what we're doing is convolving
5 the mean hazard against the mean fragility. That's
6 not the mean seismic core damage frequency, but it
7 should be -- okay. So to finish up briefly, as I say,
8 we've been doing a lot of work on developing methods
9 and convincing ourselves of different technical
10 approaches, numerical integration schemes, things like
11 this. I've been compiling the data by reading the
12 IPEEEs, things like this.

13 We'll hold another public meeting once we
14 get done with the safety risk assessment. Our panel
15 will reconvene, and, of course, there'll be a report
16 to the panel. The purpose of the panel then is to
17 decide whether they want to go forward with the
18 regulatory analysis assessment phase of this. Now,
19 the difference is the regulatory assessment phase is
20 going to decide what is the regulatory action, what's
21 the response? They're going to write a Generic
22 Letter, they're going to write a write a risk, they
23 begin to rule make, are we in compliance space? What
24 are we actually going to do?

25 MEMBER APOSTOLAKIS: So this approach at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the high level is going to help you calculate the
2 delta-CDF of the managing directive.

3 MR. STUTZKE: That's right.

4 MEMBER APOSTOLAKIS: There are so many
5 approximations here, and then you will look for a
6 delta-CDF of 10 to the minus 5.

7 MR. AKE: The idea is if we make the same
8 consistent set of assumptions using two different sets
9 of hazard estimates, we will have a reasonable idea of
10 what that change is.

11 MEMBER APOSTOLAKIS: Yes, but I mean you
12 say that -

13 (Coughing.)

14 MEMBER APOSTOLAKIS: What happens if it's
15 .5?

16 UNIDENTIFIED SPEAKER: As long as they're
17 consistent on the fragility side, that's not what
18 we're looking at.

19 UNIDENTIFIED SPEAKER: We're looking at
20 the difference in hazard curves post ESB. I mean,
21 where we are now, and where we were in the -- when we
22 did the IPEEEs. That's what we're looking at, so
23 we're looking at the change in the hazard. As long as
24 we consistently model the fragility in the same way,
25 then we're okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: No, the question is if you
2 use to instruct .4, .3, .5 what happens? And I think
3 that will be the kind of things you look -

4 UNIDENTIFIED SPEAKER: Yes, we will
5 certainly investigate.

6 MEMBER APOSTOLAKIS: It's not just that.
7 I mean, the whole idea of having this super fragility
8 curve of the plant, and then doing these things, there
9 is a lot of uncertainty and approximation. And then
10 you're saying, and now based on those, I don't want to
11 use the word "gross", but significant modeling
12 approximations, now you want to take the difference of
13 two very uncertain quantities, and decide the basis of
14 whether it's 10 to the minus 5, or 10 to the minus 6.
15 Something is wrong with that.

16 (Simultaneous speech.)

17 MEMBER POWERS: One of the things that's
18 wrong with 1.174.

19 MEMBER APOSTOLAKIS: I didn't hear that,
20 but you are -

21 MEMBER POWERS: Wrong with 1.174 -- we
22 always take delta in highly uncertain terms.

23 MEMBER APOSTOLAKIS: I'm not doing this
24 magical.

25 MEMBER POWERS: A different form of magic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Which is not black.
2 Look, I don't want to attack the approach, because I
3 appreciate that the problem Marty and his colleagues
4 have is very, very high. But maybe if we acknowledge
5 this, we can be clever and so some sensitivities, or
6 something to address it. I mean, it's not like I have
7 a better approach.

8 MEMBER BLEY: It's just I think the thing
9 that's sitting not quite right with me, and I like the
10 idea of sensitivity studies, is for the plants that
11 had a seismic PRA, and they had a -- they have the
12 overall plant fragility curve, you are able to do some
13 tests. But for plants that had the seismic margin,
14 you didn't have a seismic core damage frequency, so
15 does that simplified approach work very well? I think
16 there's no way to really know that without a test or
17 something.

18 MR. CHOKSHI: I think that's the point for
19 assumptions, is basically any two parameters for log
20 normal distribution, and you can get the HCLPF value
21 out of that analysis. Point four, there's a lot of
22 study has been done. This is not only used here.
23 This has been -- the .4 has been -

24 CHAIRMAN SHACK: Performance-based SSC is
25 the same analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: And a lot of study has been
2 done on the sensitivity of core damage frequency to
3 the different assumptions. And .4, it's based on a
4 usual component, we know what kind of uncertainties
5 are, which are integrated through the -

6 (Coughing.)

7 MR. CHOKSHI: So there's a fairly robust
8 basis for why we are using .4. And you have to go,
9 and it can give you the data, but I think sensitivity
10 study, we always do that, because this is an
11 assumption.

12 MEMBER BLEY: I think that would help.
13 And I'm not familiar with the pedigree of where that
14 comes from, so I don't know -- I don't have that
15 knowledge.

16 MR. CHOKSHI: This is -

17 (Simultaneous speech.)

18 MR. CHOKSHI: And it's performance-based.
19 There was a lot of things done to examine this
20 particular question.

21 MEMBER BLEY: Fair enough.

22 MR. STUTZKE: The other thing I would
23 point is that for most of the plants that did seismic
24 margins, all you know is that the HCLPF is above the
25 review level. You don't know the true HCLPF figure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 UNIDENTIFIED SPEAKER: That's right.

2 MEMBER BLEY: So it is probably a lower
3 bound than -

4 MR. STUTZKE: When seismic margins was
5 done, what you do is postulate the review level
6 earthquake, and that was specified -

7 MEMBER BLEY: Postulate a?

8 MR. STUTZKE: Review level earthquake.
9 Said convince me that the seismic capacity is at least
10 th is much. And for most plants, it was .03Gs. And
11 what you get out of the results of that is they came
12 back and said yes, we confirmed that it's at least
13 .3Gs. The point is you don't know how high it really
14 is. You don't have -- you don't really know the true
15 capacity. You know it has to be above .3Gs, so a
16 fragility curve that is based on this .04 beta sub C,
17 and the review level earthquake should be
18 conservative, but I don't know how conservative.

19 MEMBER STETKAR: Marty, I hate to put you
20 on the spot, but to tie together the two -

21 (Off the record comments.)

22 MEMBER STETKAR: You glossed, or at least
23 maybe I wasn't listening closely enough. You said that
24 your baseline CDF, I was going to ask you about what
25 I think is the difficult part of the problem. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 baseline CDF, this is in Slide 8, you're going to use
2 the 1999 EPRI seismic hazard curves, and you said
3 you're going to use updated seismic hazard curves for
4 the -- to evaluate the change. Any idea what updated
5 seismic hazard curves you're going to use? I mean,
6 are you going to just select USGS because they look
7 consistent and are higher? Given the fact that the
8 research folks are heavily involved on trying to
9 estimate what those hazard curves really are.

10 MS. EWELL: Can I just interrupt at one
11 point here, and that is, I think we're -- what we're
12 trying to do with the generic issue process is to
13 determine whether or not we should engage the
14 industry. The final regulatory decision on what
15 action, and the final, what has to happen at each
16 plant is going to be a function of the actual analyses
17 provided by the plant, if it gets to that point. So
18 I think what we're doing here is trying to do
19 something that's bounding, that's conservative, but
20 yet is not so completely wrong that it doesn't stand
21 up to some technical scrutiny, but it makes us say oh,
22 geez, we have enough information to then ask the more
23 specific questions to each of the plants, or what
24 subset of those plants, if we can narrow it down. So
25 the accuracy question, the final regulatory decision

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is not going to be solely based on what we're doing
2 here. That's all I was trying to put in perspective.

3 MEMBER APOSTOLAKIS: If you make the
4 convincing case that what you are doing is
5 conservative enough, I have no problem doing what you
6 said.

7 MS. EWELL: Okay.

8 MEMBER APOSTOLAKIS: Now, given all this,
9 if I go back to Slide 4, why can't I say that the
10 differences are small if I integrate a few things, I
11 will find small differences -- the curves are not that
12 different.

13 UNIDENTIFIED SPEAKER: This is one site.
14 This is North Anna in Virginia.

15 MEMBER APOSTOLAKIS: Is there another site
16 where you really have big -

17 UNIDENTIFIED SPEAKER: Well, what we're
18 looking at is okay, now we under the New Madrid is the
19 type of an earthquake in New Madrid is not going to be
20 once every 2,000 years, or 3,000, I can't remember.
21 But now we're saying it's every 500, or 600 years.
22 We're saying a Charleston earthquake in South Carolina
23 is now maybe between 500-750 years, as opposed to what
24 it was thought before, several thousand years, or at
25 least two or three thousand years. So that's the kind

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of difference in hazard, plus the new ground motion
2 prediction equations, that we're trying to look at for
3 the new plants, operating plants, and say what is the
4 implications of those new findings that we have.

5 CHAIRMAN SHACK: George, then we want to
6 at least include a first order approximation of the
7 plant response to this change. I mean, it's -

8 MEMBER APOSTOLAKIS: I didn't say I didn't
9 want to.

10 CHAIRMAN SHACK: Well, I mean, it seems to
11 me it's almost -- if you argue that you can work from
12 this and make the approximation, I'd say oh, maybe,
13 but I'd sure feel a whole lot better if they at least
14 included a first order estimate of the response of the
15 plant.

16 MEMBER APOSTOLAKIS: Let me understand
17 you. The comment about New Madrid and so on, these
18 visions are not reflected in these curves?

19 MR. STUTZKE: No.

20 MEMBER APOSTOLAKIS: They're not, not the
21 difference?

22 (Simultaneous speech.)

23 UNIDENTIFIED SPEAKER: I mean, the
24 differences -- what you're seeing is North Anna is far
25 enough away from what I was just talking about,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Charleston, and New Madrid, that the differences
2 aren't really showing up here. Is that going to be
3 the same story for all the operating plants? That's
4 what we're looking at.

5 MR. CHOKSHI: George, can I -

6 MEMBER APOSTOLAKIS: Please understand.
7 I'm not -

8 MEMBER POWERS: I think we've heard
9 enough, to be honest with you. I think it's time to
10 move on to the next topic.

11 MEMBER APOSTOLAKIS: There is the next
12 topic.

13 MEMBER POWERS: We've got two more to go,
14 George.

15 MEMBER BANERJEE: One is on the Japan
16 earthquake.

17 MEMBER POWERS: My intention, by the way,
18 is after this discussion of high frequency ground
19 motion, is to take a break, and then come back and do
20 the Japan. I didn't hear you, George.

21 UNIDENTIFIED SPEAKER: Nothing, nothing.
22 Let it go.

23 MEMBER APOSTOLAKIS: You're behind.
24 You're not running it very well.

25 (Off the record comments.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SHACK: If we can come back into
2 session here.

3 MR. CHAKRAVORTY: Well, I'm Manas
4 Chakravorty of NRO, Structure Engineering Branch. The
5 background, I have been to NRC not very long, probably
6 nine months or so. Before that, I was -- I started my
7 career at a nuclear plant and Stone & Webster
8 Engineering Corporation, and before that I had some
9 graduate studies at MIT.

10 (Off the record comments.)

11 MR. CHAKRAVORTY: When I did my research,
12 these probabilistic methods and things like that were
13 really a surprise to the industry. But, at any rate,
14 I have been in the nuclear industry for more than 30
15 years, and I was at South Texas project Nuclear Safety
16 Review Board. And then doing some out of retirement,
17 I got bored, and then I thought it's time to do some
18 regulatory activities. My friend was here, so I
19 started here.

20 Let me give you some background. I think
21 you are already aware of most of the background for
22 this interim safety guide. Basically, there has been
23 significant advances in seismological knowledge, which
24 led to updated ground motion prediction for the
25 Central and Eastern United States. And although we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 didn't build very many nuclear plants, but our quest
2 for knowledge continued, and we learned a lot. And,
3 as a result, we had some predictions about data ground
4 motion models for earthquakes in the Central and
5 Eastern United States, some recent application in our
6 ESP reviews. We have identified that site-specific
7 ground motion may not be enveloped by certified design
8 response spectra for some sites. Industry requires
9 some guidance on the evaluation of metrics for
10 assessing effects of these exceedances, where ground
11 motion response spectra exceeds the site-specific
12 design response spectra. And, basically, we call
13 those high frequency issues. However, it could be low
14 frequency issue, also, as you might be seeing at
15 Kashiwazaki plant that some of the spectra exceeded at
16 low frequencies. So it applies anywhere, but we are
17 concerned here mainly on the high frequency side.

18 This gives you an idea -

19 MEMBER BANERJEE: Is there low frequency
20 things associated with fault type earthquakes?

21 MR. CHAKRAVORTY: It could be local side
22 geology fault. I'm not a geological expert, but it
23 could be many things, but it did happen over there.

24 MEMBER APOSTOLAKIS: Well, certainly in
25 Japan, yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHAKRAVORTY: This gives an idea of
2 what a certified seismic line spectra looks like.
3 This is primarily based on Reg Guide 160 spectra. If
4 you see the lower dotted line, which is the minimum
5 PGA, .1G that we're required to meet. In other words,
6 any design center really can ask for application
7 certification for this spectra down below, which is at
8 the dotted line. That's what our regulation requires,
9 that you have to have a minimum of .1G.

10 MEMBER CORRADINI: Can you say that again?
11 I'm sorry. Can you repeat that? I didn't understand
12 the difference.

13 MR. CHAKRAVORTY: What I'm saying is these
14 are generally the spectra, the top one, the red line,
15 is the one that the design centers supply as they are
16 certified, which is normalized for .3G ground
17 acceleration. Okay?

18 MEMBER CORRADINI: All right.

19 MR. CHAKRAVORTY: Our regulation, minimum
20 requirement as per Appendix S, is .1, that's the
21 minimum.

22 MEMBER CORRADINI: But it doesn't matter
23 what the regulation says, you're using the red.

24 MR. CHAKRAVORTY: Yes, exactly. But
25 people can ask for application, there's a marketing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 point, how much you go. If you go to the other curve,
2 this is a green one which is kind of Central and
3 Eastern United States kind of soil site, which is
4 generally enveloped by our so-called certified design
5 spectra. If you see this, the blue one, which one is
6 the hard representative Central United States, hard
7 rock site spectrum, which you have seen it before also
8 in many other presentations here.

9 The problem area is this, where it
10 exceeded 10 hertz or more, we see that there has been
11 some exceedance of our certified design spectrum.

12 MEMBER ARMIJO: I've got to ask. Why did
13 this happen? I mean, what discovery that led all of
14 a sudden to the exceedance? Was it new data, new --
15 how did -

16 MR. CHOKSHI: I think to answer your
17 question, let me -- you need to go back to the
18 building, how we first started designing the nuclear
19 power plant. Those red curves initially were based on
20 30-40 years back, when we only had Western U.S.
21 records, and because those are not - answering your
22 question about magnitude, those are primarily a
23 magnitude of 6-1/2, and maybe plus/minus, so the high
24 magnitude earthquake and the ground conditions there
25 produce this kind of spectra. And those were our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 design basis. But as we learned more about Central
2 Eastern U.S. and how the ground motion attenuated or
3 propagates, we get -- and most even small magnitude,
4 5, 5-1/2, which have a lot of high frequency, but I
5 don't have this low frequency component of the
6 spectra. And that's -- as learn about Central Eastern
7 U.S., and it's been -- this issue has been known for
8 a while now, because it's been -- we have seen, as we
9 learned and started to predict Eastern ground motion
10 models, so that's the reason. But I also want to make
11 one point.

12 The low frequency component from the
13 engineering point of view is the critical, these
14 structures, components are generally in that. And we
15 are -- I mean, that you need to remember towards the
16 discussion. I mean, that's what drives the engineering
17 design.

18 MEMBER CORRADINI: So can I just ask one
19 last clarification about this. So if that's the case,
20 then the only thing that would be affected would be
21 small mass components within the large mass plant. So
22 does the large mass plant dampen the small mass
23 components' response to this spectra? In other words,
24 I've got a big, hawking big plant that only moves once
25 I see -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: In fact, it is going to go
2 up -- we take into account those effects.

3 MEMBER CORRADINI: Okay.

4 MEMBER BANERJEE: I have a question. If
5 it's very low frequency, then it doesn't excite any
6 resonances, so it's really the intermediate
7 frequencies which start the spectra -

8 MR. CHOKSHI: That's a good question. I
9 mean, most of our things I would say within, say, 2
10 and 10 hertz.

11 MEMBER BANERJEE: Right.

12 MR. CHOKSHI: But there are things like
13 tanks, or where you have to -- which could be low
14 frequency components.

15 MEMBER BANERJEE: Very low.

16 MR. CHOKSHI: Low low.

17 MEMBER BANERJEE: Below one.

18 MR. CHOKSHI: Right. And the things like
19 sloshing water levels, those are affected by the low
20 frequency motions.

21 MEMBER APOSTOLAKIS: So the range of
22 frequencies of interest is between 2 and 10, you said?

23 MR. CHOKSHI: Basically. It doesn't mean
24 -- that's for structure.

25 MEMBER BLEY: Structure is not equipment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. CHOKSHI: Well, one of the two plant
2 is also. I mean, things which has a -- what you are
3 concerned about, structural integrity type things, or
4 where the structural -- this design will go on tends
5 to be more of those -- the things like very small
6 mass, very rigid things which you have a high -

7 MEMBER CORRADINI: Well, the reason I
8 asked the question is that -

9 (Simultaneous speech.)

10 MEMBER CORRADINI: You have to transmit
11 it. The only reason I'd worry, I thought the only
12 reason I'd worry about the blue line is I have to
13 transmit to some small inertia, small mass, small
14 inertia component, but I'd have to transmit it through
15 something else.

16 MR. CHOKSHI: Through structures, and the
17 ground.

18 MEMBER CORRADINI: Thank you.

19 MR. CHOKSHI: And he's going to talk about
20 that.

21 MR. CHAKRAVORTY: So in the Central and
22 Eastern United States, as we see some rock sites, the
23 site-specific ground response spectra are higher than
24 the certified seismic design spectra at high frequency
25 range.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Again, you'll note that the ESBWR, their
2 certified design spectra would really look like this
3 up to red, and then portion of the blue. So that is
4 the ESBWR, like a double hump CSDRS. But not all the
5 plants had that certified, like AP1000 has this red
6 one, kind of. It's not exact, but -

7 CHAIRMAN SHACK: ABWR has the red one.

8 MR. CHAKRAVORTY: Right. So that's why we
9 have to really look at how these things work. So what
10 did we do? We had quite a few meetings, a number of
11 meetings with industry, and also we undertook
12 development of some methods, how to realistically
13 address these situations. And industry met, and NRC
14 met, and then we came -- basically, all the results of
15 those discussions included that in our updated safety
16 standard review plan. This regards the work for
17 review of high frequency exceedances, the SRP allows
18 that use advanced analytical techniques such as use of
19 incoherency of earthquake motions with the special
20 variations inside that, so that helped. And so, SRP
21 provides those guidance.

22 MEMBER RAY: Is the vertical component
23 always a fraction of the horizontal?

24 MR. CHAKRAVORTY: Yes, but generally these
25 applications, they are using the same, almost the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number.

2 MEMBER RAY: Two-thirds?

3 MR. CHAKRAVORTY: They are not using two-
4 thirds. The one that I know, like APR application,
5 they're using the same 4 and 3g for both vertical, as
6 well as horizontal.

7 MEMBER RAY: So they're using the same.

8 MR. CHAKRAVORTY: Same.

9 MEMBER APOSTOLAKIS: Is it two-thirds, or
10 one-third?

11 MR. CHAKRAVORTY: Two-third, we used it
12 before. When I used to the design the plant, I used
13 to design for two-thirds, long back.

14 UNIDENTIFIED SPEAKER: Yes, you're right.
15 The OBEs -

16 UNIDENTIFIED SPEAKER: I'm talking about
17 the vertical -- a function of the horizontal.

18 MR. CHAKRAVORTY: So SRP provided us some
19 guidance. For example, if it exceeds the GMRS and the
20 GSDRS level, then we go to the next step. WE
21 calculate the closed spectrum foundation spectrum,
22 including all structure and soil structure
23 interaction, and do this coherency. Now you
24 calculated the spectrum again at the foundation level,
25 and then compare those. Maybe a lot of the experience

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is that you have seen in the ground motion response
2 level may not be there because of filtering out by the
3 structures, and other things there. So those are the
4 graduated steps that we have provided in the SRP.

5 Now, implementing the SRP framework, the
6 staff developed this interim staff guidance on seismic
7 issues. The ISG identifies information to be included
8 in an application to address this issue. It also
9 presents staff technical positions, as well as
10 acceptance criteria for high frequency analysis, and
11 evaluation metrics for structures, systems, and
12 components. So that's the reason we give the issues -
13 - we issued the ISG.

14 Now, what ISG has, ISG provided
15 definitions of various ground motion. Basically,
16 people were confused, what is the SRGAs, what is GMRS,
17 what is FIRS? So they provided a systematic structure
18 for those definition of various ground spectra that we
19 use, or terminology. And you will see that in Section
20 2 of the ISG.

21 It also provided guidance on the use of
22 different ground motions, guidance on the use of OBE
23 level in pre-earthquake planning, or also maybe post
24 earthquake planning on Regulatory Guide 1.166, which
25 is really when you've have to trip the reactor. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they provided some guidance, so now it is, they allow,
2 or regulation allow use of one-third of the SSE as an
3 OBE value. Before it was half, now they use a lower
4 number. So there is some guidance on there on seismic
5 instrumentation that we are planning, Section 3.

6 It also provides staff expectations on the
7 content of COL application, when limited soil testing
8 data is available. In other words, there was some
9 difficulty getting soil testing labs previously, and
10 the industry developed a White Paper that they wanted
11 how to use a limited number of tests, and the staff
12 approved those, and provided some guidance as a
13 minimum what they are expecting. So that's also
14 included, and that's included in Section 5 of ISG.

15 Also included in the ISG, that's the main
16 portion of ISG, is the guidance on evaluation of high
17 frequency exceedance. In other words, when that
18 exceeds beyond 10 hertz, what we do, so ISG provided
19 it allows inclusion of incoherency in structural
20 response analysis, identified acceptable SSI analysis
21 codes to include the effect of incoherency of
22 earthquake motion. It also allows screening of high
23 frequency sensitive systems and components, and the
24 evaluation of screening age, and how do you screen,
25 and when you screened in some components, then how do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you evaluate those? And what information we need, and
2 these may be some evaluations which are in addition to
3 the CSGRS-based seismic qualification program that the
4 applicant had used previously. So those are some of
5 the guidance that is in the ISG.

6 Basically, let me summarize what we have.
7 We had a problem, and we fixed -- and we tried to
8 resolve the problem. We provided some framework in
9 SRP 3.7, and ISG to address this issue. Currently,
10 AP1000 topical report, they have submitted this to us,
11 and we are currently reviewing that, so we'll gain
12 some experience how well it is working.

13 ESBWR has used CSGRS, that envelope both
14 soil and rock sites, so we really don't have any
15 problem. That will be their CSGRS. Okay? That's
16 what they have decided. As we gain experience to
17 actual implementation by a few applicants, the ISG
18 will be incorporated in the standard review plan, or
19 regulatory guide as appropriate, but we want to look
20 at the experience, how it works, where there might be
21 little bit areas for improvement, and things like
22 that. So far, it's going pretty good, and that's
23 basically what my presentation is.

24 MEMBER ARMIJO: What is the ABWR doing?

25 MR. CHAKRAVORTY: ABWR, they have the old

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 spectra. Okay? And right now, the only application -
2 - which application, they have STT, which is a soil
3 site. Okay? So they will be covered on that one.
4 However, if a hard rock site, of course, we have to go
5 back and do the same kind of thing, because it is
6 really design center specific. You cannot address it
7 for AP1000, and then you extend, extrapolate it to
8 ESBWR, because systems are really different,
9 equipments may be different, so we really have to go
10 on a design center basis. All the CSDRS are design
11 center specific. It's not the standard thing. I can
12 design for the .1g and sell -- that's my CSDRS. Okay?
13 If I want to build this plant in Japan, of course, you
14 have to address the other GMRS. And it can be done.

15 MEMBER ARMIJO: Build anything in South
16 Texas.

17 MR. CHOKSHI: Let me just add one more
18 thing, because I think the industry -- this approach,
19 incoherency approach was developed over several years,
20 and industry did a lot of studies. So I don't want
21 you to understand that industry opposed this approach,
22 and conducted evaluation of recorded earthquakes, and
23 we engaged quite a bit, so this has been a product of
24 multi-year of work.

25 MEMBER POWERS: Okay. We'll take a break

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 until 10 of, and then we'll come back.

2 MR. CHAKRAVORTY: I'd like to thank you.

3 MEMBER POWERS: Thank you.

4 (Whereupon, the proceedings went off the
5 record at 10:36:05 a.m., and went back on the record
6 at 10:51:06 a.m.)

7 MEMBER POWERS: We think that the
8 earthquakes in the Western United States and the
9 earthquakes in the Eastern United States and we're
10 going to look a third class, one of a subduction zone
11 earthquake which ought to be different from everything
12 on the face of the earth and Mr. Li will discuss with
13 us the Japanese earthquake and its impact on the
14 Kashiwazaki -- Is that a correct --

15 MR. LI: Kashiwazaki, yes. That's --
16 name. The earthquake is actually called Niigataken
17 and Chuetsu-oki earthquake.

18 Anyway, thanks for the opportunity and
19 I'll brief you on this earthquake and its impact to
20 the power plant.

21 MEMBER POWERS: This is a bit of
22 advertising. The American Nuclear Society does plan
23 to have a session at its regional meeting on this
24 particular earthquake with speakers and whatnot. So
25 we all go visit Sam and learn about it at a meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: That's right. You're all
2 welcome.

3 (Laughter.)

4 MR. LI: By July 15, it's the anniversary
5 of the earthquake at 9:00 p.m. The earthquake
6 occurred at 9:00 p.m. on that day.

7 MEMBER POWERS: Yes, but that would be
8 9:00 p.m. -- that would be July 14th for us, wouldn't
9 it?

10 MR. LI: No.

11 (Simultaneous conversation.)

12 It's actually July 16, yes.

13 MEMBER SIEBER: Too bad the earth is
14 round.

15 MR. LI: Right. And the anniversary, but
16 we spent a lot of time talking about the earthquake
17 last year and I vaguely remember I was actually
18 preparing three documents, talking points, summary
19 documents and the Q&A in a very limited time frame.

20 (Laughter.)

21 Meanwhile, I had to answer questions from
22 somebody who sent the questions through their
23 BlackBerry. Yes.

24 Anyway, I'm going to start with the
25 earthquake, the basic parameter, and then we're going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to talk a little bit about the basic information about
2 the Kashiwazaki-Kariwa nuclear power plant. Then I'm
3 going to talk about the impact of earthquake vibration
4 to the power plant facilities and, lastly, I'm going
5 to talk about the major findings from the earthquake
6 impact to the power plant. And --

7 MEMBER POWERS: Equally of interest to
8 this particular Committee would be the damage to the
9 infrastructure and the ability to respond to the plant
10 from outside. So any comments you have on that would
11 be welcomed.

12 MR. LI: Would you repeat? Damage to the
13 power plant?

14 MEMBER POWERS: No, damage to the
15 infrastructure surrounding, the highways --

16 MEMBER CORRADINI: Bridges.

17 MEMBER POWERS: -- the bridges.

18 MR. LI: Highways and the bridges
19 surrounding, okay.

20 Yes, you can do any question on those
21 issues you are interested in, but when I was preparing
22 these slides, we were very careful because some of the
23 information is proprietary from TEPCO. But,
24 fortunately, I just got notice from Andy Murphy at
25 Research. There's a deal between TEPCO and IAEA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reached probably last night.

2 (Laughter.)

3 And the information can be made public.

4 MEMBER APOSTOLAKIS: Our night or their
5 night?

6 (Laughter.)

7 CHAIRMAN SHACK: I'd say it doesn't make
8 any difference because the time zones are all --

9 MEMBER POWERS: In consideration of
10 subsequent presentations, I think we ought to let this
11 presentation just go through and speak questions of
12 clarification and not --

13 MR. LI: Yes, let me explain a little bit
14 about the earthquake, the name. The Niigataken
15 earthquake Chuetsu-oki means the Niigataken County
16 like Baltimore County but there's --

17 MEMBER POWERS: Right.

18 MR. LI: Oki means "open sea." So the
19 earthquake occurred actually offshore about 16
20 kilometers from power plant.

21 MEMBER SIEBER: Pretty close.

22 MR. LI: And the magnitude of the
23 earthquake is 6.8. It was actually 6.6 a year ago,
24 but those kind of information has always been updated
25 because more arrival time, more simulation. You can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 refine your estimate about the magnitude of the
2 earthquake and you -- Don't overlook that small
3 difference because one magnitude difference actually
4 means a difference about 30 times and the earthquake
5 occurred at the depth spot of seven kilometer at the
6 surface and the accentual difference from the
7 earthquake to the power plant is about 16 kilometers.
8 The hypocenter difference is about 23 kilometers.
9 I'll explain that later. And no direct fault
10 displacement at the power plant, even the fault
11 projected beneath the power plant. But the vibration
12 impact is abundant at the site.

13 Talking about the earthquake in Japan, let
14 me give you some statistics at the beginning, also
15 about the Niigataken. They are so famous in the
16 seismology circle there.

17 First, I'll give you some status about the
18 earthquake in Japan. There is a status about the
19 earthquake occurring between 1994 and 1995, five
20 years. Twenty percent of the measured six earthquake
21 occurred in Japan and the surrounding area, but 80
22 percent occurred throughout the rest of the world.

23 (Laughter.)

24 Think about the area of Japan. It's about
25 the size of California. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Right.

2 MR. LI: So that gives you some pretty
3 idea about the seismic activity in Japan itself and
4 talking about the Niigataken, the county itself, also
5 you probably came across some pictures which shows
6 lows the ratings about four to five score, tilted but
7 not configured class. That's from Niigataken. That
8 event occurred about in the 1960s and it's so famous
9 for the fashion started in that whole world. It's
10 actually the typical example there. And the
11 earthquake caused 15 casualties, 2,315 injuries, and
12 collapsed the houses and cracked the highways in the
13 affected area.

14 Okay. Look at the information about the
15 nuclear power plant at Kashiwazaki-Kriwa nuclear power
16 plant. It's the world's largest nuclear power plant
17 in terms of power output capacity. There are seven
18 units at the site producing 8,210 megawatts. If you
19 compare that with the biggest nuclear power plant in
20 the U.S. that's in Arizona, it's only about 3,880
21 megawatts. And Units 1 through 5 --

22 MEMBER BROWN: That's electrical capacity?

23 MR. LI: Yes.

24 MEMBER BROWN: Okay.

25 MR. LI: And Units 1 through 5 are BWRs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and Units 6 and 7 are ABWRs. Actually one of the COL
2 is acting as previously presentation mentioned, the
3 submit is about -- It's going to be installed ABWR
4 here in the U.S. It's in South Texas.

5 So Units 3, 4, and 7 was important
6 operation at the time of the seismic event and Unit 2
7 was starting up. So four units were in operation at
8 the time. The rest are in refuel outage, the rest of
9 the units.

10 MEMBER BLEY: All seven of those are
11 offline for a very long time. Right?

12 MEMBER ARMIJO: Since the earthquake they
13 haven't been operating.

14 MEMBER BLEY: And for another --

15 MR. LI: So far still are sitting there,
16 yes.

17 And let's take a look at the site. It's
18 a picture taken from the air and from the south. You
19 can see --

20 (Off the record comment.)

21 -- (Indicating) yes, Units 1, 2, 3, 4 and
22 7, 6, 5. Actually, this area is called Kashiwazaki.
23 The other three units called Kriwa. That's why we
24 have KK. That's it.

25 MEMBER BLEY: What's in between? I'm just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curious.

2 MR. LI: Between?

3 MEMBER BLEY: Yes.

4 MR. LI: It's area and nothing there.

5 MEMBER BLEY: Open fields?

6 MR. LI: Open fields, yes.

7 (Off the record discussion.)

8 That's a sketch showing you the right
9 location of the earthquake relative to the nuclear
10 power plant. This is a map here. There's A to A¹.
11 That's a profile which is on the upper left. You can
12 see the 16 kilometers from the epicenter to the power
13 plant and the 17 kilometer of the earthquake to the
14 surface. The distance between the power plant and the
15 hypocenter distance from power plant is about 23
16 kilometers.

17 This seismic event caused a huge impact on
18 the KK plant and fortunately all the operating units
19 are experiencing seismic scrams safety, successfully.
20 I mean, Units 2, 3, 4 and 7 basically. However the
21 ground motion observed at all seven units
22 significantly exceeded the design values. But no
23 damage to so-called As and A type of equipment.
24 That's a Japanese standard of the seismic significance
25 and the significant damage to the B and C type of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 equipment. I'll show you the classification next
2 slide.

3 That's the classification based on
4 Japanese regulatory guide Option 2006. Yes, the As
5 and A type is listed on top here, reactor pressure
6 vessel and those kinds of things and the B type
7 include the turbine facilities and C type is
8 transformers.

9 MEMBER APOSTOLAKIS: Are these what we
10 call safety related?

11 MR. LI: Yes, A and As. Later on,
12 actually called combination of As and A are S type.
13 So assume that S stands for safety.

14 So that's the comparison between the
15 observed value of the ground motion at the lowest
16 foundation level of each unit, also side-by-side
17 listed the design value. You can see the huge
18 difference there. I pick up a dramatic one which is
19 Unit 2 which is also an operating unit at the time
20 when the earthquake occurred. You see the east-west
21 direction component. The design value is 167 gal but
22 the observed value is 607. It's about close to four
23 times a difference there. Yes, again those units
24 safely shut down during the earthquake. So all those
25 highlighted units are operating units. The rest are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the refueling outage.

2 MEMBER SIEBER: Did you get any breach or
3 distortion of supports or anything like that?

4 MR. LI: Distortion?

5 MEMBER SIEBER: Of supports?

6 MR. LI: Yes.

7 MEMBER SIEBER: In the A type and As type
8 systems?

9 MR. LI: There's a variation of the fuel
10 rod jump out of support.

11 MEMBER SIEBER: Okay.

12 MR. LI: Yes.

13 CHAIRMAN SHACK: Now when we say "design,"
14 is that an SSE value? What do they mean by "design"
15 in the earthquake?

16 MR. LI: It's according to the SSE, but
17 it's different from the SSE. This is on the
18 structure. It's on the structure. How SSE is defined
19 on the free surface and the free fuel. This is at the
20 structure. So it's a one-to-one comparison here.

21 MR. CHOXI (phonetic): Yes, he's computing
22 where the record was taken at that point in the plant.
23 So it's something -- SSE would be different. We can
24 compare. Okay.

25 CHAIRMAN SHACK: But when he says "design"

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earthquake, he means an SSE design, not an O

2 MR. CHOXI: Right. This is the value of
3 the 167 that's coming out for the design analysis.
4 Okay. And then 606 is the measure.

5 MEMBER CORRADINI: Just one last thing.
6 So this is at location. So it's a fair consistent
7 comparison. Whatever it is they design for X and
8 solve

9 MR. CHOXI: So you see how more --

10 MEMBER BLEY: It's the same in our
11 tutorial where this would be like measured at the
12 basement.

13 MR. CHOXI: Well, this one, I think --
14 Yong, where is this measured?

15 PARTICIPANT: It's the basement.

16 MR. LI: The lowest level of the
17 foundation. Yes.

18 MEMBER BLEY: It's the same thing.

19 MR. LI: Design value versus the seismic
20 instrument recording there.

21 MEMBER SIEBER: In the aux or safeguards
22 building.

23 MEMBER-AT-LARGE ABDEL-KHALIK: Have the
24 design standards changed for these plants going from
25 Unit 1 to Unit 7? I would have expected these ratios

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to be roughly the s

2 MR. CHOXI: I think as you will see that
3 there are number of factors. One thing is the plants
4 are different. Okay. They are not all the same, so
5 different footprint and stuff and different rates.
6 Also the local site conditions affect the responses
7 and that's what is the point he's going to show later
8 on why there are differences in the ground motion.

9 MR. LI: Actually, the ratio between the -
10 - There's a huge difference between the Units 5, 6, 7
11 in combination versus the others, 1, 2, 3, 4.

12 MEMBER CORRADINI: But to Said's question
13 and break it apart into pieces, the older plants are
14 one through four.

15 MR. LI: One, two, three, four, right.

16 MEMBER CORRADINI: Right. The new plants
17 are five through seven. So wouldn't I at least expect
18 the design values to be higher and that kind of goes -
19 -

20 MEMBER POWERS: They are.

21 MEMBER CORRADINI: Okay.

22 MEMBER BLEY: Except for -- you mean?

23 MEMBER CORRADINI: Well --

24 MEMBER BLEY: The design --

25 MEMBER APOSTOLAKIS: The one on the left -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1

-

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MEMBER CORRADINI: Yes, the one on the left is the design in all cases. So I'm just -- I mean the one thing that went through my mind is the one on the left of the slash is the design. So five, six and seven are bigger than two, three, four. What's going on with one?

MEMBER BLEY: One is the higher design.

MEMBER CORRADINI: Why is one's original design number higher?

MEMBER POWERS: I think you're pursuing an issue that maybe is an ancillary.

MEMBER CORRADINI: I'm sorry.

MEMBER POWERS: Please continue with your presentations.

MR. LI: Anyway, we have -- Since the earthquake occurred, we have accumulated so much data and documents. If you want some detailed explanation, we can give that to you with using an opportunity like a brown bag lunch. So we can do this in an hour maybe. I have so much data accumulated there.

(Off the record comments.)

MEMBER POWERS: Keep going.

MR. LI: Okay. The next slide I want to talk about is common cause failures and potential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vulnerabilities at the site. A lot of damage was
2 caused by settlement, especially the differential
3 settlement, and soil failures at the site. For
4 example, on the right you can see that picture which
5 is an underground fire protection piping joint which
6 is broken. So the water went away and also there are
7 so many deformations, cracks in the ducts connected to
8 the main stacks, and especially the fire caused under
9 one of the transformer at Unit 3 which is due to the
10 differential settlement at the foundation level.

11 And also potential interaction between
12 different components and equipment, that's the next
13 subject. For example, water leaking through the
14 insulation layers, you know, broken insulation, seals
15 and the damage to thermal insulator of SLC, it's
16 called a standby -- control piping and it's not direct
17 damage but damaged insulation. It's almost -- It
18 could be damaged.

19 Okay. As I mentioned before I'm going to
20 focus on the major findings from post-earthquake
21 geophysical investigation. The TEPCO and the power
22 plant spend a huge effort to investigate the
23 earthquakes and the damage. They did a lot of
24 geological surveys. They sent a boat to the ocean to
25 get the seismic line of the submarine data and also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deployed on land, on the surface seismic line, too.
2 They dug boreholes at the site. They dig trenches.
3 They did so much work to tell us what's going on
4 there. Why we observed such a huge amount of ground
5 motion at the different units here.

6 MEMBER ARMIJO: Did they know that fault
7 was there when they designed the plants?

8 MR. LI: That's the next subject. Post-
9 earthquake survey identified fault length was 34
10 kilometers, not seven as previously identified.

11 MEMBER ARMIJO: Okay. They knew something
12 was there, but they didn't know --

13 MR. LI: Yes, the seven kilometer was
14 identified in 1979. They submit that to the Nuclear
15 Regulatory Commission in Japan. It was not the kind
16 of big topic at the time because seven kilometers in
17 terms of earthquake generation it's so small because
18 you have a nearby source to consider, too. And the
19 fault has a potential to generate a magnitude of 7.0
20 earthquake. So based on that 34 kilometers, I think
21 it's conservative. It was embedded in the
22 calculations there. I actually mentioned it's six
23 point something, but they just -- For the conservative
24 -- they just --

25 MEMBER APOSTOLAKIS: So when they thought

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it was seven kilometers, what was the potential at
2 that point?

3 MR. LI: Seven kilometers?

4 MEMBER APOSTOLAKIS: When they thought it
5 was only seven.

6 MR. LI: Yes, they just didn't -- it.

7 MEMBER APOSTOLAKIS: Oh, they just didn't
8 --

9 MR. LI: Yes, because nearby there are
10 many, many faults.

11 MEMBER APOSTOLAKIS: I see. So this was
12 dominated.

13 MR. LI: Yes, Japan has so many natural
14 faults in the whole land area, in the ocean area.
15 Japan tops the -- The book called "Active Fault Atlas"
16 they detail the faults in Japan because all the
17 parameters in the trench digging, the information was
18 there. You know, what's the activity, what's the --
19 They have so much detail to start with in the whole
20 country.

21 MEMBER APOSTOLAKIS: Okay. Then the
22 question is from all these other sources, what kind of
23 activity do they expect?

24 MR. LI: In their design?

25 MEMBER APOSTOLAKIS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. LI: Yes, they used like an earthquake
2 occurred -- They used several. One is the faraway
3 7.0. The other one is closer by. They used several
4 earthquakes to give, to define, the design earthquake.
5 That's the previous story.

6 And it is a reverse fault. That's very
7 important. It dips towards the power plant with an
8 angle of 35 degrees and the nuclear power plant is
9 sitting on the hanging wall side. I don't know if you
10 can --

11 (Simultaneous conversations.)

12 MEMBER CORRADINI: It's on a shelf.

13 MEMBER SIEBER: It's on a shelf.

14 MR. LI: Yes, I wish we have a board here.
15 But I can show you quickly here.

16 (Off the record conversation.)

17 Okay. This is the surface. This is where
18 we come to the surface. There's a fault plan here
19 with my angle is 45 degree, not a 35 degree. So if
20 this fault moved -- This is called a hanging wall,
21 this side. This is called a fault wall. So if the
22 hanging wall moves up the wall like this like in Japan
23 case, it's called reverse fault. If it moves down,
24 it's called a normal fault.

25 MEMBER CORRADINI: Okay. (Indicating) So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it did that?

2 MR. LI: Yes. But the fault geometry and
3 the relative moment determine the fault
4 characteristics.

5 (Off the record discussion.)

6 So because this plant is located on the
7 hanging wall side, so according to the major
8 earthquake started around the world, the hanging wall
9 usually has more concentration on the side of the
10 waves. This happened in Kobe earthquake in 1999 and
11 many, many like Turkey earthquakes and many, many
12 earthquakes around the world. It's a recognized
13 phenomenon. It also occurred here.

14 MEMBER CORRADINI: Is the Kobe a reverse
15 fault?

16 MR. LI: Kobe --

17 PARTICIPANT: (Inaudible.)

18 MR. LI: Yes, it has some components of
19 the reverse, but mostly a strike --

20 So based on TEPCO's study with those of
21 efforts, they summarized. Extreme ground motion
22 observed is because of the following factors. First
23 is the source effect. That's what I mentioned, the
24 reverse fault, the hanging wall effect there. The
25 second one is called a deeper non-uniform layer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 formation and the third one is shallow old structure
2 bending effect which caused such a significant ground
3 motion at the seven units.

4 Let's look at this figure here. That's a
5 summarizing map presented by Japan technical
6 representative during the June 12 presentation. It
7 says Factor 1, it's source effect. That's because of
8 geometry of the fault relative to the power plant. It
9 has 1.5 times the magnification to the ground motion.
10 The Factor 2 was -- I'm sorry. Factor 2 is because a
11 non-uniform of deeper ground foundation. It also
12 indicates the level of the structure at about four to
13 six kilometers beneath the surface. And then the
14 Factor 3, it's due to the old bending structure.
15 That's somewhere here. It's also highlighted near
16 magnitude closer to the surface about two kilometers
17 from beneath the power plant.

18 And it's -- We have some questions about
19 this story here because the structure -- You know, the
20 amplification of this step usually is caused by the
21 thing called impedance contrast. Basically, it's the
22 density multiplied by the velocity. But this can --
23 you know, if you don't have that impedance contrast,
24 the wave packing through primarily results being
25 effective.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And another thing is that there was
2 another earthquake occurring 2004 on the east side of
3 the power plant, not the west side. Those effects
4 should be also, I mean, reflected by ground motion
5 observed at the power plant. But we don't see any
6 record or story about that. That earthquake was also
7 6.8 magnitude I should point out. And this is a
8 common U.S. practice for -- industry a non -- facility
9 is that use VS30, top 30 meter velocity to define the
10 site characteristics. We never defined this deep by
11 two kilometers of, you know, four to six kilometers.
12 So we have some questions for our Japanese
13 seismologists about those kind of issues. We're going
14 to raise those questions to them.

15 Yes. There's still quite a lot ongoing
16 activity at the power plant. They are doing non-
17 destructive testing for hidden damage. You did the
18 walkdown and you do the visual checking, but how about
19 behind that? You could have some hidden problem there
20 and their assessment of the new ground motion for the
21 plant safety and thinking about how to upgrade this
22 design for the power plant.

23 The key points about this earthquake at
24 the power plant is that ground motion from the
25 earthquake exceeded the design values of the KK plant,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but all units are in cold shutdown and the plant
2 systems worked as designed and radiological safety was
3 not compromised and no damage to safety related
4 structures and equipment but significant damage to the
5 other structures and equipment.

6 MEMBER BANERJEE: I heard a rumor that one
7 control rod is stuck somewhere, was stuck. Is that
8 true?

9 MR. LI: It is. It's actually -- The
10 control rod was stuck but after I think they did --

11 MEMBER BANERJEE: It may be stuck now. I
12 mean, it may not --

13 MR. LI: No, actually these -- They did --
14 After I think manually they did something. They still
15 work as it is designed. But there isn't a lot that
16 actually jump out to support as I mentioned before.

17 MS. KAMMERER: But there were some fuel
18 rods that were stuck and they did have -- But the
19 control rod, what happened, there was some
20 announcements that were just presented when we were at
21 Kashiwazaki a couple of weeks ago that they found --
22 They did find that there are the guides, of course,
23 and what they were -- what they found was it took
24 about twice as long for all of the control rods to
25 insert because what was happening was you actually had

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deformation of the guides and so it would kind of
2 deform this way and you would have -- it would be
3 bound and you would have some binding. As soon as it
4 straightened out, then it would be free again and so
5 it did take twice as long for the control rods to
6 insert which was something that they showed through
7 testing and analytical procedures and then they did
8 have problems getting -- There are certain things and
9 we actually have some pictures of some of it that we
10 could provide to you. But, yes, that is something
11 that we --

12 MEMBER APOSTOLAKIS: The reason why there
13 was no damage to safety related systems even though
14 they observed, they measured, several issues were
15 found, is that because of the extent of separatism in
16 their design?

17 PARTICIPANT: You bet.

18 MR. LI: There is an explanation from
19 TEPCO. They said that the --

20 MEMBER APOSTOLAKIS: But we don't know how
21 much it is.

22 MEMBER ARMIJO: I do.

23 MEMBER APOSTOLAKIS: You do?

24 MEMBER ARMIJO: Yes, I was involved in --

25 PARTICIPANT: There was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Wait.

2 MEMBER ARMIJO: Their design practices are
3 very, very conservative in every step of their
4 process.

5 MEMBER APOSTOLAKIS: So I think that
6 there's a public communication to say that this is a
7 design acceleration -- It's just a number that
8 initiates some process that adds a lot of margin.

9 MEMBER ARMIJO: That's correct.

10 MEMBER APOSTOLAKIS: Yes.

11 MEMBER ARMIJO: That's correct.

12 MR. LI: So it's a conservative design --

13 MEMBER APOSTOLAKIS: But how conservative
14 is it though? In other words, if I go to another
15 site, is the margin going to be the same or it depends
16 on --

17 MEMBER SIEBER: Not necessarily.

18 MS. KAMMERER: One of the finding from --
19 workshop in Kashiwazaki a couple of weeks ago is that
20 you could not extrapolate what happens at this plant
21 to other places because it was very, very
22 conservatively designed. So a lot of folks are
23 saying, "See, this shows that this is true everywhere"
24 and that's not the case.

25 Now right now, EPRI is actually assisting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 TEPCO with a margins assessment because one of the
2 things they need to explain to the regulators and to
3 the international community is why was the performance
4 good. It's great to say that it was, but we all
5 benefit from learning exactly why that was the case
6 and so EPRI is actually undertaking a seismic margins
7 assessment right now that they've presented and that
8 will be available.

9 MEMBER APOSTOLAKIS: The second question
10 is which I think -- Why were the design values so much
11 lower than what we measured? Was it a fault of the
12 methodology that was being used or the way of the
13 implementation of the methodology?

14 MEMBER BLEY: Or this just an extremely --

15 MEMBER CORRADINI: Data.

16 MEMBER BLEY: This is just an extreme
17 earthquake.

18 MEMBER APOSTOLAKIS: I think you said that
19 typically we go how many meters down and several
20 kilometers to do the characterize of --

21 (Simultaneous conversations.)

22 MEMBER APOSTOLAKIS: But that's for big --

23 MR. LI: Our nuclear facility, we do a
24 site specific --

25 MEMBER APOSTOLAKIS: So is the answer then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that there is nothing wrong with the methodology?
2 It's just that it was not implemented very well.

3 MR. LI: Well, it's already -- I think
4 it's mentioned there. The key factors, this huge
5 amount of ground motion of -- at the power plant site.
6 It's underestimated the -- factor, that source factor.
7 Second are those non-uniform layers and in the bottom
8 --

9 MEMBER APOSTOLAKIS: But my question is
10 why didn't they know about these things. Is it
11 because they had a good methodology but they just
12 didn't apply it very well or the methodology had holes
13 that didn't ask them to actually look for these
14 things? These are two different things. So what do
15 you think the answer is? The methodology needs to be
16 more complete, so to speak, or the methodology is fine
17 but those guys when they did their own site
18 characterization they didn't implement it very well.
19 What is the ans

20 MR. CHOXI: George, I think one of the
21 activities which is undergoing is to look at the
22 standards for the design, how you come up with the
23 earthquake. In fact, the next week we have
24 representatives of Japanese government coming and talk
25 to us about their new standards.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: So you're saying that
2 it was new standards that --

3 MR. CHOXI: -- the type of things we are
4 seeing now.

5 MS. KAMMERER: That's right.

6 MR. LI: Probably it's a combination
7 because --

8 (Simultaneous conversation.)

9 MEMBER POWERS: In reference to the best
10 of our agenda, we're going to have to cut things off
11 at this point. Thank you very much. It was a very
12 useful introduction to the subject.

13 MR. LI: Thank you.

14 MEMBER POWERS: And it's clear that I see
15 whole hosts of different implementations and I'm sure
16 our seismic researchers see them, too. And it's going
17 to be some time to start that up. Thank you very much
18 for an exciting morning. As you can see that this is
19 an issue the Committee has a huge amount of interest
20 in and I think we should talk about a subcommittee
21 meeting perhaps in the fall and as you complete your
22 guidelines to Shack, we can sit down and discuss this
23 research program some more.

24 Right now, just very, very worthwhile I
25 thank you very much. Mr. Chairman, it is all yours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SHACK: Okay. We're a bit behind
2 schedule. But I think it's time to start the
3 discussion of containment overpressure credit with TVA
4 and Mario will be leading us through that.

5 (Off the record comments.)

6 CHAIRMAN SHACK: Need a quick five minute
7 break. But be back at 11:30 a.m. promptly. Off the
8 record.

9 (Whereupon, at 11:24 a.m., the above-
10 entitled matter recessed and reconvened at 11:29 a.m.)

11 CHAIRMAN SHACK: On the record.

12 CONTAINMENT OVERPRESSURE ACCEPTANCE CRITERIA

13 VICE CHAIRMAN BONACA: Okay. Thank you,
14 Mr. Chairman. As most of you are aware, the Tennessee
15 Valley Authority submitted extended power uprate for
16 Browns Ferry Units back in June 2004. This is
17 requested in two steps five percent uprate for Unit 1
18 which is already been approved. It will be followed
19 by a 15 percent -- power uprate for all three units.

20 In order to meet the requirements for all
21 net positive (phonetic) suction for the ECCS pumps,
22 the Licensee takes credit for containment
23 overpressure. The Committee discussed the five
24 percent uprate in 2007 and we recommended the
25 application for five percent power uprate be approved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 However, we also noted in our letter that when the TVA
2 would come for the 120 percent power uprate we would
3 need to have more complete evaluations of two
4 scenarios. One was the long-term LOCA. And the other
5 was the Appendix R fire scenarios.

6 The concern we had with those two
7 scenarios is that the amount of credit requested was
8 significant and there was significant length of time.
9 I remember that for the long-term LOCA the credit
10 required was about 3 psi for up to a day, roughly 22
11 hours, and for the Appendix R it was up to 9 psi for
12 up to 69 hours, almost three days, and, in particular,
13 for Appendix R, the concern was that the difference
14 between the available back pressure and required back
15 pressure was only as low as 1.4 psi at some point in
16 the transit. The concern also was that to achieve
17 that 1.4 psi the operator was directed to turn off
18 drywell cooling, maximize containment pressure, which
19 is counterintuitive. So all these issues were on the
20 table.

21 At that time, we also suggested some
22 possible solutions for the issue. For the long-term
23 LOCA, we suggested that the best estimate calculation
24 to demonstrate their point that is that the credit was
25 driven by the conservatism of the LOCA would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 acceptable if, in fact, you were provided a best
2 estimate with proper treatment of uncertainty.

3 For the fire analysis, we saw no solution
4 except one in which you attempted to provide some kind
5 of context, risk context, and we were interested in
6 that. But the risk analysis was more qualitative and
7 also was not complete. It did not include all fire
8 initiators. We suggested actually in the letter that
9 you protect a second kind of RHR as other licensees
10 have done because that would cause no need for credit
11 for back pressure. The other alternative would be to
12 present a fire analysis that's complete enough to
13 address all the initiators.

14 So, with that in mind, we did not hear
15 anything from the Licensee since that time and we
16 understand now that you provided some information to
17 the staff in 2007. We have not received that. But
18 today, we anticipated the staff and the Licensee will
19 fully brief us when we come to the part of this in
20 participation for the 15 percent uprate. However,
21 your representation is an informal briefing to bring
22 us up-to-date and to provide an opportunity to hear
23 our comments and feedback.

24 Now we have received this information that
25 it isn't -- and not ready to address as the full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 committee. So we intend to have an informal meeting
2 with you rather to gather information and then we will
3 see what it does to our thinking about what you've
4 presented and the communication -- Okay. With that,
5 I turn to Eva Brown of NRR to have --

6 MR. MCGINTY: Good morning. Tim McGinty,
7 the Deputy Director from NRR -- Dr. Bonaca, it's my
8 privilege to introduce this topic to the Committee.
9 Your remarks enveloped in its entirety all of my
10 opening remarks.

11 (Laughter.)

12 So I wanted to save the Committee time.
13 The intent is to allow a dialogue directly between the
14 Committee and TVA regarding this topic. The staff, of
15 course, is here to answer any questions that the
16 Committee may have. But with that said, I'd like to
17 turn it over to TVA, James Emens and J.D. Wolcott.

18 VICE CHAIRMAN BONACA: I'd like to
19 clarify, however. We had a presentation to the
20 Commission a month ago and, in their presentation, the
21 point was made that one of the concerns is the
22 difference of criteria that we are using versus the
23 staff is using. That creates a confusion and
24 hopefully we can come to an understanding between the
25 staff and the ACRS in how we can deal with that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MCGINTY: Yes, sir. And we are acting
2 working on establishing criteria. So that is duly
3 noted.

4 VICE CHAIRMAN BONACA: All right.

5 MR. EMENS: Okay. I'm James Emens,
6 Licensing Supervisor of Browns Ferry. With me today
7 is James Wolcott. He is the State of Power Uprate
8 Engineering Manager and then we also have with us Bert
9 Morris, Licensing Engineer.

10 And just like Mr. McGinty said, you
11 captured the framework real well for this meeting. So
12 I'll try not to repeat that. We are here to address
13 the concerns that were experienced in the February
14 2007 ACRS meeting and we listed this on the first
15 slide.

16 I would like to point out that this is
17 related to extended power uprate and the extended
18 power uprate does result in an increase of magnitude
19 and duration of the licensing basis analysis for the
20 needed containment overpressure. Containment
21 overpressure has been a part of the -- licensing
22 basis. It's currently a part of the licensing basis
23 for all three units.

24 As you said, we heard your comments and we
25 saw the need to do some additional analysis to address

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Appendix R COP issue. In July of 2007, we met
2 with NRC staff and had discussions regarding your
3 comments. We undertook fire area analysis to compare
4 the containment overpressure needed for a realistic
5 fire versus the prescribed Appendix R fire. The
6 deterministic analysis that resulted from that was
7 submitted to the staff in November 2007 and
8 subsequently performed the NPSH analysis to limiting
9 cases in the fire area analysis and submitted that in
10 June of this year.

11 And with that I would like to turn the
12 presentation over to Mr. Wolcott who is going to do a
13 detail of this analysis and address your concerns.

14 MR. WOLCOTT: I'm J.D. Wolcott. I'm the
15 Engineering Manager for Power Uprate at Browns Ferry.
16 Today's presentation is going to focus on the Appendix
17 R fire event. That is what received the most
18 analytical attention from us since the February 2007
19 ACRS meeting.

20 I start out by saying a little bit about
21 Appendix R as it relates to this issue of containment
22 overpressure. The Appendix R rule has us take a
23 predefined, generic set of fire damage and then
24 demonstrate that we can safely shut down the plant per
25 a set of rules if it doesn't allow for a plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 specific fire analysis to try to figure out what kind
2 of fire you would have, what kind of damage you would
3 have.

4 So it results in some areas of the plant
5 in predicted fire damage that doesn't really match.
6 It's overly conservative compared to how that part of
7 the plant is configured and what it consists of.

8 MEMBER-AT-LARGE ABDEL-KHALIK: Before we
9 get too far into the details of it, isn't that the
10 law?

11 MR. WOLCOTT: It certainly is and we are -
12 -

13 MEMBER-AT-LARGE ABDEL-KHALIK: In a sense
14 that, you know, if you had done an analysis for a
15 large break LOCA and you found that your results do
16 not meet the acceptance criteria, you don't come back
17 to the agency and say, "Wait a minute. This is
18 unrealistic. This is overly conservative. Let me
19 show you the results of some other LOCA that meets the
20 acceptance criteria." Is that the same logic?

21 MR. WOLCOTT: No, I have to cover -- I'm
22 answering that question with this next bullet right
23 here.

24 MEMBER-AT-LARGE ABDEL-KHALIK: Okay.

25 MR. WOLCOTT: So on slide five, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 performed another analysis as you say and it is not to
2 take the place of the Appendix R analysis. We have --
3 It's a law. It's a rule and we have to comply with it
4 and we have to show that there is a success path for
5 safely shutting down the plant in accordance with
6 those rules and we've done that. But it doesn't show
7 very much margin.

8 So what the community was concerned about
9 was the amount of risk involved, you know, associated
10 with not having very much margin. And so we pursued
11 a more realistic analysis that allows us to go into
12 more detail in analyzing the plant and the purpose of
13 that is to supplement the Appendix R analysis, the
14 licensing basis analysis for the purposes of giving
15 risk insights and showing how much margin is in the
16 licensing basis analysis. So it's certainly does not
17 take its place.

18 MEMBER APOSTOLAKIS: Is the causes
19 analysis a risk analysis?

20 MR. WOLCOTT: No, it's deterministic.
21 It's strictly deterministic for us to be able to look
22 at the risk based on how much margin there is. It's
23 not a numerical risk.

24 MEMBER APOSTOLAKIS: Measuring risk --

25 MR. WOLCOTT: It's not --

1 MEMBER APOSTOLAKIS: Are you going to do
2 fire PRA before you say anything about risk or are you
3 going to infer or conclude something about risk from
4 the deterministic analysis?

5 MR. WOLCOTT: It is the latter. We are
6 inferring risk insights from a deterministic analysis
7 basically by looking at how much margin there is.

8 VICE CHAIRMAN BONACA: You do not have a
9 fire PRA.

10 MR. WOLCOTT: That is correct. We do not.

11 MEMBER APOSTOLAKIS: But again, just
12 understand something related to what Professor Abdel-
13 Khalik said. These fire hazard analysis which is
14 deterministic, is it allowed by Appendix R?

15 MR. WOLCOTT: No. No, it's not.

16 MEMBER APOSTOLAKIS: So you are trying --
17 You are being innovative here.

18 MR. WOLCOTT: We just are doing additional
19 work to try to show how much conservatism is in the
20 licensing basis approach.

21 MEMBER CORRADINI: A yes would have been
22 fine.

23 MEMBER RAY: Wait a minute, guy. I think
24 if it was over a noncompliance with Appendix R this
25 would not be legitimate. What they're doing is doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an analysis to show margin as he said.

2 MEMBER SIEBER: Yes, on the other hand, is
3 the importance of this to request an exemption?

4 (Simultaneous conversations.)

5 MR. WOLCOTT: No, it's not.

6 MEMBER APOSTOLAKIS: They are complying
7 with Appendix R.

8 MEMBER RAY: They complied with Appendix
9 R. It's just that's an emerging question.

10 MEMBER APOSTOLAKIS: And they are
11 addressing this question because the ACRS is.

12 MEMBER RAY: That's right.

13 MEMBER APOSTOLAKIS: In other words, they
14 could have told us we don't want to do it.

15 VICE CHAIRMAN BONACA: But my question
16 here is that margin that you have in that specific --
17 to show us, that -- is still there. That's limiting
18 licensing analysis. Correct?

19 MR. WOLCOTT: I think I would still agree
20 with you that because that it is always possible to
21 have that situation happen, it's not impossible, and
22 the rule does require that we assume that that amount
23 of damage occurs unless I can show you that it's
24 impossible. We should show that we can safely shut
25 down the plant given that scenario.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN BONACA: There was a reason
2 why the letter we let persevere before you, but we
3 were expecting at any time a fire analysis, a
4 quantification, a PRA analysis that -- in fact, was
5 the representation that you had a fire analysis
6 because we see the quantitative estimation of 10^{-7} or
7 something like that. And so it's important that we
8 would like to see it but we cannot forget that you
9 still are bound by the licensing commitment to -- the
10 scenario.

11 MR. WOLCOTT: Absolutely.

12 VICE CHAIRMAN BONACA: Okay. Because you
13 should.

14 MR. WOLCOTT: In this, we determined a
15 fire damage by plant specific analysis versus what you
16 would do in the rule which is a prescribed set of fire
17 damage. This involves screening each of the 39 fire
18 areas that we use at Browns Ferry using standard fire
19 protection engineering principles, some of which are
20 combustible loading in the compartment, the volume of
21 the compartment, the amount of detection and
22 suppression that is there and the ignition sources
23 that are there.

24 MEMBER ARMIJO: Now are you talking about
25 -- Do these numbers represent per unit?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WOLCOTT: No.

2 MEMBER ARMIJO: Or --

3 MR. WOLCOTT: The entire plant.

4 MEMBER ARMIJO: The whole. The three
5 units.

6 MR. WOLCOTT: That's 39 -- That's correct.

7 MEMBER ARMIJO: This is kind of all three
8 units simultaneously being analyzed.

9 MR. WOLCOTT: That's correct. If we have
10 to -- Because three units would be operating at the
11 same time and we have to take care of them all.
12 They're not all directly affected by the fire, by any
13 one fire.

14 MEMBER ARMIJO: I understand.

15 MR. WOLCOTT: Except possibly the control
16 room. But we have to handle them all any time --

17 MEMBER ARMIJO: Got it.

18 MR. WOLCOTT: With this screening by these
19 principles, there are 22 of the 39 fire areas that
20 screened out and what we mean by screened out is that
21 because of the characteristics of the area that are
22 listed the fire will be limited to the ignition
23 source. That is that you don't have the mechanisms
24 that would propagate a fire from the thing that caught
25 fire to start with to other unrelated equipment. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would generally mean it would be limited to one
2 division. And when you have a situation like that
3 because of the redundancy and divisional separation
4 that we already have you would have one division left
5 and there wouldn't be an issue with shutting down the
6 plant for those 22 areas.

7 MEMBER STETKAR: Jim, 39 fire areas per
8 unit?

9 MR. WOLCOTT: No. For the entire plant.

10 MEMBER SIEBER: The whole plant.

11 MEMBER STETKAR: Interesting that there's
12 only 39 fire --

13 MR. WOLCOTT: Well, some of them are
14 pretty large.

15 MEMBER STETKAR: Yes, like maybe the whole
16 turbine building.

17 MR. WOLCOTT: The whole reactor building.

18 MEMBER STETKAR: Because it would be
19 interesting to see what those fire areas are.

20 MR. WOLCOTT: Some of them are quite
21 large.

22 MEMBER STETKAR: Okay.

23 MR. WOLCOTT: Each reactor building, for
24 instance, is its own fire area just about. So that --

25 MEMBER SIEBER: The whole turbine building

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would be one fire area.

2 MEMBER STETKAR: I was just curious. The
3 thing that we call fire areas differs quite widely.

4 MEMBER SIEBER: Yes.

5 MEMBER MAYNARD: Depending on what their
6 need is.

7 MEMBER STETKAR: Yes.

8 MEMBER APOSTOLAKIS: Now regarding the
9 screening -- Let me understand this a little better.
10 I think you are focusing on the fire itself in saying
11 -- combustibles. So if I have a fire my deduction
12 capability is great. You don't seem to be including
13 anything regarding the damage to the plant and do I
14 have both divisions going through that area? Do I
15 have only one? Do I have none? Why is that so?

16 MR. WOLCOTT: That's the next slide. I
17 have this kind of broken up on two slides.

18 MEMBER BLEY: Were some of the 22 areas
19 that were screened out key areas in the original
20 Appendix R file that led to this scenario?

21 MR. WOLCOTT: Yes.

22 MEMBER BLEY: Can you tell us which those
23 were?

24 MR. WOLCOTT: The reactor, the one
25 associated with Unit 1 reactor building, would be one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the places not where the Browns Ferry fire started
2 but where it propagated to. When you screen one of
3 these out the Browns Ferry fire would not be screened
4 out. That fire was limited to the thing that caught
5 fire to start with. But there was a lack of basic
6 divisional separation involved in that incident which
7 for a period of time affected more than one division
8 because there are some cables that didn't meet
9 separation criteria that was originally set out. So
10 there were -- That fire would have not been excluded
11 by this screening. It would have been limited to --
12 it was limited to what was --

13 MEMBER BLEY: Just to make sure I
14 understand what you did. If you get into the fire
15 area and you do have separation between your divisions
16 in that area and there are no permanently installed
17 combustibles that would link those two divisions, that
18 room would screen out.

19 MR. WOLCOTT: Yes, transient combustibles
20 count in this, too. They sure do. Some of these
21 areas, the volume of the area, is probably a very
22 important factor as is the detection and suppression.
23 Some of these areas as you can imagine the reactor
24 point is quite large compared to the amount of
25 combustibles that you could conceivably put in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 area.

2 MEMBER SIEBER: One quick question. In
3 your screening process, one of the screening criteria
4 uses detection and suppression.

5 MR. WOLCOTT: Correct.

6 MEMBER SIEBER: That typically is not
7 allowed under the rule. Right?

8 MR. WOLCOTT: You could not exclude an
9 area just because it had detection and suppression.

10 MEMBER SIEBER: That's right.

11 MR. WOLCOTT: The rule does include that,
12 but couldn't just eliminate an area.

13 MEMBER SIEBER: Well, basically it's an
14 insurance company that says you have to have detection
15 and suppression and you'd like to know as a practical
16 matter so you could send your fire brigade there. On
17 the other hand, you can't count it under the rules.

18 MR. WOLCOTT: That's correct.

19 MEMBER SIEBER: So this third sub-bullet
20 that you have that says you screen based on these fire
21 protection parameters one of which is detection and
22 suppression.

23 MR. WOLCOTT: You have to remember that we
24 comply with the rule also but showing less margin in
25 the result. So the purpose of this is to show that if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you could relinquish some aspects of the rule you can
2 show much more margins.

3 MEMBER SIEBER: Well, you get to the point
4 where you say how effective is the suppression
5 activity which is pretty much undefined even in the
6 NFPA Code and so how did you treat that?

7 MEMBER APOSTOLAKIS: Would you remind me
8 when that rule says -- I think as I recall it says
9 that if you don't have the separation criteria then
10 you have to do automatic detection/suppression. Is
11 that correct?

12 MEMBER SIEBER: Yes. A barrier.

13 MEMBER CORRADINI: You have to have a
14 barrier for a certain amount of time.

15 MEMBER APOSTOLAKIS: Yes. So that's
16 basically what the rule says.

17 MEMBER SIEBER: Yes.

18 MEMBER APOSTOLAKIS: Mr. Sieber is right
19 that it doesn't go beyond that.

20 MEMBER SIEBER: You have to have it.

21 MR. WOLCOTT: That's right. Correct.

22 (Simultaneous conversation.)

23 MEMBER SIEBER: You can't credit the
24 barrier. You can't credit detections. He's correct.

25 MEMBER APOSTOLAKIS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I'm new to this issue a
2 little bit. Within the Appendix R rule, is there a
3 definition of -- containment overpressure or is that
4 coming from somewhere else?

5 MR. WOLCOTT: The Appendix R rule does not
6 address that point.

7 MEMBER BLEY: At all?

8 MR. WOLCOTT: No.

9 MEMBER CORRADINI: So just to -- I'm glad
10 you brought that up. So replay history back to the
11 comments that Said and Mario made, given the situation
12 at hand, you use that to justify some time period by
13 which you need the overpressure credit to show
14 compliance.

15 MR. EMENS: Correct.

16 MEMBER APOSTOLAKIS: Compliance with what?

17 MEMBER CORRADINI: Compliance but --

18 MEMBER APOSTOLAKIS: I understand now what
19 you said. Compliance with --

20 MEMBER CORRADINI: They actually can
21 satisfy the cooling under the condition of -- Make
22 sure the pumps operate. They have to show the pumps
23 operate for a set amount of time. Again, -- the NFPA
24 for a set amount of time. That's what I remember.

25 MEMBER APOSTOLAKIS: I don't feel I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 getting this. Is that what you mean?

2 MR. WOLCOTT: Yes. Did you want me to
3 just go back a little bit?

4 MEMBER CORRADINI: No, I'm okay.

5 (Simultaneous conversation.)

6 MEMBER BLEY: -- for me is where does the
7 acceptability of taking credit for containment
8 overpressure come from? Where in the regulations are
9 we anchoring that?

10 MEMBER CORRADINI: I think the history
11 might be useful.

12 MEMBER BLEY: I need a little bit of
13 history.

14 (Simultaneous conversation.)

15 MR. LOBEL: Richard Lobel from the staff.
16 If you go back to regulation, it would be GDC 35 that
17 requires abundant cooling of the ECCS. So the ECCS
18 has to operate, has to put abundant water into the
19 vessel. There is also a standard with UPM (phonetic)
20 Section 622, Containment Heat Removal, and another GDC
21 38 that requires containment heat removal. So that
22 would cover things like sprays and PWRs but not at
23 Browns Ferry. Like somebody said, we're really
24 talking about having the pumps available to do their
25 safety function and it goes back to those two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 regulations, those two GDCs.

2 MEMBER BLEY: And they're kind of general
3 in what they require.

4 MR. LOBEL: The issue of --

5 MEMBER BLEY: What they are accounting and
6 not accounting for containment overpressure, does that
7 show up anywhere in any specific guidance or anything?

8 MR. LOBEL: It's in the Regulatory Guide
9 1.82, Revision 3.

10 MEMBER BLEY: Okay.

11 MEMBER SIEBER: I believe the ACRS
12 commented on that in the past.

13 MEMBER BLEY: I know. But I don't know --
14 I didn't know the history exactly.

15 MR. LOBEL: You commented -- It did come
16 to ACRS for review, but it came to ACRS for review in
17 the context of PWR some blockage and I don't think it
18 really got much review by ACRS at that time because
19 that wasn't what the staff was emphasizing. We came
20 to you again with a Revision 4 to the Reg Guide which
21 didn't go anywhere.

22 VICE CHAIRMAN BONACA: The Reg Guide 1.1
23 dealt with also back pressure.

24 MR. LOBEL: So containment accident
25 pressure is necessary in some cases for some operating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plants to demonstrate that they have adequate
2 available MPSA so the pumps will operate and that's in
3 Reg Guide 1.82. Thank you.

4 MEMBER BLEY: That helps me.

5 VICE CHAIRMAN BONACA: Okay. So you can
6 proceed. So you did this 22 --

7 MR. WOLCOTT: That is correct. So in the
8 screening, there are 17 fire areas, however, at the
9 plant where the fire could propagate to unrelated
10 pieces of equipment other than the one that caught
11 fire to start with and by inference could affect
12 multiple divisions, multiple pieces of equipment.

13 So for those areas, we had to go through
14 and do an equipment availability analysis. In other
15 words, we had to look at what equipment would not be
16 affected by fire and try to determine how we would
17 shut down the plant --

18 MEMBER-AT-LARGE ABDEL-KHALIK: Now in some
19 of these cases this equipment's availability analysis
20 did indeed show that you would only have one RHR pump.

21 MR. WOLCOTT: Right. Yes.

22 MEMBER-AT-LARGE ABDEL-KHALIK: If that is
23 the case, if I look at the performance curves provided
24 by your supplier, it said that all the performance
25 data that you're using to evaluate the success was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 based on the average performance of all four pumps.
2 In other words, they took the characteristic curves
3 for all four pumps, came up with an average and that's
4 what you used to establish your criteria. And yet if
5 in some of your scenarios, you only have one pump
6 available and this according to your estimate is sort
7 of a realistic scenario, how can you justify using
8 average characteristics in situations where you expect
9 to have only one pump?

10 MR. WOLCOTT: I would have to do some
11 research to try to figure out exactly where you're
12 talking about there.

13 MEMBER-AT-LARGE ABDEL-KHALIK: I'm talking
14 about page --

15 MEMBER APOSTOLAKIS: Sulzer report.

16 MEMBER-AT-LARGE ABDEL-KHALIK: It's the
17 Sulzer report, for example, page seven of the report
18 that is 37 pages. No, page three of 37. It says,
19 "The basis for evaluation 35 witness desk performance
20 curves for both pump sets were averaged to produce an
21 average performance for each pump type." And that's
22 what you use to find out whether or not you actually
23 meet the criteria. So can you explain to me how you
24 can use an average performance curve for four pumps
25 when you only expect to have one pump available during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the scenario?

2 MR. WOLCOTT: I believe I can if I
3 understand it correctly.

4 MEMBER-AT-LARGE ABDEL-KHALIK: Please do.

5 MR. WOLCOTT: What they're talking about
6 there I think is that they tested every single one of
7 our pumps and it was a head flow test and reduced
8 suction head test using a -- You've done on a test
9 scatter and those are -- they are physical tests. And
10 so when you do something like that, your data points,
11 you have some data scatter any time you do that. So
12 they took all of our pump tests where their NPSH
13 determinations for all of our pump tests which are
14 testing identical pumps, putting them on, running it
15 all through the testing and like any experiment which
16 has data and a data scatter, then they took the
17 average of those tests and determined that NPSH that
18 results at a one percent head loss and a three percent
19 head loss.

20 MEMBER-AT-LARGE ABDEL-KHALIK: So are you
21 trying to tell me that the characteristic curves for
22 all four pumps are identical except for scatter in the
23 measurement data?

24 MR. WOLCOTT: Because particularly when
25 they did this test when the pumps were factory brand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 new, I would expect them to be very similar. I would
2 have to believe there could be some machining
3 tolerance or clearance tolerance that could make
4 slight differences. But these were -- When these
5 tests were done, these were factory new and assembled
6 and probably very identical. But the tests reg and
7 the test stand my intuition would tell me would
8 introduce more error into that than the differences --

9 MEMBER-AT-LARGE ABDEL-KHALIK: Do you have
10 indeed data to support that claim?

11 MR. WOLCOTT: We have all the tests data
12 from these pump tests.

13 MEMBER-AT-LARGE ABDEL-KHALIK: These are
14 1970 something data. Correct?

15 MR. WOLCOTT: That's correct.

16 MEMBER-AT-LARGE ABDEL-KHALIK: Now the
17 rotors were replaced in 1990 something.

18 MR. WOLCOTT: That's correct.

19 MEMBER-AT-LARGE ABDEL-KHALIK: And are you
20 even sure that the 1970 something data is still valid?

21 MR. WOLCOTT: If the rotors -- The rotors
22 were replaced in order to take care of wear ring
23 cracking problem. It had to do with the material the
24 wear ring was made out of. So the rotors are
25 identical with respect to hydraulic performance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They're trying to fix a material problem with them.
2 So with respect to what we're trying to determine
3 here, I have confidence that they will meet this
4 requirement.

5 MEMBER-AT-LARGE ABDEL-KHALIK: So let me
6 just cut to the chase. Do you have actual pump
7 performance data post 1990 X for the four different
8 pumps that shows that indeed they are identical, they
9 are the same as the 1976 data and that the use of an
10 average pump characteristic curve is justifiable in a
11 scenario when you expect to have only one pump
12 available and you have no idea which one of the four?

13 MR. WOLCOTT: The characteristic curves,
14 that is the head flow curve, we determine that all the
15 time and we have to test that all the time and prove
16 that it's the same. But the curve that matters here
17 is the net positive suction head curve. Typically,
18 one only tests that once if they test it at all. So
19 that's not a test that you would do periodically.

20 We have one test that's fairly famous in
21 the industry that we did at Browns Ferry on an
22 installed pump and we took it below the level, quite
23 a bit below the level, that's in this curve in an
24 attempt to figure out how far you can take it before
25 you start having a true problem with NPSH pumping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water and we took one of these pumps considerably
2 below this curve we're using here and it worked fine.

3 MEMBER-AT-LARGE ABDEL-KHALIK: But my
4 question --

5 MR. WOLCOTT: I believe that's the extent
6 to which I can answer that. The other things that
7 you're asking we do not have.

8 VICE CHAIRMAN BONACA: Go ahead.

9 CHAIRMAN SHACK: How big is the scatter in
10 the data that you're averaging? I mean, if you have
11 the raw data, you could tell --

12 VICE CHAIRMAN BONACA: The reason why this
13 is an important line of questioning is again I mean
14 you have such a little margin and that becomes
15 important because we have to make sure that you don't
16 have -- for long period of time under this scenario.
17 So that's important.

18 MR. WOLCOTT: I think when we get along
19 here we're going to find that is considerable margin.
20 That's part of -- Part of the thrust of this analysis
21 was to show that if we can forego just some of the
22 unlikely aspects of the Appendix R rule that we were
23 using in the licensing basis analysis that there's
24 quite a bit of margin.

25 MEMBER-AT-LARGE ABDEL-KHALIK: But that's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 at our discretion. That is below.

2 MEMBER RAY: I think you're mixing up.
3 You want to show that there was margin. The questions
4 that you're being asked have to do with the compliance
5 of the rule. So try and stick with answering those.
6 And then in the analysis --

7 MEMBER SIEBER: And that's why I mentioned
8 the fact that really what we're talking about is an
9 exemption. You have a rule --

10 CHAIRMAN SHACK: No, he's going to meet
11 Appendix R. The question is he wants to demonstrate
12 to us that the amount of containment overpressure he
13 needs is really low if we relax a little. But he's
14 not really going to relax his Appendix R.

15 MEMBER BLEY: And I think this line of
16 questioning is really getting at how can we have
17 confidence in the margin that you're trying to --

18 CHAIRMAN SHACK: Which you're about to
19 demonstrate.

20 MR. WOLCOTT: Yes.

21 MEMBER BLEY: It really is focused on that
22 margin.

23 MEMBER RAY: There's margin in two
24 applications. One is margin in the Appendix R case
25 which they're not here seeking an exemption for as I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understand it and that's a legitimate question to ask
2 about. And then there's margin in the alternate fire
3 shutdown analysis case which you'll see back here is
4 big which they are going to talk about. But we can
5 ask about the first case if we want to and I think
6 that's where the questions are being asked go. They
7 have to do with the different pumps because that's
8 where the margin is small in the Appendix R case.

9 VICE CHAIRMAN BONACA: That's right.

10 MEMBER RAY: And so these questions are
11 fair questions to ask, but that's not what they're
12 here to present.

13 VICE CHAIRMAN BONACA: That's right. As
14 I said, that is important to keep in mind that
15 ultimately we have to deal with that or we have to
16 hear from the staff as we have tried to do by one can
17 say, "Well, it's an unlikely scenario. Therefore I
18 don't really have to meet it."

19 MEMBER MAYNARD: This is not asking for an
20 exemption. But they're claiming that they comply with
21 the rule, that provided they get containment
22 overpressure protection. They have a success path.
23 We in the past have not been wild about that
24 particular path of containment overpressure, but
25 there's nothing in the regulations that prohibit that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They also use operator action of maintaining the
2 containment overpressure there which again there's
3 nothing that prohibits that but things we've had
4 questioned.

5 So by meeting the regulations, their
6 margin is small and we're not excited about that. But
7 they're not asking for an exemption to the regulation.
8 What they're doing is showing if you take a look at
9 reality, what they consider reality, we may or may not
10 agree that it is, but there really is considerably
11 more margin than what they can take credit in lieu of
12 that.

13 MEMBER-AT-LARGE ABDEL-KHALIK: My line of
14 questioning not only addresses the fidelity of how bad
15 the situation is under Appendix R scenario. But in
16 these so-called realistic fire scenarios there are two
17 that also require containment overpressure credit and
18 the question is whether the estimated relatively
19 modest containment overpressure credits that they
20 claim they need are really as low as they should be
21 there.

22 MR. WOLCOTT: Yes, I think if we can --
23 We're more prepared to really talk about the realistic
24 analysis here. So I feel confident in saying that the
25 amount of uncertainty, if you will, that would be in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the determination of NPSH is well within the noise
2 band of the amount of margin that we show between how
3 much containment pressure you would expect to have and
4 how much containment pressure is needed.

5 MEMBER CORRADINI: So just so that -- It
6 sounds like we're still doing this. So I think to at
7 least address Said's question that you guys ought to
8 take an action item to at least get back that data so
9 that we know what it is. Because if you can't tell us
10 what it is now but you have it somewhere --

11 MEMBER BANERJEE: I see this as more like
12 a best estimate calculation but then you need to know
13 the uncertainties.

14 MEMBER MAYNARD: I really think we should
15 let them -- We're not required or not being requested
16 to make an decision today. This will come back up
17 again with the power uprate. So they're going to be
18 providing us information --

19 CHAIRMAN SHACK: I understand but --

20 MEMBER RAY: I want to insist that if you
21 come in here and make a presentation they're making
22 they have to be prepared to answer questions that are
23 being asked that apply to Appendix R compliance. I
24 mean, that's just fair. It just seems to me like the
25 questions that Said is asking go more to are you in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 compliance, can you show you're in compliance, than to
2 the acceptability of this alternate that they're here
3 to present.

4 MEMBER-AT-LARGE ABDEL-KHALIK: Well, it
5 also addresses --

6 CHAIRMAN SHACK: We've identified an issue
7 that will have to be addressed later. So I think we
8 can move on.

9 MR. LOBEL: This is Richard Lobel from the
10 staff. Let me make one more comment and of course
11 they can correct me if I'm wrong. But I believe the
12 Sulzer report you have to keep in mind it's a pump
13 vendor report and if I remember right they have, they
14 use, data that was available to them besides the
15 Browns Ferry pump data. So just looking in detail at
16 the points on a Browns Ferry pump curve from that
17 testing isn't going to be the complete story that the
18 pump vendor used to --

19 MEMBER-AT-LARGE ABDEL-KHALIK: This is a
20 very specific statement in the report that I read that
21 says, "As a basis for evaluation certified with these
22 test performance curves for both pump sets were
23 averaged produced an average performance for each pump
24 kind."

25 MR. LOBEL: Right. But when they go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 further and they develop those curves of how long you
2 can stay at a given amount of required NPSH I believe
3 that included other pump data besides Browns Ferry's
4 pumps.

5 MEMBER-AT-LARGE ABDEL-KHALIK: That makes
6 the situation --

7 MR. LOBEL: And that's what's used in the
8 actual analysis.

9 MEMBER-AT-LARGE ABDEL-KHALIK: That makes
10 the situation even worse because if they are averaging
11 over a large number of pumps and there is a large
12 variability I have no idea where your pump falls in
13 that step.

14 MEMBER RAY: And I still say that's a
15 compliance issue. As Bill said, it's going to have to
16 be revisited.

17 MR. WOLCOTT: We'll have to prepare --

18 MEMBER RAY: We have to move on.

19 MEMBER BANERJEE: Can we table that for
20 God's sake?

21 VICE CHAIRMAN BONACA: Go ahead.

22 MR. WOLCOTT: We're now on Slide 6. To do
23 an equipment availability analysis, I'll back up a
24 little bit, we determined 17 fire areas where you
25 could get more extensive prior damage just due to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 characteristics of the area and so for those 17 areas
2 we looked at all the equipment that was either located
3 in the area or got power from the area or had a cable
4 routed through the area, etc., and determined what
5 equipment would be lost or more importantly what
6 equipment would be unaffected. Then we used that
7 unaffected equipment per the emergency operating
8 instructions (EOIs) like we would do whether we had a
9 fire or not to shut down the plant. In this analysis,
10 unlike our licensing basis Appendix R analysis, we
11 took credit for having offsite power if offsite power
12 was affected by the fire. In our Appendix R licensing
13 basis we arbitrarily assumed that offsite power loss.

14 MEMBER STETKAR: When you did that, I hate
15 to belabor details, but it's important to understand
16 how we got down from a power of 39 to two. Did you
17 look at the effects of fire induced hot sources where
18 the signals could trip?

19 MR. WOLCOTT: Yes, we did and that does --

20 MEMBER STETKAR: Yes is good enough.
21 Thanks.

22 MR. WOLCOTT: Okay. Having offsite power,
23 the difference that made, it goes a little bit to your
24 question. Many of the fires in these areas do take
25 offsite power away from the safety related equipment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just because of that reason. But it does leave
2 offsite power to the balance of the plant equipment
3 because that's quite remote physically.

4 MEMBER STETKAR: I just wanted to make
5 sure that you looked at this.

6 MR. WOLCOTT: Yes, we did.

7 MEMBER STETKAR: Thanks.

8 MR. WOLCOTT: And so we used balance of
9 plant systems when they are available as we would
10 normally. So with that analysis --

11 MEMBER CORRADINI: I'm sorry. You were
12 saying and I'm hearing, but I'm not getting it. So
13 far I understand what you said about two fires need to
14 obtain overpressure credit.

15 MR. EMENS: Yes. Correct.

16 MEMBER CORRADINI: So that means there's
17 a equipment -- I'm not following that.

18 MR. WOLCOTT: You are two notches ahead of
19 me on the slide.

20 MEMBER CORRADINI: I'm sorry. Okay.

21 MR. WOLCOTT: There are 15 of these 17
22 fire areas. When you look at equipment availability,
23 there's enough equipment available that you would not
24 need containment overpressure because the temperature
25 doesn't get high enough. This would mean that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 either have more than one RHR pump or that the
2 condenser is available and that's where the heat goes
3 to the condenser. It's different things for different
4 areas.

5 But there are only two fire areas in the
6 plant where there would -- you would possibly need
7 some containment overpressure. That would be if you
8 lost everything in the room and it was hot weather and
9 the river water was warm. Then with other conditions
10 being bounding, you could need some containment
11 overpressure.

12 That addresses something else we kind of
13 touch on a little bit. These are bounding analyses,
14 but they are best estimate. They still take all the
15 assumptions to their, what I call, 95 percent non-
16 exceeding value which they've never been higher than
17 that 95 percent. So they're from plant data.

18 These two areas are both electrical board
19 rooms. They have switch gear in them and one of them
20 is on one of the units and one of them is on another
21 and each of them affects its own unit.

22 MEMBER CORRADINI: So may I just go back
23 to the rule that was originally discussed just for
24 ratification. So just to cut to -- So if you were to
25 protect these areas you would essentially protect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 parts of the train of equipment. Am I understanding
2 correctly?

3 MEMBER SIEBER: The issue would go away.

4 MEMBER CORRADINI: The issue would go
5 away. Thank you.

6 MR. WOLCOTT: If we could separate them
7 to the Appendix R rules, then in Appendix R compliance
8 the issue would go away.

9 MEMBER CORRADINI: Okay. That's fine. I
10 just want to make sure I got it. I got it.

11 MR. WOLCOTT: Okay. We're on Slide 7.
12 The two areas that could meet containment overpressure
13 are characterized by resulting in the minimum amount
14 of equipment available that you use to cool the core
15 and cool the containment and so those were used to
16 define the scenario, the limiting scenario, that would
17 be used to calculate net positive suction head and
18 containment overpressure. So they form the design
19 basis cases, if you will.

20 In those areas, we do not have -- The unit
21 that's affected doesn't have access to the condenser.
22 So all the heat goes into the containment. They do
23 not have high pressure injection. So we have to
24 depressurize the reactor with low pressure systems.

25 What they do have is emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 depressurization which is what we do initially is
2 depressurize the reactor and then we use the balance
3 of plant systems as we would if we didn't have a fire
4 as the preferential system to control and maintain
5 reactor water level. This would be the condensate
6 system and we would use the one RHR pump to cool the
7 containment and suppression pool cooling motor.

8 One of the big differences or a couple,
9 I'll kind of go over the big differences here between
10 this and the licensing basis Appendix R analysis with
11 respect to how it affects containment overpressure.
12 One of them is that because the water in these events
13 is coming from outside of the containment, whereas, in
14 the Appendix R event we just default to circulating
15 internal containment water, that the volume of water
16 inside the containment increases throughout the
17 duration of the event and so it's heat capacity
18 increases as the event continues and it keeps the
19 temperature from getting high. In other words, it
20 lowers the temperature profile.

21 The second thing it does is it increases
22 the elevation of the water above the eye of the pump
23 as the event progresses and that adds to the
24 available, directly to the available, net positive
25 suction head. So those two things give us an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 advantage in real net positive suction.

2 VICE CHAIRMAN BONACA: This is the use of
3 the CRD pump. Right?

4 MR. WOLCOTT: The CRD pump is going all
5 the time in the background because of the control rod
6 drive system.

7 VICE CHAIRMAN BONACA: In the back.

8 MR. WOLCOTT: We're using --

9 MEMBER CORRADINI: They using condensate -
10 -

11 MR. WOLCOTT: And we're using a condensate
12 system that has an automatic level controller that
13 would just control the level of this. So they combine
14 together. One of them has a level controller and the
15 other just puts water in.

16 The other thing that we changed for this
17 analysis relative to licensing basis analysis that
18 makes a big difference is a relaxed NPSH required
19 curve. We've already talked about that a little bit.
20 The licensing basis curve we use which is as some of
21 you may remember is a time stepped curve that allows
22 you to run at reduced NPSH for shorter periods of time
23 is based on a total operating life if you were to have
24 an accident situation of 8,000 hours because all of
25 this relates back to wear and tear of the pump.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 For this analysis, we shortened the
2 duration in the event that we would expect this to
3 work to be commensurate with the regulatory driven
4 duration of the event which is 72 hours and relooked
5 at how much net positive suction head we can operate
6 at and that allowed them to drop back to the Hydraulic
7 Institute's three percent head loss curve which is
8 used as a defined minimum net positive suction head.
9 So the curve we would use in the licensing basis is
10 quite a bit above the three percent curve.

11 VICE CHAIRMAN BONACA: Once around it uses
12 7,000 gpm. Right?

13 MR. WOLCOTT: We're also operating at a
14 slightly lower flow in this operating mode which is
15 also an advantage.

16 VICE CHAIRMAN BONACA: Which means that
17 the pump is --

18 MR. WOLCOTT: No. Yes. I could go
19 through that a little bit. The way -- This is all in
20 the Sulzer report. In fact, I can kind of thumbnail
21 through it. The way they approached this is they
22 start out by calculating the NPSH that you need to
23 have to have zero cavitation operation. For this
24 pump, that's quite high. That's something like 70
25 feet. And then they compute a recommended, normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operating NPSH required which does have cavitation
2 involved all the time and it is based on operating the
3 pump for 40,000 hours which for a standby pump like
4 this is an eternity. You would hard to get 40,000
5 hours on there. So that's -- for this pump at these
6 flow rates, that's something like 30 feet and then for
7 an accident where you're not going to try to -- You
8 may have to do maintenance on the pump after that.
9 For a standard design basis accident, we have kind of
10 adopted 8,000 hours of operating time as --

11 MEMBER-AT-LARGE ABDEL-KHALIK: A question
12 for you.

13 MR. WOLCOTT: Yes.

14 MEMBER-AT-LARGE ABDEL-KHALIK: The
15 cavitation free net positive suction head required
16 cable that's provided by the vendor for 12,000 gpm
17 gives a value of NPSH required of 75.3 feet. The
18 vendor cable for the same condition has a recommended
19 NPSH which corresponds to 40,000 hours of operation.
20 It's 99.8 feet. So how can the recommended NPSH
21 required be greater than the cavitation free NPSH
22 required?

23 MR. WOLCOTT: They might be of different
24 flows. I would have to study that.

25 MEMBER-AT-LARGE ABDEL-KHALIK: For the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 same flow.

2 MR. WOLCOTT: That doesn't make sense.

3 MEMBER-AT-LARGE ABDEL-KHALIK: It doesn't
4 make sense.

5 MR. WOLCOTT: Yes.

6 MEMBER-AT-LARGE ABDEL-KHALIK: So how can
7 I have confidence in this vendor report?

8 VICE CHAIRMAN BONACA: Well, I think it
9 would need to have some clarification before -- I mean
10 this question -- I have another question here that
11 goes to the report. There is a statement that says
12 that Appendix R one of NPSH for RHR pump must be 17
13 feet and 9,000 gpm, so a 70 hour event duration which
14 implies that we can go 70 hours. When I go to curve
15 two it shows that for the 35 feet which is higher if
16 you are below that, your -- hours before you lose the
17 pump is 10 hours.

18 MR. WOLCOTT: Curve two isn't the time
19 curve. Curve two is based on how much head loss you
20 experience as you reduce net positive suction head of
21 different flows and then the time dependent curve s
22 were generated mostly by Sulzer's experience about how
23 much wear you get on something as you increase
24 cavitation. So they are really two different
25 parameters we can get with that if I understood your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question.

2 VICE CHAIRMAN BONACA: Curve three shows
3 25 feet -- and the life is 10 hours for that.

4 MR. WOLCOTT: Yes. Curve three is the
5 licensing basis curve which would say that the --
6 would be based on expecting a problem free operating
7 life of 8,000 hours.

8 VICE CHAIRMAN BONACA: Yes.

9 MR. WOLCOTT: With this event included in.
10 In other words, if you've operated it in this
11 condition, because this is all -- as long as you've
12 not gone past the point where the pump won't pump,
13 then all of this is a matter of trouble free operation
14 lifetime.

15 VICE CHAIRMAN BONACA: But still you will
16 have to look at the report more in detail because it's
17 rather informational and you are telling me that in
18 fact the relaxed NPSHR there is a cavitation taking
19 place.

20 MR. WOLCOTT: It may be helpful. I don't
21 know if it would be. All of this data and curves that
22 we're looking at here are the same thing that was used
23 to establish the licensing basis. The difference here
24 is that Sulzer took the same data, the same curves,
25 and made an additional requirement for a shortened

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 lifetime which gave a lower number. The data, the
2 tests, the curves, they're all the same thing that the
3 licensing basis is based on. They're not new.

4 VICE CHAIRMAN BONACA: I'm not saying
5 that. I'm only saying that the scenarios represented
6 as you are having a response cavitation for period of
7 times. Okay?

8 MR. WOLCOTT: That's correct.

9 VICE CHAIRMAN BONACA: And if you look at
10 it, I mean, clearly you are using even in the more
11 favorite scenario, you are using equipment outside the
12 normal design mode of operation. You are doing it
13 because you have -- you need that NPSH credit.

14 MR. WOLCOTT: But --

15 VICE CHAIRMAN BONACA: That's not normal
16 and so we need to be confident that, in fact, under
17 those conditions the pumps will work and will perform
18 their functions.

19 MR. WOLCOTT: That's right, but when
20 Sulzer applies a pump normally, their normal
21 application recommended curve does have cavitation
22 associated with it. It's just an amount of cavitation
23 that won't be a problem with the pump for 40,000
24 hours, if you just operate it that way with that
25 amount of cavitation for 40,000 hours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MAYNARD: I'd like to suggest. I
2 don't think we're going to get the answers to the
3 questions that we're asking here. I do believe it's
4 an important topic and the next time we meet on it it
5 would be helpful if you had an expert, somebody
6 familiar with the reports and maybe be able to answer
7 some of these questions. I think we're going to go
8 round and round in circles in the pump.

9 VICE CHAIRMAN BONACA: I try to get
10 information on that because that's what the meeting is
11 for.

12 MEMBER BLEY: I would like to toss one
13 more in and not to get an answer now, but just a
14 couple points on the Sulzer report that had me a
15 little confused and maybe later we can clarify it
16 somehow. One is they say the original test records
17 were lost and they didn't even use them. So it wasn't
18 clear to me they were using just Browns Ferry data and
19 they didn't have the original.

20 The one that Said pointed out, the two
21 tables on cavitation free and recommended for the RHR
22 pumps show much lower head required or recommended
23 except at 12,000 gallons which it's an anomaly. So
24 something is wrong with that. Find out what's wrong
25 with it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The last, my third point, is I'd really
2 like to see something on the uncertainty in these
3 results and the scattering of the data and uncertainty
4 in these projections and times before the pump is
5 really damaged. There's none of that in here that I
6 see.

7 MR. WOLCOTT: We'll come back and look at
8 it.

9 VICE CHAIRMAN BONACA: Let's proceed.

10 MR. WOLCOTT: Okay. The final thing on
11 the slide is that in this analysis we are not
12 determining, not shutting down the drywell cooling.
13 Our EOIs don't direct us to do that. That's something
14 we're doing in that the Appendix R specific safe
15 shutdown analysis. In the EOIs we would not do that
16 and in this analysis we don't need to do that. So
17 we're --

18 VICE CHAIRMAN BONACA: Do you have
19 separate procedures for Appendix R?

20 MR. WOLCOTT: Yes, once you've determined
21 that the condition of the plant has gone beyond a
22 certain point, then you exit the EOIs. This is common
23 for BWRs. You exit the EOIs and go into a very
24 specific Appendix R safe shutdown that is different
25 depending on where the fire is and it's no longer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 symptomatic. It's just the fire is here. You do
2 this.

3 MEMBER BLEY: Can I -- Let me ask you a
4 question about that because in the Appendix R analysis
5 I'm not sure exactly how you did it. But when did you
6 assume you'd be shutting down the cooling to maintain
7 the pressure and does that align with the way the
8 procedures would shift you over to the Appendix R
9 procedures?

10 MR. WOLCOTT: In the Appendix R analysis
11 and its procedures, everything is timed. The scenario
12 is timed and what the operator has to do is timed.
13 And so he knows when he has to do it and everything is
14 assumed to be lost at time zero. I mean, at time
15 zero, the plant's SCAMs are cut off from the heat sync
16 and nothing works until you go and do the -- In that
17 analysis, you would be cutting off the cooling rather
18 quickly or in the real event. If it somehow got to
19 this one, it would be much later in time.

20 MEMBER BLEY: That's true.

21 MR. WOLCOTT: So you would already heated
22 up some probably. We don't take credit for that one.
23 This realistic analysis also assumes everything is
24 lost at time zero and we have to proceed from there.
25 Really the difference is how we proceed from there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Okay.

2 MR. WOLCOTT: So we are not terminating
3 drywell cooling.

4 The results of this analysis we'll look at
5 in the next slide. But the results of this analysis
6 are we need about a half a pound of containment
7 overpressure and the duration of containment
8 overpressure is about six hours. Again, this is with
9 the hottest river water temperature we've ever had.
10 On an average day, we would not need containment
11 overpressure because the river water temperature makes
12 a big difference.

13 There is also significant margin between
14 the containment overpressure that would be required
15 and the minimum containment pressure that would
16 result.

17 MEMBER-AT-LARGE ABDEL-KHALIK: Now you
18 provided a table comparing conditions or boundary
19 conditions used in doing this analysis vis à vis the
20 licensing basis analysis.

21 MR. WOLCOTT: Yes, we did.

22 MEMBER-AT-LARGE ABDUL-KHALIK: And there
23 are several differences obviously. The first one is
24 initial drywell pressure. The licensing value is 15.5
25 pia. The value used in this analysis is 15.9 pia.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Second, RHR heat exchanger k-value the
2 licensing basis 227 BTU per second degrees f. the
3 value used here is 241.

4 The flow rate, you're assuming that you're
5 going to minimum flow rate in this analysis with 7,000
6 gpm versus 9,400.

7 You're assuming that the horsepower has
8 correspondingly reduced and therefore you have less
9 need for heat removal from 2,000 horsepower down to
10 1,600.

11 You're also assuming an RHR pump required
12 NPSH of 17 feet. Where do all these numbers come
13 from? Do you have the data to support all these
14 changes?

15 MR. WOLCOTT: I think we talked about the
16 17 feet. Things like the flow rate, that is a symptom
17 of the mode that you're operating in. Because in the
18 Appendix R licensing basis analysis, we go straight to
19 a very specific procedure that has a stow-in to what
20 we call alternate shutdown cooling which is a
21 different path and in that procedure we are not able
22 to control flow. We control back pressure in the
23 reactor and the flow could be as high as 9,000
24 gallons.

25 However, if you're in suppression pool

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cooling where we have specific operating instructions
2 to tell you where you can operate and so you wouldn't
3 be allowed to operate 9,000 gallons.

4 MEMBER-AT-LARGE ABDUL-KHALIK: So how
5 about the heat exchanger performance? This value of
6 241 is obviously above tech spec limits.

7 MR. WOLCOTT: It's above the limit that we
8 use in the licensing basis analysis. We don't have a
9 spec tech requirement per se on that. The one that we
10 use in all of our accident analyses is based on some
11 heat exchanger tubes that got damaged once and it made
12 its way into the licensing basis and we just reserve
13 that margin. That heat exchanger got fixed then, but
14 we just -- we preserve that amount. It's common for
15 us to do that in licensing basis is preserve amounts
16 of margin as we need to use them for something else.
17 That's why we do that.

18 MEMBER-AT-LARGE ABDUL-KHALIK: I think the
19 point I'm trying to make is that there has to be a
20 justification, supporting data, for any changes in the
21 assumptions that you've made in the analysis.

22 MR. WOLCOTT: Absolutely. And those are
23 summary results of an official calculation and that
24 calculation has to document all the assumptions.

25 VICE CHAIRMAN BONACA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. WOLCOTT: And then the final point on
2 this slide is that and the way we would really do
3 this, containment or core cooling is not dependent on
4 containment overpressure and that resolves an defense-
5 in-depth issue that you would have with containment
6 overpressure in that if you're just using the one pump
7 from the suppression pool then there's a linkage
8 between containment integrity and cladding integrity
9 that would call up a common question.

10 The next slide is a plot done in similar
11 fashion to our licensing basis analysis which shows us
12 the results of containment overpressure in this
13 particular analysis. The upper blue line is the
14 suppression pool temperature. It peaks at about 208
15 degrees in about six hours.

16 The next line down which is the red line
17 is the minimum containment pressure that you would
18 expect to get considering shifting assumptions so that
19 they create minimum containment pressure. That's a
20 requirement of Reg Guide 1.82.

21 And then the most important line is the
22 lower green line. That is the containment
23 overpressure line and that is defined as the amount of
24 containment pressure that is required to make NPSH
25 available exactly meet NPSH required which in this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 case is 17 feet. So any place that that green line
2 crosses the dotted atmospheric pressure line is what
3 is defined as containment overpressure.

4 MEMBER-AT-LARGE ABDUL-KHALIK: So if you
5 were asked to put error bars on your green curve as a
6 result of either the assumptions or parameters used in
7 the analysis, uncertainties in the assumptions, or
8 parameters used in the analyses, or uncertainties in
9 the equipment performance would you be able to do
10 that?

11 MR. WOLCOTT: These are bounding analyses.
12 So the error bar would all from that green curve would
13 all hang down.

14 MEMBER-AT-LARGE ABDUL-KHALIK: Not
15 necessarily bounding.

16 MR. WOLCOTT: Every attempt is made here
17 to make these bounding analyses. It doesn't mean that
18 there's something that somebody could identify. But
19 they are intended just like a licensing basis analysis
20 to be bounding. They're just not as bounding as a
21 licensing basis analysis and they're based in -- The
22 big difference here is this is based on a different
23 scenario.

24 MEMBER RAY: Wait a minute. He's talking
25 about the green line and you guys earlier conceded I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 thought that what you read was accurate that it was
2 error.

3 MR. WOLCOTT: Yes. There's certainly an
4 uncertainty in the 17 foot number.

5 MEMBER RAY: That's right. You know, I
6 mean, just like turn the page to the next one and put
7 the -- The concern originally stems from the margin
8 between the green line and the red line on the next
9 page. But it's the same error bar.

10 MR. WOLCOTT: It would be the same error.

11 MEMBER RAY: Okay, and that's what he's
12 asking about. So let's focus on the question.

13 MEMBER MAYNARD: It may very well be
14 conservative, but I don't think you've demonstrated
15 that and especially with the discussion we had on some
16 of the other things on addressing the error bars for
17 the pump.

18 (Simultaneous conversation.)

19 MEMBER MAYNARD: Unless there's a --
20 someplace else, I think you have to tie that in.

21 MR. EMENS: I think it's not typical in
22 any accident analysis that there are parameters that
23 we pick out and make them bounding or very
24 conservative and there are others, for instances,
25 scatter on a pump head flow curve that we wouldn't and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 even a LOCA analysis try to account for it
2 specifically.

3 MEMBER MAYNARD: I think you need to be
4 able to convince us that that does bound uncertainties
5 --

6 MR. WOLCOTT: That it's bounding.

7 MEMBER BANERJEE: The thing that concerns
8 me more is actually the Appendix R calculations. What
9 is Said is saying is right. What is the error bar on
10 the green curve there? That's a compliance matter.

11 MEMBER RAY: Right. You're raising this
12 issue here, but you're inevitably exposed to this
13 question.

14 MEMBER BANERJEE: Yes. I really care
15 about that. I really care what happens to that green
16 curve and the other curve. It's all the issues you're
17 rephrasing right now.

18 MR. WOLCOTT: Our licensing basis analysis
19 needs to be a bounding analysis and this more
20 realistic one is intended to certainly be a bounding
21 analysis.

22 MEMBER BANERJEE: But more interesting is
23 what happens if you put the error bars into the green
24 curve there.

25 MR. WOLCOTT: You're looking at the next

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 page. On the next page.

2 MEMBER BANERJEE: Sorry. The next page.

3 Yes. Sorry. That's where I'm concerned.

4 MR. WOLCOTT: We still don't have any
5 error bars for you --

6 MEMBER BLEY: Now I have a question.

7 MR. WOLCOTT: Are we done with Slide 9
8 curve and ready to move to 10?

9 MEMBER BLEY: On this one, if my memory is
10 not failing me, this is not the same curve we saw some
11 months back.

12 MR. WOLCOTT: This is the exact same
13 curve.

14 MEMBER BLEY: Because I thought the margin
15 between containment pressure and required pressure
16 dropped down real close to just a couple psi.

17 MEMBER CORRADINI: Pretty close.

18 VICE CHAIRMAN BONACA: That was in the
19 early phase --

20 MEMBER BLEY: That's what you have there.

21 MR. WOLCOTT: There's a point in time
22 where they come rather close.

23 MEMBER BLEY: Okay. It's just early. I
24 thought it was later too. Yes, you do, but I thought
25 out here there was --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: If you take the
2 uncertainties in your pump behavior and you put it on
3 there, what happens?

4 MEMBER-AT-LARGE ABDUL-KHALIK: That's what
5 we would like to find out.

6 MEMBER BANERJEE: Right.

7 MEMBER CORRADINI: So you're not prepared
8 -- no. Silence is telling me you're not prepared to
9 do it right now. But what we're also telling you back
10 is you'd be prepared either sooner or later or we're
11 going to keep on talking like this.

12 MEMBER BANERJEE: I know the other
13 calculations are interesting, but this is the
14 licensing basis.

15 MR. WOLCOTT: Yes. What I'm taking away
16 from here is that we want confidence that we're
17 complying with the licensing basis curve if that's the
18 gist of the question and to make sure that these are
19 truly, this analysis is truly, a bounding analysis.
20 I think that that's the heart of what is being brought
21 up here is that --

22 MEMBER RAY: I would say you're not
23 getting any feedback yet on the page nine picture. Is
24 that right? No, we're not giving you any feedback on
25 that now, but we are on page 10.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SHACK: No, I think on page nine
2 you also need to address the answer because --

3 MEMBER RAY: It's the same issue.

4 CHAIRMAN SHACK: It's the same issue.

5 MEMBER RAY: I mean, there's more there
6 than just the issue that is so obvious on page 10.

7 MEMBER SIEBER: Right.

8 (Simultaneous conversation.)

9 MEMBER RAY: It's more though than just
10 the uncertainty on the green line. It's also is that
11 enough margin given everything else.

12 VICE CHAIRMAN BONACA: Yes.

13 MR. WOLCOTT: Any more comments on the
14 curve on page 10? That's pretty much the --

15 VICE CHAIRMAN BONACA: One thing that I
16 spent some time looking at the other curve of the
17 vendor report and looking at page nine to understand
18 what is the chance that you have to cavitation at
19 these pumps would be this type of scenario.

20 MR. WOLCOTT: Yes. These --

21 VICE CHAIRMAN BONACA: Because of the
22 relaxed mode as they call it.

23 MR. WOLCOTT: During these event we would
24 be below the licensing basis vendor curve for about 10
25 hours and then you're back on the right side of it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again. The two curves are a little bit hard to
2 compare because the licensing basis curve is a
3 function of time.

4 VICE CHAIRMAN BONACA: Yes. No, I
5 understand.

6 MR. WOLCOTT: And this realistic one is
7 not. So there is a little bit of --

8 VICE CHAIRMAN BONACA: This is ECCS pumps.

9 MR. WOLCOTT: Yes.

10 VICE CHAIRMAN BONACA: You want them run
11 for the time that you need them.

12 MR. WOLCOTT: Absolutely.

13 VICE CHAIRMAN BONACA: And so I would have
14 to feel comfortable that to believe that even if they
15 are degraded somewhat you still are going to get the
16 flow that you need and they're going to run. Already
17 for the short time LOCA, you're showing three or four
18 minutes of cavitation even with full credit for back
19 pressure.

20 MR. WOLCOTT: Correct.

21 VICE CHAIRMAN BONACA: So now you did the
22 test and I believe that and I look at the report and
23 the results statement. Still that's not the mode to
24 operate these pumps. Okay.

25 MR. WOLCOTT: Are we done?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN BONACA: Let's move onto 11.

2 MR. WOLCOTT: Okay. I'm on slide 11.

3 We've -- Going through the Committee's
4 letter on Browns Ferry Unit 1 of February 16th, the
5 Unit 1 recommendation letter, there are several issues
6 that we extracted from there and tried to call out
7 individually. One of them is the feasibility of
8 protecting a second RHR pump for the Appendix R.

9 VICE CHAIRMAN BONACA: The reason by the
10 way why we suggested this is that that's what Vermont
11 Yankee did and now the licensees are done.

12 MR. WOLCOTT: Vermont Yankee protected a
13 second service wire building.

14 VICE CHAIRMAN BONACA: That's true.

15 MR. WOLCOTT: They still are using only
16 one RHR pump.

17 VICE CHAIRMAN BONACA: But they did that.

18 MR. WOLCOTT: But they're mechanically
19 designed a little bit different.

20 VICE CHAIRMAN BONACA: Designed different.

21 MR. WOLCOTT: That's right. So we looked
22 at protecting a second RHR pump during the recovery of
23 Unit 1 before the ACRS meeting and then when it was
24 brought up as an important point in here we looked at
25 it again afterwards and the conclusion is that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would take extensive resources to try to protect a
2 second RHR pump at Browns Ferry and I have on here a
3 couple of reasons.

4 One of them is the physical location of
5 switchgear in a couple of the electrical board rooms
6 is such that in order to get Appendix R fire
7 separations a major piece of equipment would have to
8 be moved to probably a new room, a newly created room.
9 That would be a challenge there.

10 A second one is that Browns Ferry has a
11 shared electrical system which is not very common.
12 And so everything we do to try to mitigate a
13 particular event on one unit still has the constraint
14 of mitigating all the other things that designed for
15 on the other units.

16 PARTICIPANT: And mostly Units 1 and 2.
17 Right?

18 MR. WOLCOTT: Yes. So that presents an
19 obstacle in the way of flexibility to redesigning the
20 system.

21 Thirdly, when we bring in a second RHR
22 pump we're talking about bringing in considerably more
23 equipment than just that to support it. The RHR pump,
24 of course, would have valves and controls for the
25 valves that would have to be brought in. The biggest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hitter would be a diesel generator. These generators
2 are only big enough to power one RHR pump. So if we
3 bring another RHR pump into the fold we have to bring
4 a diesel generator into the fold. That machine has a
5 lot of support equipment and a lot of support
6 circuitry and a lot of controls that would have to be
7 brought into the Appendix R separation fold, not just
8 in one location, but everywhere.

9 And then we would have to bring in an
10 additional service water pump and its power supply,
11 its valves and its controls. So there would be
12 significant modifications involved, mostly having to
13 do with rerouting, wrapping, a protecting cable and
14 some of which would be physically relocating major
15 components.

16 There would also be significant changes to
17 the program because how we would go about
18 accomplishing an Appendix R safe shutdown would be
19 different if we were to have to align a power and
20 operation of that second RHR pump and that would
21 almost certainly involve some relicensing. So it
22 wasn't -- For us, it wasn't a straightforward change,
23 say, like it was at Vermont Yankee.

24 Based on having done an analysis that
25 basically shows that we're not going to actually get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there in an event that's as severe or has little
2 margin as what is shown in the licensing basis
3 analysis, it wouldn't be beneficial to try to modify
4 the plant to that degree because of the other things
5 that --

6 MEMBER-AT-LARGE ABDEL-KHALIK: You know,
7 this is an assessment that you have to do. It doesn't
8 matter what resources are needed to do this. If
9 that's what it takes to meet the requirements of the
10 law, that's what it takes to meet the requirements of
11 the law.

12 MR. WOLCOTT: Absolutely. Our position is
13 we comply with Appendix R now and with power uprate
14 already this is part of our licensing basis.
15 Containment overpressure is currently part of our
16 licensing basis for Appendix R. The power uprate
17 issue that's under review makes the number higher and
18 the duration longer. Currently in Appendix R --

19 VICE CHAIRMAN BONACA: The fact that
20 you're already -- for it doesn't do any good.

21 MR. WOLCOTT: So we comply now.
22 Otherwise, we would have to do a --

23 MEMBER-AT-LARGE ABDEL-KHALIK: I'm sorry.
24 You have not demonstrated that today. Right? Because
25 if I don't know what the uncertainties in the green

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 curve for the Appendix R scenario, I do not know
2 whether or not you meet the requirements of the law
3 even with full credit for containment overpressure.

4 MR. WOLCOTT: And that's our obligation to
5 demonstrate that. We just didn't -- That wasn't the
6 thrust of our presentation today. But we can
7 certainly focus on that.

8 MEMBER MAYNARD: Does your current
9 licensing basis also include the required operator
10 action to secure RHR or is that new for the power
11 uprate?

12 MR. WOLCOTT: It's newly discovered. We
13 would have to do it in the current licensing basis and
14 we just didn't know it. So it was discovered as part
15 of the power uprate review and so we handled that as
16 a corrective action issue and had to implement that in
17 plant now. But it wasn't at the time because we
18 didn't realize it.

19 MEMBER BLEY: Just a question on history.
20 In the recent report you focused on, you said
21 historically you had to take credit for containment
22 pressure. Is that even before the first power uprate?

23 MR. WOLCOTT: Yes.

24 MEMBER BLEY: So all along.

25 VICE CHAIRMAN BONACA: It's tied to Sulzer

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scenario. Right?

2 MR. WOLCOTT: No, in Appendix R,
3 containment overpressure credit dates back to when
4 Appendix R was originally granted which would have
5 been the late '80s.

6 MR. EMENS: 1988 is when it was approved.

7 VICE CHAIRMAN BONACA: And the report said
8 it was introduced for the first time --

9 MR. WOLCOTT: For a LOCA.

10 VICE CHAIRMAN BONACA: Yes. For a LOCA.

11 MR. WOLCOTT: The reason that is because
12 the suction strain ratio had to do with plugging the
13 strainers and that had a big effect on NPSH. In an
14 Appendix R event, there's plenty of strainer to go
15 around. That's really not the limiting thing.

16 VICE CHAIRMAN BONACA: No, but I mean as
17 I was reading the report, there is an implication that
18 since you already got some credit for it you were
19 authorized and you were entitled to additional credit.
20 But there is a limit to how much credit you can take
21 anyway. So it says to me that because you already
22 have credit you have less credit to ask for.

23 MR. WOLCOTT: Something like that.

24 VICE CHAIRMAN BONACA: Yes. I understand
25 that there is a precedent there so far as that, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 credit. The issue raised to the Commission has been
2 purely the one of what is the criteria for
3 acceptability. How far can we go? And one of the
4 concerns that we have is that there is no limit and
5 it's left to the judgment of the applicant and the
6 judgment of the reviewer to determine case by case
7 whether or not they're going to grant it. That's not
8 a way to deal with what pressure credit in our
9 judgment at least.

10 So anyway let's proceed.

11 MR. WOLCOTT: I believe I'm on Slide 12.

12 Another specific issue that was brought up
13 was the consideration of external events in fire risk
14 evaluations. I think someone raised that question
15 earlier in the meeting here.

16 VICE CHAIRMAN BONACA: But that's what we
17 were asking for in the letter and the reason is that
18 the representation that you give is for 105 percent
19 power uprate was a quantification statement being
20 brought up and gave an impression that, in fact, there
21 was a a PRA analysis all including internal initiators
22 and we said that fire induced by seismic events may be
23 significant. Why don't you consider those?

24 MR. WOLCOTT: Yes, that evaluation was
25 done by the staff and TVA doesn't have a Browns Ferry

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fire PRA. So those -- The way we've gone about it,
2 the utility has gone about quantifying risk or -- I
3 shouldn't have said the word "quantifying,"
4 characterizing risk and looking at the amount of
5 margin we have is by a deterministic analysis. That's
6 the way we chose to do it and in that analysis we're
7 assuming that the fire occurs in each area. So it
8 kind of sets aside the need to try to figure out what
9 caused the fire. We're assuming a fire occurs in each
10 area and deal with it, show how we would deal with it.

11 So the risk analysis that was discussed in
12 our February 1, 2007 meeting was a result of the
13 staff's risk analysis. And they can address that
14 further, but that's kind of how --

15 That's everything that we've come prepared
16 to talk about having to do with Appendix R. So I'll
17 just summarize Appendix R and then we'll move onto one
18 more issue that was not an Appendix R issue.

19 For the Appendix R event, what we see and
20 I think we've made these points, that our licensing
21 basis analysis does comply with Appendix R and it
22 demonstrates a successful shutdown path.

23 VICE CHAIRMAN BONACA: If you obtain the
24 credit you're asking for.

25 MR. WOLCOTT: Yes. I mean, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 demonstrates a path. We may not be able to use it if
2 we don't obtain the credit. But it does -- We feel
3 like it demonstrates the path and I think our concern
4 -- your concern with it is the amount of margin.

5 We think we've shown that the magnitude
6 and duration of containment overpressure that shows up
7 in the licensing basis analysis is driven by Appendix
8 R rule based assumptions and not necessarily what
9 you'd actually expect to occur and that we have a fire
10 hazards analysis. When you use a fire hazards
11 analysis specific to the plant it shows a reduced or
12 no dependency on containment overpressure depending on
13 what area of the plant you're talking about.

14 I will be leaving Appendix R issue at this
15 point and picking up one additional issue and that's
16 bias and uncertainty in the realistic LOCA analysis.

17 Dr. Bonaca, you said a few things right at the
18 beginning of the meeting that shed a little bit more
19 light than what we had understood before a little bit
20 more. So we'll try to understand what the issue is as
21 best we can and address it.

22 We presented in the ACRS meeting on Unit
23 1 a series of analyses that demonstrated how much the
24 result changes as we vary input assumptions from
25 realistic assumptions to licensing basis assumptions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to worst case assumptions and where those realistic
2 analyses came from for a LOCA. This isn't for a fire
3 now but for a LOCA. Where they came from is they were
4 done in order to define the success paths that we
5 would going to use to build a PRA model so that we
6 could quantify the risk of COP for all the events
7 except a fire and our bottom line in that, in what we
8 submitted for our license amendment, was PRA risk
9 numbers and these realistic analyses that we showed
10 were made for the purposes of building that COP part
11 of that model.

12 They were in and of themselves intended to
13 be still bounding analysis. They just weren't as
14 bounding as the licensing basis analysis. For
15 instances, instead of using tech spec values, if we
16 are better than that 95 percent of the time, we used
17 our 95 percent non-exceedance value. That was an
18 important thing, say, in river water temperature
19 because we never have come close to what the tech spec
20 limit is. So that makes a big difference whether we
21 use that or we use this 95 percent value.

22 And in the case of when we actually
23 started using these in the PRA model, some of these
24 parameters like river water temperature had a
25 probability distribution associated with them rather

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 than a bounding value. If they had a distribution, we
2 used the distribution and if we couldn't determine
3 one, we used a bounding value that just might not have
4 been as bounding as the license basis.

5 And we used the same analysis methods that
6 we would have used in the licensing basis. So in that
7 sense, we called them realistic analysis, but they
8 were still bounding analyses. They weren't what I
9 guess everybody else calls best estimate. So we
10 intended them to be bounding analysis and as such that
11 was our expectation that they give bounding results.
12 And so from that standpoint, it was our intention to
13 account for bias uncertainty there by biasing them to
14 the uncertainty.

15 VICE CHAIRMAN BONACA: What happened --
16 Of course, now time has gone by, but what happened was
17 that we received a presentation and you've made the
18 point that the requirements for COP most likely the
19 long-term LOCAs is caused by the expressed concern
20 imposed the LOCA requirements and we said that makes
21 sense. We would like to see some evaluation of that
22 and one possibility would be a best estimate analysis
23 done by some means, in fact, which eliminates the
24 concern that we had earlier to the most directly your
25 point. That's a success path.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And you came back or some engineer for you
2 came back and gave us a presentation and I remember
3 that that was a limited analysis that wasn't complete
4 and not with uncertainties. So as we said, "When you
5 come back next year, show us some" -- But the path is
6 still there. As I understand, the BWR, all this
7 group, has been developing, in fact, a methodology to
8 provide for that evaluation.

9 MR. WOLCOTT: This is very much like what
10 we are using here. It has a few more elements to it,
11 added to it, but it's fundamentally like what we did
12 here.

13 VICE CHAIRMAN BONACA: Can you use that?

14 MR. WOLCOTT: It's more of a best estimate
15 than this is. This is more bounded.

16 CHAIRMAN SHACK: But here when you're
17 using the probability distributions I assume you are
18 doing calculations, sampling calculations, and looking
19 at distribution results and then giving us the 95
20 percentile of those.

21 MR. WOLCOTT: Yes, but --

22 CHAIRMAN SHACK: I mean, it's certainly
23 fair to use the 95 percent for some variables. It's
24 fair to use probability distribution. But you do have
25 to sample and come back with a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Off the record comments.)

2 And we realize it's a conservatively
3 biased 95th but it's the best you can do because you
4 don't understand all the variables.

5 MR. WOLCOTT: For the long-term LOCA in
6 the end or in our actual submittals, the conclusion
7 that the need for containment overpressure in a LOCA
8 is driven by licensing basis assumptions. It hinges
9 strictly on single failure. If we eliminate a
10 particular single failure in the RHR system, we don't
11 need containment overpressure and that's by a bounding
12 licensing basis analysis because if it got too large -
13 -

14 MEMBER BANERJEE: What's the single
15 failure you would have to eliminate?

16 MR. WOLCOTT: There are a number of them.
17 There's one that you worry about that gets us down to
18 one RHR pump.

19 MEMBER CORRADINI: Which one is that?
20 A battery failure.

21 MR. WOLCOTT: Yes, it's a battery failure.
22 That's logic on one side.

23 MEMBER BANERJEE: Logic or the battery
24 actually?

25 MR. WOLCOTT: It's a battery failure, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it affects RHR because it affects logic. That, of
2 course, takes no credit from getting around that by
3 just operating the thing by hand for which we would
4 never take credit for in the licensing basis analysis.
5 So it's a battery failure because you have to -- logic
6 power and several different things.

7 MEMBER BANERJEE: And you couldn't guard
8 against that in some way, some redundancy?

9 MR. WOLCOTT: That's a LOCA now.

10 MEMBER CORRADINI: Yes, I was just going
11 to say. That's a LOCA. That's not an Appendix R.

12 MR. WOLCOTT: It's a random thing.

13 And the other thing, it's also we have to
14 remember -- I don't have the LOCA curve for you here.
15 But in the LOCA analysis the only pump that needs
16 containment overpressure is the core spray pump. The
17 RHR pumps do not need it.

18 VICE CHAIRMAN BONACA: Yes.

19 MR. WOLCOTT: And the way we're doing our
20 licensing basis, we default to use the core spray long
21 term to cool the core and the RHR pump to cool the
22 suppression pool, but you don't have to do it that
23 way. But that's our licensing basis. That's what we
24 stick to.

25 CHAIRMAN SHACK: I want to go back to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 owner's group now. It's one thing to go and use the
2 distribution of values and then look at the best
3 estimate calculation. It's another thing to do it
4 with single failures. We're in a different universe
5 again.

6 MR. WOLCOTT: I understand. But that's --
7 But my point was the way it turns -- I think the same
8 thing was true for Vermont Yankee that there is one
9 particular single failure that drives the LOCA to need
10 containment overpressure and that's using bounding
11 licensing basis analyses so there's not a lot to
12 figure out there. You either assume that or you
13 don't. That's kind of what we boiled it down to.

14 And all these other things were much more
15 complicated but were really meant -- were really done
16 and presented to show how we built the PRA.

17 VICE CHAIRMAN BONACA: Let me ask the
18 question then. Will at some point in the future you
19 bring up an analysis like this, a bounding analysis,
20 without the conservative to show that you got a fair
21 COP or the requirement for COP is driven by the
22 conservatism of a LOCA? I haven't seen this realistic
23 LOCA.

24 MR. WOLCOTT: We submitted the analysis
25 that shows that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN BONACA: When?

2 MR. WOLCOTT: August of 2006, I believe
3 it's in there, that shows that if you don't have one
4 single failure you don't need COP if that's what
5 you're saying.

6 CHAIRMAN SHACK: Are you going to give us
7 an analysis with single failures but using these
8 assumptions to show that if you can't do without COP
9 you can greatly reduce the amount?

10 VICE CHAIRMAN BONACA: Yes. We don't want
11 to have a different analysis. Otherwise, we want to
12 have the same analysis if you take -- that the
13 requirements for COP is driven by the conservatism
14 with the LOCA model which means it has to be the same
15 assumptions of single failure LOCA which would simply
16 realizes some of the conservatisms if not all of them
17 and that would support your claim and we can look at
18 the results of it.

19 CHAIRMAN SHACK: Or you can submit the
20 same failure one, too? We can look at that. But this
21 one I think you need to submit also because again I
22 think most of the discussions have not been prone to
23 the single failure but have been doing best estimate
24 calculations like the way we do LOCA in a design basis
25 best estimate where there is still single failure but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you've done the thermal hydraulics under a best
2 estimate or a conservatively biased best estimate.

3 MR. WOLCOTT: I believe we can lay that
4 out several different ways.

5 VICE CHAIRMAN BONACA: Are there any
6 additional questions? I think this was a fruitful
7 meeting. I think that there was communication and I
8 think we have some paths laid out. I think you
9 understand what our concerns are and maybe we need to
10 get more dipping into the report that we got from your
11 vendor. I think you have some assignments there, too.
12 And I think that I don't know what the process is
13 going to be. This is an informal meeting and we have
14 no commitment your information before the subcommittee
15 meeting scheduled for November. But we will caucus
16 and let you know.

17 MR. WOLCOTT: We really appreciate your
18 time and appreciate the feedback. It was good
19 communication. I did try to capture notes. I
20 understand there are a lot of concern over the Sulzer
21 pump report, a lot of questions. I captured those and
22 I guess most importantly is how that relates to the
23 licensing basis and potential uncertainties in the
24 margin. We will be prepared to address those things
25 when we come back to the subcommittee meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN BONACA: Okay.

2 MEMBER MAYNARD: Mario, while it's
3 important to hear from the Licensee, I think an
4 important aspect for our next meeting for when the
5 licensing actually comes is going to be what the staff
6 says and I'm sure they've been listening and they
7 understand. It's going to be important to hear what
8 their basis for acceptance is if they're recommending
9 this up.

10 VICE CHAIRMAN BONACA: And we will see
11 some kind of draft SER on this issue but it's not
12 really different from what we have before it. They
13 have to understand that. I think they are working,
14 the staff, to develop this kind of criterion that we
15 mentioned to the Commission we should have and --
16 agreed to. So they are not going to review it and
17 then take the licensee through different hoops. If
18 the staff approves, then we --

19 MR. ROLAND (phonetic): Bill Roland,
20 Division Director of DSS. Mario, you talked about
21 different criteria.

22 VICE CHAIRMAN BONACA: Yes.

23 MR. ROLAND: As you know, the Commission
24 had an opportunity after the ACRS meeting to ask the
25 staff to evaluate or pose different criteria and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Commission declined that opportunity. Basically, the
2 Commission as a result of the ACRS committee meeting
3 told the staff to continue to try to adjust these
4 issues with the ACRS, with the Committee, and where
5 appropriate or we deem appropriate we would send a
6 Commission paper to get these issues resolved once and
7 for all and that's based on our judgment. So as we go
8 through this whole process, that's one thing we've
9 considered.

10 VICE CHAIRMAN BONACA: Okay.

11 MR. ROLAND: And as you might know, we
12 have almost done a white paper, a new kind of white
13 paper, that DSS has prepared on containment
14 overpressure that provides really a lot of background
15 on this whole issue. So when it's appropriate, we're
16 going to share that with the Committee.

17 VICE CHAIRMAN BONACA: Thank you. With
18 that, I would like to turn this to you, Mr. Chairman.

19 CHAIRMAN SHACK: Okay. Time to break for
20 lunch. We will return at 2:15 p.m. Off the record.

21 (Whereupon, at 1:06 p.m., the above-
22 entitled matter recessed to reconvene at 2:15 p.m. the
23 same day.)

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

CERTIFICATE


This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Toby Walter
Official Reporter
Neal R. Gross & Co., Inc.



Status of Resolution of GI-199

Marty Stutzke, Division of Risk Analysis
Jon Ake, Division of Engineering
Office of Nuclear Regulatory Research

July 10, 2008

1



Issue Summary

- The staff has identified that the estimated seismic hazard levels at some current CEUS operating sites might be higher than seismic hazard values used in design and previous evaluations.
 - Review of updates to seismic source and ground motion models provided by ESP applicants.
 - Review of recent USGS seismic hazard estimates.
 - Comparison to seismic hazard estimates developed under the IPEEE program.


2

Background

- Concern identified May 2005 in a memo from NRR to RES.
 - NRR concluded that the seismic designs of operating plants in CEUS still provided an adequate level of protection.
- GI-199, "Implications Of Updated Probabilistic Seismic Hazard Estimates In Central And Eastern United States On Existing Plants," was opened in June 2005.
- In February 2008, a screening panel concluded that GI-199 should proceed to the safety and risk assessment phase.
- Public meeting held on February 6, 2008.
- NRC and EPRI are finalizing an MOU to share seismic research information.



5

MD 6.4 Screening Criteria



6

Approximate SCDF



$$SCDF = \int_0^{\infty} H(a) \left[\frac{dP_f(a)}{da} \right] da = K_I \exp \left[-K_H \ln(C_{50}) + \frac{1}{2} K_H^2 \beta_C^2 \right]$$

9

Path Forward

- Complete the safety/risk assessment
- Hold public meeting on safety/risk assessment stage progress
- Convene the Safety/Risk Assessment Panel
- Draft memo and report for Safety/Risk Assessment Panel

10



**TENNESSEE VALLEY AUTHORITY
BROWNS FERRY NUCLEAR PLANT**

**POWER UPRATE
ACRS**

***CONTAINMENT OVERPRESSURE
(COP)***

**Rockville, Maryland
July 10, 2008**



Introduction

- COP Part of BFN Current Licensing Basis for Appendix R and LOCA
- EPU Results in Additional COP need in Licensing Basis Analysis
- ACRS Concerns from Unit 1 105% Review
 - Magnitude and duration of Appendix R event
 - Feasibility of protecting second RHR pump
 - Consider external initiators when using risk-informed arguments for the Appendix R COP credit
 - Realistic long-term LOCA analysis needs to be supported by more defensible sensitivity analyses



Introduction

- Actions Taken to Address ACRS Concerns on Appendix R COP
 - July 2007 meeting with NRC Staff
 - Fire area analysis undertaken to compare COP needs for realistic fire versus Appendix R analysis
 - Deterministic analysis to provide risk insight
 - Submitted November 15, 2007
 - Followed-up with NPSH analysis for limiting cases
 - Submitted June 12, 2008

Alternate Fire Shutdown Analysis



- Appendix R Rule Based Fire
 - Prescribed Appendix R fire damage
 - Loss of all equipment not meeting generic separation criteria
 - Fire damage not based on analysis
 - Fire damage overly conservative for many areas of the plant

Alternate Fire Shutdown Analysis

- Fire Hazards Analysis
 - Supplement to Appendix R
 - Fire damage by analysis versus prescribed fire damage
 - Screen based on fire protection parameters
 - Combustible loading
 - Volume of fire area
 - Detection/Suppression
 - Ignition sources
 - 22/39 fire areas screened out
 - Fire limited to ignition source
 - No wide spread fire damage
 - 17 fire areas screen in
 - Evaluated for equipment availability

Alternate Fire Shutdown Analysis



- **Equipment Availability Analysis**
 - All equipment in fire area assumed lost in 17 fire areas
 - Unaffected equipment used per EOs
 - Offsite power credited where unaffected
 - BOP systems available in many areas
 - 15/17 areas do not need COP
 - Sufficient equipment available to limit pool temperature
 - Only 2 fire areas need some COP
 - Electrical Board Rooms

Alternate Fire Shutdown Analysis



- NPSH Analysis – Limiting Fire Areas
 - Minimum equipment
 - Emergency depressurization
 - Reactor water level maintained with BOP
 - One RHR pump for containment cooling

 - Pool water volume increased during event
 - Peak pool temperature lower
 - Pool level/elevation head increase

 - Relaxed NPSHr based on revised vendor report
 - Based on shorter operating time consideration

 - Termination of drywell coolers not required

Alternate Fire Shutdown Analysis




- NPSH RESULTS
 - Significant reduction in COP required
 - 1/2 psi COP
 - 6 hour duration


 - Significant COP margin
 - Minimum 8 psi

 - Core cooling not dependent on COP
 - Core cooling by BOP Systems
 - Defense-In-Depth consideration

COP Available and COP Required Alternate Fire Hazards Analysis



COP Available and COP Required Licensing Basis Appendix R





Specific ACRS Recommendations

- Feasibility of Second RHR Pump for Appendix R
 - Extensive resources
 - Physical location of switchgear
 - Shared electrical system
 - Support equipment
 - Valves/controls
 - Diesel generator/controls
 - RHRSW pump/valves
 - Significant modifications
 - Significant program and licensing changes
 - Minimal safety benefit
 - Demonstrated by fire hazards analysis

Specific ACRS Recommendations



- Consideration of External Events in Fire Risk Evaluations
 - Fire risk insights from deterministic fire hazards analysis
 - Not a PRA analysis
 - Bounding fire is assumed



Appendix R Conclusions

- Licensing Basis Analysis Complies With Appendix R and Demonstrates a Success Path
- COP Magnitude and Duration for Appendix R Driven by Rule Based Assumptions
- Fire Hazards Analysis Shows Reduced or No Dependency on COP

Additional ACRS Issue

- **Bias and Uncertainty in Realistic LOCA**
 - Realistic LOCA used to build PRA model for COP
 - Use of 95% non-exceedance values
 - Use of probability distributions
 - Use of conservative licensing basis methods
 - Realistic NPSH analyses biased conservatively

Closing

- Concluding Remarks



Seismic Research Program 2008-2011

ACRS Meeting
July 2008

1






Program Overview



- Publicly available research plan
- Targeted on regulatory needs
 - Developed with NRO, NRR & NMSS
 - Efforts in many research areas to be coordinated with industry
- Developed to both push forward the science and the level of regulatory stability
- Incorporation of performance-based approaches

2

- Short- and long-term research topics
- Systematic & integrated
 - Moves from topic-by-topic approach to integrated research
 - Focused on issues with highest uncertainties
 - Risk informed plan that fills in gaps
- Cost effective
 - Piggy backing and partnering
 - Universities
 - Using “next-generation” approaches
- Highest Quality









Workshops and “Next Generation” approaches

- NRC initiated early seismic hazard work
- Seismic research moving from the development of individual tools and methods
 - Different databases, gray literature, proprietary reports, proprietary software
- The now mature field is moving to integration through workshops, working groups and “next generation” approaches
 - Common databases & inputs, community consensus, documentation of thought processes, outliers & uncertainties better understood



9



Workshops and “Next Generation” approaches

- Consistent, complete, and agreed upon data sets and information
- Key experts in the research area involved
- “Next Generation” implies fundamental redevelopment of technical tools or approaches
- Both best estimates & estimates of uncertainties



10



Before

NGA-West

After



- Went from ad hoc relationship development to unified approach
- Mutually agreed upon databases, technical bases & assumptions
- Epistemic uncertainties reduced and characterized
- Broad community consensus (removed points of contention) ¹³

- Follows up on original NGA project to address
- Approach
 - Standard agreed upon assumptions
 - Standard and complete database
 - Development program undertaken to scope project and bring in multiple agencies
 - Cooperative agreement with multiple agencies (DOE, NEHRP, EPRI)
 - USGS in-kind participation in development project
- Currently doing preliminary work
 - Technical Basis for assumptions
 - Development of earthquake record database



SSHAC Guidelines

- “Recommendations for PSHA: Guidance on Uncertainty and Use of Experts” NUREG/CR-6372 by Senior Seismic Hazard Analysis Committee
- General framework work well, but limited details
- Need recommendations on how to use and to update
- Much has been learned in trying to apply SSHAC
 - Yucca Mountain (two level 4s – seismic and volcano)
 - PEGASOS (level 4)

15




SSHAC Guidelines


- New project created to develop practical recommendations for application of the SSHAC guidelines
 - Lessons learned
 - How and when to update
 - Understanding and characterizing uncertainties (epistemic and aleatory)
- Will develop a NUREG document to accompany the SSHAC guidelines

16

CEUS Seismic Source Characterization project for Nuclear Facilities

- Major study with participation from NRC, DOE, EPRI, USGS, and other US specialists
- NRC SSHAC guidelines level-3 study
- 3 year project starting summer 2008
- Project to develop a seismic source database for the CEUS to be used as a baseline for all PSHA
- NPP applications will still study local sources
- Coordinating a CEUS SSC "International Observers Program" to allow international specialists to observe the US project firsthand





- M_{max} is largest magnitude for a source
- Issue for area sources in CEUS for long return periods
- Limited technical basis due to lack of systematic, integrated evaluation of existing models and new data
- Follows “best practices” for seismic workshops
 - Sensitivity study
 - Foundation document compiled & sent to participants before workshop for review. Also downloadable at USGS.
 - All key researchers sponsored, but open to anyone
- Results incorporated into USGS database

New US NRC Projects to Assess Seismic Hazard in CEUS

Source Characterization →

Central and Eastern US Seismic Source Characterization project for Nuclear Facilities (CEUS SSC)


Ground motion prediction equations →

Next Generation Attenuation Relationships for the Central and Eastern (NGA-East)

Framework for large PSHA studies →

Recommendations for Application of the SSHAC Guidelines

3.1 Random Vibration Theory
3.2 Site response methods



Active Projects

- Multiple methods accepted in NUREG 6728

- Theoretical framework but few details
- Only recently used
- Implementation differs between practitioners
- Focus on better understanding


- Multiple modeling tools currently in use


- Non-linear, SHAKE, and RVT methods
- Comparison of methods
- Developing public RVT software with PEER

Site SBIS (NRMS) compared to CSDRS

GRMS is based on site characterization and it is determined from detailed seismic hazard studies

CSDRS is based on engineering design of a plant





U.S. NRC
UNITED STATES NUCLEAR REGULATORY COMMISSION
Protecting People and the Environment

TSUNAMI HAZARD ZONE

IN CASE OF EARTHQUAKE, GO TO HIGH GROUND OR INLAND

Tsunami

- Continued tsunami source development with USGS
 - Phase 1 report being used by NRC staff and industry
 - Phase 2 underway
- Continued development of modeling capabilities with USGS and NOAA

24



Summary

- Seismic Research Plan publicly available
- Key drivers are both the advancement of state of practice AND greater regulatory stability
- New projects focused on seismic hazard in CEUS
- Integrated risk-informed approach
- Both short- and long-term planning
- Focus on consensus products
 - Community-wide consensus
 - Multiple stakeholders & sponsors



Impact of the Niigataken Chuetsu-oki Earthquake to the Kashiwazaki Nuclear Power Plant


Yong Li
Senior Geophysicist
NRO/DSER/RGS2
July 10, 2008

Agenda

- Niigataken Chuetsu-oki Earthquake and Kashiwazaki-Kariwa (KK) nuclear power plant
- Impact of the earthquake vibration to the Nuclear Power Plant (NPP)
- Major findings from post-earthquake activities at the plant site





A Bird's View of KK Site from South



5

Earthquake Location relative to KK plant



6

Design Peak Ground Acceleration vs. Observed (gal – cm/sec²)

Unit	North - South direction (design / measured)	East - West direction (design / measured)	Vertical direction (design / measured)
1	274 / 311	273 / 680	235 / 408
2	167 / 304	167 / 606	235 / 282
3	192 / 308	193 / 384	235 / 311
4	193 / 310	194 / 492	235 / 337
5	249 / 277	254 / 442	235 / 205
6	263 / 271	263 / 322	235 / 488
7	263 / 267	263 / 356	235 / 355

Divide gal by 1000 to approximate g-value




9

Common Cause Failures and Potential Vulnerabilities


- Settlement and soil failures
 - ✓ Breakages of underground fire protection piping joints
 - ✓ Deformations and cracks in the ducts connected to the main stacks
 - ✓ Deformations and fire on the Unit 3 house transformer secondary bus

- Potential for adverse interaction with safety related equipment
 - ✓ Water leakage through building penetrations
 - ✓ Water leakage through leaky seals
 - ✓ Damage to thermal insulator of SLC piping



10

Factors to Amplify Seismic Motions



From TEPCO 6/12/2008 presentation



13

Ongoing Activities at the KK Plant

- Non-destructive testing for hidden damages
- Assessment of new ground motion for reevaluation of the plant safety
- Evaluation of the plant design upgrading



14



Interim Staff Guidance on Seismic Issues associated with High Frequency Ground Motion


Dr. Manas Chakravorty
Structural Engineering Branch 2
July 10, 2008



Background

- Updated ground motion models for earthquakes in the CEUS.
- ESP reviews identified that site-specific ground motion may not be enveloped by certified design response spectra for some sites

CSDRS & GMRS COMPARISON





Resolution

- The updated SRP Section 3.7.1 “Seismic Design Parameters” provided the framework
- Issued ISG for the implementation of the SRP framework



Issues addressed in the ISG

- Definitions of various ground motions
- Guidance on the use of the different ground motions and seismic instrumentation
- Staff position on the use of limited dynamic testing data



Issues addressed in the ISG

- Guidance on evaluation of HF exceedance
 - Inclusion of incoherency in structural seismic response analysis
 - Screening of HF sensitive SSC's
 - Evaluation of screened components



Summary

- SRP 3.7 & ISG provides a high frequency review framework
- AP1000 Topical report has been submitted and currently under staff review
- ESBWR has used CSDRS that envelop both soil and rock sites