

Official Transcript of Proceedings  
NUCLEAR REGULATORY COMMISSION

Title: 561st Meeting of the Advisory Committee  
on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, April 3, 2009

Work Order No.: NRC-2757

Pages 1-107

**NEAL R. GROSS AND CO., INC.**  
Court Reporters and Transcribers  
1323 Rhode Island Avenue, N.W.  
Washington, D.C. 20005  
(202) 234-4433

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

561<sup>st</sup> MEETING

+ + + + +

FRIDAY,

APRIL 3, 2009

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear  
Regulatory Commission, Two White Flint North,  
Room T2B3, 11545 Rockville Pike, Rockville, Maryland,  
at 8:30 a.m., Mario V. Bonaca, Chairman, presiding.

COMMITTEE MEMBERS PRESENT:

MARIO V. BONACA	Chairman
SAID ABDEL-KHALIK	Vice Chairman
J. SAM ARMIJO	Member-at-Large
GEORGE E. APOSTOLAKIS	Member
SANJOY BANERJEE	Member
DENNIS C. BLEY	Member
CHARLES H. BROWN, JR.	Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MICHAEL CORRADINI Member

2

3 COMMITTEE MEMBERS PRESENT: (cont'd)

4 OTTO L. MAYNARD Member

5 HAROLD B. RAY Member

6 MICHAEL T. RYAN Member

7 WILLIAM J. SHACK Member

8 JOHN D. SIEBER Member

9 JOHN W. STETKAR Member

10

11 NRC STAFF PRESENT:

12 DONALD DUBE

13 CHARLES ADER

14 HOSSEIN HAMZEHEE

15

16 ALSO PRESENT:

17 DOUG TRUE

18 BIFF BRADLEY

19 STANLEY LEVINSON

20

21

22

23

24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

TABLE OF CONTENTS

AGENDA ITEM	PAGE
Opening Remarks and Objectives	4
Presentation: Implementation of Risk Metrics for New LWR Risk-Informed Applications	5
NEI Presentation	55
General Discussion	104

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

P-R-O-C-E-E-D-I-N-G-S

(8:28 a.m.)

CHAIRMAN BONACA: Good morning. The meeting will now come to order.

This is the second day of the 561st meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following: risk metrics for new lightwater reactor risk-informed applications, future ACRS activities, a report of the Planning and Procedures Subcommittee, reconciliation of ACRS comments and recommendations, subcommittee reports, preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Tanny Santos is the Designated Federal Official for the initial portion of the meeting.

Some members of NEI and NRC staff are on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the phone bridge line to listen to the discussion of  
2 risk metrics for new lightwater reactor risk-informed  
3 applications. To preclude interruption of the  
4 meeting, the phone will be placed in a listening-in  
5 mode during the presentations and Committee  
6 discussions.

7 We have received no written comments or  
8 requests for time to make oral statements from  
9 members of the public regarding today's sessions. A  
10 transcript of a portion of the meeting is being kept,  
11 and it is requested that speakers use one of the  
12 microphones, identify themselves, and speak with  
13 sufficient clarity and volume so that they can be  
14 readily heard.

15 So the first item on our agenda is the  
16 risk metrics for new lightwater reactor risk-informed  
17 applications, and Professor Apostolakis will take us  
18 through the presentation.

19 MEMBER APOSTOLAKIS: Thank you, Mr.  
20 Chairman.

21 As some members probably remember, more  
22 than 10 years ago the staff worked closely with us on  
23 what became Regulatory Guide 1.174, which laid the  
24 foundation for risk-informing the regulations. It

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 identified five principles that every change or  
2 request for change in the licensing basis had to  
3 satisfy, and also gave numerical values to the change  
4 and the core damage frequency and the large early  
5 release frequency that would serve as targets in  
6 upper bound -- in risk-informed decisions.

7           Since then, there have been many  
8 applications, always invoking the regulatory guide  
9 and its guidance. And until recently when we started  
10 receiving risk assessments for new reactors  
11 everything was fine and the numbers were more or less  
12 acceptable. But when these new core damage  
13 frequencies started coming in, we realized -- and the  
14 staff, of course, realized immediately that the rules  
15 of the game probably have changed.

16           We are now talking about core damage  
17 frequencies that are -- may be one or two or three  
18 orders of magnitude below the CDFs that we had in  
19 mind when the guide was developed for subsequent  
20 applications.

21           So the question is now: does the way --  
22 the current way of doing business in a risk-informed  
23 way still apply when somebody reports a core damage  
24 frequency, say, on the order of  $10^{-7}$ ? And the Office

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of New Reactors has of course identified this as an  
2 issue that needs some investigation, and this is the  
3 subject of today's meeting.

4 The title is -- of the presentation,  
5 "Implementation of Risk Metrics for New Light-Water  
6 Reactor Risk-Informed Applications." We will have a  
7 presentation from Mr. Donald Dube of the Office of  
8 New Reactors, and then Mr. Bradley and Mr. True of  
9 the Nuclear Energy Institute have requested time to  
10 make some comments.

11 So we are back to 1997, as some of you  
12 remember, where we are going to have debates what is  
13 appropriate, what is not appropriate, how to approach  
14 it. And this was an exciting time, and I am sure it  
15 will be exciting again.

16 So without further ado, Mr. Dube.

17 MR. DUBE: Thank you, Professor  
18 Apostolakis. Well said to -- in terms of an  
19 introduction. And, Dr. Bonaca, members of the ACRS,  
20 the purpose is to brief the ACRS regarding the  
21 implementation of risk metrics for new LWRs,  
22 specifically risk-informed application, and look at  
23 potential paths forward.

24 We are not looking at a letter at this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 time. I envision that this is going to be one of  
2 several meetings, and we are engaging stakeholders in  
3 public meetings as well. And I should also say at  
4 this point the staff does not have a position on  
5 which of several options to go forward to sort of the  
6 exploratory stage if you will.

7 We will discuss briefly the near and  
8 long-term needs to have some resolution on this  
9 issue. We will briefly describe the background, what  
10 some of the implementation issues are, the options.  
11 I won't go into too much detail, because there is  
12 some backup information, and advantages and  
13 disadvantages are discussed in the white paper, which  
14 I believe you have.

15 And then, the status, where we are in  
16 terms of engaging the stakeholders. So the time is  
17 now. There is at least one application for risk-  
18 managed technical specifications in the combined  
19 license application for risk-informed completion  
20 times and surveillance frequency control program.

21 And in the longer term -- and longer term  
22 is not too long, but it is probably post combined  
23 license issuance, EPRI, on behalf of several design  
24 centered working groups and perhaps several

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicants, has a research program on extending risk-  
2 informed in-service inspection of piping to new  
3 reactors. And also, kind of unofficially there is  
4 interest in perhaps special treatment requirements  
5 under 50.69 as well, and that is not too far down the  
6 road.

7 So the time is upon us, and in the not-  
8 too-distant future we must come to some resolution if  
9 you will.

10 For operating reactors, I am sure you are  
11 aware -- and a lot of this background is in Reg.  
12 Guide 1.174 and associated quantitative health  
13 objectives of the Commission's safety goal. The core  
14 damage frequency goes  $10^{-4}$  per year. It is a  
15 surrogate for latent cancer fatalities in the QHO.

16 In other words, if a powerplant -- a  
17 nuclear powerplant meets  $10^{-4}$  per year, or lower,  
18 there is reasonable assurance with a degree of --  
19 good degree of margin that the Commission's QHO for  
20 latent cancer fatality can be met.

21 And, likewise, if one works backwards  
22 from the Commission's policy on QHO for prompt  
23 fatalities, with a good degree of margin, there is a  
24 good assurance that if a powerplant meets large early

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 release frequency, less than  $10^{-5}$ , it will meet the  
2 QHO for prompt fatalities. And so these are the sort  
3 of metrics you use for operating reactors.

4 MEMBER APOSTOLAKIS: I need some  
5 clarification here.

6 MR. DUBE: Sure.

7 MEMBER APOSTOLAKIS: I remember that the  
8 original policy statement of the Commission -- feel  
9 free to jump in any time -- that it stated -- in  
10 fact, it is in italics as I remember -- that the  
11 frequency of releases should be less than  $10^{-6}$ .

12 MR. DUBE: Right. Large release.

13 MEMBER APOSTOLAKIS: Is there a document  
14 somewhere that says, "No, it should be  $10^{-5}$ "? When  
15 did it change by an order of magnitude?

16 MR. DUBE: I am not aware too much of the  
17 history, maybe some members in the audience, but  
18 there are several papers that -- including what used  
19 to be called the technology-neutral framework, as  
20 well as I believe some NUREGs and Brookhaven reports  
21 that did a separate series of calculations that show  
22 -- actually, one doesn't need to be as low as  $10^{-6}$  to  
23 meet the prompt fatality objective.

24 That, you know, looking at typical sites

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with typical population densities and -- although  
2 this is an individual risk, but typical sites and  
3 typical meteorology. And while one would expect for  
4 release fractions and timing one could meet 10 -- the  
5 QHO for prompt fatalities at as high a level as  $10^{-5}$   
6 per year. But you will not find that  $10^{-5}$  per year  
7 explicitly as a goal.

8 MEMBER APOSTOLAKIS: Well, the thing that  
9 bothers me a little bit is that, you know, a policy  
10 statement is an official statement from the  
11 Commission. And then, to change that because there  
12 have been some NUREG reports that show that it would  
13 be relaxed without going through a formal process,  
14 bothers me a little bit. So that is why I am asking  
15 the question.

16 I mean, a NUREG, as we all know, is just  
17 a report reporting research findings. It is not an  
18 official document from the Commission. So if anyone  
19 can help with that and point me to a place where  
20 there is an official statement, not necessarily from  
21 the Commission but with the blessings of the  
22 Commission from NRR or somebody that says that LERF  
23 could be  $10^{-5}$ , I would appreciate that.

24 MEMBER CORRADINI: But can I just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clarify? I mean, you were talking about I thought  
2 two different things, large release versus large  
3 early release. And I thought -- I think the second  
4 one has just been not spoken anymore of the large  
5 release, and large early release has some time delay  
6 relative to containment failure along with frequency,  
7 or am I misunderstanding?

8 MR. DUBE: Correct. That's right.

9 MEMBER APOSTOLAKIS: Isn't the --

10 MR. ADER: George, if I could -- this is  
11 Charles Ader with Office of New Reactors. There has  
12 been a history -- and we were trying to go back and  
13 see if there was a definitive statement that went  
14 from LRF to LERF. Staff did a lot of work trying to  
15 define the LRF, which was in the safety goal,  $10^{-6}$ .  
16 Back in the early '90s there was a SECY paper, 93-  
17 138, recommending to the Commission terminating  
18 activities to come up with a definition that was  
19 quantitative.

20 MEMBER APOSTOLAKIS: Right.

21 MR. ADER: The SECY paper that we found  
22 that sent draft 1.174 to the Commission at that time  
23 identified the LERF,  $10^{-5}$ , as the metric they would  
24 use. And I don't have it with me, but there was a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 statement that said -- and this would be consistent  
2 or encompass the Commission's  $10^{-6}$  safety goal  
3 statement.

4 It was in the SECY that went forward  
5 trying to find the exact time that the decision in  
6 1.174 was to go to  $10^{-5}$ . There is a lot of history on  
7 this, and we are still trying to --

8 MEMBER APOSTOLAKIS: If you can find that  
9 SECY later and send it to us.

10 MR. ADER: Yes, I have it upstairs.

11 MEMBER APOSTOLAKIS: I have another  
12 comment, though, because -- and it relates also to  
13 Mike's comment. Is LERF a subset of LRF? So if LRF  
14 is  $10^{-6}$ , how can a subset be  $10^{-5}$ ?

15 MR. DUBE: That is a good question.  
16 Logically, you would --

17 MEMBER APOSTOLAKIS: Silence.

18 MR. DUBE: -- expect if "large" is  
19 defined consistently, LERF should be a subset of LRF.

20 MEMBER APOSTOLAKIS: It should be a  
21 subset.

22 MR. DUBE: But you will find that it may  
23 not be.

24 MEMBER APOSTOLAKIS: Doug?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: This is Doug True from ERIN.  
2 I think we are actually going to talk a little bit  
3 about this whole topic in our presentation.

4 MEMBER APOSTOLAKIS: That's fine.

5 MR. TRUE: The short answer is it depends  
6 how you define it. It depends how you define it.

7 (Laughter.)

8 MEMBER APOSTOLAKIS: Yes. But, I mean,  
9 you know, some --

10 MR. TRUE: No. I'm not being facetious.  
11 I think that --

12 MEMBER APOSTOLAKIS: No. I know.

13 MR. TRUE: -- our track record, which we  
14 tried to lay out in our paper, that reconciles those  
15 two values.

16 MEMBER APOSTOLAKIS: Okay. First of all,  
17 the reason why I am raising the issue is just to see  
18 whether there is a document someplace. And if a SECY  
19 exists and the Commission -- I mean, I'm sure it  
20 exists -- and the Commission said fine, go ahead,  
21 then that is fine with me. But I would like to see.

22 CHAIRMAN BONACA: But didn't it come as a  
23 condition of the containment failure?

24 MEMBER APOSTOLAKIS: And then, you have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that other problem. But let's talk about LERF first.

2 MEMBER CORRADINI: Can I just go back to  
3 -- if I might, Mr. Chairman?

4 MEMBER APOSTOLAKIS: Absolutely.

5 MEMBER CORRADINI: Go back to what  
6 Charlie said, because if I remember at the time when  
7 this was being discussed, at least somebody on the  
8 staff or the Commission was struggling with how long  
9 should containment stay together. And so the ad hoc  
10 discussion was LERF was a way of trying to show that  
11 if I had a damage -- core damage accident, and I then  
12 could hold containment together for one, two -- n  
13 days, n being less than 10 but more than one -- then  
14 I have added another layer of -- I have added another  
15 layer. And an order of magnitude was expected.

16 MEMBER APOSTOLAKIS: Exactly.

17 MEMBER CORRADINI: And that is how it was  
18 left -- at least I remember back in the early '90s --  
19 very empirically.

20 CHAIRMAN BONACA: There was a condition  
21 on probability of containment failure.

22 MEMBER CORRADINI: But I think you can  
23 make -- I am just -- it is more of a question. I  
24 might be incorrect about this, but I think the way

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 Doug -- Don suggested it relative to prompt  
2 fatalities it really is a time that I have integrity.

3 And after that, something else may occur.

4 MR. ADER: I think if you look at the  
5 timeline, the new reactors that were going through in  
6 the early '90s, the System 80+ and AP-600, and some  
7 of the issues that were coming up, the Commission  
8 gave the staff guidance. And you will hear a little  
9 bit later in Don's presentation -- that is part of  
10 the dilemma we have.

11 The Commission gave staff guidance still  
12 using  $10^{-6}$  LRF. They also had some other containment  
13 performance objectives, 24 hours, not exceeding  
14 service level C, .1 containment -- conditional  
15 containment failure probability. And that was in the  
16 early '90 timeframe.

17 In '93 is when staff terminated efforts  
18 to quantitatively define a large release. We were  
19 going down a path to define it in terms of equivalent  
20 curies of iodine of some magnitude.

21 The LERF that came up in 1.174 is where  
22 we were trying to go back and see if there was a  
23 clear, definitive transition. That was in I think,  
24 what, '97? '95, '96, '97 timeframe.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The SECY that I was referring to -- and I  
2 will get a reference to it -- it was --

3           CHAIRMAN SHACK: It is 98-015.

4           PARTICIPANT: Wow.

5           CHAIRMAN SHACK: Historian

6           MR. ADER: The one I found was sending  
7 the draft 1.174 documents up for publication.

8           CHAIRMAN SHACK: Yes, right. It is  
9 sending up the draft 10.61.

10          MEMBER CORRADINI: SECY what?

11          CHAIRMAN SHACK: 98-015. At least that's  
12 what this document says.

13          MR. ADER: And as I remember it -- and I  
14 only read it probably three weeks ago, so -- it has a  
15  $10^{-5}$ , but it also mentioned the  $10^{-6}$  in Commission  
16 safety goal policy. And what we have in new  
17 reactors, you know, in the guidance is the  $10^{-6}$ , and  
18 that has not changed from the LERF. And that puts us  
19 in the dilemma that Don is going to continue to tell  
20 you about that we face.

21          CHAIRMAN SHACK: So, George, you've got  
22 to also remember they have a policy on the  $10^{-6}$ . They  
23 also have a policy that you shouldn't go beyond the  
24 safety goals.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: The safety goals are  
2 the foundation.

3 MR. DUBE: That is our dilemma.

4 MEMBER APOSTOLAKIS: That is your  
5 dilemma.

6 MR. DUBE: Yes. We wouldn't be here if  
7 there weren't that dilemma.

8 MEMBER APOSTOLAKIS: My question -- I did  
9 not call into question the  $10^{-5}$ . My question was  
10 purely administrative. How does a number that is  
11 given by the Commission in an official policy  
12 statement change? There must be some official  
13 document some place?

14 Now, you tell me there is a SECY. Fine,  
15 I am willing to accept that, and I am going to read  
16 it. But the  $10^{-5}$  I did not dispute. So because some  
17 of the discussion had to do with how it is and what  
18 it means, that is not the question now. Later there  
19 may be other questions.

20 MR. DUBE: Okay.

21 MEMBER APOSTOLAKIS: So, please. I am  
22 not --

23 MR. DUBE: Moving on to new reactors,  
24 this is what the staff is reviewing, design

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certifications, and then subsequently combined  
2 license applications against. And this comes from  
3 the staff requirements memorandum on SECY 90-016 in  
4 the 1990 timeframe.

5 A core damage frequency of  $10^{-4}$  -- in  
6 fact, the Commission explicitly states that, you  
7 know, the staff had recommended  $10^{-5}$ , and the  
8 Commission said, "No, we'll stay with  $10^{-4}$ ."

9 A large release frequency, however one  
10 wants to define "large," of  $10^{-6}$  per year, a  
11 deterministic goal that containment integrity be  
12 maintained for about 24 hours from the onset of core  
13 damage for the more likely severe accident  
14 challenges. These are pretty much words verbatim.  
15 And then, a conditional containment failure  
16 probability less than about 0.1, with some caveats  
17 that, you know, give or take that 0.1 value would be  
18 -- we are not going to get too concerned about.

19 MEMBER CORRADINI: There is no time with  
20 the 0.1.

21 MR. DUBE: No.

22 MEMBER APOSTOLAKIS: Now, if I meet the  
23 core damage frequency goal in the conditional  
24 containment failure probability, and the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 deterministic goal, then I am in good shape. It  
2 turned out, though, that I am violating the large  
3 release frequency goal?

4 MR. DUBE: Yes. Yes. It is -- the  
5 numbers are -- if you work through, and I think my  
6 white paper -- or the white paper I primarily  
7 authored --

8 MEMBER APOSTOLAKIS: Yes.

9 MR. DUBE: -- mentions they are  
10 inconsistent. In fact, assuming design meets .1, and  
11 assuming it is  $10^{-4}$ -ish in core damage frequency, you  
12 can meet the  $10^{-6}$ , which means, really, one has to  
13 meet about a  $10^{-5}$  or less core damage frequency to be  
14 consistent.

15 Now, in practice that is not too bad,  
16 because the Electric Power Research Institute has an  
17 advanced lightwater reactor requirements document.  
18 And all of the new designs being submitted for  
19 certification state that their goal is to meet  $10^{-5}$  or  
20 better.

21 So a combination of the EPRI advanced  
22 lightwater reactor and the Commission goals, one can  
23 get there. But, in practice, it really kind of means  
24 they need to meet  $10^{-5}$  CDF in order to meet all of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- in order for all of these things to fall into  
2 place.

3 There were a number of policy statements  
4 on Commission's expectations, and I take selected --

5 MEMBER APOSTOLAKIS: Excuse me. I had a  
6 question. I'm sorry.

7 MR. DUBE: Sure.

8 MEMBER APOSTOLAKIS: On the previous one.

9 When it says a "deterministic goal," that means  
10 following an accepted set of deterministic  
11 calculations, is that what it means?

12 MR. DUBE: A severe accident analysis,  
13 accident progression analysis.

14 MEMBER APOSTOLAKIS: But not in a PRA  
15 space. Well, a deterministic --

16 MR. DUBE: If you look at Chapter --  
17 Section 19 of the FSARs or design control documents,  
18 Section 19.1 is on the PRA, you know, the  
19 quantitative PRA Level 1 and Level 2. And then,  
20 there is a Section 19.2 on severe accident issues.  
21 And that is more or less where this falls in.

22 So this is an accident progression that  
23 follows core damage up to, if necessary, reactor  
24 vessel failure, combustible hydrogen control.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: But all of this is  
2 done deterministically.

3 MR. DUBE: Well, you know, a MOX code or  
4 a MAPP code.

5 MEMBER APOSTOLAKIS: Yes.

6 MR. DUBE: Or not MOX, but MAPP code or  
7 MELCOR code or some -- yes, sorry.

8 MEMBER APOSTOLAKIS: Okay.

9 MEMBER CORRADINI: So just to drive the  
10 point home, so these are the ones I remember, and  
11 none of -- this set of four do not apply to current  
12 reactors. We are not -- I understand.

13 MR. DUBE: In new reactors, this is what  
14 we are using --

15 MEMBER CORRADINI: Okay.

16 MR. DUBE: -- reviewing against.

17 MEMBER CORRADINI: So you said that one  
18 way out of the inconsistency is to drive down the  
19 CDF. Another one is to show containment is more  
20 robust.

21 MR. DUBE: Right. In practice, if you  
22 look at typical conditional containment failure  
23 probabilities -- and I have some values there -- they  
24 range from a couple percent, and there are a few

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 designs in the 10 percent range.

2 So I think what you find in practice is  
3 because the containments are robust, much more  
4 robust, than current designs, but you find that there  
5 are shared -- there are systems that are shared  
6 between the accident prevention and mitigation, like  
7 a storage tank of water.

8 And because of this coupling, core damage  
9 prevention and accident mitigation are not completely  
10 independent. Do you see what I'm saying? So in  
11 practice CCFP -- some of the designs, the new  
12 designs, are a couple percent up to a tenth of a  
13 percent. But it is very hard to drive that too far  
14 down because of this coupling.

15 MEMBER CORRADINI: So may I say it a  
16 different way, just so that I've got it in my head  
17 right. Is that if I were talking about equipment  
18 availability and various damage states there is some  
19 equipment that is shared between prevention and  
20 mitigation. And so even if I knew the phenomenology  
21 past degraded core, I would still have a non-zero  
22 containment failure probability, because other  
23 systems have failed --

24 MR. DUBE: Correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 MEMBER CORRADINI: -- that got me to this  
2 point.

3 MR. DUBE: That's right.

4 MEMBER CORRADINI: Okay. So a second  
5 question, then, about that is -- it kind of goes to  
6 what George was saying about deterministic. So this  
7 is not a DBA space, and --

8 MR. DUBE: No.

9 MEMBER CORRADINI: -- but there are  
10 calculations.

11 MR. DUBE: Right.

12 MEMBER CORRADINI: Have computer models  
13 of these calculations for their application here been  
14 reviewed by staff? Or is it an assumption because I  
15 am outside a DBA space that sort of a review of the  
16 computer models, since you are only using that to  
17 determine this, are not needed?

18 MR. DUBE: There are others on the NRO  
19 staff out there who could answer. I don't know if Ed  
20 Fuld is here, but --

21 MEMBER CORRADINI: You know my --

22 MR. DUBE: -- typically, the licensees  
23 are typically -- or applicants are typically using a  
24 code, like an advanced version of MAPP, that has been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 developed specifically for advanced new reactor  
2 designs. But in a lot of cases the staff has a  
3 MELCOR version --

4 MEMBER CORRADINI: Yes.

5 MR. DUBE: -- of these and are doing  
6 their own -- our own independent calculations. I  
7 won't call them confirmatory, because it is not  
8 design basis. But we are doing a lot of independent  
9 analyses.

10 MEMBER CORRADINI: I am going beyond your  
11 presentation, but just so you can see what some of us  
12 are thinking. I'll grant all of this, but when I do  
13 -- for bullet 3, how do I have faith that what I am  
14 doing I actually believe? So that 24 is not really  
15 two or 60? Do you see my question?

16 MR. DUBE: Well, it could be 60.

17 MEMBER CORRADINI: Could be. But I guess  
18 what I am asking, really, is to satisfy bullet 3, you  
19 are doing a deterministic calculation, which means by  
20 doing that you put some faith into the number you  
21 get.

22 MR. DUBE: Right.

23 MEMBER CORRADINI: Has the staff,  
24 relative to either their tools or industry tools,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 gone through a review of that for this application?

2 MR. DUBE: Well --

3 MEMBER CORRADINI: I think I know the  
4 answer. I just want to make sure I --

5 MR. DUBE: I mean, I believe the MAPP  
6 code users group has gone through a lot of  
7 validation.

8 MEMBER CORRADINI: Okay.

9 MEMBER APOSTOLAKIS: The answer is no.

10 MR. DUBE: I think there is reasonable  
11 assurance that --

12 MEMBER APOSTOLAKIS: The answer is no.

13 MR. DUBE: -- between the two -- okay. I  
14 will say --

15 MEMBER APOSTOLAKIS: You are saying that  
16 the "no" is kind of harsh. That it may not have been  
17 a very detailed review, but there are --

18 MEMBER CORRADINI: Yes. What I hear you  
19 say is you have done a lot of empirical calculations,  
20 done cross-comparisons, and you feel a warm, fuzzy  
21 feeling.

22 MR. DUBE: Yes.

23 MEMBER APOSTOLAKIS: Well, I don't know  
24 how warm it is, but --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: But I guess the reason  
2 I'm asking specifically about this, because of all of  
3 the three -- of all of the four, this one I can  
4 actually see a path, and I want to understand how I  
5 got to that path.

6 MEMBER APOSTOLAKIS: I really have to do  
7 some planning here. Mr. Bradley, how much time do  
8 you think you are going to need, so I can plan here?

9 MR. BRADLEY: Well, I guess we will use  
10 the time we have allotted.

11 PARTICIPANT: He expects to have 40  
12 minutes.

13 MEMBER APOSTOLAKIS: 9:30 to 10:20.  
14 Okay. So by 9:30 we should be done.

15 MR. DUBE: We are doing fine.

16 So there is a couple of Commission policy  
17 statements. You are not going to find the words  
18 written. It is somewhat implied. Briefly, the  
19 Commission expects vendors to design plants to a  
20 higher standard of severe accident safety  
21 performance, and expects advanced reactors will  
22 provide enhanced margins of safety, so on and so  
23 forth.

24 MEMBER APOSTOLAKIS: But -- okay. The

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Commission does not say explicitly "use CDF and  
2 LERF." I mean, they may have concurred, but -- and  
3 all your six options are based on those. Why? I  
4 mean, why -- isn't this a good opportunity to think a  
5 little bit beyond CDF and LERF? Which have all the  
6 problems that you identified.

7 And what comes to mind is, for example,  
8 what you call the formal technology-neutral  
9 framework. What is the new name, by the way? Is  
10 there a new name? I still know it as the technology-  
11 neutral framework.

12 I know it has not been approved  
13 officially, but that doesn't mean it doesn't have  
14 some very good ideas in there, and you don't have to  
15 accept in its totality. And that would relieve some  
16 concerns that some of us have regarding LERF or LRF,  
17 because, as you know very well, what is released and  
18 how much is not covered by these.

19 And it seems to me that we have an  
20 inconsistency as regulators if we make sure that if  
21 somebody requests a change in a risk-informed way  
22 delta CDF has to be, you know,  $10^{-5}$ , delta LERF has to  
23 be  $10^{-6}$ . And then, we turn around and say, "Oh, this  
24 application, like an extended power uprate, is not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 risk-informed, 20 percent."

2 I think there is some inconsistency  
3 there. So I am wondering whether this is a good time  
4 -- and, you know, that is not -- you don't have to  
5 answer it now, but whether it is a good --

6 (Laughter.)

7 Well, it is not an easy question to  
8 answer. To think maybe in terms of other metrics,  
9 like the technology-neutral framework goes all the  
10 way to dose. Is there an idea there we can use? The  
11 first question should be: is it practical? Because  
12 I think that is the whole idea of working with CDF  
13 and LERF, that, you know, the goals themselves don't  
14 have.

15 But I am wondering whether you have given  
16 it some thought, or you think it would be worthwhile  
17 giving it some thought in the future.

18 MR. DUBE: Yes, we could give it some  
19 thought. The only other issue here is actually by  
20 rule in the latest changes to Part 52, for design  
21 certification purposes it has to be site-independent.

22 And they are only required to do a Level 2 PRA,  
23 which starts at release and not dose. And, in fact,  
24 even at the combined license application phase, they

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are not required to do a Level 3, which is offsite  
2 consequences.

3 And the technology-neutral kind of -- I  
4 mean, relies on a dose frequency or consequence  
5 frequency correlation or set of limits. So we have  
6 that issue, that dilemma.

7 MEMBER APOSTOLAKIS: So all I'm saying is  
8 go back and look at it, and see if there are any  
9 ideas that may help you. I know that -- again, I  
10 repeat, you don't have to say, "Boy, the whole  
11 technology-neutral framework is acceptable," because  
12 I know that is very hard when it has to go through  
13 meetings and approvals and all that.

14 But there may be some interesting ideas  
15 there that will take us out of this CDF, LERF, or LRF  
16 framework, which appears to have problems. It is  
17 just a suggestion. It is not --

18 MR. DUBE: My colleague, Hossein  
19 Hamzehee, has a --

20 MR. HAMZEHEE: George, that is a great  
21 idea, but we also have to make sure that we are -- we  
22 have some technical consistency among operating  
23 reactors and new reactors. And if for some reason we  
24 decide to look at other metrics for these new

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reactors, we have to make sure they are also  
2 applicable and used for the operating reactor, and  
3 that is a challenge.

4 MEMBER APOSTOLAKIS: These are the issues  
5 that you may want to raise.

6 MR. HAMZEHEE: Yes.

7 MEMBER APOSTOLAKIS: I didn't give you an  
8 answer. I didn't say, "Do it." I said, you know,  
9 "See if there is something outside" -- I really hate  
10 to use that word "think outside the box," but it  
11 applies here, unfortunately.

12 MEMBER BLEY: Well, even within the box,  
13 if you go back -- and maybe Doug will be doing this  
14 -- to when LERF first came about, there was a lot of  
15 work and looking at complete PRAs and looking for a  
16 summary measure that seemed to cover the consequence  
17 side. And for the plants that were examined LERF did  
18 a pretty good job.

19 But now, if we start playing with the  
20 surrogates like LERF and LRF, without relating them  
21 back to their origins for designs that weren't  
22 included in that verification process, it is a little  
23 fuzzy that they will apply. So --

24 MEMBER APOSTOLAKIS: I think these are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 the issues that have to be raised. And you mentioned  
2 that you will come back to ask presumably also to the  
3 subcommittee. I would be very happy to debate these  
4 issues and the problems and the challenges. I think  
5 that that would be -- this is a briefing today. You  
6 know, it is sort of an introduction. But these are  
7 the kinds of things that would be really worthwhile  
8 to think about, because I am having a problem with  
9 LERF and CDF even for the current actions.

10 MR. ADER: Just to follow on, when staff  
11 was looking at a definition of LRF back in the '90s,  
12 the Commission's direction was to try to decouple it  
13 from having to go out and do dose calculations, to  
14 try to find something that would be a surrogate that  
15 basically would stop at containment boundary.

16 As Don mentioned, we have the challenge  
17 that nobody is required to do a Level 3 for the new  
18 plants now and in the future, and that is -- all of  
19 this that we are talking about is really the new  
20 plants that we have on our plate today, the AP-1000,  
21 the ESBWR. We are not taking this to the advanced  
22 reactors, because there is other issues.

23 We are also, at least right now, we are  
24 not looking as part of this effort to go back and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 change the current operating metrics. We are trying  
2 to get out of the dilemma. We see implementation  
3 issues for the new reactors based on the guidance we  
4 have to review the reactors, the risk metrics that  
5 are kind of tied into a safety goal, raises  
6 implementation issues. Don will get into some  
7 options; they all have pros and cons. So those are  
8 the things we are wrestling with at this point in  
9 time.

10 MR. DUBE: Thank you. If I could move  
11 on, the next slide just puts the risk metrics in  
12 perspective. These are for operating PWRs and BWRs.

13 These are data that we compiled from the MSPI basis  
14 document, so they are about as current as one can  
15 get. And, of course, there is uncertainty.

16 I have also shown the new lightwater  
17 reactors with primarily active safeguards, so the EPR  
18 for example, APWR, and the passive designs, AP-600,  
19 -1000, and ESBWR. And, again, there is uncertainty  
20 about this, but depending at what point one compares  
21 against another point, as Professor Apostolakis  
22 mentioned, there is one, maybe two, maybe three  
23 orders of magnitude lower for new reactors, compared  
24 to, say, the mean value of -- but there is some

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 overlap, and we acknowledge that.

2           And then, the lower right are, as best  
3 one could compare, large release frequency as  
4 presented in the certification -- the design control  
5 documents for new reactors against what we could  
6 extract from the IPE reports, that's NUREG-1560, and  
7 here they had something called significant early --  
8 I'm not sure I have a lot of confidence in the lower  
9 tail of those values, but certainly there is, again,  
10 one, two, three, if you want to compare the lowest  
11 data point for new lightwater reactor passive against  
12 the mean value, or upper bound is three and a half  
13 orders of magnitude or lower.

14           The point of this is that the profile for  
15 new reactors are, in general, lower than for  
16 currently operating reactors, which poses some  
17 issues.

18           MEMBER APOSTOLAKIS:       But there is a  
19 question here.  If you look at the history over the  
20 last 30-some plus years of LWR, I think the estimates  
21 of system unavailabilities and then core damage  
22 frequency, and so on, have gradually increased as  
23 their methods for analysis have become more  
24 sophisticated and realistic, as we were collecting

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 more data, and, most importantly, operating  
2 experience.

3 MEMBER BLEY: Increased?

4 MEMBER APOSTOLAKIS: Increased. If you  
5 go back to the first PRA conference of the American  
6 Nuclear Society organized in Newport Beach in 1978,  
7 you will see that almost all the papers that reported  
8 fault tree analysis of systems had a  $10^{-6}$  answer.  
9 Yes, Don was not born then.

10 (Laughter.)

11 Nobody is going to report something like  
12 that today. Okay? So the question is: do you -- is  
13 there reasonable expectation that this history will  
14 be repeated? Especially for the passive systems. I  
15 mean, there may be new failure modes. I believe you  
16 mentioned that also in your --

17 MR. DUBE: Yes.

18 MEMBER APOSTOLAKIS: -- white paper. If  
19 we build them and we start operating them, there will  
20 be maybe new insights, new failure modes, somebody  
21 does an analysis and finds something. So these  
22 numbers I am not sure they will stay there.

23 MR. DUBE: Well, I can't go all the way  
24 back to '78, but I know -- and EPRI has shown this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 before the Commissioners -- certainly, since the late  
2 '80s/early '90s, and after the IPE days, reactor trip  
3 frequencies come down almost an order of magnitude,  
4 certainly a factor of three, four.

5 Unavailability of systems has gone down,  
6 reliability of systems has gone way up. And many of  
7 the methods now are less conservative -- for example,  
8 the reactor coolant pump seal failure model, more  
9 realistic. So, since the '90s, CDFs have come down  
10 almost a factor of three. So maybe it is --

11 MEMBER APOSTOLAKIS: I agree.

12 MR. DUBE: -- an upside-down U-shaped  
13 curve in terms of the CDF, but --

14 MEMBER APOSTOLAKIS: You're right. I  
15 didn't want to imply that we have a continuous  
16 degradation of safety. The truth of the matter is  
17 that if you look at history, there is an evolution of  
18 methods, more sophisticated, more data, more  
19 operating experience. I would say that something  
20 like that probably will happen here, too, so these  
21 numbers -- they don't necessarily have to come back  
22 up to where the current reactors are, but  $10^{-8}$  or --  
23 and I have a hard time --

24 MR. DUBE: I mean, I would agree with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you, because my experience in the industry is the  
2 plants -- these new reactor designs haven't been  
3 operating, we don't have operating experiences.  
4 There are failure modes that we are not quite aware  
5 of yet, and --

6 MEMBER APOSTOLAKIS: Yes, that is the  
7 whole point. Okay.

8 MEMBER STETKAR: George, I think it is  
9 important, just for the record, to recognize that  
10 this is internal events only at full power operation.

11 So there is no -- these small numbers are only a  
12 fraction of the real total core damage frequency.

13 MEMBER APOSTOLAKIS: Right.

14 MEMBER STETKAR: That's why you include  
15 fires and seismic events and other operating modes  
16 and things like that. And there is no necessary  
17 reason a priori, given the long experience on  
18 designing against these particular types of events,  
19 to presume that that fraction of the total risk might  
20 not be a relatively small fraction today compared to  
21 what it was 30 years ago.

22 MEMBER APOSTOLAKIS: It may very well --

23 MEMBER STETKAR: The total risk might be  
24 a lot higher than implied by these numbers, but this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particular fraction that we happen to be, you know,  
2 dealing with and focused completely on today might  
3 actually be quite small.

4 MEMBER APOSTOLAKIS: I don't question  
5 that. All I am saying is that, if I look back to the  
6 history of 30 years, there have been changes due to  
7 discoveries, blah, blah, blah, blah. And it stands  
8 to reason to say we will see something like this here  
9 as well.

10 Now, the seismic risk is such a huge  
11 dependent -- potential dependent failure that  
12 probably will overwhelm these numbers. There is no  
13 question about it. So that is why it is a challenge,  
14 because you can't say one way or another what is  
15 going to happen. But history is always -- I mean,  
16 there was a time when we were not putting much  
17 attention to human error.

18 I remember that in the early days. I'm  
19 sorry, I remember it. "My operators will never do  
20 this." You know, I have heard that. Now people  
21 don't say things like that.

22 MEMBER RAY: Wait. You had started  
23 talking about details, and that's fine. But I happen  
24 to be more focused on tails. Is there some reason,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Don, that you -- it is expressed as 10<sup>90</sup>?

2 MR. DUBE: Because they are very big  
3 tails, and I didn't want -- I didn't think it was  
4 appropriate to show the 95th to 99th percentiles,  
5 because --

6 MEMBER RAY: It's not because they are  
7 not relevant, is it?

8 MR. DUBE: No, I just -- at some point  
9 it --

10 MEMBER RAY: No, it's okay. I just  
11 wondered. It's not part of any policy, it's just --

12 MR. DUBE: No.

13 MEMBER RAY: -- a choice you made.

14 MR. DUBE: Yes.

15 MEMBER RAY: Okay.

16 MR. DUBE: So new reactor PRAs are  
17 expected to demonstrate how they compare against  
18 these Commission goals, and Reg. Guide 1.206 provides  
19 the guidance. And the staff is reviewing against SRP  
20 Chapter 19.

21 There is a number of risk-informed  
22 related reg guides, and I am just going to list them  
23 here. Of course, 1.174 is kind of the umbrella reg  
24 guide, and a lot of these are specific to an

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 application like risk-informed tech specs, in-service  
2 inspection, and they refer to 1.174, not consistent  
3 with that, those methods.

4 So for new reactor implementation, these  
5 are our issues. The review of these applications has  
6 raised some questions about the risk metric  
7 guidelines, this issue of large early release  
8 frequency versus the Commission goal on large release  
9 frequency. As Charlie Ader mentioned, the large  
10 release frequency has not been previously finalized  
11 in NRC documents. There are some unofficial terms in  
12 there, but one will not find a proven or accepted  
13 definition.

14 So pretty much to this point applicants  
15 have provided their own definition of "large release  
16 frequency." The staff has reviewed these documents,  
17 bounced the idea around, looked at alternative  
18 definitions, and for the purposes of design  
19 certification wrote up a safety evaluation and  
20 provided staff's basis.

21 But one will find that, say, for example,  
22 the five active design certifications, the AP-1000,  
23 ESBWR, APR, EPR, and advanced boiling water reactor,  
24 there is five different definitions out there pretty

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 much of "large release." Some of them are dose-  
2 related, like 25 rem at a kilometer or half-mile  
3 boundary.

4 Some are release-related, so release  
5 fraction of cesium-137 and iodine, and others are  
6 really more of a containment failure mode related  
7 definition, like one applicant at one time had  
8 anything greater than design basis leakage of  
9 containment is large.

10 So the fact that there has never been a  
11 finalized definition of large release means we have  
12 this -- there is an inconsistency issue as well. But  
13 the staff has been able to deal with that as of now.

14 MR. HAMZEHEE: Don, we should also  
15 mention that one of the main reasons that we have  
16 accepted those definitions is because almost in all  
17 cases they were more conservative. So, in other  
18 words, no matter what definition you use, those  
19 values would be bounding. So that's why at that time  
20 we went ahead and approved or agreed with the  
21 definitions.

22 MR. DUBE: Right. Thank you.

23 And the other dilemma or issue is -- and  
24 this is discussed in the white paper -- is use of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 current numerical risk metric goals in Reg. Guide  
2 1.174 -- it says "would result," but "may result"  
3 perhaps is a better term -- being evaluated against  
4 less restrictive criteria than those used for  
5 licensing basis of new reactors. So we are reviewing  
6 against  $10^{-6}$  large release frequency.

7 How could one theoretically -- and I am  
8 not saying it necessarily would happen -- how could  
9 one review -- if an applicant came in with a license  
10 amendment request with a delta LERF of several times  
11  $10^{-6}$ , it just seems to be a little bit out of line  
12 proportionally speaking. And like I said, the white  
13 paper goes into that, so that -- that is one of our  
14 dilemmas.

15 So we kind of divided this into two  
16 phases, a licensing issue and an operations issue.  
17 The immediate concern is licensing. That is, risk-  
18 informed applications that are coming in for risk-  
19 informed tech specs or risk-informed in-service  
20 inspection, and there is a whole new set of issues on  
21 operations and the reactor oversight process, because  
22 if one looks at, for example, the mitigating systems  
23 performance index, the significance determination  
24 process, MD 8.3, which is the staff's response to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 incidents, they highly rely on measures of CDF, delta  
2 CDF, conditional core damage probabilities,  
3 incremental, and all of the combinations.

4 And as shown in the white paper, there  
5 are issues posed there which, you know, in some  
6 circumstances if one used a particular baseline CDF  
7 one could have major systems out of service for major  
8 -- long periods of time and still not even approach  
9 the white threshold.

10 We are not going to try to resolve that  
11 issue in the coming months, but that is -- that is  
12 something out there of concern. So the focus is on  
13 the need for licensing in the short term.

14 Reg. Guide 1.174, as I mentioned,  
15 provides -- is kind of the foundation for risk-  
16 informed license amendment requests. The risk  
17 acceptance guidelines, which I will show a couple of  
18 graphs in a second, is a basis for the baseline risk  
19 metrics for core damage frequency and LERF, and a  
20 basis for the change in core damage frequency and the  
21 change in large early release frequency for the  
22 numerical guidelines there.

23 The bases for these -- and these are  
24 spelled out as Professor Apostolakis mentioned -- the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 five principles that -- for risk-informed regulation  
2 -- you know, maintaining safety margin, defense-in-  
3 depth, and so forth. But I will concentrate on the  
4 risk-related one, and it says the increase should be  
5 limited to small increments.

6 And so the issue raised is, well, what --  
7 is "small" an absolute term, or is it a relative  
8 term? As I mentioned, one could conceive of  
9 theoretically an AP-1000 proposing a license  
10 amendment request, and its baseline core damage  
11 frequency in the lower  $10^{-7}$ , propose a license  
12 amendment request which could be several factors of  
13 that.

14 It would still meet the absolute  
15 guidelines in Reg. Guide 1.174, but it could  
16 theoretically represent factors of three and four and  
17 five times its baseline, which the staff has reviewed  
18 and approved so -- in so many words, in a safety  
19 evaluation.

20 MEMBER CORRADINI: I have a question,  
21 just for clarification. So not that you would do  
22 this, but just as an analogue, if I -- if I am  
23 looking at worker dose in an operating plant -- there  
24 was this whole thing about -- we went through the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whole thing last month on allowables, and then there  
2 is an operational limit, and there is an absolute  
3 cap.

4           Doesn't the analogue work here that if  
5 one were to agree to what the CDF and the LRF were to  
6 be, you would take a percentage of that as the  
7 definition of "small," don't worry about what the  
8 absolute value is, worry about what the limit is, and  
9 take a percentage of that, and you must fall below  
10 that. So if it is  $10^{-6}$  for -- or  $10^{-5}$  for LRF, you  
11 demand no more than one percent variation on that on  
12 the cap.

13           Now you have an operational limit that  
14 essentially goes off the cap rather than what I think  
15 is a highly uncertain number that is bouncing all  
16 over the place.

17           MR. DUBE: Well, certainly, that is one  
18 of the options presented in the white paper. There  
19 is an absolute value approach, there is a relative  
20 value approach, there is a combination of the two,  
21 and all -- everything in between, with advantages and  
22 disadvantages. There is a -- they are listed. There  
23 are a lot of disadvantages with a relative approach,  
24 too. I mean, it poses a lot of issues. I mean,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the --

2 CHAIRMAN SHACK: But relative to your  
3 expectations for new reactors, I mean, you wouldn't  
4 make it relative to the computed value for the --  
5 but, you know, base it on the  $10^{-5}$  and  $10^{-6}$

6 MEMBER CORRADINI: Right. Sure.

7 MR. DUBE: I mean, that is your goal.

8 MEMBER CORRADINI: That is an option.

9 CHAIRMAN SHACK: Especially for 1.174,  
10 where you are talking about voluntary changes. You  
11 know, I think it is more difficult when you come to  
12 the ROP and you are talking about enforcement  
13 actions, and, you know, whether you are preserving  
14 safety. In 1.174, they are asking for changes to a  
15 licensing basis that everybody has agreed on, and it  
16 is a voluntary change.

17 And so it seems to me that you -- you  
18 have a basis to go more restrictive for 1.174, but  
19 you are, in my sense of view, more constrained in  
20 terms of the ROP and SDP by the safety goal of what  
21 is safe enough.

22 MR. DUBE: Thank you. That is a good  
23 point. Appreciate that.

24 So I won't dwell on this. These are the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptance guidelines from Reg. Guide 1.174, one for  
2 CDF, and one is for LERF. Do I need to spend time  
3 explaining this or --

4 MEMBER APOSTOLAKIS: No.

5 MR. DUBE: -- it pretty well accepted?

6 MEMBER APOSTOLAKIS: You have 11 minutes.

7 MR. DUBE: So the question is: for new  
8 reactors, should the principle of small increase be  
9 based on a relative or absolute delta CDF, delta  
10 LERF, and/or delta LRF? These are rhetorical  
11 questions.

12 (Laughter.)

13 PARTICIPANT: Sure.

14 PARTICIPANT: You need to clarify that  
15 for us.

16 (Laughter.)

17 MR. DUBE: And/or should RG 1.174 include  
18 an alternate or additional delta LRF acceptance  
19 guideline for new reactors? Again, a rhetorical  
20 question.

21 MEMBER APOSTOLAKIS: Or should we drop  
22 CDF and LERF completely and do something else?

23 (Laughter.)

24 Well, there is a time for --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 PARTICIPANT: It is so easy the way it  
2 is.

3 MR. DUBE: Okay.

4 MEMBER APOSTOLAKIS: Very good.

5 MR. DUBE: These are the reg guides that  
6 are impacted. I am not going to spend any time.  
7 They are there for your reference -- and acceptance  
8 programs. These are some of the possible options.  
9 There may be more, but this was in the white paper,  
10 and we are entertaining options.

11 There is the status quo, which is current  
12 acceptance guidelines in RG 1.174 and associated reg  
13 guides, and the ROP would also be applied to new  
14 reactors. It would treat new reactors the same as  
15 the current, convert to a relative risk change for  
16 both new and current reactors, reduce acceptance  
17 guidelines for new reactors by one or more orders of  
18 magnitude solely for new reactors.

19 Option 4 is like use a combination of the  
20 two. Option 5 was added relatively recently -- use  
21 existing acceptance guidelines for current or new  
22 reactor status quo, but establish an LRF -- LRF-based  
23 acceptance guideline for new reactors. And this  
24 would go with what Mr. Shack said, which we would

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably not change the thresholds for ROP purposes  
2 for new reactors, keep them the same for current and  
3 operating reactors. And option 6 is kind of a wing-  
4 it, which is just assess new reactors case by case.

5 And my final slide -- and I am doing  
6 pretty good time -- this is a status -- the white  
7 paper was issued in February. That is the ADAMS  
8 number. There was an EDO memorandum to  
9 Commissioners, basically the same material. There  
10 was a public meeting held February 18 where we  
11 discussed these issues. It was a half-day meeting.  
12 There was a presentation at the RIC, and we plan to  
13 continue and engage stakeholders.

14 MEMBER BLEY: Don, can you say anything  
15 briefly about the public meeting or --

16 MR. DUBE: I am going to next slide,  
17 thank you.

18 MEMBER BLEY: Thank you very much.

19 MR. DUBE: Final slide that is in the  
20 backup, there was broad representation of the  
21 stakeholders. The staff described the pending risk-  
22 informed applications and some of these dilemmas on  
23 the implementation. There was a lot of discussion on  
24 how -- what was the ultimate basis for LRF and CCFP,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where did they come from, described the advantages  
2 and disadvantages.

3 There was additional sub-options  
4 suggested by Mr. Chapman, whereby one might perhaps  
5 for the first few applications use the current set of  
6 risk metrics and then assess the need for a change  
7 based on lessons learned. So it is kind of a 1A  
8 option or a 6A option, depending where one wants to  
9 put it.

10 Industry followed up with its own white  
11 papers providing its views and historical  
12 perspectives. And then, going forward we will have  
13 additional public meetings.

14 MEMBER BLEY: Do you have a plan for over  
15 time when you expect this to come together and when  
16 you expect to have a -- I assume a reg guide comes  
17 out on --

18 MR. DUBE: Nothing is official. But in  
19 broad terms, the plan is to continue to engage  
20 stakeholders, narrow down the list of options to the  
21 really most viable, make a recommendation in a  
22 Commission paper, propose it, circulate it, come  
23 before the ACRS again.

24 CHAIRMAN BONACA: Could you go over

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 page 21? That is --

2 MR. DUBE: Okay.

3 CHAIRMAN BONACA: -- option 2.

4 MR. DUBE: So I don't have a real  
5 timetable, but it can't be too -- stretched out over  
6 too many years, because then it won't be effective  
7 for risk-informed applications.

8 MR. ADER: Don, we would be looking to do  
9 this in a reasonably short time. I mean, this is not  
10 the type of issue you are going to deal with in a  
11 month or two. But we would really be looking to come  
12 to preferred options, and I am sure we would give the  
13 Commission options as opposed to -- with a  
14 recommendation.

15 But we would probably go away -- our plan  
16 is we are starting to think that, but we really need  
17 to now start putting that on paper. We knew industry  
18 was sending a white paper. We wanted to take  
19 advantage of that. We have that now. So I would  
20 expect over the next several months we will start  
21 fleshing something out with -- leaning towards a  
22 preferred option.

23 MR. DUBE: Yes, Mario. You had a  
24 question?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BONACA: Yes. Just -- would you  
2 just go over some of the advantages here on this  
3 option 2?

4 MR. DUBE: Well, option 2 would be -- I  
5 will give a hypothetical example. Reactor has a  
6 "baseline total CDF of  $10^{-7}$ ," just for purposes of  
7 discussion. And one would say to some extent, like  
8 Mr. Shack mentioned, that Reg. Guide 1.174 with the  
9 acceptance guidelines, rather than be absolute  
10 thresholds like  $10^{-5}$ ,  $10^{-6}$ , it would be 10 percent  
11 change.

12 Therefore, a plant with a baseline of  
13  $10^{-7}$ , an acceptable change for a license amendment  
14 request would be 10 percent. I am just picking  
15 numbers for example -- 10 percent of  $10^{-7}$ , which would  
16 be a delta of  $10^{-8}$ , whereas a plant with a baseline  
17 CDF of  $10^{-6}$ , using the same 10 percent, it would be  
18 allowed -- the guideline would be 10 percent of that,  
19 which would be  $10^{-7}$ .

20 So that -- the advantage is it recognizes  
21 that small increases of relative measure, it would  
22 preclude the situation where they could have a large  
23 relative change -- percent change in core damage  
24 frequency and/or LERF for the new reactor.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           The disadvantages are numerous. All ROP  
2 guidelines would have to be changed. One might not  
3 agree what is the baseline. I mean, one would have  
4 to concur on that. It would be major changes. The  
5 reg guides and processes would impact operating  
6 reactors. There would be inconsistencies. Transition  
7 would be very difficult -- I mean, I haven't ruled  
8 this out, but you can see there is a lot of --

9           (Laughter.)

10           MEMBER CORRADINI: Just to clarify --  
11 Mario asked you to look at this one. So are all of  
12 the advantages and disadvantages saying that instead  
13 of working off of what is the calculated value it is  
14 working off of the goal? So that if you demanded the  
15 LRF was  $10^{-6}$ , and you said, "I won't allow for any  
16 change more than one percent or X percent of the  
17 goal," it -- do you see the same advantages or  
18 disadvantages?

19           MR. DUBE: Option 3 is kind of like that,  
20 in the sense that if one were -- since a large  
21 release frequency of  $10^{-6}$  is one order of magnitude  
22 lower than  $10^{-5}$ , if one were to lower -- use an LRF  
23 that was one order of magnitude lower that would kind  
24 of -- it is kind of an option 3. It is not exactly

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the same. But this is against --

2 MEMBER RAY: Well, let's keep in mind we  
3 are not just evaluating acceptability of amendments,  
4 but we are also evaluating the consequences of  
5 deficiencies, for example.

6 MR. DUBE: Reactor oversight process.

7 MEMBER RAY: Right. And I don't have an  
8 answer to this, that is not what I am leading up to,  
9 but to me I think about how you weigh -- how you  
10 should weigh the consequence of a deficiency much  
11 more than what hoops you have to jump through to get  
12 an amendment approved.

13 MR. ADER: If I could add, one of the  
14 questions -- or one of the items I would look at that  
15 we would consider in decision process is the  
16 infrastructure that has been developed in the  
17 understanding of the current approach, and to perturb  
18 that significantly would be an inefficiency, and you  
19 would start that learning process all over.

20 That is something that I would view as a  
21 part of a decision process. I think Dr. Shack hit on  
22 it, too. Another question we have is: do you have  
23 metrics for amendments? Because we reviewed them  
24 against one set. Do we judge changes against one --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the same set? But that may be independent from what  
2 we do for operations. So a question could be: we  
3 could use the existing metrics for ROP and have a  
4 different set for license amendments. Those are the  
5 types of questions we have that we are looking at.

6 MEMBER CORRADINI: So I had a question  
7 that is a little bit off -- a bit off base, but I am  
8 kind of curious. Is there any other industry such as  
9 the airline industry with new planes and new -- do  
10 they any analogue that you can see how other  
11 regulatory bodies are trying to deal with a new  
12 generation of technology relative to changing the  
13 regulations for both licensing and operation?

14 MR. DUBE: I haven't researched that, so  
15 I don't know.

16 MEMBER RAY: There is not enough to --

17 MEMBER APOSTOLAKIS: Would this be a good  
18 opportunity also to address some of the issues that  
19 1.174 leaves open and that are subject to  
20 misinterpretation? I mean, I wonder what the scope  
21 of this work is. It is just do something similar for  
22 new reactors?

23 In particular, one thing that seems to be  
24 kind of not clear in people's minds is the following.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 Regulatory Guide 1.174 refers to a single action --  
2 change in the licensing basis. There was the issue  
3 of bundling the changes, and so on, and that was --  
4 there is a discussion of that.

5 As I recall, there is no discussion for  
6 placing an upper bound on the cumulative change over  
7 the years. And some people -- in fact, the staff  
8 came back here in the context I believe -- no, there  
9 isn't -- in the context of risk-informing 50.46 and  
10 started saying, you know, that we will keep track of  
11 them and put a bound.

12 I explicitly remember Gary Holahan  
13 sitting there and saying, "You are free to submit a  
14 request every Monday." Yes. We don't forget these  
15 things. And during the discussion of 50.46, much to  
16 my surprise, several members were very happy to see  
17 an upper bound or the cumulative. So is that  
18 something that you may want to think about now, or is  
19 it, again, on a case-by-case basis, and we leave it  
20 up in the air, and we wave our arms?

21 MR. DUBE: There's others in the audience  
22 that can answer that better than me, perhaps Gareth  
23 Parry, but --

24 MEMBER APOSTOLAKIS: I am not looking for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an answer to that particular issue.

2 MR. DUBE: Not to put you on the spot.

3 MEMBER APOSTOLAKIS: I am looking for an  
4 answer to the question, if there are issues with the  
5 current guide that are sort of unresolved, is this a  
6 good opportunity to resolve it? Or do you have  
7 strict marching orders to do something with CDF and  
8 LRF and -- but that was an issue that came up.

9 CHAIRMAN BONACA: We discussed it. I  
10 mean, for me, Reg. Guide 1.174 should not be a motor  
11 to drive core damage frequency up and up and up to  
12 the upper limit.

13 MEMBER APOSTOLAKIS: But then, we should  
14 say that, and we don't.

15 CHAIRMAN BONACA: We need to say that.

16 CHAIRMAN SHACK: I like Dr. Dube's words.

17 "The cumulative effect of such changes should be  
18 tracked and considered in the decision process."

19 MEMBER APOSTOLAKIS: That is very  
20 different from saying it should be  $10^{-x}$ .

21 CHAIRMAN SHACK: Well --

22 CHAIRMAN BONACA: We haven't talked about  
23 how you limit it.

24 MEMBER APOSTOLAKIS: Because, of course,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you want to deal with trivial issues in a risk-  
2 informed way, and then turn around and change the  
3 power by 20 percent. I mean, that inconsistency  
4 drives me crazy. You know, you are very stringent  
5 here. No, no, no, it is  $10^{-6}$ . But then, if you are  
6 in a non-risk-informed space, wow, double the power.

7 Anything else? Because we are already  
8 three minutes late. I am sure we will have other  
9 opportunities to discuss this in a more relaxed  
10 environment, right?

11 MR. DUBE: Yes, right. This has been  
12 good.

13 MEMBER APOSTOLAKIS: I noticed in your  
14 future plans the ACRS did not figure, but --

15 (Laughter.)

16 MR. DUBE: That's under stakeholders.

17 MEMBER APOSTOLAKIS: Oh, okay. Thank you  
18 very much.

19 MR. DUBE: Thank you.

20 MEMBER APOSTOLAKIS: This was a very  
21 insightful white paper I thought, very insightful.

22 MR. DUBE: Thank you.

23 MEMBER APOSTOLAKIS: Thank you.

24 Okay. Nuclear Energy Institute. Do you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have any slides or --

2 MR. BRADLEY: Yes. They should be -- I  
3 gave them to the staff, so --

4 CHAIRMAN BONACA: They should be on the  
5 computer.

6 MR. BRADLEY: Thank you. I am Biff  
7 Bradley of NEI, and with me is Doug True of ERIN  
8 Engineering. Both of us were involved back in the  
9 '90s, late '90s, when a lot of this similar  
10 discussion took place. So it is interesting to be  
11 back. Let me --

12 MEMBER RAY: But were you at Newport  
13 Beach in '78? That is the question.

14 MR. BRADLEY: No, I was not.

15 (Laughter.)

16 I'm going to just skip that. That is  
17 just an overview of what we want to talk about.

18 I wanted to start here -- and I am going  
19 to transition this over to Doug, who has done some  
20 work looking at the definitions of LRF and LERF, and  
21 I think that might be very informative based on the  
22 discussion we had earlier today.

23 We all know the paper was sent to the  
24 Commission. As you know, we also provided a paper to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the ACRS. We also sent our white paper to the  
2 Commission. We cc'd the Commission.

3 We have had -- the staff identified this  
4 issue to us a couple of months ago. I think we have  
5 had a positive constructive interaction with the  
6 staff on this issue. I do think there is a little  
7 concern with the timing -- the need for what appears  
8 to be very rapid resolution of this, and we know  
9 these are thorny issues. So we are a little bit  
10 concerned about the drive to do this very rapidly,  
11 but the interaction has been very good.

12 And I wanted to speak to the bullet, the  
13 first bullet -- perceived. We reason we put the word  
14 "perceived" there is that -- I think that is really a  
15 function of, as Doug indicated earlier, the  
16 definition of large release and how it equates to  
17 large early.

18 Don had one slide in his presentation  
19 that he actually corrected the word from "would" to  
20 "may," and that was an important correction, because  
21 -- that was on his slide 10 -- use of current  
22 numerical risk metric goals would result. I think  
23 that still remains to be seen, and it is a function  
24 of the definition. So that was an important

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 correction he made there. I just wanted to note  
2 that, and we will talk more about that.

3 As you might expect, industry does have  
4 some concerns in this area. The 1.174 process hasn't  
5 just been applied to CLB changes, it has also become  
6 the backbone of the reactor oversight process, which  
7 is near and dear to all plants' hearts. And it is  
8 the foundation for enforcement, inspection findings,  
9 and things of that nature that really have a major  
10 impact on a plant's operation.

11 There seems to be some question now about  
12 prior policy decisions. I know there were some  
13 Commission quotes put out or we have some of our own  
14 Commission quotes we can show as well. And I know  
15 the staff didn't propose a specific option, but we do  
16 believe that option 1 is credible, and we believe it  
17 is appropriate, and we will talk to that.

18 So as was mentioned, the Part 52 risk  
19 metrics come out of a 1990 SRM. And then, starting  
20 after that, starting in '93 when the quantitative  
21 definition of large release was directed by the  
22 Commission to be abandoned, we moved on into the era  
23 of the 1.174 development and LERF. So this has been  
24 discussed already.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           We believe these goals have been  
2 effective for the design and the licensing, initial  
3 licensing of the plants, and that some of these --  
4 some of the issues we get into with definitions of  
5 LERF or LRF are not so difficult in design space, but  
6 they do become more problematic if you try to apply  
7 them in operations space.

8           So at this point, I am going to turn it  
9 over to Doug, who has done a lot of digging on the  
10 history of LRF and LERF. Go ahead.

11           MR. TRUE: One of the things that we  
12 decided we wanted to do was kind of go back and  
13 provide this historical perspective, because a lot of  
14 the players haven't been involved all the way along.

15           I wasn't anywhere near Newport Beach in 1978 either,  
16 George, but --

17           (Laughter.)

18           -- I have been involved with LERF and LER  
19 -- and LRF for 20-some years.

20           So we tried to put the whole story  
21 together, and we basically had two tracks. We had  
22 the Part 52 track, which was going up until the early  
23 1990s, and then we jumped over to another track in  
24 the late 1990s with 1.174. And so we tried to kind

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of wind all of that out, and then attempted to kind  
2 of go back over the history of LERF and help  
3 reconcile how we ended up with LERF, at least from  
4 the industry's perspective.

5 So as we talked about, the safety goal  
6 policy statement introduced the expectation for a  
7 large release frequency less than  $10^{-6}$  for all  
8 reactors. The staff initially defined LRF as a  
9 release that had the potential for causing an offsite  
10 early fatality, and that definition was carried  
11 forward for a while.

12 The Commission came back later and said,  
13 "Well, we would really rather have a more  
14 quantitative definition and something that doesn't  
15 require a Level 3 PRA," something that we can put in  
16 terms of fraction of core inventory release or curies  
17 or something like that.

18 Charlie mentioned there was a lot of  
19 research done by the staff, and at the end, in 1993,  
20 the Commission directed the staff to abandon their  
21 efforts to quantitatively define LERF beyond this  
22 sort of qualitative definition that had been in  
23 existence. And, in fact, the SRM -- or the SECY and  
24 the SRM don't abandon large release. They sort of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 leave the qualitative definition as is, without a  
2 further quantitative definition.

3 That left the new reactor vendors who  
4 didn't have Level 3 PRAs in a little bit of a spot,  
5 in that they had to come up with their own  
6 definitions for large release. And as Don I think it  
7 was said, many of the designs have adopted different  
8 definitions. And I think in all cases they have  
9 adopted something that is significantly conservative  
10 relative to what you might be seeing in this  
11 qualitative definition.

12 So we have existing DCDs that have been  
13 -- gone through the process with a different set of  
14 criteria, but all certainly below the LRF definition  
15 that the staff initially provided.

16 We turn to the LERF track -- in 1995, the  
17 industry issued -- EPRI issued the PSA Applications  
18 Guide, and I was a member of the writing team on  
19 that, along with Carl Fleming and Gareth and Blake  
20 Putney. And one of the things -- the significant  
21 things that we were proud of is coming up with a way  
22 to deal with releases.

23 And we were actually the first people  
24 that proposed LERF as a metric, and we picked it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because we -- for regulatory decisionmaking because  
2 -- we picked it because it could be used without  
3 having to do Level 3 calculations. It was a  
4 mechanistic definition that was easily -- easy to  
5 implement, pragmatic for the industry to use in  
6 decisionmaking, and through work that had been done  
7 on Level 3 PRAs, we saw that it aligned well with the  
8 early fatality QHO.

9 And the basis for the  $10^{-5}$  that we came  
10 up with was not a CCFP or anything like that, but we  
11 had actually -- it was actually backed out from the  
12 acute -- early fatality QHO to be  $10^{-5}$ , much like the  
13 staff ended up doing as part of the 1.174 adoption of  
14 the same metric.

15 And then, since that time, since the mid-  
16 1990s, we have been working on standards that help  
17 define LERF and define how to calculate LERF  
18 properly. And that is the basis on which we have  
19 been moving forward.

20 MEMBER APOSTOLAKIS: This statement  
21 "consistency with LERF goal," again, maybe I didn't  
22 get it, but if the goal for LERF is  $10^{-6}$ , how is this  
23 consistent with that?

24 MR. TRUE: What a great --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Laughter.)

2 Let's go to the next slide.

3 The alignment of LERF and LRF -- so I  
4 went back to this, and I had to dig back through the  
5 files to find all of these things, but I went back to  
6 NUREG-1150. NUREG-1150 was done at that time when  
7 everything was still kind of in play. We were still  
8 working on LRF, and we -- the QHOs were relatively  
9 new.

10 And so in 1150 the staff actually applied  
11 that same qualitative definition that I provided to  
12 LRF, and actually reported for the various risk  
13 calculations that were done what the large release  
14 frequency was for each of those designs.

15 So I went back to that, and I looked,  
16 then, at, well, what NUREG-1150 said about LERF. And  
17 I went to the accident progression bins that 1150  
18 calculated for each of the reactors for internal  
19 events and compared the frequency of LERF that you  
20 would get from the mechanistic definition of LERF  
21 against the large release frequency calculations that  
22 they had done on the Level 3 side of things.

23 And what we actually found was that LERF  
24 was actually 10 times greater than large release

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 frequency.

2 MEMBER CORRADINI: So there is something  
3 about the definition that I would still --

4 MR. TRUE: I told you that I was going to  
5 get people to scratch their head. So the problem is  
6 we probably shouldn't have called it large early  
7 release. We probably should have called it high  
8 early release or significant early release, something  
9 like that, because everyone thinks of a pie that is  
10 made up of -- it's large, and there is a slice that  
11 is large early, and then there is a slice that is  
12 large late.

13 And it -- that's why I stood up and said  
14 it depends what you use as a definition. The  
15 qualitative definition for "large release," which is  
16 the only active viable definition today is actually  
17 tied to the potential for one or more early  
18 fatalities.

19 MEMBER BLEY: So rather than a pie, it is  
20 a layer cake with different releases at each layer,  
21 which is what you --

22 MR. TRUE: In fact, a lot of the work --  
23 I should give Carl credit, Carl Fleming, because when  
24 we were doing the PS application -- and a lot of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 work that goes on at Seabrook bore this out, this  
2 factor of 10 kind of a difference between a large  
3 early release and a LERF being about a factor of 10  
4 different.

5 MEMBER APOSTOLAKIS: Let's see if we can  
6 come up with a concise statement. What is the  
7 difference between the words here, large release  
8 versus large early release? What is the difference  
9 that makes the frequencies different?

10 MEMBER BLEY: One is measuring  
11 fatalities.

12 MEMBER APOSTOLAKIS: LRF.

13 MEMBER BLEY: LRF is measuring  
14 fatalities.

15 MR. TRUE: One or more.

16 MEMBER APOSTOLAKIS: Is referring to the  
17 fatalities. Yes, okay.

18 MR. TRUE: Referring to one or more  
19 release that results in one or more fatalities.

20 MEMBER APOSTOLAKIS: That's right.

21 MR. TRUE: Large early is a release that  
22 has -- that is early before offsite protective  
23 actions have been placed, and large in terms of an  
24 unscrubbed release of -- large quantity of unscrubbed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 fission products.

2 MEMBER BLEY: Which will have a higher  
3 consequence.

4 MR. TRUE: Which could have a higher  
5 consequence under some circumstances, under other  
6 circumstances not. And what you find is, when you go  
7 the Level 3 site, and you have accounted for weather,  
8 and you have accounted for the fact that not all  
9 LERFs happen at exactly the same time, and some  
10 evacuation may have occurred, and all of the factors  
11 that get factored into the translation to actually  
12 having an early fatality, that there is -- there is a  
13 relatively large gap between those large early  
14 releases that have the potential in one way or  
15 another to generate significant offsite consequences  
16 and actually having fatality.

17 MEMBER CORRADINI: So can I try to  
18 differentiate -- I want to make sure, because Dennis'  
19 analogy I think is right on track. So if I go back  
20 -- forget everything in the '80s, let's go back to  
21 WASH-1400. You had nine release categories, or eight  
22 or something. And like --

23 MEMBER APOSTOLAKIS: Wait, wait, wait.  
24 You didn't seem to --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER ARMIJO:     LERF -- if you were  
2     designing a plant, wouldn't you design a plant so  
3     that LERF -- with a factor of 10 lower than LRF?  
4     Because LERF is a more dangerous event. It should be  
5     less probable.

6                   MEMBER CORRADINI:   Can I try? I mean,  
7     just -- because I think this is what is bothering all  
8     of us. I think Dennis' analogy is exactly right on  
9     the money, which is that from the standpoint of what  
10    is released after a degraded accident can have a  
11    large -- larger -- different magnitudes and different  
12    timing.

13                   And so when you -- the way you described  
14    it, I listened but the way he said it is if I have a  
15    very early release with a large amount of activity,  
16    or a lot of radioactivity, I would have essentially a  
17    much lower chance of that occurring. And what you  
18    did, if I understand that last line, is I looked at  
19    all of the binning and found out that more things  
20    were included in the LERF, more categories of  
21    releases.

22                   MEMBER APOSTOLAKIS:   How can that be?

23                   MEMBER BLEY:       Let me try something,  
24    because I think this is right. Let me try something.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 LERF is related to consequences. And we went to  
2 Level 3 to see where the large numbers of  
3 consequences were coming from.

4 LRF is any large release at any time, but  
5 the definition of it wasn't linked to fatalities or  
6 results of risk assessments. It was set at  $10^{-6}$  to  
7 ensure that the things that could have large  
8 consequences were low in frequency. But, in fact, it  
9 included -- because it wasn't design -- because we  
10 hadn't done the PRA, it didn't know everything that  
11 was in there, so it just said any large release at  
12 any time.

13 So the  $10^{-6}$  was done to capture things,  
14 but you are right, if you were designing for the  
15 barrel of things that go into LRF, that could be a  
16 higher frequency than the things that go into LERF,  
17 because they have a higher consequence. It is just  
18 that when the safety goals were set we hadn't really  
19 understood the depth of what contributes to all of  
20 those -- to the consequences, so we just picked the  
21 large release frequency as --

22 MEMBER APOSTOLAKIS: Yes. But that would  
23 argue against the numerical goal they set. I mean, I  
24 can see that --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 MEMBER BLEY: Yes, it worked. It worked,  
2 because they hadn't defined it that clearly at that  
3 time. And the first one is --

4 MEMBER APOSTOLAKIS: LERF, it seems to  
5 me, should be a subset of LRF.

6 MEMBER BLEY: It is, except --

7 MR. TRUE: Not by the way it has been  
8 defined.

9 MEMBER BLEY: But the  $10^{-6}$  should not  
10 have applied to LRF. That is the thing.

11 VICE CHAIRMAN ABDEL-KHALIK: If one were  
12 to drop the L from LERF, then nobody would have any  
13 problems with this statement, right?

14 MR. TRUE: We created a problem  
15 defining --

16 VICE CHAIRMAN ABDEL-KHALIK: Let me just  
17 finish.

18 MR. TRUE: I'm sorry.

19 VICE CHAIRMAN ABDEL-KHALIK: So if one  
20 were to drop the L from LERF, so that we can say  
21 early release frequency is usually greater than 10  
22 times LRF, right? And what that implies is that an  
23 early release may not necessarily cause an offsite  
24 early fatality, an internally consistent definition.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: We are not quite there.  
2 The picture you had up where you said LERF is 10  
3 times LRF, it isn't precisely right. I would say  
4 LERF is 10 times greater than the  $10^{-6}$  that was picked  
5 in the standard, picked in the goal.

6 MEMBER APOSTOLAKIS: Of the --

7 MEMBER RAY: I think I agree with Said,  
8 but I was really trying to say something in response  
9 to Sam, which is these are two different  
10 circumstances. There is no reason why LERF should be  
11 a subset of LRF. They are completely different.

12 MR. TRUE: They are defined in totally  
13 different ways.

14 MEMBER RAY: Yes, right. And, you know,  
15 I mean, you can think of airplane crashes or whatever  
16 you want to think of, they are just different  
17 scenarios that you are addressing the consequences.

18 MEMBER APOSTOLAKIS: But how can the LRF  
19 not --

20 VICE CHAIRMAN ABDEL-KHALIK: Because the  
21 L in both of these acronyms are different.

22 MEMBER RAY: Let me answer you this way,  
23 George. Supposing you have a plant like I am  
24 familiar with -- let the experts debate here.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Guys?

2 MEMBER RAY: In which you have a large  
3 concentration of people near the plant. So early is  
4 a significantly different scenario as far as dose  
5 consequences are concerned than an event that is  
6 longer in time, right? You arbitrarily constrain the  
7 release to be early when there is no ability to  
8 protect this large group of people that are near the  
9 plant.

10 CHAIRMAN BONACA: Well, wouldn't the  
11 LRF --

12 MEMBER BLEY: Well, why don't we let --

13 MEMBER RAY: I don't think so  
14 necessarily, because I am insisting that this be an  
15 early release. It may, in fact, not be a credible  
16 case, but it is something I have insisted upon.

17 MEMBER BLEY: LERF was calculated as an  
18 -- it was what was calculated as an early large  
19 release, and it had high consequences, and that is  
20 how it got picked up from the Level 3.

21 MEMBER APOSTOLAKIS: I makes --

22 MEMBER RAY: Aren't you saying the same  
23 thing I am? It has large consequences because it is  
24 early?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER BLEY:       Yes, but it wasn't  
2 arbitrary. That is -- the scenario that led to it  
3 happening early is what was countered. It wasn't  
4 arbitrarily assumed that it happened then.

5                   MEMBER APOSTOLAKIS: Let's look at this  
6 table and then come back to the discussion. Let's  
7 let Doug --

8                   MR. TRUE:    Okay. So what I did, and the  
9 paper -- the appendix to the paper, attachment to the  
10 paper, goes through this, gives you all of the data  
11 summarized in this single table. We went through the  
12 accident progression bins of NUREG-1150, and those  
13 are described as, for example, early containment  
14 failure without sprays, early containment failure  
15 with sprays, early containment failure with -- in the  
16 drywell, early containment failure in the wetwell  
17 where it would be scrubbed.

18                   And I picked out the accident progression  
19 bins that would meet the LERF definition, the  
20 mechanistic LERF definition.

21                   MEMBER APOSTOLAKIS: LERF.

22                   MR. TRUE:    LERF.

23                   MEMBER APOSTOLAKIS: Yes.

24                   MR. TRUE:    Of being early and having a

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 significant release of unscrubbed fission products --  
2 the mechanistic definition.

3 MEMBER APOSTOLAKIS: Right.

4 MR. TRUE: Which is the way we apply LERF  
5 and the way it is defined in 1.174. Okay?

6 So I just went through the accident  
7 progression bins, picked those ones that were LERF  
8 out, added them up. That is a LERF frequency from  
9 NUREG-1150. Totals are in the first column.

10 The large release frequency is what the  
11 staff reported of having gone through and actually  
12 calculated the frequency of one or more early  
13 fatalities, of a release resulting in one or more  
14 early fatalities.

15 I divided the large release frequency by  
16 the LERF frequency, and it is greater than a factor  
17 of 10. This has been borne out by other Level 3 PRAS  
18 also.

19 MEMBER ARMIJO: Doug, in the LERF, there  
20 is no calculation of actual doses in early  
21 fatalities?

22 MR. TRUE: No. No, it's a mechanistic  
23 definition.

24 MEMBER ARMIJO: But the LRF has that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TRUE: Right.

2 MEMBER ARMIJO: And that is why they are  
3 different.

4 MR. TRUE: That's why they are different.

5 MEMBER RAY: Okay. I was wrong.

6 MR. TRUE: L is just a totally different  
7 thing.

8 MEMBER RAY: I thought you were talking  
9 about dose in both cases.

10 MR. TRUE: You can define it to be L is  
11 always based on some number of curies or something,  
12 but the staff tried to do that, and it is really hard  
13 because there is a whole bunch of factors that go  
14 into that.

15 MEMBER APOSTOLAKIS: LRF includes  
16 additional failures, additional things?

17 MR. TRUE: No. Transport, health  
18 effects. It changes from fission products being  
19 released to health effects.

20 MEMBER APOSTOLAKIS: There is still the  
21 release frequency that you are interested in, not  
22 what happens after. What happens after is part of  
23 your definition. Why would it come down by three  
24 orders of magnitude?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           MEMBER CORRADINI: I think Doug said it,  
2 but I think you should just restate it. I mean,  
3 because I think it -- I think we are all saying the  
4 same thing a different way. Said's way of saying it  
5 -- so you said in the two criteria, two attributes --  
6 one, it was early by some time, and, two, you said  
7 unscrubbed. But I would say unmitigated. That is, I  
8 didn't have a containment system functioning as it  
9 should have to have knocked down whatever was  
10 released.

11           I want to make sure you define the  
12 unscrubbed more precisely, so I understand --

13           MEMBER APOSTOLAKIS: That's all --

14           MR. TRUE: That is true if a containment  
15 -- when a containment spray was considered. The  
16 other one is the BWRs where you have wetwell  
17 failures, so the fission products have to go through  
18 the pool before they make it out. So it is not a --

19           MEMBER CORRADINI: Versus a liner  
20 failure.

21           MR. TRUE: Versus a liner failure, a  
22 drywell failure.

23           MEMBER CORRADINI: Okay. Fine. But  
24 then, I think -- if I could just finish, I think

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Said's way of saying it is -- is I think more  
2 expressive, because it is essentially unscrubbed  
3 early release, regardless of how much is released.

4 Back to the layer cake example, the LRF  
5 is the top, the LERF is a whole bunch of stuff that  
6 gets released based on time, and a definition of what  
7 -- of how it is released.

8 MEMBER APOSTOLAKIS: So it is not  
9 necessarily --

10 MEMBER RAY: But not the --

11 MEMBER APOSTOLAKIS: Is it true, then, to  
12 say that the early release is not necessarily large?

13 MEMBER CORRADINI: Correct.

14 VICE CHAIRMAN ABDEL-KHALIK: Or early  
15 release may not necessarily result in offsite early  
16 fatality.

17 MEMBER CORRADINI: Large enough.

18 MR. TRUE: Well, I also did it based on  
19 cesium-iodide fractions.

20 MEMBER APOSTOLAKIS: Do you agree with  
21 this, what we just said?

22 MR. TRUE: I agree with what --

23 MEMBER APOSTOLAKIS: That the early  
24 release is not necessarily a large release in the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 sense that it may lead to deaths.

2 MR. TRUE: LEFT. The definition of LERF  
3 that we use --

4 MEMBER APOSTOLAKIS: What we call LERF  
5 now is -- it's including all sorts of releases that  
6 do not -- some of them do not necessarily lead to  
7 fatalities, and that is why its frequency is greater.

8 MR. TRUE: Yes. Yes.

9 MEMBER RAY: See, the reason why I  
10 thought that --

11 MEMBER APOSTOLAKIS: The moment I tried  
12 to understand it -- okay.

13 MEMBER RAY: Well, because it had been  
14 said earlier that what was characteristic of the LERF  
15 was that you hadn't time to take mitigating actions.

16 So I just made the natural connection that what that  
17 meant was there was more of a threat. And that may  
18 still be true, I don't know, but in any event it is  
19 not part of the calculation.

20 MEMBER APOSTOLAKIS: But, then, if what  
21 you said is correct, which I understand now, which is  
22 at least for me progress --

23 MEMBER RAY: Yes, it is progress.

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: -- why did they call  
2 it LERF?

3 MEMBER RAY: Because it isn't a small  
4 release or an insignificant release.

5 MEMBER APOSTOLAKIS: But it does include  
6 relatively small --

7 PARTICIPANT: I think you should drop the  
8 L from LERF.

9 MEMBER APOSTOLAKIS: It is too late for  
10 that now.

11 MR. TRUE: You can't do that, because  
12 there are other scenarios -- there are -- like the  
13 drywell failure or wetwell failure scenarios that are  
14 not -- have virtually no potential to cause any --

15 CHAIRMAN SHACK: But you could call it  
16 SERF, significant early release.

17 (Laughter.)

18 MEMBER ARMIJO: I am just trying to  
19 understand this. Just one simple question. Could  
20 you consider the LERF as a reactor-specific term? In  
21 other words, and so this is a characteristic of a  
22 particular reactor, but LERF is a reactor, the site,  
23 doses, and everything else.

24 MR. TRUE: No, it is the other way

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 around.

2 MEMBER STETKAR: Let me try something  
3 here. I know what LERF means, because I have done  
4 the same exercises that you have. I think the  
5 problem is the fact that the second column in your  
6 table is called a large release frequency. It is  
7 actually a surrogate fatality frequency. It is not a  
8 release frequency. It is the frequency of having one  
9 or more fatalities from releases.

10 MR. TRUE: Right.

11 MEMBER STETKAR: And that does include  
12 the offsite consequences, the sheltering, the  
13 weather, everything, which may not be very effective  
14 for a decent fraction of the large early releases,  
15 and may be very effective for a very high fraction of  
16 the large late releases, or whatever. But, indeed,  
17 that second column, it is -- the confusion is the  
18 semantics of calling that a release frequency.

19 MR. TRUE: I only took from NUREG-1150 --

20 MEMBER STETKAR: It is not your --

21 MR. TRUE: This definition -- the  
22 definition that has been qualitatively adopted by the  
23 Commission is a release as a potential for causing  
24 one or more early fatalities. The way that has been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 interpreted, and in fact the way it was interpreted  
2 in the staff's research on trying to define the large  
3 release, was that it was one or more of the -- or  
4 frequency was a release with one or more fatalities.

5 All NUREG-1150 did was go in and say,  
6 "What is that frequency?" and they reported that as  
7 large release frequency.

8 MEMBER STETKAR: After having done,  
9 though, the consequence, seven percent of the  
10 releases do result in a --

11 MEMBER APOSTOLAKIS: In light of what  
12 John just said, I have a sequence. Okay? There is a  
13 release here, but then there are other things that  
14 must happen to have a fatality.

15 MR. TRUE: Right.

16 MEMBER APOSTOLAKIS: I understand what  
17 John said that when we say "large release frequency"  
18 we mean the frequency of the whole thing that leads  
19 to fatalities?

20 MR. TRUE: Yes.

21 MEMBER APOSTOLAKIS: Or just the release  
22 that will eventually lead to fatalities? In other  
23 words, there may be another group of things that must  
24 happen here that have some frequency. So these are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 part of the large release frequency.

2 I mean, the early release frequency,  
3 these are not included?

4 MR. TRUE: Right.

5 MEMBER STETKAR: It is just -- the large  
6 early release frequency is where you drew your first  
7 line in the air with your hand. It is the definition  
8 of a -- not taken out to curie content, but a large  
9 amount of curies that are released --

10 MEMBER APOSTOLAKIS: That is right.

11 MEMBER STETKAR: unscrubbed early. You  
12 don't know what happens to those curies after that  
13 point, so --

14 MEMBER RAY: Yes. But the assumption is  
15 that you are concerned about it because --

16 MEMBER STETKAR: A higher fraction of  
17 those releases may result in a fatality compared to a  
18 large release.

19 MEMBER RAY: That is where I got -- made  
20 the wrong connection.

21 MEMBER APOSTOLAKIS: So the misnomer,  
22 then, is the LRF.

23 So, Stan?

24 MR. LEVINSON: Stanley Levinson from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 AREVA. As I listened to the conversation, I thought  
2 of a very simple way, semantics aside. LRF is the  
3 metric for a Level 2 PRA, or LERF is a metric for a  
4 Level 2 PRA, and LRF, whatever it means, is a metric  
5 for Level 3 PRA.

6 MEMBER APOSTOLAKIS: Which is what John  
7 had said about --

8 MR. LEVINSON: Basically, right.

9 MEMBER ARMIJO: I am going to come one  
10 more time, and then I will give up.

11 MR. TRUE: Okay.

12 MEMBER ARMIJO: LERF is a plant  
13 characteristic. LRF is a plant plus all of the other  
14 stuff that happens.

15 MR. TRUE: Yes.

16 MEMBER APOSTOLAKIS: Can someone take  
17 this down and put it in --

18 (Laughter.)

19 Either you guys or the staff, somewhere  
20 there make the distinction very clear, so next time  
21 we meet we will be again confused.

22 MEMBER CORRADINI: Less.

23 MEMBER APOSTOLAKIS: No. I really  
24 think --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ADER: In the public meeting we had,  
2 Doug made that statement, and I wrestled with it the  
3 same way. When I got the white paper and saw that  
4 there is -- "large" is defined differently, then --

5 MEMBER APOSTOLAKIS: So you agree with  
6 this interpretation.

7 MR. ADER: Yes.

8 CHAIRMAN SHACK: But we still don't know  
9 what the Commission had in mind when they said the  
10 LRF was less than  $10^{-6}$ .

11 VICE CHAIRMAN ABDEL-KHALIK: Well, that  
12 is very clear. Now I understand.

13 CHAIRMAN SHACK: They didn't really have  
14 the definition at the time.

15 PARTICIPANT: Anything more you want to  
16 say about this, Doug?

17 MR. TRUE: Just that this confirmed  
18 the --

19 MEMBER APOSTOLAKIS: Would the staff  
20 entertain, then, the possibility of actually changing  
21 the nomenclature? I mean, excuse me, this is  
22 terrible. This is absolutely terrible, to have all  
23 of these experts here talking for 40 minutes trying  
24 to understand something.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I would change the terminology at some  
2 point -- not LERF, because that is well established,  
3 but LRF -- LRF I think, you know, based on the  
4 interpretation we heard, maybe we need another name.

5 Let's go on. I know nobody is going to  
6 say, yes, we are going to do it.

7 CHAIRMAN BONACA: Could you explain --  
8 what is the conditional probability of LRF given  
9 LERF?

10 MR. TRUE: It is less than .1.

11 MEMBER APOSTOLAKIS: So what he is saying  
12 -- you are saying there is that four percent of all  
13 these sequences in LERF result in --

14 MEMBER BLEY: At Peachbottom.

15 MEMBER APOSTOLAKIS: Yes, yes, yes.

16 MEMBER STETKAR: Four one-hundredths of  
17 one percent of the sequences that are binned into  
18 something called LERF would result in one or more  
19 fatalities. And at Zion, 8.5 percent of the  
20 sequences that are binned into something called LERF,  
21 would result in one or more fatalities.

22 MEMBER APOSTOLAKIS: Okay. So let's keep  
23 going.

24 MR. BRADLEY: George, we are done with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 the LERF versus LRF, so we --

2 (Laughter.)

3 MEMBER APOSTOLAKIS: It is in the  
4 statement somewhere that you favor option 1.

5 MR. BRADLEY: I want to speak to that.

6 MEMBER APOSTOLAKIS: Yes, that's  
7 important.

8 MR. BRADLEY: Okay. So we are going to  
9 move off the lofty world of LERF and LRF and talk  
10 about some -- oh, Charlie is not going to let us go  
11 quite --

12 MR. ADER: Yes, I hate to move on. That  
13 was -- LRF has not been defined. I understand Doug's  
14 logic as LRF was used in 1150. Each of the  
15 applicants, as Don said, has different definitions.  
16 One of the challenges we would have if we go to LRF  
17 is, then, we would have to come to an agreement of  
18 what a definition is. So I understand the logic, but  
19 I don't want to leave the impression that LRF has a  
20 definition that is consistent across the applications  
21 that we are struggling with.

22 MEMBER APOSTOLAKIS: And what I said is  
23 when you come up with a definition which then  
24 everybody will follow you may want to consider

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 changing the words, because it is confusing.

2 MEMBER ARMIJO: How can you calculate  
3 something that hasn't been defined?

4 MR. TRUE: You do it conservatively.  
5 That's what they have done. That's what the  
6 applicants have done is they have used a definition  
7 which they -- any definition of LRF that could be  
8 used, and they submit that and they say, "Look, we  
9 are less than  $10^{-6}$ ." That is my simplistic  
10 characterization.

11 MEMBER APOSTOLAKIS: Okay. I think we  
12 need to move on. So, Biff, you wanted to say  
13 something?

14 MR. BRADLEY: Yes, I wanted to speak a  
15 little more to some of the other reasons we believe  
16 option 1 is viable for --

17 MEMBER APOSTOLAKIS: Which is the status  
18 quo, right?

19 MR. BRADLEY: Right, status quo.

20 MEMBER APOSTOLAKIS: Okay.

21 MR. BRADLEY: I think in reading the NRC  
22 paper there was a presumption in there, or a  
23 concern, that the margin available for risk increases  
24 in a 1.174-type application could be consumed, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that plants could substantially increase their base  
2 CDFs over time above what was considered in the  
3 licensing process.

4 And I just wanted to -- and, you know, we  
5 have looked at this in terms of the operating plants,  
6 and there are a number of things you need to bear in  
7 mind, and that is historically -- and if you look at  
8 how these applications have been implemented -- that  
9 hasn't happened. There are a number of other  
10 constraints; it is not risk-based. It is a risk-  
11 informed process. It includes defense-in-depth,  
12 safety margins.

13 When the applications themselves are  
14 developed, they have all kinds of deterministic  
15 backstops and other elements in there that preclude  
16 you from just sucking up all of that risk that is  
17 theoretically available in the delta CDF, for  
18 instance.

19 Another thing to bear in mind is that the  
20 changes that are granted for -- the vast majority  
21 have been in a very small region which is an order of  
22 magnitude smaller than the allowable region. It is  
23 quite rare for NRC to grant something that goes above  
24 very small. So the reality of application has been

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 these are really constrained by an additional order  
2 of magnitude.

3 The other thing I think is that risk  
4 applications over time, even though each application  
5 may theoretically allow a small delta increase in  
6 risk, the actual effect of these applications has  
7 been shown to lead to or contribute to what -- a  
8 reduction of CDF over time.

9 Obviously, we are not trying to claim  
10 that all of this -- this reduction is all due to  
11 applications. Much of this is due to other things,  
12 plant improvements that were made as a result of the  
13 IPEs, improvements to the modeling methods, more  
14 realism in the models. But it is probably safe to  
15 conclude that the risk-informed applications have led  
16 to a better safety focus at the plant.

17 And we haven't seen a trend of increased  
18 CDF due to large numbers of plants implementing  
19 things like risk-informed tech specs, risk-informed  
20 ISI, etcetera. And this was a picture we showed to  
21 the Commission in a briefing a couple of months ago,  
22 just to try to make the point that while these things  
23 theoretically allow a risk increase, what we have  
24 seen practically has not been that effect.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: But the industry is  
2 not recalculating the CDF every year. What is the  
3 basis for this curve?

4 MR. BRADLEY: These are numbers -- as  
5 part of MSPI, we actually did go back and rebaseline,  
6 look at all of the baseline CDFs. That is the basis.

7 These are -- up to 2005 here, these are --

8 MR. TRUE: That is MSPI data. What  
9 basically we did was we went -- this started in a  
10 paper we wrote back in 2001. We went back from the  
11 1992 to then and gathered information from utilities  
12 on their calculated CDFs. So it is a progression of  
13 how the calculated CDFs have changed, not necessarily  
14 how the actual performance has changed year on year.

15 MEMBER APOSTOLAKIS: So you mean you have  
16 access to CDFs for 2001 and 2003 and --

17 MR. TRUE: Yes.

18 MEMBER APOSTOLAKIS: -- they recalculate  
19 every year?

20 MR. TRUE: Some plants recalculate; some  
21 plants don't. Everybody generally recalculates every  
22 two refueling cycles, so every three or four years.  
23 But each year this is the average of the ones we had  
24 available.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BRADLEY: I mean, the point of all of  
2 this -- go ahead.

3 MR. TRUE: If I can just add one other  
4 thing. Another thing we did to kind of validate this  
5 was we went back to NUREG-1150 -- two NUREG-1150  
6 studies and actually took the dominant cutsets from  
7 those studies, replaced the equipment reliability,  
8 initiating event frequencies, and maintenance and  
9 availability data, with the current NUREG/CR-6928  
10 data for the same events, and found that we got about  
11 a factor of four reduction on just improved industry  
12 performance over that period of time, which I think  
13 really comes out of the maintenance rule and its  
14 focus on the risk-significant equipment, making sure  
15 that we are maintaining that equipment in a good  
16 manner.

17 MEMBER APOSTOLAKIS: What do you mean --  
18 oh, A-4, because --

19 MR. BRADLEY: Configuration of --

20 MEMBER APOSTOLAKIS: What is 50.44? I  
21 forget.

22 MR. BRADLEY: That is the combustible gas  
23 control rulemaking.

24 This is to show some of the major

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applications just on the timeline and where they  
2 started, but the problem being here is that we  
3 haven't observed in reality for the operating plants  
4 an upward creep in CDF due to 1.174 coming into play.

5 VICE CHAIRMAN ABDEL-KHALIK: But without  
6 the incremental changes in CDF produced by these  
7 applications, this line would have dropped a lot  
8 faster.

9 MR. BRADLEY: Well, I mean, that's -- you  
10 could theoretically think that. I don't think that's  
11 true, and I think the things like the maintenance  
12 rule and the risk-informed tech specs actually it  
13 could be argued contribute to better CDF  
14 consideration than what we had in the old  
15 deterministic methods.

16 MR. TRUE: I will give one anecdotal  
17 retort to that also, in that one of the things we  
18 looked at in comparing the data from the study we did  
19 where we took NUREG-1150 and took the new data and  
20 put it into a NUREG-1150 model, was that the  
21 maintenance unavailability had actually gone up,  
22 because we had -- we are doing more online  
23 maintenance than we were doing in the 1990s.

24 But what we found was that the equipment

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reliability improvements that have been gained by  
2 being able to do better focused maintenance, by  
3 having more online maintenance, have actually more  
4 than offset that. And, in fact, the equipment  
5 reliability improvements have greatly outdistanced  
6 that small increase in maintenance unavailability.

7 So I think -- within the data I think  
8 there is even a case that says that at least some of  
9 these have resulted in improvements.

10 MR. BRADLEY: Okay. I know I am running  
11 out of time here. I wanted to -- in Don's  
12 presentation he had a couple of Commission quotes, so  
13 we will do likewise.

14 We are quoting policy. I think you were  
15 quoting expectations. But there are -- this is just  
16 a quote from the 2008 introduction to the advanced  
17 reactor policy statement that just came out in  
18 October of last year. And just -- you can read it.

19 But we believe the Commission has been  
20 consistent in stating that this is a goal, a design  
21 goal for the new reactors, but it doesn't result in  
22 the need for a new regulatory regime. There was also  
23 an effort by the staff some years ago to propose a  
24 whole suite of new regulations that would apply to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 new reactor designs that was also dismissed by the  
2 Commission as somewhat analogous to what is going on  
3 today.

4           So these are just some of the -- this is  
5 all in our paper. And if you have read the paper,  
6 there is nothing new here. We do believe that these  
7 metrics we are using were derived from the safety  
8 goal policy statement. So it would seem that if we  
9 are going to consider changing the metrics we need to  
10 go back and look at the underlying policy statement.

11       I already mentioned the advanced reactor policy  
12 statement.

13           We are concerned -- the new plants do  
14 have better designs, but I think, you know, we have  
15 anticipated being able to use the risk-informed  
16 applications we have developed. The tech specs, for  
17 instance, are just a better way to address equipment  
18 out of service in surveillance intervals. It is much  
19 smarter than the old version of tech specs.

20           And we are concerned if the -- if there  
21 are significant constraints put on the risk metrics,  
22 plants really won't be able to implement those or use  
23 them in the way they were designed.

24           And also, as was mentioned several times,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the whole inspection and enforcement process is  
2 predicated on 1.174-type risk numbers. And it would  
3 appear that a reduction in those would subject the  
4 new plants to inspection and enforcement at levels  
5 that really have minimal correspondence to public  
6 safety.

7 MEMBER RAY: Well, Biff, are you saying,  
8 then, that absolute -- in this problem of absolute  
9 versus relative change for significance  
10 determinations, for example --

11 MR. BRADLEY: Right, yes.

12 MEMBER RAY: -- you would go with  
13 "absolute," is that what you are saying?

14 MR. BRADLEY: Well, I would go with what  
15 we have today, which is "absolute."

16 MEMBER RAY: But even for a plant that  
17 has -- where an absolute change for this new plant  
18 design would be a much more significant change than  
19 it would be for an existing plan.

20 MR. BRADLEY: Well, yes, and I think that  
21 is tempered by some of the other things we are going  
22 to talk about, which is the fact that these are not  
23 -- this came up earlier, that these aren't -- the  
24 risk profiles for these new plants aren't complete

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 yet.

2 So we are seeing some very low internal  
3 events numbers for some of the designs, but 50.71(h)  
4 requires all these plants to have -- meet PRA  
5 standards for internal events, external events,  
6 including seismic and fire, and probably by the time  
7 we get to the actual licensing LPSD as well.

8 So I think we need to bear that in mind  
9 as well, is that the numbers are going to change as  
10 these plants move toward operation.

11 CHAIRMAN BONACA: Don't you have concern  
12 on the ROP?

13 MEMBER APOSTOLAKIS: In fact, Mr. Dube  
14 had a list of disadvantages. It would be useful if  
15 you addressed those.

16 MR. BRADLEY: Yes. We have looked at --  
17 and, you know, we had -- at the public meeting we  
18 discussed those and suggested some others that are in  
19 our paper, but we --

20 CHAIRMAN BONACA: Could you go over them  
21 now? I mean, we could look at it.

22 MEMBER APOSTOLAKIS: Or we can do it at  
23 the subcommittee level. If he wants to --

24 MR. TRUE: The fact of the matter is this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whole thing came on us fast, so we tried to get the  
2 first paper out. We just sort of set the stage. I  
3 think it may be better to come back and go through  
4 the --

5 MR. BRADLEY: Let me -- I could finish  
6 this, and if we still have time I would be happy  
7 to --

8 MEMBER APOSTOLAKIS: Sure, sure, sure.

9 MR. BRADLEY: -- go back and look at his  
10 slide.

11 One of the problems we are concerned  
12 about is really not a technical problem, it is more  
13 just a perception issue of having co-located sites  
14 where you are having enforcement actions and things  
15 that show up, you know, in the press or whatever at  
16 totally different levels. We believe that is a very  
17 difficult thing to explain and for the public to  
18 understand.

19 MEMBER CORRADINI: Let me make sure I  
20 understand what you are saying. So your point is if  
21 I've got Plant X that was built 40 years ago, and  
22 Plant Y that is coming up in five years, and they  
23 have different absolute standards, that causes a  
24 confusion by the public?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BRADLEY: Yes. You could add --

2 MEMBER CORRADINI: What is the confusion  
3 if I have a plant -- just so we're clear, what is the  
4 confusion of the plant that I -- I have a new  
5 technology, and I only demand it to be as safe as a  
6 60-year old technology.

7 MR. BRADLEY: Well, that is not -- I  
8 don't think that is what we are saying.

9 MEMBER CORRADINI: Well, but, I mean,  
10 that is kind of what I heard the argument is in  
11 reverse.

12 MR. BRADLEY: No. This is really just,  
13 you know, enforcement space. It just -- there is  
14 supposed to be a correlation in enforcement to public  
15 safety. Regardless of the plant design, I mean, if  
16 these things are at an arbitrary level, it is way  
17 below any kind of, you know, goals that we have used  
18 up to now, there would seem to be a different  
19 standard being applied.

20 MEMBER APOSTOLAKIS: It seems to me in  
21 different words, really, but the same thing. It  
22 depends on how you look at the Commission's goals.  
23 The Commission's goals are not for LWRs. The  
24 Commission's goals are a statement of the American

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 public as to what risk is acceptable for reactors.  
2 And that is independent of the type of reactor you  
3 are using.

4 If you look at it that way, then your  
5 comment doesn't apply, because the Commission says as  
6 long as you are below  $10^{-4}$ , say, core damage  
7 frequency, that is good enough.

8 MEMBER CORRADINI: So let me just counter  
9 that from a policy standpoint. If I go from 104  
10 reactors to 110 --

11 MEMBER APOSTOLAKIS: That is different.

12 MEMBER CORRADINI: -- at sites that are  
13 co-located as populations are growing, that addresses  
14 the policy. What I am asking is from the standpoint  
15 of just a design standpoint, because I do agree with  
16 you how you enforce it might be different than how  
17 you design it.

18 I thought that -- at least I thought Mr.  
19 Dube's discussion was there could be a break -- a  
20 difference as to what I have for essentially allowing  
21 for a new design versus how I enforce it. And I  
22 think you used the word ROP or --

23 MEMBER APOSTOLAKIS: Yes.

24 MR. BRADLEY: And I think we even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 suggested -- I think one of the reasons we've got a  
2 roomful of people here is that this enforcement is  
3 very, very large.

4 MEMBER CORRADINI: I understand.

5 MR. BRADLEY: CLB changes is one thing,  
6 but to say we are going to start enforcement at a  
7 different level, that gets a lot of attention.

8 MEMBER CORRADINI: I appreciate that. I  
9 appreciate that.

10 MR. BRADLEY: And we have even suggested  
11 that if there is a way to divorce that and have a --  
12 because there is a rush to do this rapidly. I think  
13 getting the enforcement part out of the immediate  
14 concern would make things a lot better.

15 MEMBER CORRADINI: Okay. Thank you.

16 MR. BRADLEY: Okay. Another issue that  
17 we struggle with even today, we are, you know,  
18 working on things like SDPs, where you are down in  
19 the  $10^{-7}$ s, fire PRA, change evaluations. These things  
20 are already down --  $10^{-7}$ ,  $10^{-8}$ s -- where we are  
21 starting to get swamped by the uncertainty bands in  
22 PRA, and it is really difficult to make, you know,  
23 well-informed decisions when the thresholds are deep  
24 within the uncertainty bands. And we are worried

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that lowering them further is just going to  
2 exacerbate that even more.

3 So that is just another concern we have  
4 with the state of the technology, and, really, its  
5 ability to go to those low numbers.

6 We are concerned that if there is a  
7 suggestion or a lowering of the values that the --  
8 you know, new plants will not be able to use risk  
9 applications that we have spent years developing, and  
10 that in many cases are just a better way to run the  
11 plant.

12 And, finally, as I mentioned, the CDFs  
13 that are -- the DCD CDFs are internal events, fire,  
14 and selected LPSD. Seismic is done separately  
15 through SMA. There is no quantification of CDF for  
16 seismic, so that is set aside for the LRF and the  
17 CCFP work that the new reactors do.

18 Now, 50.71(h) is going to require full  
19 quantification of seismic, fire, internal, and  
20 possibly shutdown one year prior to fuel load. So I  
21 think we need to bear that in mind, that we make  
22 decisions predicated on like the DCD numbers that Don  
23 showed earlier. They may not hold up once we get to  
24 that point.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1           There is also -- Part 52, I mentioned all  
2 of the backstops. Don made a statement that we could  
3 have large periods of unavailability. Well, that is  
4 not -- that is really constrained -- I am assuming he  
5 is referring to Tech Spec 4B. There is a  
6 deterministic backstop. You can never have anything  
7 unavailable longer than 30 days regardless of the  
8 risk impact.

9           So there are -- these things aren't  
10 really allowing you to suck up all of that, you know,  
11 or have huge amounts of unavailability. That is  
12 really a misnomer. There are all kinds of  
13 constraints that are built into these applications.

14           As a matter of fact, there is a  
15 cumulative -- we have talked about cumulative  
16 impacts. Some of these -- 4B, 5B -- actually have  
17 requirements to go cumulatively look at the impact of  
18 what you are doing and adjust it as necessary if your  
19 CDF is going up.

20           So a lot of that is really built into the  
21 applications. A lot of the things that the NRC paper  
22 seems worried about are really taken care of pretty  
23 well in the applications themselves.

24           Just a final note. This really isn't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pertinent to -- directly pertinent to this, but the  
2 design features that are put into the new plants that  
3 make them so much safer, both in-vessel, ex-vessel,  
4 all the design features, those things are codified  
5 into the DCD and the COL process.

6           They can't be -- there is Tier 1, Tier 2  
7 requirements. There is a change control process with  
8 explicit consideration of severe accidents. We have  
9 gone way beyond what we do for operating plants there  
10 that -- these things are locked in place, and there  
11 is strong change control. So if the concern is we  
12 are going to remove features from the plants, that,  
13 you know, there is other deterministic constraints in  
14 the regulation that would preclude that. So just to  
15 note that.

16           So, in summary, we believe, you know,  
17 Part 52 has been very effective for design and  
18 licensing, but that once we transition to the  
19 operating phase, in part due to a lot of these  
20 definitional issues we have discussed, we should --  
21 we believe 1.174 is adequate and supportable.

22           Obviously, the definition of LRF and LERF  
23 and all of this discussion we had today plays into  
24 that determination, but we believe that we can make

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that case. And we think it is good to have a  
2 consistent Commission policy across the fleet, and so  
3 -- that's all we have.

4 MEMBER APOSTOLAKIS: Thank you, Biff.

5 I would really like to have a  
6 subcommittee meeting with more time to discuss these  
7 things. And I hope you guys would be willing to  
8 come.

9 MR. BRADLEY: Yes.

10 MEMBER APOSTOLAKIS: So maybe we can  
11 schedule this offline at some point in the near  
12 future. And I will say -- I will repeat what I said  
13 a long time ago, that you don't have to have  
14 definitive answers to questions before they come to  
15 us. We will do it the way we did 1.174.

16 I mean, if you have what you would  
17 consider a half-baked idea, let's talk about it. You  
18 know, and there is no --

19 (Laughter.)

20 Didn't we do that -- quarter data.

21 CHAIRMAN BONACA: I would like to  
22 understand what are the next steps that they are  
23 planning. Could I --

24 MEMBER APOSTOLAKIS: Charlie, do you want

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to brief us as to --

2 CHAIRMAN BONACA: Tell us what the next  
3 steps are going to be and the timing of it.

4 MR. ADER: We are trying to take the  
5 information we got from the public meeting. We've  
6 got the industry white paper now. We have internally  
7 been discussing, but we need to start putting on  
8 paper, again expanding the white paper that Don had  
9 written to better define what we would see advantages  
10 and disadvantages, to a set of options.

11 They may not be the options that were in  
12 the white paper. They may be a subset, or they may  
13 be the same.

14 I am anticipating over the next several  
15 months we need to start narrowing some of that down.  
16 We don't have a definitive date that we have to  
17 deliver a product, but we need to -- from our end we  
18 need to try to move it through at a timely -- I won't  
19 say rapid, but a timely pace, because it is I think a  
20 significant issue that needs a fair amount of  
21 discussion. We want to try to allow that.

22 CHAIRMAN BONACA: But there are some  
23 pieces -- for example, we just heard that, you know,  
24 there is a belief that Reg. Guide 1.174 should be as

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effective as it is today. Now, we need to verify  
2 that.

3 MEMBER APOSTOLAKIS: And discuss it.

4 CHAIRMAN BONACA: And discuss it. And so  
5 do you have plans for doing that, a kind of analysis  
6 and understanding and -- because that is -- will be,  
7 on our part, for example, opportunity for  
8 participation.

9 MEMBER APOSTOLAKIS: Yes. I mean, at  
10 which timeframe do you think we can have a  
11 subcommittee meeting? The fall?

12 MR. ADER: We would hope that we would be  
13 before that. I know your schedule is going to be  
14 difficult, but -- and from our perspective, we do --  
15 from New Reactors, we do have an application in that  
16 is trying to take advantage of risk-informed tech  
17 specs. We are trying to accommodate that  
18 application.

19 So this is -- originally, when we looked  
20 at this issue, we were saying this is -- this is four  
21 years down the road. We don't have to worry about it  
22 until we have operating -- you know, have granted the  
23 COLs. We are starting to see the applications, so we  
24 are trying to support that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           By doing that, that would -- we would  
2           tend to want to narrow the focus of what we are  
3           trying to do and not solve all of the issues that are  
4           out there.   Some of this is a policy decision of  
5           where you want to go, where the Commission wants to  
6           go, with the current risk metrics versus new risk  
7           metrics with their expectations of enhanced safety.

8           We would like to try to get that  
9           decision, and that would start framing -- if the  
10          Commission says "status quo," then our work to  
11          implement this is very minimal.   If the Commission  
12          says, "No, we would like to -- we have given you  
13          direction to use a more restrictive LRF definition,  
14          and we would like you to implement that, then we have  
15          a fair amount of work."   If they take a different  
16          tack, then it could open it up, so --

17                   MEMBER APOSTOLAKIS:   I was --

18           MR. ADER:   I guess what I am saying, I  
19          would not see -- I mean, we will take this question  
20          back on 1.174 issues, but I would not see trying to  
21          tackle those until we have tried to deal with the --  
22          you know, the fundamental policy issues that we --

23                   MEMBER APOSTOLAKIS:   But you have already  
24          sent this -- the SECY to the Commission.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ADER: We have sent the white paper  
2 to the Commission to inform them of these were the  
3 issues that we were -- seeing implementation issues  
4 that we would start engaging stakeholders.

5 MEMBER APOSTOLAKIS: I would really like  
6 to have a subcommittee meeting before you guys send  
7 the recommendation to the Commission.

8 MR. ADER: We would anticipate that.

9 MEMBER APOSTOLAKIS: Good.

10 MR. HAMZEHEE: That means it has to  
11 happen soon, if you want to have that subcommittee  
12 meeting.

13 MEMBER APOSTOLAKIS: You don't want it  
14 not to happen, because if we disagree we are going to  
15 end up, again, you know, they sent this letter and  
16 now they disagree with the staff, let's do it before  
17 you send any recommendations.

18 MR. ADER: That would be --

19 MEMBER APOSTOLAKIS: What we want --

20 MR. ADER: No, that would be our plan,  
21 clearly.

22 MEMBER APOSTOLAKIS: So we will schedule  
23 a meeting, then, offline. The calendar is already  
24 full for the next few months.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Any other comments or questions from  
2 members?

3 MEMBER RAY: Yes. George, I wanted to --  
4 Biff said something that I absolutely agree with. It  
5 applies to other things we are discussing here now --  
6 I just wanted to reinforce it -- which was at some  
7 point you can just establish an arbitrary limit, a  
8 deterministic limit that eliminates this concern that  
9 people develop over, well, on a probabilistic basis  
10 we can do -- take something out of service forever.

11 Take my battery charger, for example. It  
12 always used to drive me nuts the short time you could  
13 have the battery charger out of service.

14 Well, on a risk-informed basis, it would  
15 be out a long, long time, but it doesn't need to be  
16 and it shouldn't be. So my point is simply to  
17 underscore that sometimes in order to get the  
18 advantages of PRA you need to have some reasonable  
19 deterministic, arbitrary limit, and just say that's  
20 it. And --

21 MEMBER APOSTOLAKIS: These are the  
22 backstops he mentioned?

23 MEMBER RAY: Yes. That's what he said.  
24 And he mentioned that -- and it was in a hurry, and I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



1 just wanted to underscore it, because I think it's  
2 important.

3 MEMBER APOSTOLAKIS: Anything else from  
4 the members? Yes, sir.

5 MEMBER BLEY: Just two points. One, I  
6 want to thank Doug for the great presentation. And I  
7 guess my memory of how LERF had come about -- I had  
8 been doing Level 3 PRAs -- was a little corrupt. I  
9 thought we did it from the Level 3 back, but we did  
10 it from the Level 2 bins that could lead to Level 3  
11 consequences.

12 The only point I want to make is LERF  
13 does have the potential -- any LERF, any large  
14 unscrubbed release has the potential for one or more  
15 fatalities. But the LRFs that were calculated, the  
16 ones the staff had done, are the ones that were  
17 actually calculated in Level 3 to lead to one or more  
18 fatalities.

19 And that is a distinction that still  
20 causes us a little of the problem you raised in the  
21 beginning, George. That's all.

22 MR. TRUE: It is also true, though, that  
23 SERFs --

24 (Laughter.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 -- small early releases --

2 (Laughter.)

3 MEMBER APOSTOLAKIS: Any other comments?

4 MR. TRUE: -- has the potential.

5 MEMBER APOSTOLAKIS: The staff, do you  
6 have any comments, parting remarks?

7 (No response.)

8 The public? Anyone who wants to say a  
9 few words?

10 (No response.)

11 Well, thank you very much, gentlemen.

12 And, Don, this was very informative.

13 Back to you, Mr. Chairman.

14 CHAIRMAN BONACA: Yes, very helpful  
15 indeed.

16 With that, we will take a break until  
17 10:50, and close the record at this point.

18 (Whereupon, at 10:34 a.m., the proceedings in the  
19 foregoing matter went off the record.)

20

21

22

23

24

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

# **Risk Metrics for Operating New Reactors**

**ACRS Committee Meeting**

**April 3, 2009**

**Biff Bradley - NEI**

**Doug True - ERIN**



NUCLEAR  
ENERGY  
INSTITUTE

# Overview

- Issue
- Evolution of risk metrics
- PRA & risk metrics in design and licensing
- Risk metrics in the operational phase
- LRF vs. LERF
- Quantitative thresholds
- Problems with different metrics

# Issue to be Addressed

- **NRC paper on risk metrics recently provided to ACRS and Commission**
  - Perceived differences in risk metrics and thresholds between Part 52 licensing and currently operating plants
  - Concern with existing NRC risk informed processes (CLB changes, reactor oversight process, MSPI)
  - Prior NRC policy decisions called into question
  - Proposes six options for consideration
- **Industry supports Option 1 (same metrics as for existing plants)**

# Evolution of Risk Metrics

- **Part 52 risk metrics preceded Regulatory Guide 1.174 development**
- **Design Certifications and COLs rely upon:**
  - Core Damage Frequency (CDF)
  - Conditional Containment Failure Probability (CCFP)
  - Large Release Frequency (LRF)
- **Operating plants rely upon:**
  - CDF
  - Large Early Release Frequency (LERF)

# PRA & Risk Metrics in Design and Licensing

- **Part 52 requirements and risk goals for new plants have put appropriate focus on:**
  - **A low and balanced computed CDF,**
  - **A low computed CCFP ( $<0.1$ ) for the corresponding computed CDF, and**
  - **A low LRF for the corresponding computed CDF.**
- **These metrics have been effective for design and initial licensing purposes**



# LRF History

- **Safety Goal Policy Statement introduced large release expectation**
- **Staff initially defined LRF qualitatively:**
  - “A large release is a release that has a potential for causing an offsite early fatality.”*
- **Commission directed staff to provide more quantitative definition**
- **In 1993, the Commission directed NRC staff to abandon efforts to quantitatively define LRF**
- **New reactor vendors have provided their own definitions**
  - Unique to Design Certification application
  - Generally very conservative and simplified definitions

# LERF History

- In 1995, EPRI PSA Applications Guide introduced LERF as a risk metric
- Mechanistic definition, aligned to early fatality (EF) QHO
- LERF quantitative threshold of  $1 \times 10^{-5}/\text{ry}$  suggested based on
  - Level 3 PRAs
  - Consistency with LRF goal
- Staff adopted LERF for RG 1.174 as surrogate for EF QHO
- PRA standards developed to address LERF

# Alignment of LERF & LRF


- **NUREG-1150 applied staff qualitative definition of LRF**
- **Recent comparison performed of internal event LERF accident progression bins to computed LRF**
- **Results show for all NUREG 1150 plants:**  
 **$LERF > 10 * LRF$**

# NUREG-1150 LERF vs. LRF

<b>Plant</b>	<b>Estimated LERF (/yr)</b>	<b>Large Release Frequency (/yr)</b>	<b>Conditional Probability of LRF Given LERF</b>
Peach Bottom	2.27E-06	1.0E-09	0.04%
Surry	5.29E-06	2.0E-07	3.8%
Grand Gulf	6.46E-07	3.0E-10	0.05%
Sequoyah	6.75E-06	6.0E-07	8.9%
Zion	7.10E-06	6.0E-07	8.5%

# Risk Applications at Operating Plants

- **RG 1.174 applications have not led to increased CDFs or reduction of margin**
  - **Changes constrained by other elements of risk informed process (DID, margins, etc)**
  - **Changes mostly granted in “very small” delta risk region of RG 1.174**
  - **Risk informed applications have led to improved safety, not reduction of safety**



# Risk Metrics in The Operational Phase

- Commission consistent in maintaining that new reactors would not be measured against a more stringent risk requirement
- Reiterating in 2008:  
*“... the policy statement\* does not state that advanced reactor designs must be safer than the current generation of reactors, but rather that they must provide the same degree of protection of the environment and public health and safety and the common defense and security that is required for current-generation light-water reactors.”*

\*Policy statement on Advanced Reactor Regulation, October 14, 2008

# Problems with different or new metrics for Part 52 plants

- **Inconsistent with commission policy**
  - Safety goal policy statement
  - Advanced reactor policy statement
- **New risk metrics would penalize new plants**
  - Limit operational flexibility (maintenance rule, Tech Specs)
  - Subject plants to inspection and enforcement at levels not corresponding to public health and safety
- **New risk metrics would create public perception problems**
  - For example, co-located sites with different thresholds for enforcement actions



# Problems with different or new metrics for Part 52 plants

- The proposed risk metrics values could be well within PRA uncertainty bands
- Proposed new risk metrics could truncate ability of new plants to use risk applications
- Risk profiles for new reactors are not yet complete
  - Internal events, fire, external events (seismic) and possibly shutdown PRA will be required prior to fuel load

# Preservation of Safety

- Risk applications contain deterministic backstops and DID considerations
- Part 52 contains comprehensive change control process that addresses severe accident features

# Summary

- **Part 52 licensing process and commission policy effective in enhancing new reactor severe accident prevention and mitigation capability**
- **New reactors should transition to RG 1.174 risk metrics when operating**
- **Maintains consistent commission policy and rational regulatory framework**



# **Implementation of Risk Metrics for New Light-Water Reactor Risk-Informed Applications**

**Advisory Committee on Reactor Safeguards**

Donald A. Dube, NRC, Office of New Reactors (301) 415-1483

**April 3, 2009**



# Meeting Purpose

**Brief the ACRS regarding the implementation of risk metrics for new light-water reactor risk-informed applications, and identify potential paths forward.**

# Agenda

- **Near term and longer term needs**
- **Background**
- **Implementation issues**
- **Options**
- **Status**



# **Risk-Informed Initiatives for New Reactors**

- **In the near term, risk-informed applications have been proposed:**
  - **Risk-Managed Technical Specifications**
    - **Risk-informed completion times**
    - **Surveillance frequency control program**
- **Longer term initiatives (post-COL) may include:**
  - **EPRI research program on risk-informed inservice inspection of piping**
  - **Special treatment requirements (10CFR50.69)**



# Background: Risk Metrics for Operating Reactors

- **Core Damage Frequency (CDF)  $< 10^{-4}$  /yr**
  - **Surrogate for latent cancer fatalities in the Commission's quantitative health objective (QHO)**
  
- **Large Early Release Frequency (LERF)  $< 10^{-5}$  /yr**
  - **Surrogate for prompt fatalities in QHO**





# Risk Goals for New Reactors

- **Core Damage Frequency (CDF)  $< 10^{-4}$  /yr**
- **Large Release Frequency (LRF)  $< 10^{-6}$  /yr**
- **A deterministic goal that containment integrity be maintained for approximately 24 hours following the onset of core damage for the more likely severe accident challenges**
- **Conditional containment failure probability (CCFP) less than approximately 0.1**

# Commission's Expectations

The Commission “fully expects that vendors engaged in designing new standard (or custom) plants will achieve a **higher standard of severe accident safety performance** than their prior designs.”


- August 1985

“The Commission expects that advanced reactors will provide **enhanced margins of safety** and/or utilize simplified, inherent, passive, or other innovative means to accomplish their safety functions.”


- July 1994

# CDF and LRF by Plant Type

(internal events at-power for U.S. plants only)



(internal events at-power only)



Source:  
 NUREG-1560

## **Background (cont.)**

- **New reactor applicants' PRAs are expected to demonstrate how the design compares against the Commission Goals**
  - **RG 1.206, "Combined License Applications for Nuclear Power Plants (LWR Edition)"**
  - **Standard Review Plan (SRP) Chapter 19.0, "Probabilistic Risk Assessment and Severe Accident Evaluation for New Reactors"**
- **Regulatory guidance associated with risk-informed initiatives are based on LERF (e.g., RG 1.174, 1.175, 1.177, 1.178, 1.201)**

# **New Reactor Implementation Issues**

- **Review of these applications has raised questions about risk metric acceptance guidelines for implementation of risk-informed initiatives for new reactors:**
  - **LERF versus Commission's goal on LRF**
  - **LRF was not previously finalized in NRC documents.**
- **Use of current numerical risk metric goals (e.g., LERF) would result in risk-informed applications/amendments being evaluated against less restrictive criteria than those used for the licensing basis of new reactors.**

# New Reactor Risk Metrics

- **Licensing:**
  - How should acceptance guidelines for new reactor license applications or amendments proposing to implement risk-informed initiatives consider Commission's expectations:
    - CDF?
    - LRF?
- **Operations:**
  - Reactor Oversight Process thresholds rely on CDF,  $\Delta$ CDF, conditional core damage probability (CCDP), incremental CCDP, LERF,  $\Delta$ LERF, etc.
  - How should risk metrics for new reactor operations consider Commission's expectations?
- **Focus on needs for licensing first**

# Regulatory Guidance

- **Regulatory Guide 1.174, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis”**
- **Risk-Acceptance Guidelines:**
  - **Baseline risk metrics of CDF and LERF**
  - AND**
  - **$\Delta$ CDF and  $\Delta$ LERF due to change**
- **Basis:**
  - **Increases should be limited to **small** increments**
  - **CDF threshold related to backfit regulatory analysis guidelines**
  - **$\Delta$ CDF limit based on **absolute** change and set close to limit of resolution of PRA models**

# From RG 1.174




Figure 3. Acceptance Guidelines for Core Damage Frequency (CDF)




Figure 4. Acceptance Guidelines for Large Early Release Frequency (LERF)



- **For new reactors, should the principle of “small increase” be based on *relative* or *absolute*  $\Delta$ CDF and  $\Delta$ LERF or  $\Delta$ LRF?**
- **Should RG 1.174 include an alternate or additional  $\Delta$ LRF acceptance guideline for new reactors?**

# Regulatory Guidance (Cont.)

- Other programs, processes, and regulations:
  - **Regulatory Guide 1.163, “Performance-Based Containment Leak-Test Program”** (specifically, ILRT test interval extension)
  - **Regulatory Guide 1.175, “An Approach for Plant-Specific, Risk-Informed Decisionmaking: Inservice Testing”**
  - **Regulatory Guide 1.177, “An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications”**
  - **Regulatory Guide 1.178, “An Approach for Plant-Specific Risk-Informed Decisionmaking for Inservice Inspection of Piping”**
  - **Regulatory Guide 1.200, “An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities”**
  - **Regulatory Guide 1.201, “Guidelines for Categorizing Structures, Systems, and Components in Nuclear Power Plants According to Their Safety Significance,” 10CFR50.69**
  - **10CFR50.65, “Maintenance Rule”**

## Some Possible Options

- **Option 1 Status Quo:** Current acceptance guidelines in RG 1.174 (and associated regulatory guides) would also be applied to new reactors
- **Option 2 Convert to *Relative Risk Changes*:** New and current reactors
- **Option 3 Reduce Acceptance Guidelines for New Reactors:** Acceptance guidelines in RG 1.174 would be lowered by 1 or more orders of magnitude solely for new reactors
- **Option 4 Use a Combination of Existing and New Acceptance Guidelines**
- **Option 5 Use Existing Acceptance Guidelines for Current and New Reactors (*Status Quo*), but Establish an LRF-Based Acceptance Guideline for New Reactors**
- **Option 6 Assess New Reactors on a Case-by-Case Basis**

# Status

- **White paper issued (Adams # ML090430220)**
- **EDO Memorandum to Commissioners, February 12, 2009 (ML090160008)**
- **Public meeting held February 18, 2009**
- **Presentation at RIC 2009**
- **Continued engagement of stakeholders**



## Results of February 18, 2009 Public Meeting

- **Broad representation of stakeholders in attendance**
- **Staff described pending risk-informed applications and implementation issues**
- **Significant discussion on derivation of LRF and CCFP**
- **Advantages and disadvantages of each option discussed**
- **Additional sub-option suggested whereby one might proceed with the current set of risk metrics per RG 1.174 on the first few risk-informed applications, then to assess the need for change based on lessons learned**
- **Industry to follow-up with white papers regarding its views on the historical perspective of *large release* as well as preferred option(s)**



# Back-up Slides

# Options in Detail

**Option 1 Status Quo:** Current acceptance guidelines in RG 1.174 (and associated regulatory guides) would also be applied to new reactors

## Advantages

- Provides a consistent set of acceptance guidelines for both existing and new reactors
- The bases for RG 1.174 acceptance guidelines are derived from Commission's 1986 Safety Goals
- Acknowledges and gives credit to new reactors for lower risk estimates

## Disadvantages

- May not be consistent with Commission 1985 policy statement on expectations that new reactor designs "will achieve a higher standard of severe accident safety performance...."
- Less restrictive change process than the Commission established for the review of new reactors
- Options could allow large **relative** increases in CDF and LERF compared to the baseline CDF and LERF estimates for new reactor designs

# Options (cont.)

## Option 2 Convert to *Relative* Risk Changes: New and current reactors

### Advantages

- Option recognizes that “small increase” is a relative measure and precludes large % change in CDF and/or LERF for new reactors

### Disadvantages

- Inconsistent with the underlying technical basis for the current *absolute* thresholds in RG 1.174
- Potential disagreement between industry and staff regarding what constitutes the “baseline” for CDF and LERF changes
- Major changes to current regulatory guides and other processes would be required
- Impacts currently operating reactors
- Results in inconsistency between existing and new reactors, and may be viewed as penalizing new reactors for having lower risk estimates
- Transition from existing *absolute* acceptance guidelines to *relative* (% changes) could be difficult
- Depending on the chosen limits for acceptance guidelines, past conditions that were deemed acceptable might not be found acceptable under the new formulation



# Options (cont.)

## **Option 3 Reduce Acceptance Guidelines for New Reactors:**

Acceptance guidelines in RG 1.174 (and associated regulatory guides) would be lowered by 1 or more orders of magnitude solely for new reactors

### **Advantages**

- Acknowledges that new reactor CDF/LERF estimates are significantly lower than existing reactors and adjusts acceptance guidelines accordingly
- Consistent with Commission policy statements on expectations that new reactor designs “will achieve a higher standard of severe accident safety performance....”

### **Disadvantages**

- Inconsistent with the underlying technical basis for the current **absolute** thresholds in RG 1.174
- Penalizes new reactors for having lower risk estimates
- Results in different treatment for new and current reactors of a proposed licensing basis change resulting in a  $\Delta$ LERF of  $4 \times 10^{-8}$ /yr, for example
- May be inconsistent with the Commission’s Safety Goal Policy Statement on acceptable level of risk

## Option 4 Use a Combination of Existing and New Acceptance Guidelines

### Advantages

- Option addresses some of the concerns regarding large **relative** changes to risk with new reactors
- Consistent with Commission policy statements on expectations that new reactor designs “will achieve a higher standard of severe accident safety performance....”

### Disadvantages

- Inconsistent with the underlying technical basis for the current **absolute** thresholds in RG 1.174
- Penalizes new reactors for having lower risk estimates
- Results in different treatment at new and current reactors of a proposed licensing basis change resulting in a  $\Delta$ LERF of  $4 \times 10^{-8}/\text{yr}$
- May be inconsistent with the Commission’s Safety Goal Policy Statement on acceptable level of risk

# Options (cont.)

## **Option 5 Use Existing Acceptance Guidelines for Current and New Reactors (*Status Quo*), but Establish an LRF-Based Acceptance Guideline for New Reactors**

### **Advantages**

- Option consistent with the goals that the Commission established for the review of new reactors
- Provides a consistent set of acceptance guidelines for both existing and new reactors with regard to  $\Delta$ CDF
- Consistent with the underlying technical basis for the current absolute thresholds for  $\Delta$ CDF and  $\Delta$ LERF in RG 1.174, as modified to reflect Commission policy regarding  $\Delta$ LRF for new reactors
- Consistent with Commission policy statements on expectations that new reactor designs “will achieve a higher standard of severe accident safety performance....”
- Allows anticipated risk-informed initiatives to move forward

### **Disadvantages**

- Options could allow large *relative* increases in CDF and LERF compared to baseline CDF and LERF estimates for new reactors
- Requires significant changes to regulatory guides

## Option 6 Assess New Reactors on a Case-by-Case Basis

### Advantages

- No changes needed to regulatory guides and related documents for current reactors
- Staff could await the accumulation of sufficient new reactor operating experience before making a decision on the treatment of new reactors

### Disadvantages

- Current and new reactors would be treated inconsistently
- New reactor applicants/licensees would not know the acceptance guidelines for risk-informed initiatives
- Defers any decision on the treatment of new reactors