

# **Appendix I Pump Station Technical and Detailed Report**

---





Pre-Hurricane Katrina – View from Inlet Canal

**4200 Jean Lafitte Pkwy.  
Chalmette, LA 70043  
504.512.6331**

Position: Latitude 29.966557° Longitude -89.975821°



Pre-Hurricane Katrina – Arial view of pump station

### **Pump Station Description**

Fortification is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three vertical pumps that were installed in 1972 with a total pumping capacity of 980 cubic feet per second (cfs)<sup>1</sup>. Two of the pumps are driven by diesel engines and one by an electric motor. The drainage water is supplied to the pumps from the Florida Walk canal and discharges through the interior back levee to the marsh known as

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

Bayou Bienvenue. The individual pump discharges have a tainter gate installed to cut off water flow in either direction.

## **Pump Station Operation**

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately -6 feet (NGVD) and turned off when the water level reaches -6.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -8.5 feet (NGVD). If the water elevation on the discharge side of the pump station is predicted to exceed 3.5 feet (NGVD) the station operator closes the discharge tainter gates.

## **Fuel Endurance Calculation**

### Assumptions :

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 1 Fortification**

3 pump drivers - 2 diesel and 1 electric. The diesels are rated at 1200 horsepower

The approximate burn rate for each diesel is then calculated:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{1200\text{hp}}{500\text{kW}} \qquad R_{\text{burn}} = 62.639 \frac{\text{gal}}{\text{hr}}$$

### Fuel Capacity

- 4 - 5000 gallon tanks
- 2 - 110 gallon day tanks

### Fuel Endurance

The time the 5000 gallon tanks will last is calculated:

$$t_1 := \frac{4 \cdot 5000\text{gal}}{2R_{\text{burn}}} \qquad t_1 = 159.645 \text{ hr}$$

The time the 110 gallon tanks will last is calculated:

$$t_2 := \frac{2 \cdot 110\text{gal}}{2R_{\text{burn}}} \qquad t_2 = 1.756 \text{ hr}$$

The approximate total continuous run time for the pump station is:

$$T_t := t_1 + t_2 \qquad \boxed{T_t = 161.402 \text{ hr}}$$

$$\boxed{T_t = 6.725 \text{ day}}$$

## **Pump Curves**

Pump capacity curves were obtained either from the parish or from the manufacturer of each pump. From these curves, a curve fit process was used to create new curves and equations.

Using drawings provided, assumptions were made regarding the dimensions of the pump station and the pump. Using these assumptions, the minor and friction losses were calculated in order to create the system curve. Two system curves were created due to the range of heads reported by the parish. The two curves represent the maximum and minimum operating heads reported.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

**8/28/05** -Operators pumped water in canal down to approximately 8.5 ft.

**8/29/05** -Operators evacuated pump station at approximately 1:15 am.

**8/30/05** -Operators returned to the station at 10:00 am. Water was the same elevation on both sides of pump station.

**9/01/05** -Both pumps running.

**9/11/05** -**Pump station back to normal operation.**

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 1 sustained relatively minor damage because its operating floor elevation is 16 feet N.G.V.D. Flooding from the storm flooded the lower level of the station but the flood waters were approximately three feet below the concrete operating floor level. Pump station equipment that was damaged includes an electric pump motor, generator, trash rack bearing and gear box, and lighting. The building sustained damage to the metal siding and roof. Additionally, the diesel engine cooling system developed a leak. Auxiliary equipment damage included flooding of a bobcat used to remove debris from the trash racks.



**Post-Hurricane Katrina – View from the Inlet Canal**




PS1 Fortification

Post-Hurricane Katrina – Aerial view of the pump station

CURVE NO.

F-15915

REF. 51343-550 548x1-15-4




CURVE NO. F 15915

CURVE NO. F-15914

F-15914


REF. 51343-550



CURVE NO. F-15914



66'-4" CENTRAL STRUCTURE



NOTE: PROPOSED METAL ROOF AND WALL SYSTEMS, INCLUDING CANOPIES AND PROPOSED WORK, ARE SHOWN SHADED AND SUPERIMPOSED ON EXISTING CRANE RUNWAY SUPPORT. LEFT ENDWALL PROPOSED WORK IDENTICAL AS SHOWN BUT OPPOSITE HAND.

RIGHT ENDWALL ELEVATION  
SCALE: 1/4" = 1'-0"

**RIGHT ENDWALL ELEVATION**

STATE OF LOUISIANA  
LOUISIANA DEPARTMENT OF PUBLIC WORKS  
**METAL ROOF AND WALL SYSTEMS**  
FOR  
FORTIFICATION AND MERAUX PUMPING STATION  
ST. BERNARD PARISH

PREPARED BY LOUISIANA DEPARTMENT OF PUBLIC WORKS  
BATON ROUGE, LA.

SUBMITTED BY *Carl J. Massey* DISTRICT ENGINEER APPROVED BY *Daniel V. Crain* CHIEF ENGINEER

DATED JUNE 1975 APPROVED BY *Ray Sigall*

DATE	DESCRIPTION	BY	DESIGNED	G.G.	DETAILED	P.G.K.	TRACED
	REVISIONS		CHECKED	A.E.S.	CHECKED	G.G.	CHECKED
			APPROVED				


SHEET 3 OF 9 SHEETS



Pre-Hurricane Katrina – View from the south end

**4201 Jean Lafitte Pkwy.  
Chalmette, LA 70043  
504.512.6331**

Position: Latitude 29.961649° Longitude -89.964442°



PS2 Guichard

Pre-Hurricane Katrina – Aerial view of pump station

### **Pump Station Description**

Guichard is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains four horizontal pumps that were installed in the 1950's with a total pumping capacity of approximately 755 cubic feet per second (cfs)<sup>1</sup>. All four pumps are driven by diesel engines. The drainage water is supplied to the pumps from the Florida Walk canal and discharges through the interior back levee to the marsh known as Bayou Bienvenue.

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

There was not enough information available to determine the rated capacity for pump 3. It was assumed it would be similar to the pump 1 (42") based on the available information.

## Pump Station Operation

This pump station was available but not used in the days before Hurricane Katrina.

## Fuel Endurance Calculation

### Assumptions :

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 2 Guichard**

4 pump drivers - All diesels

2 diesels are 800 hp, 1 diesel is 335 hp, and 1 is approximately 300 hp

The approximate burn rate for each diesel is then calculated at:

$$R1_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{800\text{hp}}{500\text{kW}} \qquad R1_{\text{burn}} = 41.75 \frac{\text{gal}}{\text{hr}}$$

$$R2_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{335\text{hp}}{500\text{kW}} \qquad R2_{\text{burn}} = 17.48 \frac{\text{gal}}{\text{hr}}$$

$$R3_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{300\text{hp}}{500\text{kW}} \qquad R3_{\text{burn}} = 15.66 \frac{\text{gal}}{\text{hr}}$$

### Fuel Capacity

1 - 5,000 gallon tank

4 - 60 gallon day tanks

### Fuel Endurance

The time the 5,000 gallon tank will last is calculated:

$$t_1 := \frac{5000\text{gal}}{R1_{\text{burn}} + R2_{\text{burn}} + R3_{\text{burn}}} \qquad t_1 = 66.75 \text{ hr}$$

The time the 60 gallon tanks will last is calculated:

$$t_2 := \frac{4 \cdot 60\text{gal}}{R1_{\text{burn}} + R2_{\text{burn}} + R3_{\text{burn}}} \qquad t_2 = 3.204 \text{ hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 \qquad \boxed{T_t = 69.95 \text{ hr}}$$

$$\boxed{T_t = 2.915 \text{ day}}$$

## Pump Curves

Pump curves were obtained from the manufacturer of the pumps. Serial numbers were unobtainable, and therefore only by making assumptions regarding the size and make of the pump as well as the similarity to that of PS 3 Bayou Villere and PS 5 E.J. Gore were any usable curves located. There was no usable information regarding pump 3, so it was assumed similar to

pump 1. From these curves, a curve fit process was used to create new curves and equations. From these curves, further assumptions were made regarding the dimensions of the pump station, pipe, and pumps so that friction and minor losses could be calculated. These calculations created the system curves. There are two curves using the maximum and minimum reported operating heads by the parish.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

This station was designated as a backup and therefore was not used prior to Hurricane Katrina. After the hurricane the pump station could not be operated as the motors were overtopped with water.

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 2 sustained substantial damage. With its operating floor at or near the natural ground elevation, the pump station was flooded to a depth of 6 to 7 feet. The four diesel engines were flooded along with control panels, compressors, motors, and vacuum pumps. The diesel fuel storage tank was moved off its concrete saddle foundation. All exterior and interior lighting was damaged. While the existing building was in poor condition prior to the storm, the wind and water caused additional damage to all four sides of the building and the building roof.



**Post-Hurricane Katrina – View from the North**





PS2 Guichard

**Post-Hurricane Katrina – Aerial view of the pump station**

# AXIAL FLOW 42"

C169

*St. Bernard Sta 2 and Sta 3*



PUMP BOWL PERFORMANCE CURVE	
TYPE: AXIAL FLOW	PROPELLER DIA.: 42"
MODEL NO.: NC342P25	SPEED (RPM): 409
INTAKE DIA.: 63"	DISCHARGE COLUMN DIA.: 42"
CURVE NO.: CS4225	Ns: 12,050 CODE: 50
SINGLE STAGE FOR TWO STAGES MULTIPLY HEAD AND HORSEPOWER BY <u>2.0</u> AND EFFICIENCY BY <u>1.0</u>	
PERFORMANCE BASED ON PUMPING CLEAR COLD NON-AERATED WATER, SPECIFIC GRAVITY 1.0, TEMPERATURE 65 DEGREES (FAHRENHEIT) OR LESS, AT SEA LEVEL. PERFORMANCE MAY BE AFFECTED BY HIGHER TEMPERATURES, SPECIFIC GRAVITIES, ALTITUDES, AND SUMP CONDITIONS.	

IT IS HEREBY CERTIFIED THAT THIS CURVE REPRESENTS THE TRUE PERFORMANCE CHARACTERISTICS OF THE M&W PUMP MODEL SHOWN AND WAS OBTAINED BY SCALE MODEL TEST AND CALCULATIONS IN ACCORDANCE WITH STANDARDS OF THE HYDRAULIC INSTITUTE.





© All rights reserved, M&W PUMP CORPORATION 1985

PS#2 Pumps 2+4; PS#3 Pump

CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER IN PROPERLY DESIGNED PUMP WITH PROPER SUBMERGENCE.  
NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.  
HORSEPOWERS (HP) SHOWN REPRESENT NOMINAL RECOMMENDED ELECTRIC MOTOR SIZES.  
PERCENTAGES (%) SHOWN REPRESENT BOWL EFFICIENCIES.

*all 60" pumps*




PUMP BOWL PERFORMANCE CURVE VARIABLE SPEED	
TYPE: AXIAL FLOW	PROPELLER DIA.: 60"
MODEL NO.: NC360P12	SPEED (RPM): AS NOTED
INTAKE DIA.: 90"	DISCHARGE COLUMN DIA.: 60"
CURVE NO.: VS60P12	Ng: 11,900 CODE: 50
SINGLE STAGE FOR TWO STAGES MULTIPLY HEAD AND HORSEPOWER BY 2.0 AND EFFICIENCY BY 1.0 PERFORMANCE BASED ON PUMPING CLEAR COLD NON-AERATED WATER, SPECIFIC GRAVITY 1.0, TEMPERATURE 65 DEGREES (FAHRENHEIT) OR LESS, AT SEA LEVEL. PERFORMANCE MAY BE AFFECTED BY HIGHER TEMPERATURES, SPECIFIC GRAVITIES, ALTITUDES, AND PUMP CONDITIONS.	

IT IS HEREBY CERTIFIED THAT THIS CURVE REPRESENTS THE TRUE PERFORMANCE CHARACTERISTICS OF THE M&W PUMP MODEL SHOWN AND WAS OBTAINED BY SCALE MODEL TEST AND CALCULATIONS IN ACCORDANCE WITH STANDARDS OF THE HYDRAULIC INSTITUTE.



† All rights reserved, M&W PUMP CORPORATION 1985







Pre-Hurricane Katrina - View to the North

**3700 Bartolo  
Meraux, LA 70075  
504.512.6331**

Position: Latitude 29.951279° Longitude -89.934607°



PS3 Bayou Villere

Pre-Hurricane Katrina – Arial view of pump station

### **Pump Station Description**

Bayou Villere is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three horizontal pumps that were installed in the 1950's with a total pumping capacity of 800 cubic feet per second (cfs)<sup>1</sup>. All three pumps are driven by diesel engines. The drainage water is supplied to the pumps from the Forty Arpent

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

canal and discharges through the interior back levee to the marsh known as Bayou Villere. Pumps 1 and 2 have butterfly valves on the inlet piping leading to the pump to cut off water flow in either direction.

## **Pump Station Operation**

This pump station is designated as a back up and therefore was not used in the days leading up to Hurricane Katrina.

## **Fuel Endurance Calculation**

### Assumptions:

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 3 Bayou Villere**

3 pump drivers - All diesels

Diesels are 800 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{800\text{hp}}{500\text{kW}} \qquad R_{\text{burn}} = 41.75 \frac{\text{gal}}{\text{hr}}$$

### Fuel Capacity

1 - 2500 gallon tank

3 - 60 gallon day tanks

### Fuel Endurance

The time the 2500 gallon tank will last is calculated:

$$t_1 := \frac{2500\text{gal}}{3R_{\text{burn}}} \qquad t_1 = 19.95\text{hr}$$

The time the 60 gallon tank will last is calculated:

$$t_2 := \frac{3 \cdot 60\text{gal}}{3R_{\text{burn}}} \qquad t_2 = 1.43\text{hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 \qquad T_t = 21.39\text{hr}$$

$$T_t = 0.89\text{day}$$

## **Pump Curves**

Pump capacity curves were obtained. From these curves, a curve fit process was used to create new curves and equations. During the data collection, only one pump serial number was found, so the others were assumed to be similar. Using manufacturer data and making assumptions regarding the dimensions of the pump station and pump, as well as other necessary assumptions, the minor and friction losses were calculated so that system curves could be created. Two curves were made due to the range of operating heads reported from the parish. The two curves represent the maximum and minimum operating heads reported.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

This station was designated as a backup and therefore was not used prior to Hurricane Katrina. After the hurricane the pump station could not be operated as the motors were overtopped with water.

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 3 sustained substantial damage. With its operating floor at or near the natural ground elevation, the pump station was flooded to a depth of 8 feet. The three diesel engines and hydraulic drives were flooded along with the vacuum pump system and ancillary equipment. The diesel fuel storage tank was moved off its foundation. All exterior and interior lighting was damaged. While the existing building was in poor condition prior to the storm, the wind and water caused additional damage to all four sides of the building.





**Post-Hurricane Katrina – View to the South**



PS3 Bayou Villere

**Post-Hurricane Katrina – Arial view of the pump station**

*St. Bernard Sta 2 and Sta 3*



PUMP BOWL PERFORMANCE CURVE	
TYPE: AXIAL FLOW	PROPELLER DIA.: 42"
MODEL NO.: NC342P25	SPEED (RPM): 409
INTAKE DIA.: 63"	DISCHARGE COLUMN DIA.: 42"
CURVE NO.: CS4225	Ns: 12,050 CODE: 50
<small>SINGLE STAGE FOR TWO STAGES MULTIPLY HEAD AND HORSEPOWER BY 2.0 AND EFFICIENCY BY 1.0</small>	
<small>PERFORMANCE BASED ON PUMPING CLEAR COLD NON-AERATED WATER, SPECIFIC GRAVITY 1.0, TEMPERATURE 65 DEGREES (FAHRENHEIT) OR LESS, AT SEA LEVEL. PERFORMANCE MAY BE AFFECTED BY HIGHER TEMPERATURES, SPECIFIC GRAVITIES, ALTITUDES, AND SUMP CONDITIONS.</small>	

IT IS HEREBY CERTIFIED THAT THIS CURVE REPRESENTS THE TRUE PERFORMANCE CHARACTERISTICS OF THE M&W PUMP MODEL SHOWN AND WAS OBTAINED BY SCALE MODEL TEST AND CALCULATIONS IN ACCORDANCE WITH STANDARDS OF THE HYDRAULIC INSTITUTE.





© All rights reserved, M&W PUMP CORPORATION 1985

*PS#2 Pumps 2+4; PS#3 Pump*

CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER IN PROPERLY DESIGNED PUMP WITH PROPER SUBMERGENCE.  
NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.  
HORSEPOWERS (HP) SHOWN REPRESENT NOMINAL RECOMMENDED ELECTRIC MOTOR SIZES.  
PERCENTAGES (%) SHOWN REPRESENT BOWL EFFICIENCIES.

*all 60" pumps*




PUMP BOWL PERFORMANCE CURVE VARIABLE SPEED	
TYPE: AXIAL FLOW	PROPELLER DIA.: 60"
MODEL NO.: NC360P12	SPEED (RPM): AS NOTED
INTAKE DIA.: 90"	DISCHARGE COLUMN DIA.: 60"
CURVE NO.: VS60P12	Ng: 11,900 CODE: 50
<small>SINGLE STAGE FOR TWO STAGES MULTIPLY HEAD AND HORSEPOWER BY 2.0 AND EFFICIENCY BY 1.0 PERFORMANCE BASED ON PUMPING CLEAR COLD NON-AERATED WATER, SPECIFIC GRAVITY 1.0, TEMPERATURE 65 DEGREES (FAHRENHEIT) OR LESS, AT SEA LEVEL. PERFORMANCE MAY BE AFFECTED BY HIGHER TEMPERATURES, SPECIFIC GRAVITIES, ALTITUDES, AND PUMP CONDITIONS.</small>	

IT IS HEREBY CERTIFIED THAT THIS CURVE REPRESENTS THE TRUE PERFORMANCE CHARACTERISTICS OF THE M&W PUMP MODEL SHOWN AND WAS OBTAINED BY SCALE MODEL TEST AND CALCULATIONS IN ACCORDANCE WITH STANDARDS OF THE HYDRAULIC INSTITUTE.



† All rights reserved, M&W PUMP CORPORATION 1985



NOT TO SCALE



Pre-Hurricane Katrina – View from Inlet Canal

**3200 Guerra Dr.  
Violet, LA 70092  
504.512.6331**

Position: Latitude 29.921331° Longitude -89.891292°



PS 4 - Meraux

Pre-Hurricane Katrina – Aerial view of pump station

### **Pump Station Description**

Meraux is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three vertical pumps that were installed in 1972 with a total pumping capacity of 980 cubic feet per second (cfs)<sup>1</sup>. Two of the pumps are driven by diesel engines and one by an electric motor. The drainage water is supplied to the pumps from the Forty Arpent canal and discharges through the interior back levee to the marsh known as

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.



Bayou Dupre. The individual pump discharges have a tainter gates installed to cut off water flow in either direction.

## Pump Station Operation

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately -6 feet (NGVD) and turned off when the water level reaches -6.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -8.5 feet (NGVD). If the water elevation on the discharge side of the pump station is predicted to exceed 3.5 feet (NGVD) the station operator closes the discharge tainter gates.

## Fuel Endurance Calculation

### Assumptions :

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 4 Meraux**

3 pump drivers - 2 are diesels and 1 is electric

The 2 diesels are 1200 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{1200 \text{hp}}{500 \text{kW}} \qquad R_{\text{burn}} = 62.639 \frac{\text{gal}}{\text{hr}}$$

Fuel Capacity

- 4 - 5000 gallon tanks
- 2 - 110 gallon day tanks

Fuel Endurance

The time the 5000 gallon tanks will last is calculated:

$$t_1 := \frac{4 \cdot 5000 \text{gal}}{2R_{\text{burn}}} \qquad t_1 = 159.64 \text{hr}$$

The time the 110 gallon tanks will last is calculated:

$$t_2 := \frac{2 \cdot 110 \text{gal}}{2R_{\text{burn}}} \qquad t_2 = 1.75 \text{hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 \qquad T_t = 161.40 \text{hr}$$

$$T_t = 6.725 \text{day}$$

---

## Pump Curves

Pump capacity curves were obtained either from the parish or from the manufacturer of each pump. From these curves, a curve fit process was used to create new curves and equations.

Using drawings provided, assumptions were made regarding the dimensions of the pump station and the pump. Using these assumptions, the minor and friction losses were calculated in order to create the system curve. Two system curves were created due to the range of heads reported by the parish. The two curves represent the maximum and minimum operating heads reported.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

**8/28/05** - Operators pumped water in canal down to approximately -8.5 feet (NGVD).

**8/29/05** - Operators evacuated pump station at approximately 1:15 am.

**9/03/05** - Operators returned to pump water down.

**9/09/05** - **Pump Station back to normal operation.**

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 4 sustained relatively minor damage because its operating floor elevation is 16 feet N.G.V.D. Flooding from the storm flooded the lower level of the station but the flood waters were approximately three feet below the concrete operating floor level. Pump station equipment that was damaged includes an air compressor, electromode heater, controller for compressed air dryer motor, and generator. The building sustained damage to metal siding and roof. Finally, one discharge flap gate was damaged and is not operational.



**Post-Hurricane Katrina – View from the inlet canal**



PS 4 - Meraux

**Post-Hurricane Katrina – Arial view of the pump station**

CURVE NO.

F-15915


REF. 51343-550 548x1-15-4

STATE of LOUISIANA  
CHALMETTE

BALDWIN-LIMA-HAMILTON CORPORATION  
INDUSTRIAL EQUIPMENT DIVISION  
PHILADELPHIA 42, PA.

CHARACTERISTIC PUMP CURVES

PUMP TYPE **AFV** SIZE **94x128**  
RATING: GPM **200,000** FT. HD. **19** RPM **212**




CURVE NO. F 15915

CURVE NO. F-15914

**BALDWIN-LIMAHAMILTON CORPORATION**  
**INDUSTRIAL EQUIPMENT DIVISION**  
 PHILADELPHIA 42, PA.  
 CHARACTERISTIC PUMP CURVES  
 PUMP TYPE AFV SIZE 42x54  
 RATING: GPM 40000 FL. HD. 20 RPM 505  
5 1/4 SYNCH. IP MOTOR


STATE of LOUISIANA  
CHALMETTE

REF. 51243-550



CURVE NO. F-15914

66'-4" CENTRAL STRUCTURE



NOTE: PROPOSED METAL ROOF AND WALL SYSTEMS, INCLUDING CANOPIES AND PROPOSED WORK, ARE SHOWN SHADED AND SUPERIMPOSED ON EXISTING CRANE RUNWAY SUPPORT. LEFT ENDWALL PROPOSED WORK IDENTICAL AS SHOWN BUT OPPOSITE HAND.

RIGHT ENDWALL ELEVATION  
SCALE: 1/4" = 1'-0"

**RIGHT ENDWALL ELEVATION**

STATE OF LOUISIANA  
LOUISIANA DEPARTMENT OF PUBLIC WORKS  
**METAL ROOF AND WALL SYSTEMS**  
FOR  
**FORTIFICATION AND MERAUX PUMPING STATION**  
ST. BERNARD PARISH

PREPARED BY LOUISIANA DEPARTMENT OF PUBLIC WORKS  
BATON ROUGE, LA.

SUBMITTED BY *Carl J. Massey* DISTRICT ENGINEER APPROVED BY *Daniel V. Crain* CHIEF ENGINEER

DATED JUNE 1975 APPROVED BY *Greg Sigall*

DATE	DESCRIPTION	BY
DESIGNED	G.G.	P.G.K.
CHECKED	A.E.S.	G.G.
APPROVED		

TRACED  
CHECKED  
SHEET 3 OF 9 SHEETS



Pre-Hurricane Katrina – View to the North

**7701 East Judge Perez Dr.  
Violet, LA 70085  
504.512.6331**

Position: Latitude 29.961649° Longitude -89.964442°



PS 5 – EJ Gore

Pre-Hurricane Katrina – Aerial view of the pump station

### **Pump Station Description**

EJ Gore is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains six horizontal pumps that were installed in the 1980's with a total pumping capacity of 665 cubic feet per second (cfs)<sup>1</sup> and are driven by diesel engines. The drainage water is supplied to the pumps from the Forty Arpent canal and discharges through the interior back levee to the marsh known as Bayou Dupre. All pumps are equipped flap gates.

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

## Pump Station Operation

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately 0.0 feet (NGVD) and turned off when the water level reaches -0.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -3.0 feet (NGVD).

## Fuel Endurance Calculation

### Assumptions :

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 5 E.J. Gore**

6 pump drivers - All diesels

Diesels are 335 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{335 \text{hp}}{500 \text{kW}} \quad R_{\text{burn}} = 17.48 \frac{\text{gal}}{\text{hr}}$$

Fuel Capacity

- 1 - 20,000 gallon tank
- 5 - 50 gallon day tanks
- 1 - 75 gallon tank

Fuel Endurance

The time the 20,000 gallon tank will last is calculated:

$$t_1 := \frac{20000 \text{gal}}{6R_{\text{burn}}} \quad t_1 = 190.62 \text{ hr}$$

The time the 50 gallon tanks will last is calculated:

$$t_2 := \frac{5 \cdot 50 \text{gal}}{6R_{\text{burn}}} \quad t_2 = 2.383 \text{ hr}$$

The time the 75 gallon tank will last is calculated:

$$t_3 := \frac{75 \text{gal}}{6R_{\text{burn}}} \quad t_3 = 0.715 \text{ hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 + t_3 \quad T_t = 193.719 \text{ hr}$$

$$T_t = 8.072 \text{ day}$$

## Pump Curves

Pump curves were obtained from both the parish and the manufacturer. From these curves, a curve fit process was used to create new curves and equations. Using this data as well as making assumptions regarding the dimensions of the pump and the pump station, minor and friction losses were accounted for. These calculations led to the creation of the system curves. Two



curves were made due to the range of operating heads provided by the parish. The two curves represent the maximum and minimum operating heads reported.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

**8/28/05** - Operators pumped water in canal down to approximately -3.0ft.

**8/29/05** - Operators evacuated station at approximately 1:15 am.

**8/30/05** - **Motors were overtopped during storm. Pumps had not been repaired as of site visit.**

## **Damage Report**



**Post-Hurricane Katrina – View to the North**



The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 5 sustained substantial damage. With the operating floor at approximately 2 feet N.G.V.D, flood waters within the building reached a height of 5 approximately 6 feet. The hydraulic driven pumps were damaged along with the six diesel engines. The generator and the electric pump motor and its controller were flooded. The hydraulic oil tank is not on its foundation and is contaminated with salt water along with the fuel system. The trash rack bar screens are damaged along with the slope pavement adjacent to the discharge pipes. Building damage includes damage to the rollup door, roof, and building office and restroom facility.

St. Bernard PS#5


# AXIAL FLOW 42"


C166



PUMP BOWL PERFORMANCE CURVE VARIABLE SPEED	
TYPE: AXIAL FLOW	PROPELLER DIA.: 42"
MODEL NO.: NC342P12	SPEED (RPM): AS NOTED
INTAKE DIA.: 63"	DISCHARGE COLUMN DIA.: 42"
CURVE NO.: VS42P12	Na: 11,800 CODE: .50
SINGLE STAGE FOR TWO STAGES MULTIPLY HEAD AND HORSEPOWER BY 2.0 AND EFFICIENCY BY 1.0	
PERFORMANCE BASED ON PUMPING CLEAR COLD NON-AERATED WATER, SPECIFIC GRAVITY 1.0, TEMPERATURE 85 DEGREES (FAHRENHEIT) OR LESS, AT SEA LEVEL. PERFORMANCE MAY BE AFFECTED BY HIGHER TEMPERATURES, SPECIFIC GRAVITIES, ALTITUDES, AND SUMP CONDITIONS.	

IT IS HEREBY CERTIFIED THAT THIS CURVE REPRESENTS THE TRUE PERFORMANCE CHARACTERISTICS OF THE M&W PUMP MODEL SHOWN AND WAS OBTAINED BY SCALE MODEL TEST AND CALCULATIONS IN ACCORDANCE WITH STANDARDS OF THE HYDRAULIC INSTITUTE.





NOT TO SCALE



Pre-Hurricane Katrina – View from Inlet Canal

**4200 Jean Lafitte Pkwy.  
Chalmette, LA 70043  
504.512.6331**

Position: Latitude 29.966557° Longitude -89.975821°



PS 6 – Jean Lafitte

Pre-Hurricane Katrina – Aerial view of pump station

### **Pump Station Description**

Jean Lafitte is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three vertical pumps that were installed in 1990 with a total pumping capacity of 945 cubic feet per second (cfs)<sup>1</sup> and are driven by diesel engines. The drainage water is supplied to the pumps from the Florida Walk canal and discharges through the interior back levee to the marsh known as Bayou Bienvenue.

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

## Pump Station Operation

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately -6 feet (NGVD) and turned off when the water level reaches -6.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -8.5 feet (NGVD).

## Fuel Endurance Calculation

### Assumptions :

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 6 Jean Lafitte**

3 pump drivers - All diesels

Diesels are 335 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{335 \text{hp}}{500 \text{kW}} \quad R_{\text{burn}} = 17.487 \frac{\text{gal}}{\text{hr}}$$

### Fuel Capacity

- 1 - 20,000 gallon tank
- 5 - 50 gallon day tanks
- 1 - 75 gallon tank

### Fuel Endurance

The time the 20,000 gallon tank will last is calculated:

$$t_1 := \frac{20000 \text{gal}}{6R_{\text{burn}}} \quad t_1 = 190.62 \text{hr}$$

The time the 50 gallon tanks will last is calculated:

$$t_2 := \frac{5 \cdot 50 \text{gal}}{6R_{\text{burn}}} \quad t_2 = 2.383 \text{hr}$$

The time the 75 gallon tank will last is calculated:

$$t_3 := \frac{75 \text{gal}}{6R_{\text{burn}}} \quad t_3 = 0.713 \text{hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 + t_3 \quad T_t = 193.719 \text{hr}$$

$$T_t = 8.072 \text{day}$$

## Pump Curves

Pump capacity curves were obtained. From these curves, a curve fit process was used to create new curves and equations. Using this information and making assumptions about the pump and the pump station, friction and minor head losses were accounted for. These calculations led to the creation of the systems curves. Two curves were created due to the range of operation reported by the parish using only the maximum and minimum head required.

## Reverse Flow

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## Katrina Event

**8/28/05** - Operators pumped water in canal down to approximately -8.5 feet (NGVD).

**8/29/05** - Operators evacuated pump station at approximately 1:15 am.

**8/30/05** - Operators returned to the station at 10:00 am. Water was the same elevation on both sides of pump station.

**9/11/05** - **Pump station back to normal operation.**

## Damage Report

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 6 sustained relatively minor damage because its operating floor elevation is 16 feet N.G.V.D. Flooding from the storm flooded the lower level of the station but the flood waters were approximately three feet below the concrete operating floor level. The building damage consists of damaged roof panels. Mechanical damage includes damage to the trash rack gear boxes, trash removal equipment, engine exhaust flappers, and sanitation plant. Electrical damage consists of damage to lighting and the remote engine alarm panel.




Post-Hurricane Katrina – View from the Inlet Canal



PS 6 – Jean Lafitte

**Post-Hurricane Katrina – Aerial view of the pump station**



PATTERSON PUMP COMPANY  
A Subsidiary of Banner Industries, Inc.

CURVE NO. JC-576-94-01

REF.


BR. H.P.	1500	1000	500	0
EFF. %	90	80	70	60
HEAD FT.	30	20	10	0

CHARACTERISTIC CURVES

PUMP TYPE AFV SIZE 7.5 X 7.2  
 RATING: GPM \_\_\_\_\_ FT. HD. \_\_\_\_\_ RPM 272

JEAN LAFITTE P.S. (P.S.#6)  
BAYOU DUCROS P.S. (P.S.#7)

PUMP EFFICIENCY



Q, U.S. GALLONS PER MINUTE / 1000


American blueprint 500228



Sold To: \_\_\_\_\_ Date 10-4-83 Tested By BUJ Serial No. X-624


Job Driver:	HP	Motor Turbine Engine	GPM	Imp. Patt.	Imp. Type
Test Driver:	HP	Motor Dyn.	Ft. Hd.	No. Stages	Size
Motor Effy	Test Speed	Rated Speed	Test No.		

CERTIFIED TEST BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_  
 WITNESSED BY \_\_\_\_\_



CURVE NO. 8544


PROTOTYPE




100000. 110000. 120000. 130000. 140000. 150000. 160000. 170000. 180000.


U.S. GALLONS PER MINUTE

CURVE NO. 8544





CURVE NO. 8532  
PROTOTYPE



REF. HEAD FT. 20. 16. 12. 8. 4. 0.

EFF. % 90 80 70 60 50 40 30 20 10 0


BR. H.P. 800. 400. 0.

100000. 110000. 120000. 130000. 140000. 150000. 160000.

American blueprint 313844

CURVE NO. 8533


This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.



PATTERSON PUMP COMPANY  
A SUBSIDIARY OF THE GORMAN-RUPPT CO.



CURVE NO. 8522  
PROTOTYPE

REF.




0577

CURVE NO. 8511  
PROTOTYPE



This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.

CURVE NO. 8511



HIGH SUCTION LEVEL		
AVE	LEVEL	-7.0
LOW	LEVEL	-8.0
LOWEST	LEVEL	-9.0

This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.


**RECEIVED**  
 JAN 5 1989  
 PUMP SERVICE & I-46  
 REPAIR CO., INC.  
 JEFFERSON, LA 70181



Pre-Hurricane Katrina – View from Inlet Canal

**3701 Bartolo Dr.  
Meraux, LA 70075  
504.512.6331**

Position: Latitude 29.946969° Longitude -89.922244°



PS 7 – Bayou Ducros

Pre-Hurricane Katrina – Arial view of pump station

### **Pump Station Description**

Bayou Ducros is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three vertical pumps that were installed in 1992 with a total pumping capacity of 1000 cubic feet per second (cfs)<sup>1</sup> and are driven by diesel engines. The drainage water is supplied to the pumps from the Forty Arpent canal and discharges through the interior back levee to the marsh known as Bayou Ducros.

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

## Pump Station Operation

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately -6 feet (NGVD) and turned off when the water level reaches -6.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -8.5 feet (NGVD).

## Fuel Endurance Calculation

### Assumptions:

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

### **PS 7 Bayou Ducros**

3 pump drivers - All diesels

Diesels are 1020 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{1020\text{hp}}{500\text{kW}} \qquad R_{\text{burn}} = 53.243 \frac{\text{ga}}{\text{hr}}$$

Fuel Capacity

- 2 - 10,000 gallon tanks
- 2 - 300 gallon day tanks

Fuel Endurance

The time the 10,000 gallon tank will last is calculated:

$$t_1 := \frac{2 \cdot 10000\text{gal}}{3R_{\text{burn}}} \qquad t_1 = 125.212\text{hr}$$

The time the 300 gallon tanks will last is calculated:

$$t_2 := \frac{2 \cdot 300\text{gal}}{3R_{\text{burn}}} \qquad t_2 = 3.756\text{hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 \qquad T_t = 128.969\text{hr}$$

$$T_t = 5.374\text{day}$$

## Pump Curves

Pump capacity curves were obtained. From these curves, a curve fit process was used to create new curves and equations. Using drawings and manufacturer data, assumptions regarding the pump station and the pump were made in order to determine the minor and friction losses in the system. These calculations created the system curves. Two curves were created in order to



accommodate the range of operating heads provided by the parish. The maximum and minimum head values were used to generate these curves.

## **Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

**8/28/05** - Operators pumped water in canal down to approximately -8.5 feet (NGVD).

**8/29/05** - Operators evacuated pump station at approximately 1:15 am.

**8/30/05** - Operators returned to the station at 10:00 am. Water was the same elevation on both sides of pump station.

**9/11/05** - **Pump station back to normal operation.**

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 7 sustained relatively minor damage because its operating floor elevation is 16 feet N.G.V.D. Flooding from the storm flooded the lower level of the station but the flood waters were approximately three feet below the concrete operating floor level. Bearing and gears for the trash racks were damaged. Auxiliary equipment damage included flooding of a bobcat used to remove debris from the trash racks, fuel tank, and sanitation plant. Pump damage consists of a broken drain line. Engine damage consists of damage to an engine cooling motor, radiator leak and remote engine alarm panel. Two areas had some erosion including scour behind the station and near the west end stairs.




**Post-Hurricane Katrina – Erosion**



PS 7 – Bayou Ducros

Post-Hurricane Katrina – Aerial view of the pump station



PATTERSON PUMP COMPANY  
A Subsidiary of Banner Industries, Inc.

REF.

EFF. %

BR. H.P.

HEAD FT.

90

80

70

60

50

40

30

20

10

0

1500

1000

500

0

American blueprint 500228

100

110

120

130

140

150

160

170

180

N.P.S.H.

30

20

10

0

CHARACTERISTIC CURVES

PUMP TYPE AFV SIZE 7.5 X 7.2

RATING: GPM \_\_\_\_\_ FT. HD. \_\_\_\_\_ RPM 272

JEAN LAFITTE P.S. (P.S. #6)

BAYOU DUCROS P.S. (P.S. #7)

PUMP EFFICIENCY

PUMP TDH VS Q, 272 RPM  
POOL-TO-POOL HEAD VS Q

NPSHR

BHP VS. Q

TDH VS Q, 253 RPM

Q, U.S. GALLONS PER MINUTE / 1000


CURVE NO. JC-576-94-01

To: \_\_\_\_\_ Date 10-4-83 Tested By BWJ Serial No. X-624

Job Driver:	HP	Motor Turbine Engine	GPM	Imp. Patt.	Imp. Type
Test Driver:	HP	Motor Dyn.	Ft. Hd.	No. Stages	Size
Motor Effy	Test Speed	Rated Speed	Test No.		

PATTERNS AVAILABLE FOR RATIOS:  
 2.959  
 3.23


CERTIFIED TEST BY \_\_\_\_\_  
 APPROVED BY \_\_\_\_\_  
 WITNESSED BY \_\_\_\_\_




This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.

CURVE NO. 8544

PROTOTYPE



PATTERSON PUMP COMPANY  
A SUBSIDIARY OF THE GORMAN-RUPP CO




PROTOTYPE PERFORMANCE - 9' EL @ 100% RPM


100000. 110000. 120000. 130000. 140000. 150000. 160000. 170000. 180000.

U.S. GALLONS PER MINUTE

CURVE NO. 8544



CURVE NO. 8532  
PROTOTYPE



REF. HEAD FT. 20. 16. 12. 8. 4. 0.

EFF. % 90 80 70 60 50 40 30 20 10 0


BR. H.P. 800. 400. 0.

american blueprint 313844

80000. 90000. 100000. 110000. 120000. 130000. 140000. 150000. 160000.

CURVE NO. 8533


This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.



PATERSON PUMP COMPANY  
A SUBSIDIARY OF THE GORMAN-RUPP CO.

CURVE NO. 8522  
PROTOTYPE



REF.



american blueprint 313844


U.S. GALLONS PER MINUTE

CURVE NO. 8511  
PROTOTYPE



CURVE NO. 8511





NOT TO SCALE



Pre-Hurricane Katrina – View from Inlet Canal

**3616 Bayou Rd.  
Verret, LA 70085  
504-682-0591**

Position: Latitude 29.854064° Longitude -89.795715

## **Pump Station Description**

St Mary is 1 of 8 pumping stations in St Bernard Parish owned and operated by the Lake Borne Basin Levee District. The station contains three vertical pumps that were installed in 1996 with a total pumping capacity of 835 cubic feet per second (cfs)<sup>1</sup> and are driven by diesel engines. The drainage water is supplied to the pumps from the Twenty Arpent canal and discharges through the hurricane protection levee to Lake Lery. The discharge pipes have check valves to prevent flow in the reverse direction.

## **Pump Station Operation**

Pump station operators will turn the pumps on as they are required to reduce the water elevation in the canal. The pumps are normally turned on when the water in the canal reaches approximately 0.0 feet (NGVD) and turned off when the water level reaches -0.5 feet (NGVD). When heavy rainfall events are expected the station operators will pump the canal down to an elevation of -3.5 feet (NGVD).

## **Fuel Endurance Calculation**

---

<sup>1</sup> The Pump Information Table contains more details about the individual pump data and is located at the beginning of this section.

Assumptions:

- 1) #2 Diesel fuel is used with an HHV rating of 140,000 btu/gal
- 2) Burn rate of 35 gph @ 500 kW with above HHV rating
- 3) Diesel engines are running at rated capacity

**PS 8 St Mary**

3 pump drivers - All diesels

Diesels are 1020 hp

The approximate burn rate for each diesel is then calculated at:

$$R_{\text{burn}} := \left( 35 \frac{\text{gal}}{\text{hr}} \right) \cdot \frac{1020\text{hp}}{500\text{kW}} \qquad R_{\text{burn}} = 53.243 \frac{\text{gal}}{\text{hr}}$$

Fuel Capacity

- 2 - 10,000 gallon tanks
- 2 - 300 gallon day tanks

Fuel Endurance

The time the 10,000 gallon tank will last is calculated:

$$t_1 := \frac{2 \cdot 10000\text{gal}}{3R_{\text{burn}}} \qquad t_1 = 125.212\text{hr}$$

The time the 300 gallon tanks will last is calculated:

$$t_2 := \frac{2 \cdot 300\text{gal}}{3R_{\text{burn}}} \qquad t_2 = 3.756\text{hr}$$

The approximate total continuous run time for the station is:

$$T_t := t_1 + t_2 \qquad \boxed{T_t = 128.969\text{hr}}$$

$$\qquad \qquad \qquad \boxed{T_t = 5.374\text{day}}$$

**Pump Curves**

Pump capacity curves were obtained from the parish. These curves were recreated using a curve fit process. Analysis of the system necessitated the use of assumptions about the pump station and pump dimensions. These allowed for calculations regarding minor and friction losses. The system curves were created using these calculations. Two system curves were generated to accommodate the range of operation recorded by the parish, using maximum and minimum values of head.

**Reverse Flow**

The Engineering Hydraulics Design section of the US Army Corps of Engineers Portland District office performed analysis of reverse flow characteristics for each pump. The results are reverse flow rating curves that are attached to this section. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

## **Katrina Event**

**8/28/05** - Operators pumped water in canal down to approximately -3.5 feet (NGVD).

**8/29/05** - Operators evacuated pump station at approximately 1:15 am.

**9/11/05** - **Pump station back to normal operation.**

## **Damage Report**

The following information was obtained from the Project Information Report (PIR) for New Orleans District:

Pump Station 8 sustained relatively minor damage because its operating floor elevation is 16 feet N.G.V.D. Flooding from the storm flooded the lower level of the station but the flood waters were approximately eight feet below the concrete operating floor level. Building damage consists of loose roof panels, scour section near the discharge pipes, light fixtures, and the sewage aerator motor. Bearing and gears for the trash racks were damaged. Auxiliary equipment damage includes a front end loader used to remove debris from the trash racks.



**Post-Hurricane Katrina – View from the Inlet Canal**



CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER. NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.

CUSTOMER: ST. BERNARD PARISH  
 CAENARVON STATION NO. 8  
 CURVE NO. 840-70120-A  
 TYPE WCA X CENT. PUMP

CUST. P.O. NO.: PR07 716-44-0006 ITEM NO.: 125,000 G.P.M. 2.5 FT. HD. 230 R.P.M.  
 SIZE 108 x 66  
 (P.L.F.) VANE - 3

STEP-UP OF MODEL WITNESS  
 PERFORMANCE TEST NO. 1  
 IMPPELLER DWG. MAX. SPHERE  
 IMP. DIA. 61.34 RMS

SUCTION POOL ELEV. = 0 FT. 100% SPEED  
 CERTIFIED FOR  
 PUMP SERIAL NO.  
 SIGNED *M. R. ...* DATE 1-8-96




CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER. NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.

CUSTOMER: ST. BERNARD PARISH  
 CAENARVAN STATION NO. 8  
 CURVE NO. 840-70120-B  
 TYPE WCAX CENT. PUMP  
 SIZE 10 8 X 6 6  
 FT. HD. 218.5 R.P.M.  
 G.P.M.  
 VANE - 3  
 IMP. DIA. 6 1/34 IN.

CUST. P.O. NO: PROJ. 716-44-0006 ITEM NO:  
 STEP-UP OF MODEL WITNESS  
 PERFORMANCE TEST NO. 2  
 IMPELLER DWG.  
 MAX. SPHERE  
 CERTIFIED FOR  
 PUMP SERIAL NO.  
 SIGNED M. R. [Signature] DATE 1-8-96

SUCTION POOL ELEV. = 0 FT., 95% SPEED  
 POOL-TO-POOL HEAD  
 4" TDH  
 ILLINOIS A-C PUMP  
 A Unit of IIT Corporation



CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER. NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.


FORM CP-1010-1

CUSTOMER: ST. BERNARD PARISH  
 CAENARVON STATION No. 8  
 SIZE 10.8 x 6.6  
 TYPE W/CLAX CENT. PUMP  
 CURVE NO. 840-70120-C

CUST. P.O. NO.: PROJ. T16-44-0006 ITEM NO. 207  
 G.P.M. 207 R.P.M.  
 IMPELLER DWG. VANE-3  
 MAX SPHERE IMP. DIA. 6.134" MS

STEP-UP OF MODEL WITNESS  
 PERFORMANCE TEST No. 3  
 CERTIFIED FOR

STATION POOL ELEV. 2.0 FT. 90% SPEED  
 PUMP SERIAL NO.  
 SIGNED *M. R. ...* DATE 1-8-96




CURVES SHOW APPROXIMATELY THE CHARACTERISTICS WHEN PUMPING CLEAR WATER. NO GUARANTEE IS MADE EXCEPT FOR THE RATED POINT.

CUSTOMER: ST. BERNARD PARISH  
 CAENARVON STATION NO. 8  
 SIZE 108 X 66  
 TYPE WCAX CENT. PUMP  
 CURVE NO. 840-70120-D


CUST. P.O. NO: PROJ. 76-44-0006 ITEM NO. 125000  
 GPM. 2.5 FT. HD. (P-P)  
 IMPELLER DWG. VANE-3  
 IMP. DIA 61.34 INMS

STEP-UP OF MODEL WITNESS  
 PERFORMANCE TEST NO. 4  
 CERTIFIED FOR

SUCTION POOL ELEV. = -2.0 FT, 100% SPEED  
 PUMP SERIAL NO.  
 SIGNED *M. R. ...* DATE 1-8-96







NOT TO SCALE

CENWP-EC-HD

**DRAFT**

24 February 2006

**MEMORANDUM FOR RECORD**

**SUBJECT** 60% Draft Submission of Estimated Backflow Rating Curves for St. Bernard Parish, LA

**Problem Statement:** A post Katrina flood study is being conducted for a watershed in Jefferson Parish in New Orleans District. During the flood event, the pumps stopped operating and reverse flow discharged backwards through the pump station conduits. The needs of the study include an approximate rating curve for reverse flow through the pump station.

**Objectives:** Develop rating curve for reverse flow rate versus head differential and provide documentation of rating and methods used.

**Assumptions:** Many assumptions needed to be made in order to complete the draft backflow rating curves associated with this document. Assumptions made in developing the backflow rating curve estimates are listed in the Excel file worksheets for each unique pump and configuration. The most significant assumptions have been included in the rating curve worksheets attached to this memorandum and are summarized below.

- **Data Assumptions:**  
Many of the pump stations in St. Bernard Parish only had very sketchy information on pumps, intakes and discharge pipes with regard to: elevations, sizes, cross-sections, bends, diffusers, lengths, pump intake grates, discharge pipe baffles etc. In addition, elevations of the pump station and system were not always available or there appeared to be inconsistencies between collected questionnaire responses, sketches and photos. Lack of data may contribute to significant uncertainty in the backflow rating curves. For pump stations 1 and 4, all that was missing was the width of the discharge channel (assumed to be 10 feet from photos). The minimum error margin for all calculations is  $\pm 30\%$ . The error margin will naturally increase for those cases where station data is missing and pertinent dimensions must be estimated.
- **System Loss Assumptions:**  
Intake, exit, bend, expansion, impeller and friction losses have been included for each unique pump and configuration. Some assumptions were made when system details were not available from the data (see above). The most significant loss was typically through the pump itself and is the largest cause of uncertainty. We currently estimate an error margin of  $\pm 30\%$  related to the pump loss.
- **Flow Control Assumptions:**  
Conditions that trigger variations in flow control were estimated using the following criteria:

- Backflow starts when the lake or reservoir head (H1 at intake of backflow condition) is greater than the controlling crest of the discharge pipe. The first trigger point is that H1 must exceed this crest elevation to start flow.
- Siphon flow starts with rising reservoir:
  - If there is no open air valve or vent, when H1 is greater than the controlling soffit of the discharge pipe. In this case the full flow rating curves (“If pipe primes, then full outlet control...”) are applied. The full flow curve table is provided in a matrix of H1 and H2 (downstream water level at normal pump intake). The second trigger point is this H1 value that initiates siphon flow condition.<sup>1</sup>
  - If an open air vent is available, siphon does not develop. The critical flow control shown on the left side of the rating curve (“Assuming the pipe never primes”) controls. However, full flow will occur with an open air vent when certain H1 thresholds are exceeded (such that the soffit pressures exceed atmospheric pressure). The H1 thresholds are listed under respective tailwater levels in two rows beneath the full flow rating curve table.
- If siphon flow develops, then it will continue until either the pressure at the soffit of the crest pipe drops below -9.5 psi, or when H1 falls below with 1 foot of the top of the outlet to the lake (which acts as the intake in reverse flow conditions). The third trigger point is the estimated elevation at which the siphon breaks. If the siphon breaks, then critical flow controls.

**Conclusions:** Modifications could be made to the estimates if and when more detailed information becomes available to make more conclusive backflow rating curve assumptions. The CENWP-EC-HD will continue to seek data on pump loss coefficients.

The 60% reverse flow rating curves are attached in order of pump stations. The tables present the flow rates per individual pump. The detailed calculations, assumptions, and assumed dimensions are available upon request.

Steve Schlenker  
 Karen Kuhn  
 Hydraulic Engineers  
 CENWP-EC-HD

---

<sup>1</sup> The threshold for which siphon flow develops is unpredictable and is dependent on conditions and system geometry. A momentary abrupt rise in the lake water surface could send a pulse that primes the conduit. On the other hand, minor cracks or air leaks in the conduit could also prevent or break the siphon before it would normally give way (3<sup>rd</sup> trigger point). The current H1 threshold values are based on EC-HD judgment—however the values are subject to change as more information is obtained.

St. Bernard Parish, #1 Fortifications Canal Pumping Station: 42 x 54 inches

<p><b>ENGINEERING DESIGN SHEET</b></p> <p>PROJECT: St. Bernard Parish Pump Stations                  #1/ Foundation Canal Pumping Station-42x54" pump                  40,000 gpm (1 pump this size, 3 total in station)</p> <p>SUBJECT: Backflow Rating Curves</p>		<p>OFFICE SYMBOL: CENWP-EC-HD                  COMPUTED BY: KK/SS    DATE: 22 Feb 2006                  WORKSHEET: Rating Curve</p> <p>CHECKED BY: SJS/KAK</p>						
<p>Crest Elevation (ft) = 3.83</p> <p>Trigger Points:                  Flow starts when H1 &gt; is greater than 3.83 ft crest of intake</p> <p>Assume Tainter Gate Left Open</p> <p><b>DRAFT Rating Curves for Approx 40,000 gpm Pump (42 X 54" diam propeller)</b>                  (assumed Pump #1 for #1 Fortification Canal Pumping Station)</p> <p>Discharge in CFS for H1 &amp; H2</p>								
<p><b>Rating Curve Per Pump: Flow Rate for H1 versus H2</b></p>								
		Elevation (H2) at Backflow Outlet C3						
		-6	-4	-2	0	2	4	6
H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	H2 = -6 (ft)	H2 = -4 (ft)	H2 = -2 (ft)	H2 = 0 (ft)	H2 = 2 (ft)	H2 = 4 (ft)	H2 = 6 (ft)
3.00	-0.83	0	0	0	0	0	0	0
3.50	-0.33	0	0	0	0	0	0	0
4.00	0.17	2	2	2	2	2	0	-88
4.50	0.67	17	17	17	17	17	17	-76
5.00	1.17	39	39	39	39	39	39	-62
5.50	1.67	66	66	66	66	66	66	-44
6.00	2.17	98	98	98	98	98	98	0
6.50	2.67	134	134	134	134	132	98	44
7.00	3.17	173	173	173	164	139	107	62
7.50	3.67	215	210	191	170	145	116	76
8.00	4.17	232	215	196	175	152	124	88
8.50	4.67	236	219	201	181	158	132	98
9.00	5.17	240	224	206	186	164	139	107
9.50	5.67	244	228	210	191	170	145	116
10.00	6.17	248	232	215	196	175	152	124
10.50	6.67	252	236	219	201	181	158	132
11.00	7.17	256	240	224	206	186	164	139
11.50	7.67	259	244	228	210	191	170	145
12.00	8.17	263	248	232	215	196	175	152
12.50	8.67	267	252	236	219	201	181	158
13.00	9.17	270	256	240	224	206	186	164

NOTES:

- 1 Rating curve is accurate within ± 30% due uncertainty of pump curve loss coefficient and unknown width of discharge channel
- 2 Loss and Trigger Point Assumptions:
  - Pump loss coefficient = 3.00
  - Siphon flow does not start till H1 > soffit of pipe at crest(Zt)
  - Intake loss = 0.5
  - Exit Loss = 1.2 (grating effect)
  - Bend and expansion losses also incorporated
- 3 Data Assumptions:
  - Tainter Gate Left open
  - Discharge Channel width = 10 feet
- 4 Data Needs:
  - Discharge Channel width
- 5 Backflow prevention:
  - Available: Tainter Gate for closure

St. Bernard Parish, #1 Fortifications Canal Pumping Station: 94 x 128 inches

<p><b>ENGINEERING DESIGN SHEET</b>                  PROJECT: St. Bernard Parish Pump Stations                  #4 Meraux Pump Station-94x128" pumps                  200,000 gpm (2 pumps this size, 3 total in station)                  SUBJECT: Backflow Rating Curves</p>		<p>OFFICE SYMBOL: CENWP-EC-HD                  COMPUTED BY: KK/SS DATE: 22 Feb 2006                  WORKSHEET: Rating Curve                  CHECKED BY: SJS/KAK</p>						
<p>Crest Elevation (ft) = 3.83                  Trigger Points:                  Flow starts when H1 &gt; is greater than 3.83 ft crest of weir</p> <p>Assume Tainter Gate Left Open</p> <p><b>DRAFT Rating Curves for Approx 200,000 gpm Pump (94X128" diam propeller)</b>                  (assumed Pump #2&amp;3 for #4 Meraux Pumping Station)</p> <p>Discharge in CFS for H1 &amp; H2</p>								
<p><b>Rating Curve per Pump: Flow Rate for H1 versus H2</b>                  Elevation (H2) at Backflow Outlet C3</p>								
		-6	-4	-2	0	2	4	6
H1 U/s Reservoir Elevation (ft)	Level Above Weir Crest (ft)	H2 = -6 (ft)	H2 = -4 (ft)	H2 = -2 (ft)	H2 = 0 (ft)	H2 = 2 (ft)	H2 = 4 (ft)	H2 = 6 (ft)
3.00	-0.83	0	0	0	0	0	0	0
3.50	-0.33	0	0	0	0	0	0	0
4.00	0.17	2	2	2	2	2	0	-361
4.50	0.67	17	17	17	17	17	17	-312
5.00	1.17	39	39	39	39	39	39	-255
5.50	1.67	66	66	66	66	66	66	-180
6.00	2.17	98	98	98	98	98	98	0
6.50	2.67	134	134	134	134	134	134	134
7.00	3.17	173	173	173	173	173	173	173
7.50	3.67	215	215	215	215	215	215	215
8.00	4.17	259	259	259	259	259	259	259
8.50	4.67	306	306	306	306	306	306	306
9.00	5.17	355	355	355	355	355	355	355
9.50	5.67	405	405	405	405	405	405	405
10.00	6.17	458	458	458	458	458	458	458
10.50	6.67	512	512	512	512	512	512	512
11.00	7.17	567	567	567	567	567	567	567
11.50	7.67	624	624	624	624	624	624	598
12.00	8.17	682	682	682	682	682	682	625
12.50	8.67	741	741	741	741	741	741	650
13.00	9.17	800	800	800	800	800	765	675

NOTES:

- 1 Full flow Rating curve is accurate within  $\pm 30\%$  due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed
- 2 Loss and Trigger Point Assumptions:
  - Pump loss coefficient = 3.00
  - Siphon flow does not start till H1 > soffit of pipe at crest(Zt)
  - Intake loss = 0.5
  - Exit Loss = 1.2
  - Bend and expansion losses also incorporated
- 3 Data Assumptions:
  - Tainter Gate Left open
  - Discharge gate width = 10 feet
- 4 Data Needs:
  - Discharge gate width
- 5 Backflow prevention:
  - Available: Tainter Gate for Closure

St. Bernard Parish, #2 Guichard and #3 Bayou Villere: 42 inch Pumps

<b>ENGINEERING DESIGN SHEET</b>			OFFICE SYMBOL: CENWP-EC-HD			
PROJECT: St. Bernard Parish Pump Stations			COMPUTED BY: KK/SS		DATE: 22 Feb 2006	
Guichard #2/ Bayou Villere #3 -42" pumps approx 50,000 gpm					WORKSHEET: Rating Curve	
SUBJECT: Backflow Rating Curves			CHECKED BY: SJS/KAK			

Crest Elevation (ft) = 11

Trigger Points:  
 Flow starts when H1 > is greater than 11 ft crest of conduit  
 Siphon Flow starts with rising H1 when:  
     If no open air valve or vent, when H1 > Soffit = 14.5 ft assume siphon starts when H1 = Zt  
     If open vent; see bottom of table for when full flow occurs  
 If siphon flow develops, flow stops (approx.) when H1 < 2 ft assume drawdown at intake ≈1 ft.

**DRAFT Rating Curves for Approx 50,000 gpm Pump (42" propeller)**  
 (assumed Pump #1 for Guichard PS#2 and possible pump(s) for Bayou Villere PS#3)

Discharge in CFS for H1 & H2

**Assuming Pipe never primes:**

H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	Q Flow Rate (cfs)
8.00	-3.00	0
8.50	-2.50	0
9.00	-2.00	0
9.50	-1.50	0
10.00	-1.00	0
10.50	-0.50	0
11.00	0.00	0
11.50	0.50	2
12.00	1.00	6
12.50	1.50	13
13.00	2.00	21
13.50	2.50	30
14.00	3.00	39
14.50	3.50	48
15.00	4.00	56
15.50	4.50	65
16.00	5.00	73
16.50	5.50	80
17.00	6.00	87
17.50	6.50	94
18.00	7.00	101

**If Pipe primes then full flow outlet control as siphon:**  
 Primed Flow (full Outlet Control) as function of H2  
 Elevation (H2) at Backflow Outlet C3

-6	-3.16667	-0.333333	2.5	5.333333	8.166667	11
Primed Conduit, H2 =-6 (ft)	Primed Conduit, H2 =-3 (ft)	Primed Conduit, H2 =0 (ft)	Primed Conduit, H2 =3 (ft)	Primed Conduit, H2 =5 (ft)	Primed Conduit, H2 =8 (ft)	Primed Conduit, H2 =11 (ft)
113	101	87	71	49	-12	-52
115	103	90	74	54	17	-48
117	105	92	77	58	28	-43
119	107	95	80	62	35	-37
121	109	97	83	65	41	-30
123	112	99	85	69	46	-21
124	114	102	88	72	51	0
126	116	104	91	75	55	21
128	118	106	93	78	59	30
130	119	108	95	81	63	37
132	121	110	98	84	66	43
133	123	112	100	86	70	48
135	125	114	102	89	73	52
137	127	116	105	91	76	56
138	129	118	107	94	79	60
140	130	120	109	96	82	64
142	132	122	111	99	84	67
143	134	124	113	101	87	71
145	136	126	115	103	90	74
146	137	127	117	105	92	77
148	139	129	119	107	95	80

Estimated H1 required for full flow if Open Air Valve or vent:  
 TW=-6 TW=-3 TW=0 TW=3 TW=5 TW=8 TW=11  
 If Open Air Valve H1 > 19 18 17 15 14 12 #NUM!

NOTES:

- 1 Full flow Rating curve is accurate within ± 30% due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed
- 2 Loss and Trigger Point Assumptions:  
 Pump loss coefficient = 3.00  
 Siphon flow does not start till H1 > soffit of pipe at crest(Zt)  
 Intake loss = 0.5  
 Exit Loss = 1  
 Bend and expansion losses also incorporated
- 3 Data Assumptions:  
 Shape/length/angle of: bends, pipes, outlet, intake assumed from Pump info in questionnaire and photos.  
 Elevations assumed from information on questionnaire sheets for PS#2 & assumed similarity to PS#6.  
 NOTE: Information regarding elevations for PS#2 and PS#3 are not consistent (varies by about 10 feet)
- 4 Data Needs:  
 Shape/length/angle of: bends, pipes, outlet, intake.  
 Elevations for bends, pipes, pump, outlet, intake etc.  
 Pump info for Pump #3 at Guichard PS#2; and for Pumps #1, #2, #3 for Bayou Villere PS#3  
 Cover sheet for PS#2 indicates pump #3 is 75,000 gpm pump. No other usable info given.  
 Need pump diam for pump #3 to estimate backflow curve.  
 Cover sheet for PS#3 indicates 3 pumps @ 50,000 & 75,000 & 100,000 gpm  
 Questionnaire responses indicate 3 pumps @ 60" propeller, 90" intake, 60" discharge column.  
 More information needed to determine if curves given are usable for PS#3.
- 5 Backflow prevention:  
 Available: PS#2 No floodgates; No backflow valves  
 PS#3 Intake pipes to pumps 1 and 2 have butterfly valves  
 Installed/used: PS#2 n/a  
 PS#3 No backstops/brakes installed to prevent reverse rotation

St. Bernard Parish, #2 Guichard and #3 Bayou Villere: 60 inch Pumps

<b>ENGINEERING DESIGN SHEET</b>			OFFICE SYMBOL: CENWP-EC-HD			
PROJECT: St. Bernard Parish Pump Stations			COMPUTED BY: KK/SS		DATE: 22 Feb 2006	
Guichard #2/ Bayou Villere #3-60" pumps appr 100,000 gpm			WORKSHEET: Rating Curve			
SUBJECT: Backflow Rating Curves			CHECKED BY: SJS/KAK			

Crest Elevation (ft) = 11

Trigger Points:  
 Flow starts when H1 > is greater than 11 ft crest of conduit  
 Siphon Flow starts with rising H1 when:  
     If no open air valve or vent, when H1 > Soffit = 16.0 ft assume siphon starts when H1 = Zt  
     If open vent; see bottom of table for when full flow occurs  
 If siphon flow develops, flow stops (approx.) when H1 < 3 ft assume drawdown at intake ≈1 ft.

**DRAFT Rating Curves for Approx 100,000 gpm Pump (60" diam propeller)**  
**(assumed Pump #2 & #4 for Guichard PS#2 and possible pump(s) for Bayou Villere PS#3)**

Discharge in CFS for H1 & H2

**Assuming Pipe never primes:**

H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	Q Flow Rate (cfs)
8.00	-3.00	0
8.50	-2.50	0
9.00	-2.00	0
9.50	-1.50	0
10.00	-1.00	0
10.50	-0.50	0
11.00	0.00	0
11.50	0.50	2
12.00	1.00	7
12.50	1.50	16
13.00	2.00	27
13.50	2.50	41
14.00	3.00	55
14.50	3.50	70
15.00	4.00	86
15.50	4.50	102
16.00	5.00	118
16.50	5.50	133
17.00	6.00	148
17.50	6.50	162
18.00	7.00	176

**If Pipe primes then full flow outlet control as siphon:**  
 Primed Flow (full Outlet Control) as function of H2  
 Elevation (H2) at Backflow Outlet C3

-6	-3.16667	-0.33333	2.5	5.33333	8.16667	11
Primed Conduit, H2 = -6 (ft)	Primed Conduit, H2 = -3 (ft)	Primed Conduit, H2 = 0 (ft)	Primed Conduit, H2 = 3 (ft)	Primed Conduit, H2 = 5 (ft)	Primed Conduit, H2 = 8 (ft)	Primed Conduit, H2 = 11 (ft)
233	208	180	146	102	-25	-108
237	212	185	152	111	36	-98
241	217	190	159	119	57	-88
245	221	195	165	127	72	-76
249	226	200	170	134	84	-62
253	230	205	176	141	95	-44
256	234	209	181	148	105	0
260	238	214	187	154	114	44
264	242	218	192	161	122	62
268	246	223	197	167	129	76
271	250	227	202	172	137	88
275	254	231	206	178	144	98
278	258	236	211	183	150	108
282	261	240	215	188	157	116
285	265	244	220	193	163	124
288	269	248	224	198	168	132
292	272	251	229	203	174	139
295	276	255	233	208	180	146
298	279	259	237	212	185	152
302	283	263	241	217	190	159
305	286	266	245	221	195	165

Estimated H1 required for full flow if Open Air Valve or vent:  
 TW=-6 TW=-3 TW=0 TW=3 TW=5 TW=8 TW=11  
 If Open Air Valve H1 > 19 18 16 15 14 12 #NUM!

**NOTES:**

- Full flow Rating curve is accurate within ± 30% due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed
- Loss and Trigger Point Assumptions:  
 Pump loss coefficient = 3.00  
 Siphon flow does not start till H1 > soffit of pipe at crest(Zt)  
 Intake loss = 0.5  
 Exit Loss = 1  
 Bend and expansion losses also incorporated
- Data Assumptions:  
 Shape/length/angle of: bends, pipes, outlet, intake assumed from Pump info in questionnaire and photos.  
 Elevations assumed from information on questionnaire sheets for PS#2 & assumed similarity to PS#6.  
 NOTE: Information regarding elevations for PS#2 and PS#3 are not consistent (varies by about 10 feet)
- Data Needs:  
 Shape/length/angle of: bends, pipes, outlet, intake.  
 Elevations for bends, pipes, pump, outlet, intake etc.  
 Pump info for Pump #3 at Guichard PS#2; and for Pumps #1, #2, #3 for Bayou Villere PS#3  
 Cover sheet for PS#2 indicates pump #3 is 75,000 gpm pump. No other usable info given.  
 Need pump diam for pump #3 to estimate backflow curve.  
 Cover sheet for PS#3 indicates 3 pumps @ 50,000 & 75,000 & 100,000 gpm  
 Questionnaire responses indicate 3 pumps @ 60" propeller, 90" intake, 60" discharge column  
 More information needed to determine if curves given are usable for PS#3.
- Backflow prevention:  
 Available: PS#2 No floodgates; No backflow valves  
 PS#3 Intake pipes to pumps 1 and 2 have butterfly valves  
 Installed/used: PS#2 n/a  
 PS#3 No backstops/brakes installed to prevent reverse rotation

St. Bernard Parish, #4 Meraux Pumping Station: 42 x 54 inches

<b>ENGINEERING DESIGN SHEET</b>		OFFICE SYMBOL: CENWP-EC-HD	
PROJECT: St. Bernard Parish Pump Stations #4 Meraux Pumping Station-42x54" pump 40,000 gpm (1 pump this size, 3 total in station)		COMPUTED BY: KK/SS	DATE: 22 Feb 2006
SUBJECT: Backflow Rating Curves		CHECKED BY: SJS/KAK	WORKSHEET: Rating Curve

Crest Elevation (ft) = 3.83  
 Trigger Points:  
 Flow starts when H1 > is greater than 3.83 ft crest of intake

Assume Tainter Gate Left Open

**DRAFT Rating Curves for Approx 40,000 gpm Pump (42 X 54" diam propeller)**  
**(assumed Pump #1 for #4 Meraux Pumping Station)**

Discharge in CFS for H1 & H2

**Rating Curve Per Pump: Flow Rate for H1 versus H2**

		Elevation (H2) at Backflow Outlet C3						
		-6	-4	-2	0	2	4	6
H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	H2 = -6 (ft)	H2 = -4 (ft)	H2 = -2 (ft)	H2 = 0 (ft)	H2 = 2 (ft)	H2 = 4 (ft)	H2 = 6 (ft)
3.00	-0.83	0	0	0	0	0	0	0
3.50	-0.33	0	0	0	0	0	0	0
4.00	0.17	2	2	2	2	2	0	-88
4.50	0.67	17	17	17	17	17	17	-76
5.00	1.17	39	39	39	39	39	39	-62
5.50	1.67	66	66	66	66	66	66	-44
6.00	2.17	98	98	98	98	98	88	0
6.50	2.67	134	134	134	134	132	98	44
7.00	3.17	173	173	173	164	139	107	62
7.50	3.67	215	210	191	170	145	116	76
8.00	4.17	232	215	196	175	152	124	88
8.50	4.67	236	219	201	181	158	132	98
9.00	5.17	240	224	206	186	164	139	107
9.50	5.67	244	228	210	191	170	145	116
10.00	6.17	248	232	215	196	175	152	124
10.50	6.67	252	236	219	201	181	158	132
11.00	7.17	256	240	224	206	186	164	139
11.50	7.67	259	244	228	210	191	170	145
12.00	8.17	263	248	232	215	196	175	152
12.50	8.67	267	252	236	219	201	181	158
13.00	9.17	270	256	240	224	206	186	164

NOTES:

- 1 Rating curve is accurate within  $\pm 30\%$  due uncertainty of pump curve loss coefficient and unknown width of discharge channel
- 2 Loss and Trigger Point Assumptions:  
 Pump loss coefficient = 3.00  
 Siphon flow does not start till H1 > soffit of pipe at crest(Zt)  
 Intake loss = 0.5  
 Exit Loss = 1.2 (grating effect)  
 Bend and expansion losses also incorporated
- 3 Data Assumptions:  
 Tainter Gate Left open  
 Discharge Channel width = 10 feet
- 4 Data Needs:  
 Discharge Channel width
- 5 Backflow prevention:  
 Available: Tainter Gate for closure



St. Bernard Parish, #4 Meraux Pumping Station: 94 x 128 inches

<b>ENGINEERING DESIGN SHEET</b>		OFFICE SYMBOL: CENWP-EC-HD						
PROJECT: St. Bernard Parish Pump Stations		COMPUTED BY: KK/SS	DATE: 22 Feb 2006					
#4 Meraux Pumping Station-94x128" pumps		WORKSHEET: Rating Curve						
200,000 gpm (2 pumps this size, 3 total in station)		CHECKED BY: SJS/KAK						
SUBJECT: Backflow Rating Curves								
Crest Elevation (ft) = 3.83								
Trigger Points:								
Flow starts when H1 > is greater than		3.83 ft	crest of weir					
Assume Tainter Gate Left Open								
<b>DRAFT Rating Curves for Approx 200,000 gpm Pump (94X128" diam propeller)</b>								
<b>(assumed Pump #2&amp;3 for #4 Meraux Pumping Station)</b>								
Discharge in CFS for H1 & H2								
<b>Rating Curve per Pump: Flow Rate for H1 versus H2</b>								
Elevation (H2) at Backflow Outlet C3								
		-6	-4	-2	0	2	4	6
H1 U/s Reservoir Elevation (ft)	Level Above Weir Crest (ft)	H2 = -6 (ft)	H2 = -4 (ft)	H2 = -2 (ft)	H2 = 0 (ft)	H2 = 2 (ft)	H2 = 4 (ft)	H2 = 6 (ft)
3.00	-0.83	0	0	0	0	0	0	0
3.50	-0.33	0	0	0	0	0	0	0
4.00	0.17	2	2	2	2	2	0	-361
4.50	0.67	17	17	17	17	17	17	-312
5.00	1.17	39	39	39	39	39	39	-255
5.50	1.67	66	66	66	66	66	66	-180
6.00	2.17	98	98	98	98	98	98	0
6.50	2.67	134	134	134	134	134	134	134
7.00	3.17	173	173	173	173	173	173	173
7.50	3.67	215	215	215	215	215	215	215
8.00	4.17	259	259	259	259	259	259	259
8.50	4.67	306	306	306	306	306	306	306
9.00	5.17	355	355	355	355	355	355	355
9.50	5.67	405	405	405	405	405	405	405
10.00	6.17	458	458	458	458	458	458	458
10.50	6.67	512	512	512	512	512	512	512
11.00	7.17	567	567	567	567	567	567	567
11.50	7.67	624	624	624	624	624	624	598
12.00	8.17	682	682	682	682	682	682	625
12.50	8.67	741	741	741	741	741	741	650
13.00	9.17	800	800	800	800	800	765	675

NOTES:

- 1 Full flow Rating curve is accurate within  $\pm 30\%$  due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed
- 2 Loss and Trigger Point Assumptions:
  - Pump loss coefficient = 3.00
  - Siphon flow does not start till H1 > soffit of pipe at crest(Zt)
  - Intake loss = 0.5
  - Exit Loss = 1.2
  - Bend and expansion losses also incorporated
- 3 Data Assumptions:
  - Tainter Gate Left open
  - Discharge gate width = 10 feet
- 4 Data Needs:
  - Discharge gate width
- 5 Backflow prevention:
  - Available: Tainter Gate for Closure

St. Bernard Parish, #5 E.J. Gore Pump Station

Flap gates on pipe exits prevent reverse flow through pumps.

St. Bernard Parish, #6 Jean Laffitte and #7 Bayou Ducros pumps

**ENGINEERING DESIGN SHEET**

PROJECT: St. Bernard Parish Pump Stations  
Jean Laffitte #6 & Bayou Ducros #7

SUBJECT: Backflow Rating Curves

OFFICE SYMBOL: CENWP-EC-HD

COMPUTED BY: KK/SS DATE: 22 Feb 2006

WORKSHEET: Rating Curve

CHECKED BY: SJS/KAK

Crest Elevation (ft) = 5

Trigger Points:

Flow starts when H1 > is greater than 5 ft crest of conduit

Siphon Flow starts with rising H1 when:

If no open air valve or vent, when H1 > Soffit = 11.0 ft assume siphon starts when H1 = Zt

If open vent; see bottom of table for when full flow occurs

If siphon flow develops, flow stops (approx.) when H1 < 4 ft assume drawdown at intake ?1 ft.

**DRAFT Rating Curves for Each Pump (3 total for each pump station)**

Discharge in CFS for H1 & H2

Assuming Pipe never primes:

H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	Q Flow Rate (cfs)
5.00	0.00	0
5.45	0.45	2
5.90	0.90	7
6.35	1.35	14
6.80	1.80	25
7.25	2.25	37
7.70	2.70	51
8.15	3.15	65
8.60	3.60	80
9.05	4.05	95
9.50	4.50	110
9.95	4.95	125
10.40	5.40	139
10.85	5.85	154
11.30	6.30	167
11.75	6.75	181
12.20	7.20	194
12.65	7.65	206
13.10	8.10	219
13.55	8.55	231
14.00	9.00	242

If Pipe primes then full flow outlet control as siphon:

Primed Flow (full Outlet Control) as function of H2

Elevation (H2) at Backflow Outlet C3						
-7.0	-5.0	-3.0	-1.0	1.0	3.0	5.0
Primed Conduit, H2 = -7 (ft)	Primed Conduit, H2 = -5 (ft)	Primed Conduit, H2 = -3 (ft)	Primed Conduit, H2 = -1 (ft)	Primed Conduit, H2 = 1 (ft)	Primed Conduit, H2 = 3 (ft)	Primed Conduit, H2 = 5 (ft)
301	274	245	213	174	123	0
306	280	252	220	183	136	58
312	286	259	228	192	148	82
317	292	265	235	201	159	101
322	298	272	242	209	169	116
328	304	278	249	217	179	130
333	309	284	256	225	188	143
338	315	290	262	232	197	154
343	320	295	269	239	205	165
348	325	301	275	246	213	175
352	330	307	281	253	221	184
357	335	312	287	260	229	193
362	340	318	293	266	236	202
367	345	323	299	272	243	210
371	350	328	304	278	250	218
376	355	333	310	284	257	225
380	360	338	315	290	263	233
385	364	343	321	296	270	240
389	369	348	326	302	276	247
393	374	353	331	307	282	254
398	378	358	336	313	288	260

Estimated H1 required for full flow if Open Air Valve or vent:

TW=-7 TW=-5 TW=-3 TW=-1 TW=1 TW=3 TW=5

If Open Air Valve H1 > 17 15 13 11 9 7 5

NOTES:

1 Full flow Rating curve is accurate within ± 30% due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed

2 Loss and Trigger Point Assumptions:

Pump loss coefficient = 3.00

Siphon flow does not start till H1 > soffit of pipe at crest(Zt)

Intake loss = 2 (diffusion chamber at normal exit)

Exit Loss = 1

Bend and expansion losses also incorporated

3 Data Assumptions:

Shape/length/angle of diffuser/baffle based on photos

Shape/length/angle of 2nd bend based on sketch and photos

Pipe lengths estimated from photos and 1988 Design Worksheet.

Elevations in msl and NGVD are same

4 Data Needs:

Shape/length/angle of diffuser & detail of baffle

Detail of pumps incl bend to discharge pipe, impeller

St. Bernard Parish, #8 St Mary pumps

**ENGINEERING DESIGN SHEET**

PROJECT: St. Bernard Parish Pump Stations  
St. Mary #8

SUBJECT: Backflow Rating Curves

OFFICE SYMBOL: CENWP-EC-HD

COMPUTED BY: KK/SS DATE: 22 Feb 2006  
WORKSHEET: Rating Curve

CHECKED BY: SJS/KAK

Crest Elevation (ft) = 4.75

Trigger Points:

Flow starts when H1 > is greater than 4.75 ft crest of conduit

Siphon Flow starts with rising H1 when:

If no open air valve or vent, when H1 > Soffit = 10.3 ft assume siphon starts when H1 = Zt

If open vent; see bottom of table for when full flow occurs

If siphon flow develops, flow stops (approx.) when H1 < 4 ft assume drawdown at intake ?1 ft.

**DRAFT Rating Curves for Each Pump, 108x66 Centrifugal, approx 125,000 gpm, No. of Identical Pumps = 3**

Discharge in CFS for H1 & H2

**If Pipe primes then full flow outlet control as siphon:**

Primed Flow (full Outlet Control) as function of H2

Elevation (H2) at Backflow Outlet C3

Assuming Pipe never primes:

H1 U/s Reservoir Elevation (ft)	Level Above Discharge Pipe Crest (ft)	Q Flow Rate (cfs)
3.00	-1.75	0
3.50	-1.25	0
4.00	-0.75	0
4.50	-0.25	0
5.00	0.25	1
5.50	0.75	4
6.00	1.25	12
6.50	1.75	22
7.00	2.25	35
7.50	2.75	49
8.00	3.25	63
8.50	3.75	78
9.00	4.25	92
9.50	4.75	107
10.00	5.25	120
10.50	5.75	134
11.00	6.25	147
11.50	6.75	159
12.00	7.25	172
12.50	7.75	183
13.00	8.25	195

-7	-5	-3	-1	1	3	5
Primed Conduit, H2 = -7 (ft)	Primed Conduit, H2 = -5 (ft)	Primed Conduit, H2 = -3 (ft)	Primed Conduit, H2 = -1 (ft)	Primed Conduit, H2 = 1 (ft)	Primed Conduit, H2 = 3 (ft)	Primed Conduit, H2 = 5 (ft)
228	204	176	144	102	0	-102
233	210	184	153	114	51	-88
239	216	191	161	125	72	-72
244	222	197	169	135	88	-51
249	228	204	176	144	102	0
255	233	210	184	153	114	51
260	239	216	191	161	125	72
265	244	222	197	169	135	88
269	249	228	204	176	144	102
274	255	233	210	184	153	114
279	260	239	216	191	161	125
283	265	244	222	197	169	135
288	269	249	228	204	176	144
292	274	255	233	210	184	153
297	279	260	239	216	191	161
301	283	265	244	222	197	169
306	288	269	249	228	204	176
310	292	274	255	233	210	184
314	297	279	260	239	216	191
318	301	283	265	244	222	197
322	306	288	269	249	228	204

Estimated H1 required for full flow if Open Air Valve or vent:

TW=-7 TW=-5 TW=-3 TW=-1 TW=1 TW=3 TW=5

If Open Air Valve H1 > 16 14 12 10 8 6 #NUM!

NOTES:

1 Full flow Rating curve is accurate within ± 30% due uncertainty of pump curve loss coefficient and timing and degree of siphoning developed

2 Loss and Trigger Point Assumptions:

Pump loss coefficient = 3.00  
Siphon flow does not start till H1 > soffit of pipe at crest(Zt)  
Intake loss = 2  
Exit Loss = 1  
Bend and expansion losses also incorporated

3 Data Assumptions:

Shape/length/angle of diffuser/baffle based on photos for PS#6 and PS#8 (similar to PS#6 but longer pipe)  
Shape/length/angle of 2nd bend based on 1/2 dwg and photos (assumed similar to PS#6/7)  
Pipe lengths estimated from photos and 1988 Design Worksheet for PS#6 and photos for PS#8.

4 Data Needs:

Shape/length/angle of diffuser & detail of baffle  
Detail of pumps incl bend to discharge pipe, impeller

Name	Pump	Capacity (cfs)	Manufacture	Size (in)	Model Number	Serial Number	Installed (year)	Driver Electric /Diesel	Rated Pump Speed (rpm)	Pump Type (Vertical/Horizontal)	Pump Elevation* (NGVD)	Pump Curve (yes/no)	Discharge Gates (type)	Rated Head (ft)	Track Rack Design Head (ft)	Intake Location	Discharge Location	Intake water	Intake water	Intake water	Water	Bearing Lubrication (oil/water)	Backstops or brakes (yes/no)	
																		elevation at Start (NGVD)	elevation at Stop (NGVD)	elevation range (NGVD)	elevations that effects station (NGVD)			
<b>Fortification #1</b>	1	445	Baldwin-Lima-Hamilton (Patterson)	94 x 128	AFV	?	1972	Diesel	212	Vertical	-1.5	yes	tainter gates	19	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	8	Oil	No	
	2	90	Baldwin-Lima-Hamilton (Patterson)	42 x 54	AFV	?	1972	Electric 60 Hz	505	Vertical	-1.5	yes	tainter gates	20	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	8	Oil	No	
	3	445	Baldwin-Lima-Hamilton (Patterson)	94 x 128	AFV	?	1972	Diesel	212	Vertical	-1.5	yes	tainter gates	19	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	8	Oil	No	
	<b>Total</b>	<b>980</b>																						
<b>Guichard #2</b>	1**	111	M&W (MWI)	42	NC342P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	none	n/a	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	4	Oil	No	
	2**	267	M&W (MWI)	60	NC360P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	none	n/a	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	4	Oil	No	
	3**	110	?	?	?	1950's	Diesel	n/a	Horizontal	-8	yes	none	n/a	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	4	Oil	No		
	4**	267	M&W (MWI)	60	NC360P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	none	n/a	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	4	Oil	No	
<b>Total</b>	<b>755</b>																							
<b>Bayou Villere #3</b>	1**	266	M&W (MWI)	60	NC360P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	butterfly valve	n/a	n/a	Forty Arpent Canal	Bayou Villere	-6.0	-6.5	0.5	12	Oil	Yes	
	2**	267	M&W (MWI)	60	NC360P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	butterfly valve	n/a	n/a	Forty Arpent Canal	Bayou Villere	-6.0	-6.5	0.5	12	Oil	Yes	
	3***	267	M&W (MWI)	60	NC360P12	?	1950's	Diesel	n/a	Horizontal	-8	yes	none	n/a	n/a	Forty Arpent Canal	Bayou Villere	-6.0	-6.5	0.5	12	Oil	No	
	<b>Total</b>	<b>800</b>																						
<b>Meraux #4</b>	1	445	Baldwin-Lima-Hamilton (Patterson)	94 x 128	AFV	?	1972	Diesel	212	Vertical	-1.5	yes	floodgate	n/a	n/a	Forty Arpent Canal	Bayou Dupre	-6.0	-6.5	0.5	16	Grease	No	
	2	90	Baldwin-Lima-Hamilton (Patterson)	42 x 54	AFV	?	1972	Electric 60 Hz	505	Vertical	-1.5	yes	floodgate	n/a	n/a	Forty Arpent Canal	Bayou Dupre	-6.0	-6.5	0.5	16	Grease	No	
	3	445	Baldwin-Lima-Hamilton (Patterson)	94 x 128	AFV	?	1972	Diesel	212	Vertical	-1.5	yes	floodgate	n/a	n/a	Forty Arpent Canal	Bayou Dupre	-6.0	-6.5	0.5	16	Grease	No	
	<b>Total</b>	<b>980</b>																						
<b>E.J. Gore #5</b>	1	111	M&W (MWI)	42	NC342P12	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
	2	111	M&W (MWI)	42	NC342P13	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
	3	111	M&W (MWI)	42	NC342P14	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
	4	111	M&W (MWI)	42	NC342P15	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
	5	111	M&W (MWI)	42	NC342P16	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
	6	110	M&W (MWI)	42	NC342P17	?	1980's	Diesel	n/a	Horizontal	-8	yes	flap gates	n/a	n/a	Forty Arpent Canal	Bayou Dupre	0.0	-0.5	0.5	2	Oil	No	
<b>Total</b>	<b>665</b>																							
<b>Jean Lafitte #6</b>	1	315	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G72	1990	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	9	Grease	Yes	
	2	315	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G72	1990	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	9	Grease	Yes	
	3	315	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G73	1990	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Florida Walk Canal	Bayou Bienvenue	-6.0	-6.5	0.5	9	Grease	Yes	
<b>Total</b>	<b>945</b>																							
<b>Bayou Ducros #7</b>	1	333	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G73	1992	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Forty Arpent Canal	Bayou Ducros	-6.0	-6.5	0.5	16	Grease	Yes	
	2	333	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G73	1992	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Forty Arpent Canal	Bayou Ducros	-6.0	-6.5	0.5	16	Grease	Yes	
	3	334	Patterson Pump Co.	75 x 72	AFV	90PT-14688-90-G73	1992	Diesel	272	Vertical	-8	yes	none	10.5	n/a	Forty Arpent Canal	Bayou Ducros	-6.0	-6.5	0.5	16	Grease	Yes	
<b>Total</b>	<b>1000</b>																							
<b>St. Mary #8</b>	1	278	ITT-AC	108 x 66	115-143543	1-0840-70720-02	1996	Diesel	230	Vertical	-9 (intake)	yes	none	2.5	n/a	Twenty Arpent Canal	Lake Lery	0.0	-0.5	0.5	8	Grease	Yes	
	2	278	ITT-AC	108 x 66	115-143543	1-0840-70720-01	1996	Diesel	230	Vertical	-9 (intake)	yes	none	2.5	n/a	Twenty Arpent Canal	Lake Lery	0.0	-0.5	0.5	8	Grease	Yes	
	3	279	ITT-AC	108 x 66	115-143543	1-0840-70720-03	1996	Diesel	230	Vertical	-9 (intake)	yes	none	2.5	n/a	Twenty Arpent Canal	Lake Lery	0.0	-0.5	0.5	8	Grease	Yes	
<b>Total</b>	<b>835</b>																							

\* Elevations estimated by Bob Turner/Lake Borgne Levee District and from engineering plans (when available)

Pump Station	Pump	Capacity (cfs)	8/28/2005 Start Stop	8/29/2005 Start Stop	8/30/2005 Start Stop	8/31/2005 Start Stop	9/1/2005 Start Stop	9/2/2005 Start Stop	9/3/2005 Start Stop	9/4/2005 Start Stop	9/5/2005 Start Stop	9/6/2005 Start Stop	9/7/2005 Start Stop	9/8/2005 Start Stop	9/9/2005 Start Stop	9/10/2005 Start Stop	9/11/2005 Start Stop	9/12/2005 Start Stop	9/13/2005 Start Stop	9/14/2005 Start Stop	9/15/2005 Start Stop	
Fortification #1	1 (East)	577					NA	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR				
	2 (Center)	100					NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR	NR				
	3 (West)	577					20:00 Run	Run 11:30	9:00 16:00	9:00 22:00	NR	NR	NR	NR	NR	NR	NR	NR				
	<b>Total</b>	<b>1254</b>																				
Guichard #2	1	111	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	2	223	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	3	167	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	4	223	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
<b>Total</b>	<b>724</b>																					
Bayou Villere #3	1	n/a	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	2	n/a	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	3	n/a	NR	NR	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
<b>Total</b>	<b>500</b>																					
Meraux #4	1 (East)	557	19:05 20:25						9:20 16:20													
	2 (Electric)	89	NR						NR													
	3 (West)	557	NR						NR													
<b>Total</b>	<b>1203</b>																					
E.J. Gore #5	1	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	2	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	3	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	4	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	5	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
	6	110			NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
<b>Total</b>	<b>660</b>																					
Jean Lafitte #6	1	334	16:00 16:45		14:45 22:00	6:00 20:00	6:00 Run	Run 6:00	8:00 19:30 20:30 Run	Run 14:00	7:30 22:00	22:00 Run	Run 1:00 22:00 Run	Run Run	Run Run	Run Run	Run 9:00 11:30 13:30 16:30 18:30 22:30 0:00	3:30 5:00				
	2	334	16:00 16:45		14:45 22:00	6:00 20:00	6:00 Run	Run 6:00	8:00 19:30 20:30 Run	Run 14:00	7:30 22:00	22:00 Run	Run 1:00 22:00 Run	Run Run	Run Run	Run Run	Run 9:00 11:30 13:30 16:30 18:30 22:30 0:00	3:30 5:00				
	3	334	16:00 16:45		14:45 22:00	6:00 20:00	6:00 Run	Run 6:00	8:00 19:30 20:30 Run	Run 14:00	7:30 22:00	22:00 Run	Run 1:00 22:00 Run	Run Run	Run Run	Run Run	Run 9:00 11:30 13:30 16:30 18:30 22:30 0:00	3:30 5:00				
<b>Total</b>	<b>1002</b>																					
Bayou Ducros #7	1	334	7:40 9:10 17:00 17:45 19:35 20:05							8:00 Run	Run 16:00 18:00 Run	Run Run	Run Run	Run Run	Run Run	Run 0:00	8:30 12:00					
	2	334	7:40 9:10 17:00 17:45 19:35 20:05							8:00 Run	Run 16:00 18:00 Run	Run Run	Run Run	Run Run	Run Run	Run 0:00	8:30 12:00					
	3	334	7:40 9:10 17:00 17:45 19:35 20:05							8:00 Run	Run 16:00 18:00 Run	Run Run	Run Run	Run Run	Run Run	Run 0:00	8:30 12:00					
<b>Total</b>	<b>1002</b>																					
St. Mary #8	1	279					15:45 Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run 20:00		15:00 Run	Run 17:30	14:00 19:30	7:00 Run	Run Run	Run 1:00
	2	279	9:15 0:00				15:45 Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run 14:00	6:00 Run	Run 21:30	14:00 16:30	7:15 Run	Run Run	Run 3:00
	3	279								11:45 Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run Run	Run 6:00
<b>Total</b>	<b>837</b>																					

Time in Local CST Day Light Savings  
Pumps Not Available NA  
No Reported Run Times NR  
Continued to Run Run  
Damaged/ Lost/ Unavailable Record  
Information was not obtained (Area  
considered Unwatered)



St Bernard Parish Canal and Tide Level Readings

Pump Stations	28-Aug-05		29-Aug-05		30-Aug-05		31-Aug-05		1-Sep-05		2-Sep-05		3-Sep-05		4-Sep-05		5-Sep-05		6-Sep-05		7-Sep-05		8-Sep-05		9-Sep-05		10-Sep-05		11-Sep-05		12-Sep-05		13-Sep-05		14-Sep-05		15-Sep-05		
	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	Time	Gage	
PS 1 - Fortication	Canal	2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00	
	Tide	6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00	
	Canal	10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00	
	Tide	14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00	
	Canal	18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00	
	Tide	22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00	
	Canal	2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00	
	Tide	6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00	
	Canal	10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00	
	Tide	14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00	
	Canal	18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00	
	Tide	22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00	
	Canal	2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00		2:00	
	Tide	6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00		6:00	
	Canal	10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00		10:00	
	Tide	14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00		14:00	
	Canal	18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00		18:00	
	Tide	22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00		22:00	

Readings were extracted from Operations Logs acquired by IPET Task 8 for each pump station where available.

This is a preliminary report subject to revision; it does not contain final conclusions of the United States Army Corps of Engineers.