

**QUESTIONS AND ANSWERS
CA PFH 149-1(4) & 150-1(1)
TRINITY COUNTY 3R**

November 15, 2012

Question 1: Please specify the type of culvert and thickness if culvert is to be steel. Also, please specify joint type. Please specify type of pipe to be used for the standard underdrain-plastic or steel. These questions pertain to the following bid items: 60201-0600, 60201-0800, 60201-0900, 60201-1000, 60201-1200, 60201-1400, 60201-1600, 60201-1800, 60202-1200, 60501-0000, 60501

Answer 1: The culverts should be metal pipe culverts, as shown in plan sheets T2-T5. The thicknesses are shown on sheet T2 and coupling bands are shown on sheet T3.

The pipes used for standard underdrains are discussed in section 706.08 of the SCR's, as referenced on plan sheet T9.