

# **Fifth Annual Conference on Carbon Capture & Sequestration**

*Steps Toward Deployment*

*CCS Economic Analyses*

## **2006 Cost & Performance Comparison of Fossil Energy Power Plants**

Jared Ciferno, NETL

Julianne Klara, NETL

Ronald Schoff, Parsons

Pamela Capicotto, Parsons

May 8-11, 2006 • Hilton Alexandria Mark Center • Alexandria, Virginia



# Disclaimer

**This presentation was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.**



# Overview

- **Purpose**: To compare near-term commercial offerings for IGCC, PC and NGCC cases both with and without current technology for CO<sub>2</sub> capture
  - Developed with consistent design requirements and up-to-date performance and capital cost estimates
  - Considered technologies that could be built now and deployed by 2010
  - Provides baseline costs and performance for which to compare advancing technologies within the FE R&D Program
- **Public report available Summer 2006**



# Study Matrix

Case	Plant Type	ST Cond. (psig/°F/°F)	GT	Gasifier/ Boiler	Acid Gas Removal / CO <sub>2</sub> Separation / Sulfur Recovery	CO <sub>2</sub> Cap
1	IGCC	1800/1050/1050	F Class	GE	Selexol / - / Claus	
2					Selexol / Selexol / Claus	90%
3				CoP E-Gas	MDEA / - / Claus	
4					Selexol / Selexol / Claus	90%
5				Shell	Sulfinol-M / - / Claus	
6					Selexol / Selexol / Claus	90%
7	PC	2400/1050/1050		Subcritical	Wet FGD / - / Gypsum	
8					Wet FGD / Econamine / Gypsum	90%
9		3500/1100/1100		Supercritical	Wet FGD / - / Gypsum	
10					Wet FGD / Econamine / Gypsum	90%
11	NGCC	2400/1050/950	F Class	HRSG		
12					- / Econamine / -	90%



GEE – GE Energy  
CoP – Conoco Phillips

# Design Basis: Coal Type

## Illinois #6 Coal Ultimate Analysis (weight %)

	As Rec'd	Dry
Moisture	11.12	0
Carbon	63.75	71.72
Hydrogen	4.50	5.06
Nitrogen	1.25	1.41
Chlorine	0.29	0.33
Sulfur	<b>2.51</b>	2.82
Ash	9.70	10.91
Oxygen (by difference)	6.88	7.75
	100.0	100.0
HHV (Btu/lb)	11,666	13,126

# Design Basis: Assumptions

## *Economic*

Startup	2010
Plant Life (Years)	20
Capital Charge Factor (%)	13.8
Dollars (Constant)	2006
Coal (\$/MM Btu)	1.34
Capacity Factor	85

## *Site*


Greenfield, Midwestern USA, 0 ft Elevation  
Rail and Highway Access  
Municipal Water  
300 Acres



# Technical Approach

## 1. Extensive Process Simulation (ASPEN)

- All major chemical processes and equipment are simulated
- Detailed mass and energy balances
- Performance calculations (auxiliary power, gross/net power output)



## 2. Cost Estimation

- Inputs from process simulation (Flow Rates/Gas Composition/Pressure Temp.)
- Sources for cost estimation
  - Parsons
  - Vendor sources where available
- Follow DOE Analysis Guidelines

---

# **IGCC Power Plant**

## ***Current State CO<sub>2</sub> Capture Using Selexol™***


**Pre-Combustion CO<sub>2</sub> Capture Baseline**





# Pre-Combustion Current Technology

## IGCC Power Plant with CO<sub>2</sub> Scrubbing



### Emission Controls:

- PM:** Water scrubbing to get 0.013 lb/MMBtu
- NO<sub>x</sub>:** N<sub>2</sub> dilution to 200 Btu/scf LHV to get **15 ppmv @ 15% O<sub>2</sub>**
- SO<sub>x</sub>:** Selexol AGR removal of sulfur to **30 ppmv** in syngas  
Claus plant with tail gas recycle to Selexol for ~99.8% overall S recovery
- Hg:** Activated Carbon beds for ~90% removal

**Advanced F-Class Turbine - 232 MWe (42% LHV)**


**Steam Conditions - 1800 psig/1050°F/1050°F**

**Gross Power (MW)**  
 2 Comb. Turbines: 464  
 1 Stm. Turb: 200-300  
**Total Gross: 664-764**



# IGCC Current Technology

## IGCC Power Plant without CO<sub>2</sub> Capture



### Emission Controls:

- PM:** Water scrubbing to get 0.013 lb/MMBtu
- NOx:** N<sub>2</sub> dilution to 200 Btu/scf LHV to get **15 ppmv @ 15% O<sub>2</sub>**
- SOx:** Selexol AGR removal of sulfur to **30 ppmv** in syngas  
Claus plant with tail gas recycle to Selexol for ~99.8%  
overall S recovery
- Hg:** Activated Carbon beds for ~90% removal

**Advanced F-Class Turbine - 232 MWe (42% LHV)**


**Steam Conditions - 1800 psig/1050°F/1050°F**

### Gross Power (MW)

2 Comb. Turbines: 464  
1 Stm. Turb: 200-300  
Total Gross: 664-764




# Cases 1 & 2: GE Energy Radiant




**Design:** Pressurized, single-stage, downward firing, entrained flow, slurry feed, oxygen blown, slagging, radiant and quench cooling

**Note:** All gasification performance data estimated by the project team to be representative of GE gasifier

# Cases 3 & 4: ConocoPhillips E-Gas™



# Cases 5 & 6: Shell Gasification



**Design:** Pressurized, single-stage, downward firing, entrained flow, dry feed, oxygen blown, convective cooler

**Note:** All gasification performance data estimated by the project team to be representative of Shell gasifier

<b>Syngas</b>	
350°F, 600 Psia	
<u>Composition (Mole%):</u>	
H <sub>2</sub>	29%
CO	60%
CO <sub>2</sub>	2%
H <sub>2</sub> O	4%
Other	5%
<b>H<sub>2</sub>O/CO = 0.1</b>	

→ To Shift




Source: "The Shell Gasification Process", Uhde, ThyssenKrupp Technologies

# Water-Gas Shift Reactor System

## Design:

- Haldor Topsoe SSK Sulfur Tolerant Catalyst
- Up to 99% CO Conversion
- $H_2O/CO = 2.3$  (Project Assumption)
- Overall  $\Delta P = \sim 30$  psia



**$H_2O/CO$  has great effect on relative performance**




# CO<sub>2</sub> Capture via Selexol Scrubbing

## Advantages


- Physical Liquid Sorbent → High loadings at high CO<sub>2</sub> partial pressure
- Highly selective for H<sub>2</sub>S and CO<sub>2</sub> → No need for separate sulfur capture system
- No heat of reaction ( $\Delta H_{rxn}$ ), small heat of solution
- Chemically and thermally stable, low vapor pressure
- 30+ years of commercial operation (55 worldwide plants)

## Disadvantages

- Requires Gas Cooling (to ~100°F)
- CO<sub>2</sub> regeneration by flashing



# Selexol™ Scrubbing



P <sub>CO2</sub>	
GE	300
E-Gas	200
Shell	200





---

# IGCC Power Plant

## *Results*

**Pre-Combustion CO<sub>2</sub> Capture Baseline**




# Cases 1 & 2: GE Energy Radiant Performance

	Case 1 No Capture	Case 2 Capture	
Coal Flow Rate (Ton/day)	5,846	6,063	
CO <sub>2</sub> Captured (Ton/day)	-	13,120	
Total Gross Power (MW)	769	741	Steam for Capture
Auxiliary Power (MW)			
Base Plant Load	26	26	
Air Separation Unit	96	115	- Additional O <sub>2</sub> - ↑ in ASU air comp. load w/o CT integ.
Gas Cleanup/CO <sub>2</sub> Capture	3	8	
CO <sub>2</sub> Compression	-	29	
Total Auxiliary Load (MW)	125	178	Includes H <sub>2</sub> S/COS Removal in Selexol Solvent
Net Power (MW)	644	563	
Net Heat Rate (Btu/kWh)	8,832	10,463	
Efficiency (% HHV)	38.6	32.6	
Energy Penalty (%) <sup>1</sup>	-	16%	

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent decrease in net power plant efficiency due to CO<sub>2</sub> capture



# IGCC Auxiliary Load Summary




\*main air compressor



# IGCC Thermal Efficiency Summary

CO<sub>2</sub> Capture decreases net efficiency by 6-10 percentage points



\*Water Gas Shift

# Cases 1 & 2: GE Energy Radiant Economics


	Case 1 No Capture	Case 2 Capture	Difference
<b>Plant Cost (\$/kWe)<sup>1</sup></b>			
Base Plant	1,311	1,457	146
Air Separation Unit	100	165	65
Gas Cleanup/CO <sub>2</sub> Capture	146	262	116
CO <sub>2</sub> Compression	-	66	66
<b>Total Plant Cost (\$/kWe)</b>	<b>1,557</b>	<b>1,950</b>	<b>393</b>
<b>Capital COE (Cents/kWh)</b>	<b>3.21</b>	<b>4.02</b>	<b>0.81</b>
<b>Variable COE (Cents/kWh)</b>	<b>2.24</b>	<b>2.72</b>	<b>0.48</b>
<b>Total COE (Cents/kWh)<sup>2</sup></b>	<b>5.45</b>	<b>6.74</b>	<b>1.29</b>
<b>Increase in COE (%)</b>	-	<b>24</b>	
<b>\$/tonne CO<sub>2</sub> Avoided</b>	-	<b>18</b>	

<sup>1</sup>Total Plant Capital Cost (Includes contingencies and engineering fees)

<sup>2</sup>January 2006 Dollars, 85% Capacity Factor, 13.8% Levelization Factor, Coal cost \$1.34/10<sup>6</sup> Btu




# IGCC Economic Results Summary



**Average COE (cents/kWh) = 5.3 and 6.8 (w/capture)**  
**Average increase in COE for CO<sub>2</sub> capture = 30%**



# IGCC CO<sub>2</sub> Capture Mitigation Cost Summary



# IGCC CO<sub>2</sub> Capture Key Points

- 1. No ASU integration with CO<sub>2</sub> Capture cases, this increases ASU MAC\* power load and overall ASU capital costs**
- 2. Syngas H<sub>2</sub>O/CO ratio has large influence on water-gas shift steam requirement, steam turbine output and net plant efficiency**
- 3. CoP/E-Gas has high methane content, with Selexol at 95% capture, can only get 89% carbon capture**

\*Main Air Compressor





---

# **Pulverized Coal Power Plant**


## ***Current State* CO<sub>2</sub> Capture Using Advanced Amines**

**Post-Combustion CO<sub>2</sub> Capture Baseline**



# Post-Combustion Current Technology

## *Pulverized Coal Power Plant with CO<sub>2</sub> Scrubbing*



**PM Control:** Bag House to get 0.015 lb/MMBtu (99.8% removal)

**SO<sub>x</sub> Control:** FGD to get 0.086 lb/MMBtu (98.5% removal)

**NO<sub>x</sub> Control:** LNB + OFA + SCR to maintain 0.7 lb/MMBtu

**Mercury Control:** Activated Carbon Injection

**Steam Conditions (Subcritical) - 2400 psig/1050°F/1050°F**

**Steam Conditions (Supercritical) - 3500 psig/1100°F/1100°F**



# Amine Scrubbing Advantages/Disadvantages

## Amine Advantages

1. Proven Technology → Remove CO<sub>2</sub> and H<sub>2</sub>S from NG
2. Chemical solvent → *High* loadings at *low* CO<sub>2</sub> partial pressure
3. Relatively Cheap

## Amine Disadvantages

1. High heat of reaction → high regeneration energy required
  - 1,500 to 3,500 Btu/lb CO<sub>2</sub> removed
2. Degradation and Corrosion
  - Requires 10 ppm sulfur or less




# Amine Scrubbing Improvements

*Amine CO<sub>2</sub> scrubbing technology leaders are Fluor (Econamine FG Plus<sup>SM</sup>) and Mitsubishi (KS)*

Improvements	Benefits	Outcome
1. New Solvent Formulation	↑ Reaction Rates	↓ Packing volume, ↓ Absorber size ↓ Absorber cost
	↑ CO <sub>2</sub> Capacity	↓ Solvent circulation, ↓ Reboiler Duty
2. Heat Integration	↑ Reaction Rates	↓ Packing volume, ↓ Absorber size ↓ Absorber cost
	↑ CO <sub>2</sub> Capacity	↓ Solvent circulation, ↓ Reboiler Duty
3. Split Flow	↓ Reboiler Duty	↑ Power plant efficiency
4. Condensate Flash Steam Stripping	↓ Semi-Lean Loading	↓ Reboiler Duty
5. Integrated Steam Generation	↓ Reboiler Duty	↑ Power plant efficiency
6. Larger Diameter Vessels	60 foot diameter	Accommodate power plants
7. Non-Thermal Reclaimer	↓ Solvent Losses	↓ Solvent make-up costs, eliminate any solid hazardous waste



# Fluor Econamine FG Plus<sup>SM</sup> Scrubbing



Reboiler Heat Duty (Btu/lb CO <sub>2</sub> )	1,530	Regeneration (°F)	250's
MEA Circulation Rate (GPM)	35,000	Auxiliary Power (MW)	22-25
Absorption (°F)	100's	Induced Draft Fan (MW)	13-15



---

# Pulverized Coal Power Plant

## *Results*

**Post-Combustion CO<sub>2</sub> Capture Baseline**




# Pulverized Coal Combustion Performance

	Subcritical		Supercritical	
	No Capture	Capture	No Capture	Capture
Coal Flow Rate (Ton/day)	5,310	8,069	5,013	7,091
CO <sub>2</sub> Captured (Ton/day)	-	15,880	-	14,620
Total Gross Power (MW)	597	690	593	672
Auxiliary Power (MW)				
Base Plant Load	27	31	24	27
Forced + Induced Draft Fans	13	19	12	17
CO <sub>2</sub> Capture	-	25	-	22
CO <sub>2</sub> Compression	-	58	-	49
Flue Gas Cleanup	7	7	7	7
Total Auxiliary Load (MW)	47	140	43	122
Net Power (MW)	550	550	550	550
Net Heat Rate (Btu/kWh)	9,389	14,274	8,857	12,517
Efficiency (% HHV)	36	24	39	27
CO <sub>2</sub> Energy Penalty (%) <sup>1</sup>	-	33	-	31

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent decrease in net power plant efficiency due to CO<sub>2</sub> capture




# Pulverized Coal Auxiliary Load Summary





# Pulverized Coal Thermal Efficiency Summary

**CO<sub>2</sub> capture decreases net efficiency by 12 percentage points**



# Pulverized Coal Combustion Economics


	Subcritical		Supercritical	
	No Capture	Capture	No Capture	Capture
<b>Plant Cost (\$/kWe)<sup>1</sup></b>				
Base Plant	1,117	1,367	1,159	1,661
CO <sub>2</sub> Capture	-	624	-	622
CO <sub>2</sub> Compression	-	82	-	82
SOx and NOx Cleanup	206	285	196	257
<b>Total Plant Cost (\$/kWe)</b>	<b>1,323</b>	<b>2,358</b>	<b>1,355</b>	<b>2,365</b>
<b>Capital COE (Cents/kWh)</b>	<b>2.73</b>	<b>4.87</b>	<b>2.79</b>	<b>4.87</b>
<b>Variable COE (Cents/kWh)</b>	<b>2.22</b>	<b>3.70</b>	<b>2.14</b>	<b>3.39</b>
<b>Total COE (Cents/kWh)<sup>2</sup></b>	<b>4.95</b>	<b>8.57</b>	<b>4.94</b>	<b>8.27</b>
<b>Increase in COE (%)</b>	-	<b>73</b>	-	<b>67</b>
<b>\$/tonne CO<sub>2</sub> Avoided</b>	-	<b>49</b>	-	<b>48</b>

<sup>1</sup>Installed Plant Capital Cost (Includes contingencies and engineering fees)

<sup>2</sup>January 2006 Dollars, 85% Capacity Factor, 13.8% Levelization Factor, Coal cost \$1.34/10<sup>6</sup> Btu




# Pulverized Coal Summary Results



**PC CO<sub>2</sub> capture average increase in COE = 70%**



# Pulverized Coal CO<sub>2</sub> Capture Mitigation Costs



# Pulverized Coal CO<sub>2</sub> Capture Key Points

1. **Advanced amine scrubbing technology for 90% CO<sub>2</sub> capture continues to be very energy intensive and costly**
  - Definite need for performance and cost improvements
  - Good opportunity for R&D
2. **“Post-combustion CO<sub>2</sub> capture processes can be regarded as *current technology*, but some demonstration of these technologies at large scale coal fired power plants is needed before they can be widely adopted with an acceptable level of commercial risk.” (IEA 2004)**



# Acknowledgements

- **NETL Team**

- Juli Klara – Subtask Manager
- Jared Ciferno – Technical Monitor
- Mike Reed – Technical Monitor

- **RDS Team**

- Ron Schoff (Parsons Corporation) – Technical
- Pam Capicotto (Parsons Corporation) – Performance
- Mike Rutkowski (Parsons Corporation) – Technical
- Vlad Vaysman (WorleyParsons) – Technical
- Tom Buchanan (WorleyParsons) – Cost
- Massood Ramezan (SAIC) – Subtask Manager



---

**Thank You!**



# Cases 3 & 4: ConocoPhillips E-Gas™ Performance

	Case 3 No Capture	Case 4 Capture
Coal Flow Rate (Ton/day)	5,583	5,768
CO <sub>2</sub> Captured (Ton/day)	-	11,870
Total Gross Power (MW)	734	680
Auxiliary Power (MW)		
Base Plant Load	29	29
Air Separation Unit	91	103
Gas Cleanup/CO <sub>2</sub> Capture	2	7
CO <sub>2</sub> Compression	-	27
Total Auxiliary Load (MW)	122	166
Net Power (MW)	612	515
Net Heat Rate (Btu/kWh)	8,870	10,895
Efficiency (% HHV)	38.5	31.3
CO <sub>2</sub> Energy Penalty (%) <sup>1</sup>	-	19

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent decrease in net power plant efficiency due to CO<sub>2</sub> capture





# Cases 3 & 4: ConocoPhillips E-Gas™ Economics

	Case 3 No Capture	Case 4 Capture	Difference
<b>Plant Cost (\$/kWe)<sup>1</sup></b>			
Base Plant	1,173	1,399	226
Air Separation Unit	133	158	25
Gas Cleanup/CO <sub>2</sub> Capture	111	237	126
CO <sub>2</sub> Compression	-	67	67
<b>Total Plant Cost (\$/kWe)</b>	<b>1,417</b>	<b>1,861</b>	<b>444</b>
<b>Capital COE (Cents/kWh)</b>	<b>2.92</b>	<b>3.83</b>	<b>0.91</b>
<b>Variable COE (Cents/kWh)</b>	<b>2.01</b>	<b>2.51</b>	<b>0.50</b>
<b>Total COE (Cents/kWh)<sup>2</sup></b>	<b>4.93</b>	<b>6.34</b>	<b>1.41</b>
<b>Increase in COE (%)</b>	-	<b>29</b>	
<b>\$/tonne CO<sub>2</sub> Avoided</b>		<b>21</b>	

<sup>1</sup>Total Plant Capital Cost (Includes contingencies and engineering fees)

<sup>2</sup>January 2006 Dollars, 85% Capacity Factor, 13.8% Levelization Factor, Coal cost \$1.34/10<sup>6</sup> Btu



# Cases 5 & 6: Shell Gasification Performance

	Case 5 No Capture	Case 6 Capture
Coal Flow Rate (Ton/day)	5,401	5,743
CO <sub>2</sub> Captured (Ton/day)	-	12,430
Total Gross Power (MW)	736	667
Auxiliary Power (MW)		
Base Plant Load	25	23
Air Separation Unit	90	107
Gas Cleanup/CO <sub>2</sub> Capture	1	7
CO <sub>2</sub> Compression	-	29
Total Auxiliary Load (MW)	115	166
Net Power (MW)	621	501
Net Heat Rate (Btu/kWh)	8,468	11,156
Efficiency (% HHV)	40.3	30.6
CO <sub>2</sub> Energy Penalty (%) <sup>1</sup>	-	25

<sup>1</sup>CO<sub>2</sub> Capture Energy Penalty = Percent decrease in net power plant efficiency due to CO<sub>2</sub> capture



# Cases 5 & 6: Shell Gasification Economics

	Case 5 No Capture	Case 6 Capture	Difference
<b>Plant Cost (\$/kWe)<sup>1</sup></b>			
Base Plant	1,354	1,726	372
Air Separation Unit	124	154	30
Gas Cleanup/CO <sub>2</sub> Capture	115	302	187
CO <sub>2</sub> Compression	-	70	70
<b>Total Plant Cost (\$/kWe)</b>	<b>1,593</b>	<b>2,252</b>	<b>659</b>
<b>Capital COE (Cents/kWh)</b>	<b>3.28</b>	<b>4.63</b>	<b>1.35</b>
<b>Variable COE (Cents/kWh)</b>	<b>2.08</b>	<b>2.74</b>	<b>0.66</b>
<b>Total COE (Cents/kWh)<sup>2</sup></b>	<b>5.36</b>	<b>7.38</b>	<b>2.02</b>
<b>Increase in COE (%)</b>	-	<b>38</b>	
<b>\$/tonne CO<sub>2</sub> Avoided</b>		<b>30</b>	

<sup>1</sup>Total Plant Capital Cost (Includes contingencies and engineering fees)

<sup>2</sup>January 2006 Dollars, 85% Capacity Factor, 13.8% Levelization Factor, Coal cost \$1.34/10<sup>6</sup> Btu

