



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
1600 EAST LAMAR BLVD
ARLINGTON, TEXAS 76011-4511

December 10, 2012

Mr. Peter Dietrich
Senior Vice President and
Chief Nuclear Officer
Southern California Edison Company
San Onofre Nuclear Generating Station
P.O. Box 128
San Clemente, CA 92674-0128

SUBJECT: MEETING SUMMARY FOR NOVEMBER 30, 2012, MEETING WITH SOUTHERN CALIFORNIA EDISON COMPANY

Dear Mr. Dietrich:

On November 30, 2012, NRC personnel met with representatives of Southern California Edison at The Hills Hotel in Laguna Hills, California, to discuss the Confirmatory Action Letter dated March 27, 2012, concerning actions required to be taken to address steam generator tube degradation.

The meeting was recorded and copies of the recorded video, as well as written transcripts of the meeting will be made available on the NRC's website at <http://www.nrc.gov/info-finder/reactor/songs/tube-degradation.html>.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Ryan E. Lantz, Chief
SONGS Project Branch

Docket Nos.: 0500050361, 0500050362
License Nos.: NPF-10, NPF-15

Enclosures:

1. NRC Presentation
2. Southern California Edison Presentation

Electronic Distribution:

Regional Administrator (Elmo.Collins@nrc.gov)
 Deputy Regional Administrator (Steven.Reynolds@nrc.gov)
 SONGS Project Branch Team Manager (Art.Howell@nrc.gov)
 DRP Director (Kriss.Kennedy@nrc.gov)
 DRP Acting Deputy Director (Barry.Westreich@nrc.gov)
 DRS Acting Director (Tom.Blount@nrc.gov)
 DRS Acting Deputy Director (Jeff.Clark@nrc.gov)
 Senior Resident Inspector (Greg.Warnick@nrc.gov)
 Resident Inspector (John.Reynoso@nrc.gov)
 Chief, SONGS Project Branch (Ryan.Lantz@nrc.gov)
 SONGS Administrative Assistant (Heather.Hutchinson@nrc.gov)
 Senior Project Engineer, SONGS Project Branch (Nick.Taylor@nrc.gov)
 Project Engineer, SONGS Project Branch (Brian.Parks@nrc.gov)
 SONGS Project Branch Inspection Lead (Greg.Werner@nrc.gov)
 NRR SONGS Branch Chief (Doug.Broadus@nrc.gov)
 Public Affairs Officer (Victor.Dricks@nrc.gov)
 Public Affairs Officer (Lara.Uselding@nrc.gov)
 Project Manager (Randy.Hall@nrc.gov)
 Chief, DRS/TSB (Ray.Kellar@nrc.gov)
 RITS Coordinator (Marisa.Herrera@nrc.gov)
 Regional Counsel (Karla.Fuller@nrc.gov)
 Technical Support Assistant (Loretta.Williams@nrc.gov)
 Congressional Affairs Officer (Jenny.Weil@nrc.gov)
 Facilitator (fxcameo@gmail.com)
 RIV ETA (Cayetano.Santos@nrc.gov)
 State Liaison Officer (Bill.Maier@nrc.gov)
 OEmail.Resource@nrc.gov

S:\SPB\SO 11-30-12 MS

R:\ REACTORS\ SONGS\2012\SO 11-30-12 MS.docx

ADAMS: <input type="checkbox"/> No <input checked="" type="checkbox"/> Yes	<input type="checkbox"/> <input checked="" type="checkbox"/> SUNSI Review Complete	Reviewer Initials:
	<input checked="" type="checkbox"/> Publicly Available	<input checked="" type="checkbox"/> Non-Sensitive
	<input type="checkbox"/> Non-publicly Available	<input type="checkbox"/> Sensitive

RIV:SPE:SPB	C:SPB		
NHTaylor;dlf,	RELantz		
/RA/	/RA/		
12/6/12	12/6/12		

OFFICIAL RECORD COPY

T=Telephone

E=E-mail

F=Fax

**San Onofre Nuclear Generating Station
Unit 2 CAL Response
Public Meeting**



Nuclear Regulatory Commission - Region IV
November 30, 2012

1

Purpose of Today's Meeting

- Technical Presentation of SCE's Confirmatory Action Letter Response for Unit 2
- Discuss Activities Going Forward
- Answer Questions from the Audience

2

Agenda

- Introduction
- SCE Response to Confirmatory Action Letter
- NRC Remarks
- Path Forward
- Question and Answer Session

3

NRC Representatives

- Art Howell, Team Manager SONGS Special Project, Region IV
- Ryan Lantz, Branch Chief, SONGS Project Branch
- Greg Werner, Inspection and Assessment Lead Inspector
- Doug Broaddus, Branch Chief, SONGS Special Projects, NRR

4

NRC Representatives (Cont)

- Kenneth Karwoski, Senior Level Advisor, Division of Engineering, NRR
- Victor Dricks, Senior Public Affairs Officer
- Greg Warnick, Senior Resident Inspector, SONGS
- John Reynoso, Resident Inspector, SONGS
- Heather Hutchinson, NRC Administrative Assistant, SONGS

5

SONGS Representatives

- Peter Dietrich, Senior Vice President and Chief Nuclear Officer, SONGS, SCE
- Douglas Bauder, Vice President and Station Manager, SONGS, SCE
- Thomas Palmisano, Vice President of Engineering, Projects and Site Support, SONGS, SCE

6

Methodology


- Engaged world class experts in Steam Generator construction, thermal-hydraulics, and vibration
- Based on finding of Unit 3 Tube-to-Tube contact, determined tube vibration mode
- Determined causes of excessive tube vibration
- Determined corrective actions based on physical cause of tube vibration
- Validated causes and corrective actions with independent experts
- Established substantial safety margin

Technical Expertise Supporting SCE


- Mitsubishi Heavy Industries 
 - AREVA 
 - Westinghouse 
 - B&W Canada 
 - MPR Associates 
 - EPRI 
- Industry personnel, recognized academics and specialized consultants

STEAM GENERATOR OVERVIEW


Pressurized Water Reactor Layout









Steam Generator



Steam Generator Tubes





STEAM GENERATOR INSPECTION

Unit 2 Steam Generator Inspection

- Tube Inspections for Unit 2 Steam Generators
 - Eddy Current Bobbin Coil examinations of the full length of all tubes
 - Eddy Current Rotating Coil examinations
 - Full U-bend exam of tubes adjacent to retainer bars
 - Visual inspections
 - Specialty Eddy Current and Ultrasonic examinations

Unit 2 Steam Generator Inspection Results

- U2C17 Inspection Results
 - Steam Generator Technical Specification performance criteria were satisfied
 - Per industry guidelines, a single tube pressure test was required for Retainer Bar Wear and performed with satisfactory results
- Tube Wear Locations
 - Wear was detected at:
 - Anti-Vibration Bars (AVBs)
 - Tube Support Plates (TSPs)
 - Retainer Bar locations
 - Free-span Tube-to-Tube Wear (TTW)

Unit 2 Steam Generator Inspection Results

- Tube Wear at Anti-Vibration Bars (AVBs) and Tube Support Plates
 - Two tubes with wear above 35% limit were plugged
 - Preventatively plugged two tubes conservatively to add safety margin
- Tube Wear at Retainer Bars
 - Retainer bar size inadequate to prevent vibrating and contacting adjacent tubes
 - Vibration due to turbulent two-phase flow across retainer bars
 - Four tubes with wear above 35% limit were plugged
 - Preventatively plugged 182 tubes conservatively to add safety margin
- Tube-to-Tube Wear
 - Most likely caused by in-plane vibration
 - Two affected tubes with 14% wear depth were plugged
 - Preventatively plugged 321 tubes conservatively to add safety margin

Unit 3 Steam Generator Inspection

- Tube Inspections for Unit 3 Steam Generators
 - Leaking tube detected with leakage test
 - Eddy Current Bobbin and Rotating Coil examinations used to confirm location of leak
 - Eddy Current Bobbin Coil examinations of the full length of all tubes
 - Eddy Current Rotating Coil examinations
 - Full U-bend exam of tubes adjacent to retainer bars
 - Visual inspections
 - Specialty Eddy Current and Ultrasonic examinations

Unit 3 Steam Generator Inspection Results


- U3 Mid-Cycle Inspection Results
 - Steam Generator Technical Specification performance criteria were not satisfied
 - Per industry guidelines, 129 tube pressure tests were required due to Tube-to-Tube Wear
 - Eight tubes did not meet performance criteria due to Tube-to-Tube Wear
- Tube Wear Locations
 - Wear was detected at:
 - Anti-Vibration Bars (AVBs)
 - Tube Support Plates (TSPs)
 - Retainer Bar locations
 - Free-span Tube-to-Tube Wear (TTW)

Unit 3 Steam Generator Inspection Actions


- Tube Wear at Retainer Bars
 - Similar causes and actions as taken for Unit 2 Steam Generators
 - 94 tubes adjacent to retainer bars plugged in each Steam Generator
- Tube Wear at Anti-Vibration Bars
 - Three tubes with wear above 35% limit were plugged
- Tube Wear at Tube Support Plates
 - 230 tubes with wear above 35% limit
 - Included in actions taken for Tube-to-Tube Wear
- Tube-to-Tube Wear
 - Caused by in-plane vibration
 - All affected tubes (326) plugged
 - Preventatively plugged additional 292 tubes

TUBE-TO-TUBE WEAR


Steam Generator Cut-Away Elevation View




In Plane Motion and Tube-to-Tube Wear






Unit 3 Steam Generator Tube-to-Tube Wear Indications



Unit 3 SG E-088 Tube-to-Tube Wear





SONGS EXCELLENCE 2012

Comparison of Tube-to-Tube Wear (TTW) Between Unit 2 and Unit 3

Description	Unit 2	Unit 3
TTW Indications	2	823
TTW Tubes	2	326
Max Depth (ECT %TW)	14%	100%
Max Length	~6"	~41"
TTW In-Situ Pressure Tests	0	129
TTW In-Situ Pressure Tests (Unsatisfactory)	0	8
Operating Period (Months)	21	11

Leading the Way in Electricity

34

- SONGS EXCELLENCE 2012
- Tube-to-Tube Wear Cause**
- Fluid Elastic Instability (FEI): excessive tube vibration which occurs when a tube is subject to fluid velocities above a critical value
 - Adverse Thermal-Hydraulic (T/H) Conditions
 - High fluid velocities: transfers energy to the tube
 - High localized void fractions: reduces tube damping
 - Support structure unable to control resulting vibration
 - Anti-Vibration Bars unable to dampen tube vibration at full power
 - Combined with T/H conditions does not provide adequate damping to prevent FEI
- Leading the Way in Electricity
- 35


SONGS EXCELLENCE 2012

ROLE OF THERMAL- HYDRAULIC CODE

Leading the Way in Electricity

36

Modeling Use Flow Chart



Thermal-Hydraulic Codes


- FIT III used by MHI in design of Replacement Steam Generators
- FIT III under predicted critical Thermal-Hydraulic conditions such as fluid velocity and void fraction
- Use of ATHOS model during Replacement Steam Generator design would have identified reduced margin to fluid elastic instability
- All analysis supporting Unit 2 return to service uses ATHOS
- MHI's ATHOS model independently verified by AREVA and Westinghouse

CORRECTIVE ACTIONS


Preventing Fluid Elastic Instability (FEI)




- Reduce fluid velocity
 - Velocity of fluid: transfers energy to the tube
- Improve tube damping
 - Fluid film between tube and supports: function of void fraction/steam quality
 - Fluid interaction with tube: function of void fraction/steam quality
- Reducing power level
 - Reduces velocity
 - Improves void fraction/steam quality
 - Improves tube damping

Maximum Void Fraction as a Function of Power Level



Maximum Void Fraction as a Function of Power Level





- SONGS EXCELLENCE 2012
- ### Operational Assessments
- Forward looking analysis of Steam Generator performance
 - Three assessments prepared using diverse methods by independent companies
 - Demonstrate 16 -18 months of operation at 70% power until the next inspection
 - More than three times longer than conservatively proposed five month operating period
- Leading the Way in Electricity
- 46

- SONGS EXCELLENCE 2012
- ### Conservative Actions to Improve Safety Margin
- Power Reduction to 70%
 - Significantly reduces fluid velocities; less energy causing tubes to vibrate
 - Significantly reduces void fraction; better damping
 - Prevents Fluid Elastic Instability (FEI)
 - Preventive Plugging of Tubes
 - Tubes most susceptible to FEI at 100% power
 - Eliminates possibility of tube leakage
 - Short Operating Interval
 - Five month window is significantly shorter than analysis allows
 - 100% tube inspection during mid-cycle outage
- Leading the Way in Electricity
- 47

- SONGS EXCELLENCE 2012
- ### Additional CAL Response Actions
- Improved ability to detect minor leakage
 - Established more restrictive limits on primary to secondary leakage
 - Enhanced radiation monitors on secondary system
 - Upgraded vibration monitoring instrumentation
 - Sensors located above and below the tubesheet
 - Adjacent to top of tube bundle
- Leading the Way in Electricity
- 48


Conclusions

- SCE has performed a thorough investigation and determined the causes of the Tube-to-Tube Wear
- Corrective actions to prevent loss of integrity in Unit 2 Steam Generator tubes have been implemented
- Corrective actions are conservative with considerable safety margin
- SCE has met the requirements of the Confirmatory Action Letter
- SCE has taken a deliberate, conservative approach to restart of Unit 2 to assure public health and safety

Southern California Edison Commitment

We operate San Onofre Nuclear Generating Station (SONGS) safely and reliably to the highest standards to protect the health and safety of the public and our employees

We will not restart either Unit 2 or Unit 3 until we and the NRC are satisfied it is safe to do




All materials are available on

www.SONGSCommunity.com

Follow us on Twitter on @SCE_SONGS

SONGS EXCELLENCE 2012



**Public Meeting with the
Nuclear Regulatory Commission
Unit 2 Confirmatory Action Letter**

November 30, 2012

Leading the Way in Electricity

SONGS EXCELLENCE 2012


Southern California Edison Commitment

We operate San Onofre Nuclear Generating Station (SONGS) safely and reliably to the highest standards to protect the health and safety of the public and our employees

We will not restart either Unit 2 or Unit 3 until we and the NRC are satisfied it is safe to do

Leading the Way in Electricity

SONGS EXCELLENCE 2012



There is no timeline on safety

Leading the Way in Electricity

SONGS EXCELLENCE 2012

History of Replacement Steam Generators

- Replacement Steam Generators (RSGs) awarded to Mitsubishi Heavy Industries (MHI) in September 2004
 - Unit 2 RSGs installed in Fall 2009
 - Unit 3 RSGs installed in Fall 2010
- Replacement performed in accordance with NRC requirements
- Two license amendments were submitted and approved

Leading the Way in Electricity

SONGS EXCELLENCE 2012

Unit 3 Tube Leak and Tube-to-Tube Wear

- Steam Generator tube leakage occurred on Jan. 31, 2012
- Leakage was small and managed by plant operators using established plant operating procedures
- Approximately 11 months of full power operation following installation of Replacement Steam Generators
- Inspections found unexpected Tube-to-Tube Wear

Leading the Way in Electricity

SONGS EXCELLENCE 2012

Conservative Approach

- SCE recognized significance of Unit 3 condition
- SCE recognized susceptibility of Unit 2
- SCE engaged the best world-wide expertise and took a deliberate, thorough approach to the investigation
- SCE delayed restart of Unit 2 as a prudent, conservative action to ensure public health and safety
- SCE has ensured significant safety margin exists prior to restart of Unit 2

Leading the Way in Electricity

NRC Opening Remarks

Ryan Lantz
Branch Chief
SONGS Project Branch
Region IV

7

SONGS Technical Presentation

Thomas Palmisano
Vice President of Engineering,
Projects and Site Support, SONGS, SCE


8

NRC Remarks

Art Howell
Deputy Regional Administrator
Region IV


9

Region IV SONGS Organization



10

HQ SONGS Organization




11

Path Forward – Key NRC Activities

Ryan Lantz
Branch Chief
SONGS Project Branch
Region IV

12

Path Forward – Key NRC Activities



11

15 Minute Break

14

Questions and Answers

15

Contacting the NRC

- Report an Emergency
 - > (301) 816-5100 (24/7 NRC Headquarters' Operation Center)
(call collect)
- Report a Safety Concern:
 - > (800) 695-7403 (Toll-free Safety Hotline)
 - > Allegation@nrc.gov
- General Information or Questions
 - > www.nrc.gov
- Victor Dricks, Public Affairs Officer, RIV
 - > 817-200-1128
 - > Victor.Dricks@nrc.gov

16