

Hunt

**CONTRACTOR'S SUBMITTAL TRANSMITTAL**  
LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

FROM CONTRACTOR HARRY DEPPER  
HARRY DEPPER & ASSOCIATES, INC.  
TO HARRY DEPPER & ASSOCIATES, INC.

CONTRACT NO 1644 TRANSMITTAL NO 90 DATE 9-15-85  
PROJECT TITLE AND LOCATION  
WOLFEVILLE WATER TREATMENT PLANT  
400, W. BRUNNEN, NORTH CAROLINA

**CONTRACTOR USE ONLY**

**REVIEWER USE ONLY**

\*List only one specification division per form.

\*\*ACTION CODES

List only one of the following categories on each transmittal form, and indicate which is being submitted

A-Approved  
D-Disapproved  
AN-Approved as noted  
RA-Receipt acknowledged  
C-Comments  
R-Resubmit

- Contractor Approved
- OICC Approval
- Deviation/Substitution For OICC Approval

| ITEM NO  | PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. * | ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number) | NO. COPIES | ACTION CODES ** | REVIEWER'S INITIALS CODE AND DATE |
|----------|---|---|------------|-----------------|-----------------------------------|
|          | <u>16402</u>                                      | <u>TRANSFORMERS, SUBSTITUTIONS &amp; SWITCHGEAR, LINEATOR</u>                   |            |                 |                                   |
| <u>1</u> | <u>2.6.2</u>                                      | <u>Manufacturer's Data and Shop Drawings on Transformer</u>                     | <u>4</u>   | <u>R</u>        | <u>RDM 9/6/85</u>                 |
| <u>2</u> | <u>1.3.2</u>                                      | <u>Spare Parts Data</u>   | <u>4</u>   | <u>R</u>        | <u>RDM 9/6/85</u>                 |
|          |   |   |            |                 |                                   |
|          |   |   |            |                 |                                   |
|          |   |   |            |                 |                                   |

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC CONTRACTOR REPRESENTATIVE (Signature) [Signature]

DATE RECEIVED BY REVIEWER 12 September 85 FROM (Reviewer) Lantdiv TO Distribution

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS  
1. Transformer data insufficient for review  
2. No spare parts review data received.  
3. Motor control center drawings received w/ this submittal all returned w/ no action. Submit w/ proper transmittal & complete data on components

COPIES TO: ROICC (2) LANTDIV (1) A-E (1) DATE 12 Sept 85 SIGNATURE Maylene Kawalski

20 SEP 1985 12 58



