

6287
NREAD
FEB 13 1987

Division of Environmental Management
North Carolina Department of Natural
Resources and Community Development
7225 Wrightsville Avenue
Wilmington, North Carolina 28403

Dear Sir:

This letter is to report a 22 January 1987 bypass in the Hagnot Point Wastewater Treatment System, Marine Corps Base, Camp Lejeune, North Carolina. Telephonic notification was made to your office on 23 January 1987. Approximately 2,000 gallons of wastewater overflowed into an unnamed creek just south of the Highway 24 bridge over Northeast Creek. The main feeder running from the Sidway Park Housing area to the lift station at Wallace Creek, runs across the unnamed creek with manholes on either bank. When the line became clogged, and the flow increased due to heavy rains, the wastewater overflowed at the manholes and ran into the creek. The area was treated with 100 pounds of HTH and the line was cleared. Fecal coliform samples were taken on 23 January 1987 upstream and downstream of the bypass, the counts were 240/100 ml upstream and 260/100 ml downstream.

If additional information is desired, please contact Ms. Elizabeth A. Betz, Supervisory Chemist at (919) 451-5977.

Sincerely,

J. I. NGOTEN
Director, Natural Resources Division
~~Assistant Chief of Staff, Facilities~~
by direction of the Commanding General

Copy to:
NAVFACEBUCON

Blind copy to:
DIR, PRU, NAVHOSP
BMO
ECNL, NREAD (2)

Writer/Typist Betz / Trinidad
Date Typed 13 Feb 87
Word Processor Number 6287

FEB 19 1991

RECEIVED

Write to: Jack C. Johnson
Box # 12
Word Processor Rental - 1234