




# A UTILITY STUDY FOR COURTHOUSE BAY AREA MARINE CORPS BASE

CAMP LEJEUNE, NORTH CAROLINA A-E CONTRACT NO. N 62470-78-C-3675





JANUARY 31, 1979



A

1

1

#### A UTILITY STUDY

### FOR


#### THE COURTHOUSE BAY AREA

Marine Corps Base Camp Lejeune, North Carolina

Prepared by: J. E. Sirrine Company Greenville, South Carolina 5 February 1979

A-E Contract No. N62470-78-C-3675

Sirrine Job No. A-1086



Þ

#### FOREWORD:

The contents of this study are based on the scope forwarded to Sirrine by LANTDIV letter 09A21E:MLB, dated 17 July 1978, and that later determined at a meeting held at LANTDIV on 2 August 1978, covered by J. E. Sirrine's history of the meeting dated 24 August 1978. In addition to this scope, a total of 32 man days was spent in the Courthouse Bay Area gathering information necessary to establish existing conditions. A survey crew was also in the area for approximately four days establishing elevations, inverts, line lengths, etc., necessary for the accuracy of the study.

The study determines and evaluates the existing conditions at Courthouse Bay and the AMTRAC Area and makes recommendations for upgrading and increasing capacities of the following systems:


1. Water and Sanitary Sewer Distribution and Collector System

- 2. Water Treatment Plant
- 3. Wastewater Treatment Plant
- 4. Steam Generation and Distribution System

The study includes all projects scheduled for construction prior to FY-86. The exception to this would be the Mini Gym which has not been programmed, but the spare capacity of the steam generation plant is considered to be adequate to serve the addition of this building. According to the information given Sirrine by Mr. Al Auston and/or Mr. Bill Barnes, Base Facilities and Planning the projects scheduled through fiscal year 1986 include:

1. Bachelor Enlisted Quarters Project P-613; FY-80

1



- Mini Gym, to include basketball, handball, sauna, and showers.
   Size will be from 4000 to 6000 sq. ft. Unprogrammed and no information is available for this study.
- 4. Location Exchange, 7200 sq. ft.; FY-79.


þ

ł

- 5. Fresh waterline to AMTRAC Area; FY-79.
- 6. Oil collection project at AMTRAC Area; FY-80.

Note: It is recommended by this Study, Section 100, page 13, that a leak survey be performed on the existing water distribution system before proceeding with the other recommendations in the Study.

-000-



A UTILITY STUDY

A

?

1

1

1

I

1


J. E. SIRRINE COMPANY

# FOR

# THE COURTHOUSE BAY AREA

# INDEX

SECTION NO.	UTILITY
100	Water and Sanitary Sewer Distribution and Collector System
200	Water Treatment Plant
300	Wastewater Treatment Plant
400	Steam Generation and Distribution System
500	Cost Estimate



4

1


Î

-

# -<u>SECTION 100</u>-WATER AND SANITARY SEWER DISTRIBUTION AND COLLECTOR SYSTEM A UTILITY STUDY

FOR

THE COURTHOUSE BAY AREA




J. E. SIRR	NE CO	MPANY
------------	-------	-------

Δ

# TABLE OF CONTENTS

		Page
Ι.	COURTHOUSE BAY SANITARY SEWER COLLECTOR SYSTEM - DESCRIPTION OF EXISTING SYSTEM	1
	A. General .	1
	B. Method of Making Flow Test	2
	C. Field Measurements	2
	D. Peak Discharge	2
	E. Design Parameter	2
	F. Infiltration Rate	3
	G. Sanitary Sewer Collector System	3
	H. Lift Station	5
II.	RECOMMENDATIONS FOR SANITARY SEWER COLLECTOR SYSTEM	6
	A. General	6
	B. Sanitary Sewer Collector System	7
	C. Lift Station	8
III.	COURTHOUSE BAY WATER DISTRIBUTION SYSTEM - DESCRIPTION OF EXISTING SYSTEM	9
10. 11. 11.	A. General	9
	B. Water Demand	10
	C. Wells	11
	D. Fire Protection	11
IV.	RECOMMENDATIONS FOR WATER DISTRIBUTION SYSTEM	12
:	A. Water Demand	12
	B. Wells	13
	C. Fire Protection	14



-

#### I. COURTHOUSE BAY SANITARY SEWER COLLECTOR SYSTEM -DESCRIPTION OF EXISTING SYSTEM

#### A. General

During the period of field measurement and site investigation, the Courthouse Bay and Amtrac Area was not operating at maximum capacity. There were two companies of Amtrac troops off on maneuvers (approximately 450 people) and only 400 of the 654 assigned engineering students on base. Information from the using agencies indicates that the present authorized capacity of the area is as follows:

#### 1. Present:


(a)	Two existing engineering students barracks (BB-250 and BB-255)	= `	654
(b)	Four existing substandard barracks (BB-11, 12, 13, and 14)	=	664
(c)	Bachelor Officers Quarters (BB-45)	=	30
(d)	Married Officers Housing (assuming 4 people per house) (BB-17, 18, 19, 20, 21, 22, 23, and 24)	=	32
(e)	Off base Total Daytime Capacity	=	825 2,025

When the B.E.Q. Project P-613 is completed, which is the only housing facility projected for the future, the authorized capacity of the area will be as follows:

#### 2. Fiscal Year 1986:

Two existing engineering students barracks	=	654
Three new barracks (P-613)	=	882
Bachelor Officers Quarters	=	30
) Married Officers Housing		32
Off base Total Daytime Capacity	=	<u>607</u> 2,025
	Married Officers Housing Off base	Three new barracks (P-613) = Bachelor Officers Quarters = Married Officers Housing = Off base =

The Courthouse Bay and Amtrac Area is adjacent to New River. The flood elevation of New River is ten feet above mean sea level. The site is basically flat and composed of sandy soil. The ground water table generally stabilizes at three to six feet below existing grade (information taken from soil report by Soil Systems, Inc. dated August 8, 1978, see Appendix I).



#### I. DESCRIPTION OF EXISTING SYSTEM - (Continued)

The untreated raw sewage in the Amtrac Area is pumped to Courthouse Bay. The sewage in Courthouse Bay Area is then pumped to the wastewater treatment plant.

#### B. Method of Making Flow Test

Manning Recorders were used for making flow test. This type recorder was best suited to get the type of information needed for this study. The Manning Recorder is designed to record on a graph the depth of flow through a manhole plus the time of day that it occurs. By knowing the depth and the time it occurs, the peak discharge time for that day can be determined. The recorders were installed in Manholes No. 422, No. 413, and No. 1000. They were left in the manholes for approximately one week to obtain some consistency in the peak discharge time. The recorder from Manholes No. 422 and No. 413 clearly indicated that the maximum discharge time occurs from 5:30 a.m. to 7 a.m.; during this time troops were getting dressed, showering, and eating. The recorders showed the next highest discharge time occurring from 6 p.m. to 7 p.m. This discharge was not as large as the one in the morning. The recorder in Manhole No. 1000 did not clearly indicate a maximum discharge time except for one particular day, from 4 p.m. to 4:30 p.m.; during this time span, the Amtrac Troops were washing up and getting ready to go back to the barracks.

#### C. Field Measurements


The existing maximum peak discharge for each line was obtained by field measuring each manhole with a yardstick during peak times and calculating the discharge rate from the depth of flow measured. The results of these measurements can be seen in Appendix I. These measurements cannot be used as existing peak discharges since the manpower at Courthouse Bay was not at its capacity as stated hereinbefore. The results were used to give an idea of sediment in the inlet and outlet pipes of the manhole and as a guide for the maximum existing peak discharge calculations.

#### D. Peak Discharge

Since the existing maximum peak discharges could not be determined by field measuring, they had to be calculated. The procedure used for calculating this flow was fixture units.

#### E. Design Parameter

The sanitary sewer design for sizing sewer pipes was based on Manning Formula of n = 0.013.



DESCRIPTION OF EXISTING SYSTEM - (Continued)

Manning Formula

$$Q = \frac{1.486}{n} R^{2/3} S^{1/2} A$$

Q = Flow through pipe in cubic feet per second (c.f.s)

n = Coefficient of roughness of pipe

- R = Hydraulic radius; the cross-sectional area of waterway divided by the wetted perimeter
- S = Slope of hydraulic gradient
- A = Cross-sectional area of pipe

The coefficient of roughness from the sewer will be 0.013 per NAVFAC DM-5 Manual.

The new pipes were designed to insure a velocity of at least 2.5 feet per second when pipe is flowing full, per NAVFAC DM-5 Manual.

#### F. Infiltration Rate

The rate of infiltration of water into the sanitary sewer collector lines was found to be very high. There are several possible reasons for the high rate of infiltration, but the major reason could be as follows:


Infiltration could be due to the high ground water table on this site (three to six feet below existing grade). The average depth of the sanitary sewer lines is approximately ten feet. This would indicate that the sanitary sewer lines are installed below the water table for most of the site and ground water is seeping in through joints or broken pipe.

The infiltration rate used in this study was not assumed. The rate was obtained by field measuring the flow through certain sanitary sewer manholes during hours of nonactivity in the area. Once the depth of flow was known, slope of pipe, total length of pipe to point of measurement and pipe size, the rate of infiltration can be calculated using Manning Formula.

#### G. Sanitary Sewer Collector System

#### 1. Amtrac Area:

The Amtrac collection lines consist of approximately 976 feet of vitrified clay pipe and approximately 264 feet of cast iron pipe. The manholes on this system consist of precast



#### I. DESCRIPTION OF EXISTING SYSTEM - (Continued)

concrete and brick masonry. The precast manholes are in very good condition, but the brick manholes are only in fair condition.

The infiltration rate was obtained by field measuring the manholes during hours of nonactivity. The rate of infiltration was arrived from data taken from Manhole No. 1009. This rate was found to be 0.0224 gpm/linear foot of pipe. See Appendix I.


The existing flow through the collection system was obtained by using fixture units from each building and converting them into gallons per minute. The maximum existing flow is equal to the existing flow plus the infiltration rate at any length throughout the system. Appendix I indicates the system to be adequate.

#### 2. Courthouse Bay:

The collection lines consist of approximately 6,840 linear feet of vitrified clay pipe and approximately 1,050 linear feet of cast iron pipe. The majority of manholes are brick masonry. The bottoms in several of the manholes are in very bad condition, due to settlement of the manholes and scouring from pipes that have been tied into the manhole without using an outside drop. The collection system is approximately 35 years old. Sediment of sand and waste was very evident in several manholes. The sand is probably due to new construction tying onto the system, while the waste is contributed to low velocity in the lines. The collection lines are constructed on a very flat slope (0.003 ft/ft approximate average). Appendix I gives a detailed picture of the characteristics of the collection system.

Courthouse Bay has basically two collection line systems that terminate at Manhole No. 412. The first system consists of Manhole Nos. 425 through 413. The eixsting flow through this system was arrived at by adding the fixture units per building at the manhole under consideration. Then the fixture units were converted into gpm. Most of the buildings connected to this collection system were considered contributing to the existing flow during peak discharge. It should be noted that the total existing flow through the system does not exceed the maximum design flow of the pipe.

The other collection system consists of Manhole No. 666 to Manhole No. 412. The existing flow through this system from Manhole No. 666 to Manhole No. 431-A was arrived at by adding the fixture units per building at the manhole under consideration. Then the fixture units were converted into gpm and added to the 275 gpm pumped by the sanitary sewer lift station



-

#### I. DESCRIPTION OF EXISTING SYSTEM - (Continued)

in the Amtrac Area. The existing flow from Manhole No. 431-A to Manhole No. 412 was arrived at by using the fixture units from Buildings Nos. 250 and 255. Since the peak discharge flow occurs from 5:30 a.m. to 7 a.m., the other buildings connecting to this system will not be considered contributing to the flow during peak discharge. Exhibit "A" describes the existing sanitary sewer layout system. The characteristics of this system are shown in Appendix I. Appendix I shows that the maximum existing flow during peak discharge only exceeds the maximum design flow of the system between Manholes No. 438 to No. 431-A and Manholes No. 429 to No. 428.

Due to peak discharge time of day, the Amtrac lift station should not be running, but since the effected storage capacity of the lift station is only 188 gallons and the rate of infiltration in the Amtrac Area is 27.8 gpm, it will take the station approximately 7 minutes to start up. Therefore, the lift station would come on several times during peak discharge time. Considering the flow from the lift station contributing to the peak discharge rate, it is evident that lines from Manholes Nos. 438 to 412 are undersized. Since the discharge from the lift station will last approximately one minute, it is our opinion that this flow will not be the deciding factor in peak discharge. What the system is experiencing during this flow is some back up of the system for a short period of time.


#### H. Lift Station

#### 1. Amtrac Area:

The Amtrac Area has no facilities to treat the raw sewage; therefore, the sewage is pumped through a 6-inch cast iron pipe to Manhole No. 666 at Courthouse Bay.

The lift station is a one-story concrete building with a fourfoot diameter concrete manhole as a wet well. The station is approximately one year old. The contents of the building consist of two 275 gpm pumps with 15 horsepower electrical motors.

The station has one diesel engine, used as a standby power supply. The pumps are designed to alternate during run time. The effective storage capacity of wet well consists of 188 gallons, which will produce a run time of less than one minute per pump. The infiltration rate coming into the lift station is 27.8 gpm. At this rate, it will take the wet well approximately 7 minutes to fill up. This means that every 7 minutes the pumps will come on during nonactive hours. See Appendix I. During active hours, the pumps will come on more frequently.



#### DESCRIPTION OF EXISTING SYSTEM - (Continued)

#### 2. Courthouse Bay:

The existing sanitary sewer lift station at Courthouse Bay pumps the untreated sewage to the wastewater treatment plant. The station building consists of two floors. The main floor is the operating floor and the lower floor consists of valves, pumps, and discharge piping. The concrete building is approximately 35 years old. At present, the station has one 500 gpm pump with a 7-1/2 horsepower motor and one 300 gpm pump with a 5 horsepower motor. A gasoline engine in the station is used for auxiliary power to run the pump.

The Courthouse Bay waste flows by gravity to Manhole No. 412; while the Amtrac Area is pumped to Manhole No. 666 and then flows by gravity to Manhole No. 412. There is a 12-inch cast iron pipe leading from Manhole No. 412 to the wet well of the lift station. The capacity of the wet well up to the invert of the 12-inch cast iron pipe is 6,600 gallons. The waste is then pumped out of the wet well by vertical, dry pit, nonclog, centrifugal sewage pumps through approximately 1,000 feet of 8-inch cast iron pipe to the wastewater treatment plant.


The calculated maximum existing flow that the wet well is receiving is 776 gpm. Taking into consideration the storage capacity of the wet well and assuming the maximum pumping capacity with both pumps running is around 600 gpm; this would leave a difference of 176 gpm or 38 minutes before the wet well would back the flow up in Manhole No. 412. See Appendix I.

#### II. RECOMMENDATIONS FOR SANITARY SEWER COLLECTOR SYSTEM

#### A. General

The schedule of projects to be constructed during the next eight years consist of the following:

- P-613, B.E.Q. Project. This project consists of constructing three new barracks. The three barracks will be located west of the existing engineering barracks and south of Grace Lane. The existing barracks (BB-11, 12, 13, and 14) will be demolished.
- 2. A 7,200 square foot Exchange Building will be located just north of Clinton Street and east of Marines Road.
- 3. An oil spill prevention plan is proposed for the Amtrac vehicles in the Amtrac Area. This plan will consist of concrete aprons and drainage system around Building A-3 to collect the oil spills. A 150,000 gallon storage tank and



A

#### II. RECOMMENDATIONS FOR SANITARY SEWER COLLECTOR SYSTEM - (Continued)

oil separator are also included.

4. Under P-996, Industrial Waste Collection and Treatment Facilities, the filter backwash from the water treatment plant may be pumped into sanitary sewer Manhole No. 428 at 50 gpm from a holding tank.

#### B. Sanitary Sewer Collector System

#### 1. Amtrac Area:


This system is capable of handling the additions in this area. Due to the high rate of infiltration in this system, we recommend a video test to determine where the cracks are in the lines and grouting the cracks. This recommendation has been included in our cost estimate.

#### 2. Courthouse Bay:

The three new barracks are to be located west of the existing engineering barracks and south of Grace Lane. The new sanitary sewer collector line servicing these barracks will tie into existing Manhole No. 428. This collector line will consist of 8-inch and 10-inch Polyvinyl Chloride Pipe (PVC) per LANTDIV recommendations. Due to the terrain, the new collector line will have to be laid on a very flat slope, which contributes to the size of the pipes. The minimum required 2.5 feet per second velocity (NAVFAC DM-5) also contributes to the pipe size.

The infiltration rate was assumed to be 30,000 gpd/mile of sewer pipe. This rate is for average conditions where a portion of the length of the sewers is above the ground water table and a portion below. This rate is also based on the anticipated condition of the sewer when it is nearing the end of its useful life. This information was taken from the ASCE Manuals and Reports on Engineering Practice - No. 37 (WPCF Manual of Practice No. 9) entitled "Design and Construction of Sanitary and Storm Sewers." The flow characteristics of this system are shown in Appendix I. The alignment of this system is shown in Exhibit "B".

The proposed collector line will cross over a wet weather draw, which will require piers to support the sewer line. The material used for sewer line pipes where crossing on piers will be cast iron. The new collector line will consist of approximately 3,490 linear feet of Polyvinyl Chloride pipe and approximately 80 feet of cast iron pipe. Project No. P-613 will cover the cost of the new sanitary sewer collector line down to Manhole No. 428. This study will only address itself to the additional cost of collector lines beyond the P-613 Project. The study reveals only an addition of 1,355 feet of sanitary sewer collector lines will be needed.



#### II. RECOMMENDATIONS FOR SANITARY SEWER COLLECTOR SYSTEM - (Continued)

A new sanitary sewer collector line will be constructed out of existing Manhold No. 428, per LANTDIV recommendation, see Exhibit "B". This line will help relieve the existing line during surcharge.

Under P-996, Industrial Waste Collection and Treatment Facilities, the filter backwash from the water treatment plant will gravity drain into a surge storage tank and then pumped into sanitary sewer Manhole No. 428 at a rate of 50 gpm. Our recommendations are to pump the backwash from the holding tank during nonpeak discharge times.

The sanitary sewer lines between Manholes Nos. 438 to 431-A and 429 to 428 are experiencing surcharge. LANTDIV concurs with this conclusion. LANTDIV decided that the amount and frequency of surcharge between these manholes do not warrant replacing these lines at this time.

Our recommendation is to clean out all of the sanitary sewer lines and run a video test to determine where the cracks are in the lines and grout them.

#### C. Lift Station

b


J. E. SIRRINE COMPANY

#### 1. Amtrac Area:

The only addition affecting the lift station is the proposed oil spill prevention plan for the Amtrac vehicles. This plan will consist of concrete pavement and drainage system around Building A-3, to collect the oil spills. The spills will then drain into a drainage system, which drains into a 150,000 gallon holding tank. The tank will have two 50 gpm pumps to pump the oil and water to a dual coalescing parallel plate separator. The water will then drain into the lift station.

Since the holding tank pumps can be turned on at any time to drain the tank, our recommendation is to run the pumps during nonpeak days for the wastewater treatment plant. Neither sanitary sewer collector system nor the wastewater treatment plant will be designed to handle this additional flow during peak hours or maximum days.

-8-



#### II. RECOMMENDATIONS FOR SANITARY SEWER COLLECTOR SYSTEM - (Continued)

Since the storage capacity of the lift station is only 188 gallons, it will only take approximately 3.5 minutes to fill the storage with one of the 50 gpm pumps running. It should take approximately two minutes for the 275 gpm lift station pump to pump the storage out and turn off while the 50 gpm pump is still on. This cycle will repeat itself until the 150,000 gallon holding tank is empty or the 50 gpm pumps are turned off. This kind of cycle time is not desirable from our view.

Our recommendation is to adjust the level indicator float switches to obtain more storage capacity in the wet well and install a 8' x 10' x 4' concrete wet well adjacent to the existing wet well and connect them with a 12" diameter concrete pipe. See Appendix I. This will increase the storage capacity from 188 gallons to approximately 2,000 gallons. This will also increase the run time of the pumps from one minute to seven minutes. During nonactive hours when the lift station will only see infiltration at a rate of 27.8 gpm, it will take the station approximately 72 minutes to start up.


#### 2. Courthouse Bay:

The addition of the new Amtrac Troop Barracks will bring the maximum flow to the lift station up to 885.2 gpm and 1160.2 gpm if the lift station in the Amtrac Area is pumping. Since the combined pumping flow of the existing pumps is approximately 600 gpm, this would mean that the wet well will start backing up the flow into Manhole No. 412 in 23 minutes. See Appendix I. Since peak discharge time lasts over one hour and the maximum head that the existing pumps can pump against is 40 feet, it is our recommendation to replace both pumps and motors with two 700 gpm pumps at a pumping head of 50 ft. The same pumps must also be able to pump 625 gpm at a pumping head of 90 ft., when both are pumping. This recommendation would mean that the total combined pumping flow will be around 1250 gpm. The proposed expansion of the wastewater treatment plant is hydraulically designed to handle around 1250 gpm. The increase in flow should have very little effect on the existing 8-inch cast iron pipe force main to the treatment plant. The pipe should be able to handle the increase flow with a velocity of eight feet per second and a friction loss of 4.5 feet per one hundred feet of pipe.

#### III. <u>COURTHOUSE BAY WATER DISTRIBUTION SYSTEM - DESCRIPTION OF EXISTING</u> <u>SYSTEM</u>

#### A. General

The water treatment plant at Courthouse Bay obtains its raw water



#### III. <u>COURTHOUSE BAY WATER DISTRIBUTION SYSTEM - DESCRIPTION OF EXISTING</u> <u>SYSTEM - (Continued)</u>

from four wells. After the water is treated, it is then pumped to a 350,000 gallon underground storage tank and a 100,000 gallon elevated tank. The elevated tank is used to provide a maximum pressure of 52 psi and a minimum of 42 psi on the distribution system.

The water treatment plant has two 500 gpm pumps and one 750 gpm pump with the capability of pumping 1250 gpm of potable water into the distribution system. At present, only one of the two 500 gpm pumps can operate while the 750 gpm pump is running.

At present, the Courthouse Bay water treatment plant does not furnish potable water to the AMTRAC AREA. There is a well in the Amtrac Area that provides water for this area. There is an 8-inch treated water line being installed now under Construction Contract No. N62470-78-B-3001 to serve the Amtrac Area with potable water. See Exhibit "D". It is our understanding that the existing well in this area will be used as a standby only. It is also our understanding that the 8-inch treated water line will serve only what the existing well is now serving.


#### B. Water Demand

The existing water demand was arrived by using per capita figures from the "Naval Facilities Design Manual" DM-5 and some assumptions. The following assumptions were made: number of motor vehicles being washed, amount of lawn sprinkling, number of meals, and average number of engineering students in barracks.

The average daily demand of potable water before the engineering barracks BB-250 and BB-255 were added was calculated to be 224,450 gallons per day (gpd). The maximum 24-hour demand was calculated to be 445,515 gpd. The average of the calculated maximum 24-hour demand and the average calculated daily demand will be 334,980 gpd. Comparing this figure with the actual average daily demand of 318,900 gpd, it can be assumed that factors used and assumptions made are realistic. See Appendix I for calculation data.

After the construction of the two new engineering barracks, the average calculated flow became 324,000 gpd. Compared with 385,000 gpd as the actual average daily flow, the maximum 24-hour demand was calculated to be 656,400 gpd. This figure is very realistic, since the plant has exceeded 600,000 gpd. See Appendix I for calculations.

It is very important to note that a per capita figure of 225 gpd was used for the new engineering barracks. This figure was obtained by taking the maximum difference between what the sanitary sewage treatment plant was recording before the new engineering barracks



## III. <u>COURTHOUSE BAY WATER DISTRIBUTION SYSTEM - DESCRIPTION OF EXISTING</u> <u>SYSTEM - (Continued)</u>

were constructed and the recording after construction. The difference was divided by the average days per month, which would give a figure in gallons per day. The assumption was made that the barracks averaged 500 students per day. Dividing the gallons per day by the number of students, one can obtain a figure of 212.88 gpd/person. Therefore, 225 gpd/person will be a good figure to use for the Engineering Barracks and the B.E.Q. P-613 since they will be similar to the Engineering Barracks. This figure does not include infiltration rate, since the Engineering Barracks tiein line is very short. See Appendix I for calculations.

#### C. Wells

The Courthouse Bay Area has four wells supplying raw water to the water treatment plant. The location of these wells can be seen on Exhibit "D". Well data is listed as follows:

Well Numbers	BB-221	BB-220	BB-44	<u>BB-43</u>
Motor Horsepower	10.0	7.5	5.0	5.0
Rated Gallon Per Minute	300	150	190	175
Designed Head (Ft.)	82	78	60	63
Age of Well (Approx. Years)	3	3	35	35
Depth of Well (Approx. Feet)	200	200	62	60
Type of Building	Prefab	Prefab	Masonry	Masonry

Johnston vertical turbine pumps are used for Wells Nos. BB-43 and BB-44. Layne and Bowler pumps are used for Wells Nos. BB-220 and BB-221.


It is our understanding that most of the raw water supplied to the treatment plant is obtained from Wells Nos. 220 and 221. Well No. 44 is used occasionally, and Well No. 43 is not used at all.

## D. Fire Protection

#### 1. Water Demand for Unsprinklered Facilities:

The classification of occupancies rating for building and the water demand required for each classification was taken from the Naval Facilities Design Manual DM-8 "Fire Protection". Courthouse Bay consists of four types of occupancies. The four types of rating are listed below:

-11-



## III. COURTHOUSE BAY WATER DISTRIBUTION SYSTEM - DESCRIPTION OF EXISTING SYSTEM - (Continued)

OCCUPANCY	HOSE STREAM	DURATION
Light Hazard Occupancies	750 gpm	60 minutes
Ordinary Hazard Group 1 Occupancies	1000 gpm	75 minutes
Ordinary Hazard Group 2 Occupancies	1250 gpm	90 minutes
Ordinary Hazard Group 3 Occupancies	1750 gpm	120 minutes

The above hose stream gpm and duration minutes were taken from NAVFAC DM-8 Table 7-2 under Favorable Conditions. The Favorable Condition column can be used since there is a well-trained fire department. See Appendix I for list of individual dwelling rating.

It should be noted that the above water demand for the fire rating must be accomplished with a pressure of not less than 20 pounds per square inch.

The existing pressure and flow rating was obtained by field testing of fire hydrants. The hydrants were tested with a pitot tube and pressure gages. See Appendix I for results.


#### 2. Storage Requirements:

According to NAVFAC DM-8, the requirements for fire protection water storage are based on the assumption that there will be only one fire at a time. The total storage capacity required is equal to the peak fire flow demand plus 50 percent of the peak daily consumption. Therefore, a storage of 538,195 gallons is required. See Appendix I. The existing system only has 450,000 gallons of storage available, leaving the system short by 88,195 gallons. The 525,000 gpd capacity water treatment plant will only be able to supply approximately 44,000 gallons during the two-hour fire fighting period. This will leave the present storage system short by some 44,200 gallons according to NAVFAC DM-8. NAVFAC DM-8 requires that the storage replenishment shall reach required volume during normal consumption within 48 hours and within 24 hours by curtailing normal consumption. The existing system can meet these requirements. See Appendix I.

#### IV. RECOMMENDATIONS FOR WATER DISTRIBUTION SYSTEM

#### A. Water Demand

The water demand for fiscal year 1986 was arrived by using per capita figures from the "Naval Facilities Design Manual" DM-5 and



## IV. RECOMMENDATIONS FOR WATER DISTRIBUTION SYSTEM - (Continued)

the same assumptions, as were used to calculate the existing water demand.

The calculated average daily flow of potable water for fiscal year 1986 is 462,950 gallons per day. See Appendix I. The calculated maximum 24-hour demand is 960,200 gallons per day or 670 gallons per minute, compared to the existing 525,000 gallons per day or 365 gallons per minute treatment plant. See Appendix I.

Our recommendation is to have a leak survey performed on the existing water distribution system. The results of this survey should be analyzed before proceeding with the other recommendations in this study.

#### B. Wells


Our recommendation is to install a new well in the Courthouse Bay Area. The location of the well would be subject to studies to determine a source with adequate supply and good quality. For the purpose of this study, the assumption was made that the well could be located approximately 2000 feet east of existing Well BB-221 along Sneads Ferry Road. The well should be able to produce 300 gpm. See Exhibit "E".

Our recommendation for the new well is based on the following reasons:

- The maximum supply of raw water needed for fiscal year 1986 will be 670 gpm compared to the existing 365 gpm. To supply 670 gpm to the treatment plant, all four wells must be running to produce this quantity of flow, therefore, leaving the system without a standby well.
- 2. Wells No. 43 and No. 44 are used very little. The quality of water from these wells is not as good as the water obtained from Wells No. 220 and No. 221.

Due to the additional head on the existing pumps, caused by the new well, the following recommendations are also made:

- 1. Well No. 221: Add one more stage to the vertical turbine pump and replace the four existing impellers with the next largest size; also replace the existing 10 HP motor with a 15 HP motor.
- Well No. 220: Add two more stages to the vertical turbine pump and replace the existing 7-1/2 HP motor with the 10 HP motor from Well No. 221.



## IV. RECOMMENDATIONS FOR WATER DISTRIBUTION SYSTEM - (Continued)

## C. Fire Protection


The existing fire distribution system should have no trouble accommodating the new projects to be built by fiscal year 1986.

It should be noted that the existing system fire flow for Building No. 51 is marginal. LANTDIV concurs with this conclusion. No cost estimate has been prepared for upgrading this fire line. See Appendix I.

The total storage capacity required for fire protection per NAVFAC DM-8 Manual is equal to the product of the fire protection water demand and the required duration. This must be added to 50 percent of the peak daily domestic consumption. The total storage required is 690,200 gallons. See Appendix I for calculations. The existing storage available is 450,000 gallons; therefore, there is a shortage of 240,200 gallons. Our recommendation is to install a new 250,000 gallon storage tank adjacent and similar to the existing 350,000 gallon tank.

The three pumps (one 750 gpm and two 500 gpm) in the treatment plant that pump potable water into the distribution system will have the capability of all running at the same time.

The water used for fire protection in the Amtrac Area comes from the bay. The fire trucks can drop their suction hoses into the bay and pump the water from the bay to the fire.



ł

## TABLE OF CONTENTS - (Continued)

۱	1.	EXHIBITS	5				
		Exhibit	"A"	-	Existing	Sanitary Sewer System	
		Exhibit	"B"	-	Proposed	Sanitary Sewer System	
		Exhibit	"C"	-	Sanitary	Sewer System Data Charts	
		Exhibit	"D"	-	Existing	Water Distribution System	
		Exhibit	"E"	-	Proposed	Water Distribution System	
		Exhibit	"F"	-	Proposed	Water Treatment Plant Yard Piping	


VI. APPENDICES

Λ		1.2	т	
AD	pend	11X	1	

- 1. Soil Report
- Field Measurement Sketches of Existing Sanitary Sewer Manholes
- 3. Infiltration Rate Calculations
- Existing Sanitary Sewer Collector System Calculations

Page

- Proposed Sanitary Sewer Collector System Calculations
- Existing Sanitary Sewer Lift Station Calculations
- 7. Calculation for the Recommendation to the Existing Sanitary Sewer Lift Station
- 8. Existing Raw Water Supply Calculations
- 9. Proposed Raw Water Supply Calculations
- 10. Existing Water Demand Calculations
- 11. Proposed Water Demand Calculations
- 12. Fire Protection Requirement for Courthouse Bay Area
- 13. Fire Protection Requirement for Amtrac Area
- 14. Fire Protection Charts
- 15. Fire Protection Calculations




6

Ĭ

-

-<u>SECTION 200</u>-WATER TREATMENT PLANT A UTILITY STUDY FOR


THE COURTHOUSE BAY AREA



J. E. SIRRINE COMPANY -

## TABLE OF CONTENTS

		Page
Ι.	DESCRIPTION OF EXISTING FACILITIES	1
	A. General	1
	B. Treatment Equipment Description	1
	1. Decarbonation	1
	2. Pressure Filtration	2
	3. Brine Regenerated Water Softeners	2
	4. Treated Water System	3
	5. Controls	3
II.	EVALUATION OF THE EXISTING FACILITIES	4
	A. General	4
	B. Operational Evaluation	5
	C. Equipment Evaluation	7
III.	PROPOSED FACILITY EXPANSION	8
	A. General	8
	B. Design Criteria	8
	C. Equipment Additions	8
	D. Decarbonation and Lime Addition	8
	E. Pressure Filtration	9
	F. Softener System	10
	G. Controls	11
1.1	H. Building Expansion	12
	I. Water Consumption	12



A

þ


# TABLE OF CONTENTS (Contd)

IV. EXHIBITS

Exhibit G - Water Treatment Flow Diagram Exhibit H - Water Treatment Plant General Arrangement Exhibit I - Water Sample Analyses

V, APPENDICES

Appendix II - Design Calculations



-

## COURTHOUSE BAY WATER TREATMENT PLANT

## I. DESCRIPTION OF EXISTING FACILITIES

#### A. General

The existing water treatment plant at Courthouse Bay, Camp Lejeune, North Carolina was constructed in 1969. The facility had a design capacity of approximately 400 gallons per minute, with a daily production designed for 576,000 gallons per day. Raw water is supplied to the treatment plant from four wells designated by their well house numbers of BB43, BB44, BB220, and BB221. Their design pumping rates are respectively, 175 gpm, 190 gpm, 150 gpm, and 300 gpm. Normal operations have only two wells pumping at any one time supplying the treatment plant with raw water. The actual water production is considerably less than the design plant capacity of 576,000 gallons per day. Plant downtime during filter backwash and water used during the backwash cycles, and regeneration of the softeners totals approximately 50,000 gallons per day. This results in a net design production capacity of approximately 525,000 gallons per day.


The actual water production flows in the present plant show daily totals of approximately 400,000 gallons per day to a maximum of over 600,000 gallons per day. The extra flow over the design capacity was achieved through bypassing the treatment equipment, chlorinating raw well water, and pumping the raw well water into the distribution system.

#### B. Treatment Equipment Description

The treatment of the raw well water consists of the following processes in the order of treatment: decarbonation, lime addition, chlorination, pressure filtration, and brine regenerated water softening. A flow diagram is found in Exhibit G.

1. Decarbonation

The well water is pumped to the decarbonator which reduces the excess carbonate and assists in oxidizing iron. The design capacity of the decarbonator is 750 gpm. As the water enters an approximately 25,000 gallon detention tank a lime slurry is added for pH adjustment. Chlorine is added to the detention tank at this point for bacteria removal. The chlorine addition had little effect on the total iron which is primarily in the suspended form.



A

b

## I. DESCRIPTION OF EXISTING FACILITIES


## B. Treatment Equipment Description - Contd

2. Pressure Filtration

The water is piped to the pump suction of the two filter pumps. Each pump has 400 gpm capacity; however, only one pump will operate with the other pump as an online standby. A bypass line connects the service water suction line and the filter feed pump suction piping. This permits bypassing the filters and softeners in the plant. The filter feed pump supplies the chlorinated water to the three sand and gravel filters which removes suspended solids and turbidity from the raw water. The filters are 7'-6" diameter with 6'-0" straight The filter media consists of 12" graded gravel and sides. 30" of graded sand. The filters operate at 400 gpm with a hydraulic loading of slightly over 3 gpm per square foot. From inlet and outlet pressure gauge readings the pressure drop is less than 4 psig. The units are backwashed once per day with treated water; each unit is backwashed individually while the other units are on a standby status. While the filters are backwashed no treated water is produced at the plant. The total backwash of the three existing filters takes 50 minutes.

## 3. Brine Regenerated Water Softening

A portion of the effluent from the filters is piped to the brine regenerated water softeners. The softeners remove calcium and magnesium ions which contribute to the hardness of the raw water. With the bicarbonate which is present in the raw water, calcium and magnesium carbonate scale could be formed in the distribution piping. The 400 gpm filter effluent flow is divided into 256 gpm for the softeners with 144 gpm bypassed to the softener effluent. This allows the treated water hardness range to be controlled to about 50 to 60 mg/l total hardness. The softeners are 5'-0" diameter with 6'-0" straight sides containing 49 cubic feet of ion exchange resin. At 256 gpm the softeners operate at a hydraulic loading of 6.5 gpm per square foot with both units on line. The units are equipped with individual brine measuring tanks with level controls controlling brine supply pumps. The brine is stored in a 46 ton salt storage and brine saturator structure. The softener backwash, regeneration, brine dilution and rinse water are supplied from the filter effluent piping. The two existing softeners undergo a total of three regeneration cycles per 24 hours during which a total of approximately 13,440 gallons of filtered water is used and discharged to drain.



A

## I. DESCRIPTION OF EXISTING FACILITIES

## B. Treatment Equipment Description - Contd


4. Treated Water System

The combination of softened and filtered water hereafter identified as treated water is piped to a 350,000 gallon ground level storage reservoir. Between the treatment plant building and the reservoir a chlorine dosing station is located, but it is not used at the present time due to operational history of the plant and operator preference. The three treated water distribution pumps take suction from the reservoir with the treated water pumped to a 100,000 gallon elevated storage tank for distribution. The three distribution pumps are 500, 500, and 750 gpm in capacity. The 750 gpm pump is also equipped with a water cooled gasoline engine for standby power as well as an electric motor. The two 500 gpm pumps are supplied only with electric motors.

#### 5. Controls

The control systems for the operation of the water treatment plant are of the pushbutton fully automatic/manual type. The control of the well pumps, after manual selection, are governed by the level of the detention tank. The decarbonator air blower, lime slurry pump, and the filter feed pump are controlled by the level controls in the detention tank. The filter feed pumps are also controlled by the filter backwash controls and the level controls in the ground level storage reservoir. The service pumps are controlled by the level instrumentation in the elevated storage tank and the level of the ground level storage reservoir. The filters are backwashed automatically from a timer control. The softeners are also regenerated on the basis of a timer. The softeners and filters can be backwashed and regenerated by manual initiation of the cycles. The brine pumps are controlled by level controls in the brine measuring tanks.

The raw water and treated water flows and quantities are indicated, totalized and recorded. The levels of the detention tank, ground level reservoir, and the elevated tower are indicated and recorded on the control panel.



4

## II. EVALUATION OF THE EXISTING FACILITIES

#### A. General

The present water treatment plant at Courthouse Bay is operating at a maximum capacity of 400 gpm with the present equipment. With all units on line the filters operate at a flow loading of 3 gpm per square foot, and the softeners operate at a loading of 6.5 gpm per square foot. The flow rate cannot be increased without a decrease in quality or operational problems such as: excessive pressure drop, short service runs, and a corresponding increase in chemical regenerant usages. The present overall quality of water produced in the plant is at design quality. Any raw water bypassing of the plant with only chlorine addition to increase water production is not recommended. The corresponding increase in total hardness, turbidity, iron, dissolved solids, and color would contribute to a worsening quality for the potable water supply.

Water samples were collected on September 20, and 21, 1978 from the following sources:


- 1. Raw well water Well BB43
- 2. Raw well water Well BB44
- 3. Raw well water Well BB220
- 4. Raw well water Well BB221
- 5. Plant raw water Wells BB43 and BB220 combined
- 6. Detention tank surface water after lime addition and chlorination
- 7. Filter influent
- 8. Combined filter effluent after backwash

9. Softener effluents

10. Combined plant effluent

Copies of the analyses are enclosed, see Exhibit I. The analyses of the four well water sources show considerable calcium hardness, bicarbonate alkalinity, high dissolved solids, iron, turbidity, and color. The sample taken from Well No. BB43 shows significant differences from the other three wells; the following parameters are higher for Well No. BB43: calcium, bicarbonate, total hardness, solids, iron, turbidity, and color.

After decarbonation, lime addition and chlorination the following changes are noted: the pH was raised from 7.2 to 7.8; the free



## II. EVALUATION OF THE EXISTING FACILITIES

## A. General - Contd

carbon dioxide was decreased from 29 ppm to 7.2; some decrease in turbidity was noted but not a significant amount; before decarbonation the turbidity was 9.0 and after decarbonation it was 8.2. The total iron increased from 1.9 to 3.3 ppm. The decarbonation is effective at reducing the free carbon dioxide; however, the lime addition had only an effect on the pH but not on other parameters. The sample which was taken prior to the filter feed pumps showed little improvement in total dissolved solids and suspended iron due to the added detention tank time.


The pressure filter effluent sample was taken from the common effluent of the three filters after a backwash cycle had been completed. The total iron had decreased but total dissolved solids were not decreased. This could have occurred due to the filter beds not being compacted after the backwash cycle had been completed or an incomplete rinse cycle occurred. The reduction of the solids would improve with time after solids were trapped and the bed became more compacted.

The softener effluents were taken under two operating conditions. The effluent of No. 1 softener was taken prior to regeneration according to volume readings on the totalizing water meter. As seen in the analysis, hardness breakthrough had already occurred. The hardness was 23 mg/l as CaCO<sub>3</sub>. After regeneration, no hardness was present in the effluent; however, 66 mg/l chlorides were present. With a more complete rinsing this figure would be lower. The No. 2 softener was sampled during its service run and showed no hardness and little chlorides present.

The final sample was taken from the service pumps which use the ground level reservoir for supply. The combined softener effluent and bypassed filter effluent form the treated product water. The hardness was 79 mg/l which is over the 50 - 60 mg/l criteria. All other criteria were within expected ranges. On the basis of the results from these samples we do not see any water quality problems at the Courthouse Bay plant.

#### B. Operational Evaluation

The operation of the water treatment equipment is conducted in a conscientious fashion by the operators who are working under certain operational handicaps. The operators run frequent routine hardness tests on the softener effluents using the soap test. This is not as accurate as the EDTA titration. The EDTA titration would allow closer monitoring for the hardness breakthrough.



## II. EVALUATION OF THE EXISTING FACILITIES

## B. Operational Evaluation - Contd.

Provision for adding chlorine is provided at three points in the water treatment plant: raw water detention tank; the piping leading to the ground level reservoir; and the piping from the ground level reservoir to the distribution pumps. Presently the chlorine is added only to the raw water detention tank. This is a preferred place for an effective bacteria kill but disadvantages are present. A free chlorine residual was checked on the No. 1 softener effluent with a 0.6 ppm result. This level of chlorine residual passing through a softener ion exchange resin leads to oxidation of the resin with corresponding loss of ion exchange capacity. This will be evidenced by shorter service times. A preferred site for chlorine addition would be prior to the ground level reservoir, and if needed, after ground level reservoir if the residuals were too low for the distribution system.


The amount of lime addition is approximately 50 pounds daily for 300,000 to 400,000 gallons of water treated. This dosing rate is approximately 15 mg/l at the 400,000 gallon per day rate. A Langelier Index determination was made to determine the corrosion rating. The raw water at pH 7.2 was determined to be slightly corrosive; therefore, lime addition is correctly used to raise the pH to 7.8. This places the Langelier Index to the slightly scaling phase which is desirable.

A problem is present in the method of reporting the raw incoming water and the service (treated) water produced in the plant. A study of the figures reported for the month of September indicates that more water is treated than the raw water coming into the plant. The instrumentation recording the water flows are in need of calibration.

Another point of error is the fact that the filter backwash water comes from the treated water supply in the elevated storage tank. This water has been recorded as treated water but it never is used in the distribution system. The actual distributed treated water is therefore less than what is reported.

Another point is that the water which is reported as softened water is also in error. During the backwash and regeneration cycles, the water used for backwash, rinse and dilution pass through the totalizing water meters. This inflates the softened water figures by those water quantities which actually goes to drain and not to the treated water storage.

The operators at present do not report the quantities of water softened between regenerations. This would give the operators an insight into the effectiveness of the regenerations and changes in the ion exchange capacities of the resin.



## II. EVALUATION OF THE EXISTING FACILITIES - Contd

## C. Equipment Evaluation


The major deficiencies in the equipment are the control systems and equipment maintenance requirements. Some equipment needs immediate replacement to maintain operations.

The control systems for the filter backwash cycles, softener regeneration, and brine tank level control are in need of replacement. The filter system currently operates under a "battery backwash" method. When the timer initiates backwash, all filters are removed from service and the plant does not produce any treated water until all the filters are backwashed. Each filter is backwashed individually while the other units are in a standby status awaiting return to service or awaiting backwash. This backwash period takes about 50 minutes to complete while the treatment plant is shutdown. This results in a loss of treated water of 20,000 gallons daily; this 20,000 gallons does not include the water used for backwash and rinse. The controls are unreliable and the operator must standby to ensure the cycles are initiated and completed. Some valves do not operate on the automatic mode and must be manually assisted. Several backwash valves currently leak and therefore, must be manually shut off during the service run. The flowmeters for the filter units are out of calibration or are inoperable.

The softener regeneration system is also in need of repair and maintenance. The regeneration is initiated from a timer, as in the case of the filters, and the operator must standby to ensure that the cycles are started and completed.

The brine injection cycle at the time of our inspection was out of adjustment. The brine drawdown in the measuring tank was only 21-1/4" where the operator's manual states a drawdown of 38-3/8" to ensure a complete regeneration of the resin takes place. Without a full salt regeneration the subsequent service times will be shortened. The brine tank level controls are inoperable due to rust penetrations. The brine supply pumps must be manually operated to refill the brine tanks.

In summary, the automatic control systems for operating the filters and softeners are inoperable or unreliable. The systems are essentially operated manually by the plant personnel in order to produce the treated water.



A

#### III. PROPOSED FACILITY EXPANSION

## A. General

The purpose of this study is to expand the Courthouse Bay water treatment plant capacity to meet the projected water demands of 1986. It has been estimated that the average daily demand of 1986 will be approximately 463,000 gallons per day, and the maximum 24-hour demand will be approximately 960,000 gallons per day. The proposed expansion will increase the design daily production of the water treatment plant from 576,000 to approximately 960,000 gallons per day. The expansion will follow the guidelines established in Civil Engineering Design Manual NAVFAC DM-5, dated April, 1974.

#### B. Design Criteria

The existing filter system with all units on line operates at about 3 gpm per sq. ft. The DM-5 criteria is 2.0 gpm per sq.ft. for a daily maximum rate, and the criteria for a maximum rate is 3 gpm per sq.ft. The proposed filter system consisting of a total of seven filters is designed for a daily maximum rate of 2.01 gpm per sq.ft. with all units on line. During backwash with one unit off-line the flow loading will increase to 2.36 gpm per sq. ft. for the six remaining on line filters.

The original softeners were designed on a flow loading rate of 6.5 gpm per sq. ft. with both units on line; with one unit on-line during regeneration the flow loading is 13.0 gpm per sq.ft. The proposed softener system consisting of a total of four softeners was designed on a flow loading rate of 5.25 gpm per sq.ft. During regeneration of one unit, the flow loading for the system will increase to 7.44 gpm per sq.ft. which is well within the conservative design.


The design criteria as found in DM-5 was not followed in the present installation of the gasoline engine for the alternate power source for the 750 gpm service pump. DM-5 states that gasoline power sources are not to be installed in a below grade location. The alternate power source for the proposed filter feed pump is a diesel engine power unit installed in a below grade location.

## C. Equipment Additions

The basic method of the treatment has not changed: decarbonation, pressure filtration, lime addition, chlorination and softening will still be conducted. The system will, however, be expanded to treat the increased flow where necessary.

## D. Decarbonation and Lime Addition

The existing decarbonator has a design capacity of 750 gpm. No



## III. PROPOSED FACILITY EXPANSION


## D. Decarbonation and Lime Addition - Contd

expansion or modification will be necessary to treat the projected flow rate of 670 gpm. The lime slurry tank and feed pump currently use approximately 50 pounds of lime per 300,000 to 400,000 gallons of water daily. The pump is running at about 2/3 capacity, 60 gallons per hour. The additional flow would require additional lime to be added to the slurry tank and require adjustment of the pump to correctly adjust the pH to non-corrosive levels as determined by the Langelier Index. Replacement of the lime mix tank or the metering pump is not required. The practice of chlorine addition to the detention tank should be discontinued in order to protect the softener ion exchange resin from loss of capacity. Chlorine should be added to the piping leading to the ground level reservoir. If the chlorine residuals are low, as measured in the distribution piping, additional chlorine can be added in the piping from the ground level reservoir to the service pumps. There are three chlorine addition points presently at the plant: one at the detention tank and, one at the inlet of the ground level reservoir, and one at the outlet of the ground level reservoir. Those at the reservoir are not being used presently.

## E. Pressure Filtration

The two existing 400 gpm filter feed pumps will be replaced with two new 670 gpm pumps. They will be powered by 20 hp electric motors. One of the units will have a small diesel water cooled engine for a standby power source in addition to an electric motor. One pump will be required to sustain the flow through the plant. The second pump will operate as an inline standby unit as is now the case.

The filter system will require major expansion and modifications to treat the increased flow rate. In addition to the existing three 7'-6" diameter by 6'-0" straight side units, the system will be expanded to include four additional 8'-0" diameter by 6'-0" straight side filters. These seven units will be installed in a parallel configuration served by common inlet and outlet interconnecting piping. The existing piping for the three unit filter system will be extensively modified. New face piping, automatic valves, and interconnecting piping will be necessary to incorporate the new operating conditions. The system will be designed in order that while one unit is off-line undergoing backwash, the remaining six units will continue carrying the load of the treatment plant. This eliminates the downtime which is currently a disadvantage at the plant causing lost water production. The present hydropneumatic valve controls and face piping will be replaced with electronic controls to handle all seven units. The existing control system and face piping cannot be modified to incorporate the expansion. The new filter units will use the same type filter media and depth as the existing units, and the tanks will be mounted on structural legs similar to the existing units. The existing piping from the present filter feed pumps will be retained and used for



J. E. SIRRINE COMPANY

### III. PROPOSED FACILITY EXPANSION

## E. Pressure Filtration - Contd


the expanded system. The existing piping for backwash will also be retained. The increased flow in the 8" piping at 670 gpm will result in less than 4.3 feet per second velocities which remains acceptable. The estimated backwash flow rates of 755 gpm in 8" piping is less than 4.8 feet per second which also remains acceptable.

The number of the new units could be decreased from four units if larger vessels were used. For an example, a 9'-6" or 10' diameter unit system would require only two units. However, larger units require larger volumes of treated water for backwash at a 15 gpm per sq.ft. rate. This greatly increases the wastewater flows, and in addition lowers the plant's treated water production. An additional disadvantage occurs when a large unit would be undergoing backwash. The other units on line would then experience a larger flow loading increase. The backwash piping would also need to be increased to handle the much higher backwash flow rates which would approach 1180 gpm for a 10' diameter unit. It is, therefore recommended to stay with smaller diameter units.

## F. Softener System

The present two 5'-0" diameter units will be expanded to include two additional 6'-0" diameter units. The concept of a hardness bypass would be retained. The flow rate sent to the four unit softener system would be about 503 gpm; the hardness bypass will allow 167 gpm to bypass the softener units. The existing softeners and the new softeners will have a resin bed depth of 2'-6". The resin volumes will be 49 cubic feet each for the existing 5'-0" diameter units and 70.7 cubic feet for the new 6'-0" diameter units. The units will have service runs of about 20 hours. The units will be staged in startup as well as the controls being interlocked to prevent more than one unit regenerating at any one time. In addition to the two new units, it is recommended that a new 49 cubic feet quantity of resin be replaced in the No. 1 unit. The existing No. 2 unit has had the resin replaced recently. The capacity of cation resin tends to decrease after five years; and the high chlorine residuals are also deterimental to the exchange capacity.

Presently two brine measuring tanks serve the existing two 5'-0" diameter softeners. The tanks are in a severe state of corrosion. It is proposed to delete one of the tanks, to replace the other tank, and to connect the two 5'-0" diameter softeners to the new brine tank. New float controls would be included with the replaced tank. The two new 6'-0" diameter softeners will have their own single brine measuring tank supplying brine for regeneration.



## III. PROPOSED FACILITY EXPANSION

#### F. Softener System

This brine tank will have level control equipment included. The brine piping from the existing brine pumps will be extended to the brine measuring tank for the new larger softeners.

## G. Controls

The next major areas to be modified are the control systems for the filters, softeners, and the softener regeneration system. The existing control system for the control of the filter feed pumps, well pumps, detention tank level, ground level storage tank level, elevated storage tank level, and the service pumps will remain intact.


The new pushbutton automatic controls for the filter system will permit operation of the system with one unit off-line for backwash. The backwash will be initiated by a timer or by manual initiation. The automatic valves with electric operators, flowmeters, sample cocks, and pressure gauges will be included for all units. The automatic valves will have a manual operator in case of power failure and the system will be designed for failure in the normal operating positions.

The softener control system will be interlocked to prevent two softeners from a simultaneous regeneration; the regeneration can be started automatically from a timer or by manual initiation. The new softeners will be equipped with totalizing water meters, pressure gauges, and sample cocks. These features are present in the existing softeners. In addition, all softeners will be equipped with flowmeters. The brine measuring tanks will be equipped with level controls to allow automatic brine refilling at the completion of the brine injection cycle of regeneration.

The new control panel will house the control systems for the filters, softeners, and the regeneration equipment. The panel will include the status run lights, timers, sequencing controls, manual pushbuttons, and interlocks to control the equipment. The panel will be protected from power surges which presently occur during thunderstorms.

## H. Building Expansion

In order to house the necessary new water treatment equipment the existing building will need to be expanded by approximately 40 feet. Exhibit H shows the expansion and equipment arrangement. The salt storage area will not be expanded. With the present 46 tons of salt storage capacity, this will allow a 30 day supply.



## III. PROPOSED FACILITY EXPANSION


## H. Building Expansion - Contd

The raw water detention tank will not be enlarged; the approximately 25,000 gallon capacity will allow a detention time of 37 minutes at a 670 gpm flow rate. This will pose no problem for pH adjustment. It does, however, shorten the plant operating time in the event of well pump failure. At the present time with a 400 gpm flow rate 62 minutes of detention time exists.

#### I. Water Consumption

The present water treatment plant consumes water for the backwash and rinse of the filters, and the regeneration of the softener systems. The present system consumes approximately 27,200 gallons on a daily basis. This is an estimate based on daily backwash of the three filters and three softener regeneration cycles, assuming the cycle times are as specified in the operating manuals. This 27,200 gallons per day may be higher if during the manual operation longer cycle times and higher flow rates than specified are used.

The new system will consume approximately 65,000 gallons of water on a daily basis. The source of filter backwash water supply and softener regeneration water supply will not be changed. The filters will use treated water and the softeners will use filtered water. The system is sized to produce 670 gpm of treated water. This 670 gpm of water does not include the additional flow rate provisions for continuously making up the waste backwash, rinse, and regeneration water. It is assumed that during the off load hours this 65,000 gallons of water will be replaced in the storage facilities. At a flow rate of 670 gpm the 65,000 gallons will be made up in approximately 97 minutes.



# -<u>SECTION 300</u>-WASTEWATER TREATMENT PLANT A UTILITY STUDY FOR

THE COURTHOUSE BAY AREA


A

1

I

1


1



 1.	E.	SIRRINE	COMPANY			
				 	 9	

## TABLE OF CONTENTS

		Page			
Ι.	DESCRIPTION OF EXISTING FACILITIES	1			
	A. General	1			
	B. Flow And Waste Characteristics	1			
	C. Description of Existing Facility	3			
	1. Deviation Of Existing Plant With DM-5	5			
	D. Operational Deficiencies and Problems Of The Existing Plant	6			
II.	BASIS FOR DESIGN	7			
	A. General	7			
	1. Future Waste Characteristics	7			
	2. Unit Process Capabilities	8			
	3. Discharge Limits	9			
III.	PROPOSED FACILITY EXPANSION				
	A. General	9			
	1. Proposed Expansion	9			
	2. Deviation Of Proposed Plant With DM-5	14			
IV.	EXHIBITS				
	Exhibit "J" - Wastewater Treatment Flow Diagram				
	Exhibit "K" - Wastewater Treatment Plant General Arrangement				
۷.	APPENDICES				
	Appendix III - 1. J. E. Sirrine Company Sewer Study Results J. E. Sirrine Company Sample Analysis				
	2. Courthouse Bay Wastewater Treatment Plant Monitoring Data Statistical Analysis of Monitoring Data				
	3. NPDES Permit Conditions				
	4. Design Calculations				



#### COURTHOUSE BAY WASTEWATER TREATMENT PLANT

## I. DESCRIPTION OF EXISTING FACILITIES

#### A. General

J. E. SIRRINE COMPANY

4

The Courthouse Bay Wastewater Treatment Plant was constructed in 1942 and consisted of one Imhoff tank and two sludge drying beds. This was a primary wastewater treatment plant with the Imhoff tank used for suspended solids removal and sludge stabilization. The sludge drying beds were used for sludge dewatering. The plant utilized prechlorination for odor control and postchlorination for disinfection. Postchlorination was accomplished in a manhole using the outfall to provide the required contact time.


The treatment plant was expanded in 1956 with the addition of another Imhoff tank, an additional sludge drying bed, and a new chlorine contact chamber. In 1968 the treatment plant was upgraded to the existing condition with the addition of a trickling filter and secondary clarifier. A new chlorine contact chamber was constructed to provide the required contact time due to increase wastewater flows.

## B. Flow and Wastewater Characteristics

An accurate characterization of flow and raw wastewater parameters is necessary for the evaluation of the existing unit processes and also for the development of design criteria. Raw wastewater characteristics considered are the five day Biochemical Oxygen Demand (BOD<sub>5</sub>) and suspended solids (S.S.) concentrations. Four sources of data were available: the Navy Facilities Design Manual (DM-5), sewer flow study conducted by the J. E. Sirrine Company, Courthouse Bay Wastewater Plant monitoring data, and wastewater samples collected by the J. E. Sirrine Company.

DM-5 provides typical wastewater concentrations for naval domestic waste

Characteristics	Concentrations (mg/1)
Total Solids	800
Violate Solids	420
Fixed Solids (highly variable)	380



## I. DESCRIPTION OF EXISTING FACILITIES

#### B. Flow and Wastewater Characteristics - Contd


<u>Characteristics</u>	Concentrations (mg/1)
Total Suspended Solids Volatile Suspended Solids Fixed Suspended Solids	200 144 56
Floatable Solids (such as oil)	25-40
BOD <sub>5</sub> at 20 <sup>o</sup> C	200
Total Nitrogen as N Organic Nitrogen Ammonia Nitrogen	32 16 16
Total Phosphorus as P	12

Based on the sewer flow study, which was conducted in September 1978, when the AMTRAC personnel were on base, the average daily flow was approximately 397,000 pgd. Of this flow approximately 137,000 gpd is relatively uncontaminated wastewater, and consists of blowdown from the power plant and infiltration and inflow. This results in an estimated sewage flow of approximately 260,000 gpd. At an assumed BOD<sub>5</sub> concentration of 200 mg/l, based on DM-5, the average daily BOD<sub>5</sub> loading is 433 lbs./day. See Appendix III for detailed flow analysis. When the sewage and other wastewater flows are added together the resulting BOD<sub>5</sub> concentration is 130 mg/l.

Courthouse Bay Wastewater Treatment Plant monitoring data was obtained for an eight month period from January thru August 1978, see Appendix III. At Courthouse Bay weekly composite samples are taken as required by the EPA. Contained in the monitoring data were thirty-five composite samples varying as follows:

Parameter	Average Value	Range
Flow	0.45 MGD	0.143 - 0.505 MGD
BOD5	223 mg/1	30 - 780 mg/1
S.S.	329 mg/1	26 - 2680 mg/1

The monitoring data was statistically analyzed to develop a probability of occurrence curve for BOD5, Appendix III. The 50 percent occurrence BOD5 was equal to 110 mg/l and the 90 percent occurrence was equal to 640 mg/l. This analysis indicates that 50 percent of the time the BOD5 is less than 110 mg/l and 90 percent of the time less than 640 mg/l. The high average value for BOD5, 230 mg/l, and for the 90 percent BOD5, 640 mg/l, from the monitoring data was due to five samples ranging from 570 mg/l to 780 mg/l. These values all



## I. DESCRIPTION OF EXISTING FACILITIES

## B. Flow and Wastewater Characteristics - Contd

occurred during the month of July 1978. The high values were probably due to a specific activity which was not identifiable at this late date (December).

A sampling program and information gathering site visitation was carried out on September 18 thru 21, 1978. See Appendix III for sample analysis. Wastewater samples were collected at four points throughout the treatment plant with results as follows:

BOD	COD	SS			on
(mg/1)	(mg/1)	(mg/1)	BOD5	COD	SS
61	137	27	_	_	-
36	87	16	41	40	41
23 30	55 125	13	62 51	60 9	52 65
	(mg/1) 61 36	(mg/1) (mg/1) 61 137 36 87 23 55	(mg/1)         (mg/1)         (mg/1)           61         137         27           36         87         16           23         55         13	BOD (mg/1)         COD (mg/1)         SS (mg/1)         % Re (mg/1)           61         137         27         -           36         87         16         41           23         55         13         62	(mg/1)         (mg/1)         (mg/1)         BOD5         COD           61         137         27         -         -         -           36         87         16         41         40           23         55         13         62         60


Based on the sample analysis there appears to be an increase in BOD5 and COD across the secondary clarifier. However, due to transportation delays the samples were held for 22 hours. This can result in BOD5 sample results which are significantly less than actually exists. The low influent BOD at the inlet structure was probably the result of the AMTRAC personnel being deployed in the field. This corresponds to a sewage flow reduction of 100,000 gpd or 167 lbs. BOD5/day at 200 mg/l. Deployed personnel resulted in the dilution water comprising a greater percentage of the total flow. This corresponds to a calculated BOD5 concentration of 98 mg/l.

The above discussion indicates that the wastewater flows and composition vary significantly. This variation is caused by changing base populations due to personnel being deployed in the field, and also base operations, such as military vehicle washing.

## C. <u>Description of Existing Facility</u>

The existing Courthouse Bay Wastewater Treatment Plant is a secondary treatment plant at a design average daily flow of 525,000 gpd. The plant consists of primary clarification, biological stabilization, secondary clarification and disinfection. Sludge is stabilized in Imhoff tanks then dewatered on sludge drying beds.

The influent to the plant is pumped to the inlet structure where it flows by gravity into Imhoff tanks. The Imhoff tanks are parallel units which are used for primary clarification and sludge digestion. Each unit has 416 sq. ft. of surface area, which results in an



## I. DESCRIPTION OF EXISTING FACILITIES

#### C. Description of Existing Facility


overflow rate of 630 gpd/sq.ft. at the design flow, 525,000 gpd (average 24 hour flow). The effluent overflow from the Imhoff tanks flows by gravity to the trickling filter lift pump sump located under the pump house.

There are three (3) existing trickling filter lift pumps used to pump wastewater through the reaction driven rotary distributor of the trickling filter. Two of the lift pumps are three (3) HP twospeed, 200 gpm - 400 gpm, vortex pumps. The third pump is a one (1) HP two-speed, 65 gpm - 130 gpm, vortex pump. The pumps are activated on level by a float system operating on the following pump schedule:

Water Level Elev Ft.	Rising Level-Read up Start Pump Stop Pump	Falling Level-Read Down Start Pump Stop Pump	GPM Total
8.0	#3 Hi	Pumps 2 & 3 Running	800
7.0	#2 Hi	#3	400
6.5	#2 Lo #1	#2 Lo #2 Hi	200
6.0	#1 Hi	#1 Hi #2	130
5.5	#1 Lo	#1 Lo #1 Hi	65
5.0	No Pumps Running	#1	0

The trickling filter is a 62 ft. diameter unit with a 7.5 ft. bed depth. Rock media is used to support the biological population responsible for the waste stabilization. At the average daily flow of 397,000 gpd, from Sirrine sewer survey, and a BOD concentration of 200 mg/l, from DM-5, the existing filter is hydraulically and organically loaded at 6.0 MGD/acre and 13 lbs. BOD/day/1,000 cu.ft. respectively. This is assuming that the Imhoff tanks are removing 30 percent of the BOD5 associated with suspended solids, and neglecting recirculated flow and BOD5. Based on present loading the existing trickling filter is operating as an intermediate - rate filter. Intermediate - rate trickling filters are generally designed to treat hydraulic loadings of 4 to 10 MGD/acre, including recirculation, and organic loadings range from 15 to 30 lbs. BOD/day/1000 cu.ft., excluding recirculation.

There is a provision for trickling filter effluent recirculation prior to secondary clarification, via a six (6) inch line connecting the trickling filter effluent line to the trickling filter lift pump sump. There is a Kennison Open Flow Nozzle located on the recirculation line in the pump sump; however, the necessary instrumentation, flow transmitter and indicator, were not installed. Therefore, there is no means of measuring this flow. The recycle flow can be regulated by manually opening or closing a plug valve.



þ

## I. DESCRIPTION OF EXISTING FACILITIES

#### C. Description of Existing Facility - Contd

The existing secondary clarifier is a 26 ft. diameter unit. Influent to the clarifier enters by way of a gravity line from the trickling filter. At the present average daily flow of 397,000 gpd the resulting overflow rate is 750 gpd/sq.ft. At the design 24 hour average daily flow, 525,000 gpd, the overflow rate is 990 gpd/sq.ft., which exceeds the DM-5 design criteria of 800 gpd/sq.ft. at average 24 hour design flow. Therefore, any flow in excess of 424,000 gpd will result in exceeding the recommended overflow rate resulting in deterioration of the effluent. The overflow from the secondary clarifier flows by gravity to the clarifier effluent box and then to the chlorine contact chamber. Settled solids are removed from the secondary clarifier by a six (6) inch sludge underflow pipe. The available head in the clarifier is used to move the sludge from the clarifier to the secondary sludge recirculation pump sump, located under the pump house. There is no provision for measuring the sludge underflow; however, the flow can be varied at the pump sump by manually opening or closing the existing plug valve. Secondary sludge is recirculated back to the Imhoff tanks where the solids settle and are stabilized. Sludge is periodically wasted via gravity lines to the sludge drying beds for dewatering.


There is presently 3150 sq.ft. of sludge drying bed area. The area is segregated into three (3) beds which are alternatingly dosed. The dryed sludge cake is removed to a landfill. Filtrate from the beds is collected in an underdrain system which flows by gravity to the filtrate pump sump. The filtrate is then pumped to the Imhoff tank effluent box.

The chlorine contact chamber contains a water volume of 1,050 cu.ft. At the design average daily flow of 525,000 gpd (49 cfm) the detention time is 21 minutes.

The existing chlorination system utilizes 150 lb. gas cylinders for chlorine storage. Two cylinders are connected with automatic switchover. A chlorine gas bubbler is used to deliver the gaseous chlorine to the contact chamber

The existing Courthouse Bay Wastewater Treatment Plant has achieved good treatment efficiencies, as observed from the monitoring data with only one violation of the  $BOD_5$  weekly limit, 45 mg/l, noted. However, due to anticipated increases in flow and  $BOD_5$  loadings the existing facility should be expanded.

- 1. Deviation of Existing Plant With DM-5
  - a. Imhoff Tanks (primary clarification) being an antiquated



J. E. SIRRINE COMPANY

þ

## I. DESCRIPTION OF EXISTING FACILITIES

- C. Description of Existing Facility
  - 1. Deviation of Existing Plant With DM-5
    - a. Contd

technology it is not addressed in DM-5.


- b. Trickling Filter no spare units as required in DM-5.
- c. Secondary Clarifier at the 24 hour average daily flow, 525,000 gpd, the overflow rate is 990 gpd/sq.ft. which is in excess of the 800 gpd/sq.ft. in DM-5. No spare unit as required in DM-5.
- d. Chlorine Contact Chamber only one tank is used to satisfy the detention requirements. DM-5 requires two tanks to allow for periodic cleaning.
- e. Chlorination Equipment only one feed system is installed. DM-5 requires two feed systems, each capable of handling the maximum required dosages.
- f. Imhoff Tanks (sludge stablization) DM-5 does not consider the Imhoff tanks as an available waste stabilization process.
- g. Sludge Drying Beds (sand) no deviation with DM-5. Based on DM-5 rational and per capita allowance design criteria there is adequate bed area.

#### D. Operational Deficiencies and Problems of the Existing Plant

Operational control of trickling filter plants can be achieved through the manipulation of solids underflows from the clarifier and recirculation of the wastewater around the trickling filter.

The lack of quantifying instrumentation on the secondary clarifier underflow lends itself to a higher underflow rate than is necessary for solids removal, which results in higher pumping costs.

The recirculated flow around the trickling filter is presently not measured. A Kennison Nozzle is installed on the recycle line; however, the associated instrumentation is absent. This limits the operators control over the hydraulic loading and to some extent the BOD loading on the trickling filter.



ł

## I. DESCRIPTION OF EXISTING FACILITIES

D. Operational Deficiencies and Problems of the Existing Plant - Contd

The existing office is located within the pump house. This results in nuisance noise levels which emanate from the trickling filter lift pumps and sludge recirculation lift pumps. The noise level probably violates OSHA noise level regulations and therefore, the office should be relocated.

#### II. BASIS FOR DESIGN

#### A. General

The basis for the design expansion of the existing treatment plant is made up of three components: future waste characteristics, unit process capabilities, and treated waste discharge limits.


### 1. Future Waste Characteristics

Future waste characteristics considered include flow, BOD5, and suspended solids.

The development of design flows was based on the maximum population for the year 1986. The sewer flow analysis included in Appendix III establishes the average daily flow. Maximum, minimum, and peak flows were developed using DM-5 flow ratio factors. The DM-5 factors are only applied to the sewage flows and not to constant relatively non-contaminated wastewater flows. The projected average daily flow is 678,000 gpd of which 393,000 gpd is contaminated and 285,000 gpd is non-contaminated wastewater. Design flows are as follows:

Flow Measure	DM-5 Factor	Flow
Average Daily Flow	-	678,000 gpd
Maximum 24 hr. Flow	2.7	1,347,000 gpd
Minimum Flow	0.23	375,000 gpd
Peak Flow	3.8	1,779,000 gpd

The various flows were developed for the following design applications (from DM-5).



## II. BASIS FOR DESIGN

J. E. SIRRINE COMPANY

A. General

#### 1. Future Wastewater Characteristics - Contd

Flow Measure	Explanation	Design Application
Average 24 hr. flow	Annual average of daily flow	Estimate of annual cost
Maximum 24 hr. flow	Highest 24 hr. flow over year	Hydraulic design of process units
Minimum flow	Least instantaneous flow	Design of plant conduits
Peak flow	Highest instantaneous flow	Design of hydraulic elements of treatment plant


The development of a design  $BOD_5$  was based on DM-5 domestic waste characteristic, which is 200 mg/l. This value is applied only to sewage flows and not non-contaminated wastewaters. The projected  $BOD_5$  loading, at the average daily flow, is 656 lbs.  $BOD_5/day$  at a concentration of 116 mg/l. The reduction in  $BOD_5$  from the existing average concentration of 223 mg/l to the future average concentration of relatively uncontaminated wastewater flows to the sewer system.

## 2. Unit Process Capabilities

Unit process capabilities are important considerations in the development of treatment efficiencies. Approximate process capabilities of the proposed units responsible for BOD<sub>5</sub> and suspended solids removal are as follows:

Unit Process	%BOD5 removed	% of total sus- pended solids removed	% solids by weight in underflow
Primary Clarifier	30%	60%	3%
Trickling Filter	60%	5 J - 18 - 19	- 6.5
Secondary Clarifier	-	38%	3%
Gravity Thickener	-		9%
Aerobic Digester	50% (Volatile solid: oxidized)	50% s (Volatile solids oxidized)	5%

-8-



-

## II. BASIS FOR DESIGN

## A. General

3. Discharge Limits

The existing NPDES permit sets the  $BOD_5$  and SS concentrations at 30 mg/l, and fecal coliform bacteria at 200/100 ml. (See Appendix III for NPDES permit).

The existing permit will expire December 31, 1979. The new permit, which becomes effective January 1, 1980, will be upgraded with respect to bacterial concentrations in the effluent. The new discharge standard will be a total coliform bacteria concentration of 70/100 ml. The new bacteria standard will be imposed because the Courthouse Bay Wastewater Treatment Plant outfall is located in an existing shellfish area. The BOD<sub>5</sub> and SS discharge standards will remain at 30 mg/l.

## III. PROPOSED FACILITY EXPANSION

#### A. General


The existing facility at Courthouse Bay is being expanded from 525,000 gpd to 678,000 gpd (average daily flow). See Exhibits J and K, for flow diagram and general arrangement drawings.

#### 1. Proposed Expansion

It is proposed that the existing inlet structure, Imhoff tanks and the Imhoff tanks effluent structure be demolished and removed. A new dual barminutor system is proposed to be placed at the head of the plant for the purpose of screening and comminuting debris. The flow will then be split between two new primary clarifiers; 22 foot diameter. The overflow rate at the 24 hour maximum daily flow with one unit out of operation is 3600 gpd/sq.ft. The overflow rate at the average daily flow, with both units in operation, is 906 gpd/sq.ft.

The effluent overflow from the primary clarifiers will flow by gravity to a new flow splitter box. The flow splitter box is required to divide the flow prior to entering the trickling filter pump sumps.

A new trickling filter, 62 foot diameter, and secondary clarifier, 29 foot diameter, are proposed. The new trickling filter will have the flexibility to operate in parallel or series with the existing unit. The proposed piping arrangement allows the trickling filters and secondary clarifiers to be bypassed for maintenance.



ł

#### III. PROPOSED FACILITY EXPANSION

## A. General

1. Proposed Expansion - Contd

A new pump house and pumps are required for the operation of ' the new reaction type rotary distributor. These pumps are two speed vortex pumps as follows:


Trickling Filter Lifting Pump	HP	Low Speed	High Speed
No. 4	1	.75 gpm	150 gpm
No. 5	3	200 gpm	400 gpm
No. 6	3	200 gpm	400 gpm

The pumps will be activated on level by mercury float switches on the following schedule:

Water Level Elev Ft.	Rising Level - Read Up Start Pump Stop Pump	Falling Level-Read Down Start Pump Stop Pump	GPM Total
8.0	#3 Hi	Pumps 2 & 3 Running	800
7.0	#2 Hi	#3	400
6.5	#2 Lo #1	#2 Lo #2 Hi	200
6.0	#1 Hi	#2 Hi #2	150
5.5	#1 Lo	#1 Lo #1 Hi	75
5.0	No Pumps Running	#1	0

It is proposed that the flow be split equally between the new and existing trickling filter at the average daily flow. The existing filter is hydraulically limited to 424,000 gpd, not including recycle, due to the secondary clarifier surface area. At 424,000 gpd the clarifier overflow rate is 800 gpd/sq.ft. Therefore, any increase in plant influent flow above 848,000 gpd should be diverted to the new trickling filter. This flow diversion can be accomplished at the flow splitter box, ahead of the trickling filter lift pumps. Both the new and existing trickling filters will utilize effluent recirculation around the filters to enhance  $BOD_5$  removal and to maintain the minimum hydraulic loading. Both the new and existing trickling filters will utilize a manual plug valve and a Kennison Nozzle with a flow indicator and recorder for flow measurement and control of recirculated flow. At the average daily flow, 678,000 gpd, the hydraulic and BOD<sub>5</sub> loadings are as follows:

Recycle	Existing Trick Filter Loadin		New Trickling Filter Loadings		
	BOD5*	Hydraulic	BOD5*	Hydraulic	
0% 50%	10 lbs./Day/1000 cu.ft. 10 lbs./Day/1000 cu.ft.	4.8 MGD/acre 7.2 MGD/acre	10 lbs./Day/1000 cu.ft. 10 lbs./Day/1000 cu.ft.	4.8 MGD/acre 7.2 MGD/acre	



A. General

J. E. SIRRINE COMPANY

ł

1. Proposed Expansion - Contd

\*BOD<sub>5</sub> loadings assuming 30 percent BOD<sub>5</sub> removed during primary clarification.

The BOD<sub>5</sub> removal as predicted by the National Research Council Equation (NRC) is as follows:

NRC	EFFLUENT	QUALITY	FOR	NEW	å	EXISTING	TRICKLING	FILIERS
	Sola Roberts and the			8.14			12	

PARALLEL OPERATION\*

	THUELE		
Recycle	%BOD5 Removal	Influent BOD5	Effluent BOD5
0%	85%	116 mg/l	17.4 mg/1
50%	88%	116 mg/1	14.0 mg/1

#### NRC EFFLUENT QUALITY FOR NEW & EXISTING


## TRICKLING FILTERS SERIES OPERATION\*

	OVERALL			
Recycle	%BOD5 Removal	Influent BOD5	Effluent BOD5	
0%	98%	116 mg/l	2.3 mg/1	
50%	99%	116 mg/1	1.2 mg/1	

\*BOD<sub>5</sub> loadings assume 30 percent BOD<sub>5</sub> removed during primary clarification.

The new secondary clarifier was designed at an overflow rate of 2000 gpd/sq.ft. during the maximum 24 hour flow, 1,347,000 gpd, with the existing secondary clarifier out of service. Using this design criteria the new secondary clarifier is a 29 foot diameter unit with a 10 foot side water depth. At the average daily flow the overflow rates on the new and existing secondary clarifiers are 573 gpd/sq.ft. and 640 gpd/ sq.ft. respectively.

The solids underflow from the new secondary clarifier will flow by gravity to the existing sludge pump sump. For operational control a manually operated plug valve and Kennison Open Flow Nozzle with flow indicator recorder, and totalizer are to be installed on both solids underflow lines.



J. E. SIRRINE COMPANY

## III. PROPOSED FACILITY EXPANSION

## A. General

## 1. Proposed Expansion - Contd

It is proposed that the existing Chlorine Contact Chamber be demolished and removed. A new Chlorine Contact Chamber is to be installed with a 30 minute detention time at the peak flow. (This is to insure that the total coliform bacteria effluent standard of 70/100 mT is not violated.) Two tanks are proposed, 18,540 gallons each, to allow periodic cleaning with the operational flexibility of diverting the flow to either chamber or both.

The existing chlorination system utilizes two 150 lb. chlorine gas cylinders with automatic switchover. The chlorine is added to the wastewater through a gas bubble diffuser located in the existing Chlorine Contract Chamber. It is proposed that two (2) new vacuum feed, flow proporational chlorination system be installed. These systems would utilize one-ton chlorine gas cylinders with two cylinders on line with automatic switchover. The new system will also differ from the existing system in that the chlorine will be delivered to the contact chambers in a gas-water solution through a distribution manifold. This is an important safety feature when handling a dangerous gas like chlorine. The new chlorination system will also utilize an automatic chlorine residual analyzer and recorder, with an alarm for low chlorine residual.


The existing chlorination system is to be removed.

The chlorine usage rate is 57 lbs/day based on the average daily flow, 678,000 gpd, and a dosage rate of 10 mg/l. This converts to a system run time, from full to empty, of approximately 70 days (two (2) cylinders).

Adjoining the new pump house there is to be a new chlorine storage building. Within this building the chlorine and chlorination equipment is to be located. An office will be partioned off within the chlorine storage building. A monorail with hoist will be installed for moving the chlorine cylinders. Scales incorporated in the cylinder stands will be provided to measure chlorine usage.

A new road will be required to allow a truck access to the chlorine storage building, see the general arrangement in Exhibit K.

Solids underflows from the secondary clarifiers will flow to the existing sludge pump sump as described above. The sludge is then pumped to the primary clarifiers. The mixed primary and



Δ

Ì

## III. PROPOSED FACILITY EXPANSION

#### A. General

1. Proposed Expansion - Contd

secondary solids underflows from the primary clarifiers is pumped, using two new progressive cavity sludge pumps for each clarifier, to the gravity thickener. The new primary sludge pumps are 3HP, 280 RPM units in a lead lag configuration which operate on a timer and alternate each cycle.

The anticipated sludge volume from the primary and secondary clarifiers underflows is 2,500 gpd. This is based on a solids mass removed of 640 lbs/day, a specific gravity of 1.02, and a solids concentration of 3 percent by weight.

The new gravity thickener was sized on a solids loading of 15 lbs. dry solids/sq.ft./day. At this solids loading a 7.5 foot diameter vessel is required with a 10 foot side water depth. The gravity thickener is responsible for concentrating the waste sludge from 3% in the influent to 9% in the thickened underflow. This correspondence to a sludge volume reduction of 67%, from 2,500 gpd to 840 gpd.


Effluent from the chlorine contact chamber will be recirculated back through the gravity thickener to prevent possible septic conditions. Two vertical dry pit pumps capable of delivering 50 gpm can be utilized. The pumps are 1.5 HP, 1150 RPM units in a lead lag configuration which operate on a timer and alternated each cycle. The pumps can be used to drain either of the dual chlorine contact chambers should maintenance be required.

The thickened solids underflow from the gravity thickener is pumped using two new progressive cavity sludge pumps to the new aerobic digester. The new sludge pumps are 1.5 HP, 210 RPM units in a lead lag configuration which operate on a timer and alternate on cycle.

The effluent overflow from the gravity thickener flows by gravity back to the primary clarifiers.

The new aerobic digester was sized for a solids loading of 0.1 lb. volatile solids/cu.ft./day. This results in a 20 foot diameter unit with a 15 foot side water depth.

This corresponds to a 40 day hydraulic detention time for sludge stabilization. The oxygen requirement, based on 1.5 lb.  $0_2$ /lb BOD<sub>5</sub> reduced is 700 lbs./day. This requirement can be met with



## III. PROPOSED FACILITY EXPANSION


## A. General

1. Proposed Expansion - Contd

two 15 HP, 300 cfm air blowers each capable of 100 percent capacity. The air blowers will be arranged in a lead Tag configuration and alternated daily. This arrangement will provide reliability should one of the blowers require maintenance. Periodically the blower is to be turned off and the solids allowed to settle. It is then possible to decant off the supernate and return it by gravity to the primary clarifiers. Also, with the blower off, solids can be wasted from the digester underflow, by gravity, to the sludge drying beds. Assuming 40 percent of solids are oxidized completely, sludge should be wasted to one of the three existing sludge drying beds once every 15 days.

There is no additional sludge drying bed area required.

- 2. Deviation of Proposed Expanded Plant with DM-5
  - a. Primary Clarifiers no deviation with DM-5
  - b. Trickling Filters no deviation with DM-5
  - c. Secondary Clarifiers no deviation of new clarifier. Existing unit is overloaded at 24 hour maximum flow with the new clarifier off line the overflow rate is 2,540 gpd/ sq.ft.
  - d. Chlorine Contact Chamber 30 minute detention time. Longer contact time is required to protect shellfish beds.
  - e. Chlorination Equipment no deviation with DM-5
  - f. Primary Clarifiers and Gravity Thickener Sludge Pumps estimate is based on progressive cavity pumps in dry wells. DM-5 recommends plunger pumps in dry well. Progressive cavity pumps are proposed because of reliability and low maintenance costs.
  - g. Gravity Thickener only one unit is proposed. If unit should require maintenance sludge can be wasted directly to the aerobic digester.
  - Aerobic Digester DM-5 recommends anerobic digestion for primary or mixed sludges. Aerobic digestion is proposed because of operational reliability, low capital costs, and low maintenance costs.



J. E. SIRRINE COMPANY


Î

1

ł

# III. PROPOSED FACILITY EXPANSION


- A. General
  - 2. Deviation of proposed Expanded Plant with DM-5 Contd
    - i. Sludge Drying Beds no deviation with DM-5
    - j. Effluent Recirculation Pumps no deviation with DM-5.



A

-<u>SECTION 400</u>-STEAM GENERATION AND DISTRIBUTION SYSTEM A UTILITY STUDY FOR

THE COURTHOUSE BAY AREA



# TABLE OF CONTENTS

J. E. SIRRINE COMPANY

4

1

1

Ι.	DET	ERMINATION OF ADEQUACY OF STEAM GENERATING PLANT	Page 1
	Α.	Boilers	1
	Β.	Fuel Oil System	1
	с.	Feedwater System	1
	D.	Plant Deficiencies	1
	Ε.	Existing Steam Demand	2
	F.	Steam Demands For New Construction	2
	G.	Additional Steam Generation Required For New Construction	2
п.	DET	ERMINATION OF ADEQUACY OF THE STEAM DISTRIBUTION SYSTEM	3
	Α.	Existing Steam Distribution System	3
	Β.	Individual Steam Demands	3
	с.	Pipe Sizing	3
	D.	Pressure Drop	4
	Ε.	Minimum Pressure	4
	F.	Proposed New Construction	4
	G.	Proposed New Steam Mains	4
	н.	Deficiencies	4
III.	REC	COMMENDATIONS FOR STEAM DISTRIBUTION SYSTEM	5
	Α.	Steam Distribution	5
IV.	EXH	IBITS	

Exhibit "L" - Existing Steam Distribution Exhibit "M" - Proposed Steam Distribution





TABLE OF CONTENTS - (Continued)

J. E. SIRRINE COMPANY

4

- V. APPENDICES (Continued)
  - Appendix IV 1. References
    - 2. Boiler House Information
    - 3. Building Steam Requirements
    - 4. Steam Line Distribution Pressure Losses
    - 5. Alternatives Cost Estimates



## I. DETERMINATION OF ADEQUACY OF STEAM GENERATING PLANT, BUILDING NO. BB-9

A. Boilers (Note: PPH is pounds per hour)

Boiler No.	Year <u>Built</u>	Mfgr.	Design PSIG	Design Capacity, PPH	Actual Capacity, PPH
55	1957	Erie City	160	12,000	10,000
54	1952	Orr-Sembower	Unknown	12,075	8,000
53	1978	Nebraska	200	15,000	15,000

Total Actual Capacity: 33,000 PPH

# B. Fuel Oil System


Type Fuel Oil: No. 6 Fuel Oil List of Tanks and Capacities: 3 @ 10,000 Total Tank Capacity: 30,000 gal; usable tank capacity: 24,000 gal.

#### C. Feedwater System

Deaerating feedwater heater: 45,000 PPH, Cochrane (1962), adequate. Percent of condensate returned: 33 to 40% in winter; 50% in summer. Type and condition of softeners: Zeolite, Hungerford-Terry, adequate. Ability of deaerator to hold dissolved oxygen below .005 cc/liter: satisfactory.

## D. Plant Deficiencies

- 1. The new fuel oil pump-heater unit is of adequate capacity; however, in its present location, the long suction line from the storage tanks at times has caused the pump to lose suction and has required temporary changeover to the old fuel oil pump having the day-tank suction connection. This has occurred even with the fuel oil tank half full.
- 2. Two feedwater pumps are reported to be in need of replacement. The third pump is new.
- 3. The existing fuel oil storage capacity necessitates delivery of fuel oil twice a week during the coldest winter months. Additional storage capacity is outlined in I.G.6.
- 4. At present, there is a single pump (with no spare) for transferring condensate from the reciever up to the deaerating feedwater heater. If a breakdown of the single pump occurs, it becomes necessary to waste the condensate and to feed make-up water to the feedwater heater. Spare parts are not readily available for the existing pump.
- 5. There are orifices in the two 6" mains serving the distribution system, but no meters. The present meters record flow from each boiler. Additional meters would indicate the net export steam.



J. E. SIRRINE COMPANY

- I. <u>DETERMINATION OF ADEQUACY OF STEAM GENERATING PLANT, BUILDING NO. BB-9</u> (Continued)
  - 6. The insulation in the plant is in need of repair.
  - E. Existing Steam Demand

24,400 PPH peak generation during extreme winter weather (Jan. 1978) -2,928 PPH required for in-plant use (12% for deaerator, etc.) 21,472 PPH net export steam leaving plant -2,147 PPH distribution losses = 10% of demand 19,325 PPH actual peak demand of facilities, with diversity

F. <u>Steam Demands For New Construction</u>: (Individual demands are interpolated from definitive designs, or from existing facilities.)

Project No.	Facility	PPH Individual Demands	PPH 80% Demands
P-613	BEQ (3)	5043	4035
U.P.	PX	1000 (Estimated)	800
U.P.	Bldg. 48	967	774 805
U.P.	Bldg. 49	1006	
U.P.	BEQ (2)	3362	2690
	*Barracks	(7940)	(6352)
		3438	2752

Sum of individual demand: 34

3438 PPH


\* To be removed upon completion of new BEQ (3)

## G. Additional Steam Generation Required For New Construction

- 1. None required.
- 2. The excess generation available:

Excess generation, PPH = (Total actual capacity (I.A)) - (Existing peak generation (I.E)) = 33,000 - 24,400 = 8,600 PPH

- Some of the excess generation is required to meet the projected new construction; however, no new boilers are required at the present time.
- 4. A deficiency in steam generation capacity does not exist.
- 5. A deficiency in auxiliary equipment capacity does not exist.



|--|

- I. <u>DETERMINATION OF ADEQUACY OF STEAM GENERATING PLANT, BUILDING NO. BB-9</u> (Continued)
  - 6. Provision for 30 days of fuel oil storage, based on the coldest period of the year.

85,576 gal. oil used, January 1977 (maximum) 24,000 gal. usable existing tank capacity 61,576 gal. additional usable storage required 3- 25,000 gal. tanks = 60,000 gal. additional usable storage

- 7. Not applicable.
- 8. Consideration of whether a coal-burning capability is required.

Conversion to coal-burning

- (a) Boiler No. 55, Erie City (1957) water tube package boiler, is only unit that could be converted to stoker firing. Other units are limited to oil or gas firing.
- (b) There is insufficient space in present plant for coal storage and handling, and ash handling and storage.
- (c) An entire new site and plant would be required, designed for coal-burning and should include fly-ash removal.
- (d) Conversion to coal-burning accordingly is not recommended.

## II. DETERMINATION OF ADEQUACY OF THE STEAM DISTRIBUTION SYSTEM

A. Existing Steam Distribution System

Exhibit L shows plan of the existing steam distribution system at a scale of 1" = 200'. The plan shows all facilities served, building numbers, pipe sizes, and steam demand of each facility (in PPH). Proposed new construction is shown on Exhibit M with corresponding steam demands. The required steam utilization pressure (in PPH) is shown for each facility, using a combination number to show the demand and required pressure.


B. Individual Steam Demands

Each major branch, and trunkline, are marked to show the individual steam demands and to show the actual demands with 80% diversity.

C. Pipe Sizing

Based on the DM-3 steam-flow nomographs, the carrying capacities of each size pipe have been listed, using the optimum pressure drop as follows:

> 0.4 psi per 100' for pressures from 23 to 37 psig 0.5 psi per 100' for pressures from 40 to 75 psig 1.0 psi per 100' for pressures from 75 to 125 psig 1.0 psi per 100' for pressures from 127 to 180 psig



## II. DETERMINATION OF ADEQUACY OF THE STEAM DISTRIBUTION SYSTEM (Continued)

# D. Pressure Drop

Starting at the steam plant, and working toward the outlying facilities, each segment of piping has been evaluated for pressure drop. The calculated steam pressures are indicated for the mains, based on data from paragraph II.C and the DM-3 nomographs.

#### E. Minimum Pressure

The entire run of pipe has been determined satisfactory since it can deliver the diversified demand, with sufficient residual pressure; at least 15 PSI minimum above the required utilization pressure in each facility served.

# F. Proposed New Construction


Future projected demands are shown on Exhibit M, as listed in paragraph I.F, and the piping system has been checked for adequacy in meeting these demands.

#### G. Proposed New Steam Mains

Proposed mains to serve the new construction are shown on Exhibit M. There is no other forecasted extension of main trunklines.

# H. Deficiencies

- 1. Overhead condensate piping, between Boiler Plant BB-26 and Building BB-9, is now developing leaks from pitting. Sections of pipe have been repaired or replaced.
- 2. Steam is now being wasted (without return to system) at the wash rack near Building BB-52. A steam jenny could be provided for this purpose and the use of boiler steam be discontinued.
- 3. Existing 2" condensate line and underground conduit, from overhead steam condensate main to Building BB-50, is reported to be in need of replacement.
- 4. Three drips for the overhead distribution system serving BEQ Nos. 250 and 255, now discharge into dry wells, thus wasting condensate, instead of discharging into the pumped return condensate system. The present trap discharge pipes have, at times, frozen at ground level, stopping flow and backing up condensate in the steam mains.
- 5. Condensate from Building BB-16 is presently wasted instead of being collected and pumped back into the condensate return main.




A

i b

#### III. RECOMMENDATIONS FOR STEAM DISTRIBUTION SYSTEM

# A. Steam Distribution

Exhibit M shows a proposed overhead steam and condensate return system starting at the existing 6" - 3" overhead system at station 7+96 and continuing to the three BEQs, routed to clear the existing water treatment plant and parking areas. This is the system recommended. Connection into existing mains would be at one point and the new piping could be completed and hydraulically tested prior to the cut-in. An Alternate system is also shown on Exhibit M starting near the end of the existing 6" - 3" overhead system. This requires replacing the existing 4" - 2" overhead mains to the connection point of the branch line to BEQ-250. From this location, a new overhead system would extend to the three BEQs. This Alternate system is complicated in having to maintain steam for the existing buildings during installation of the larger mains on the existing poles; also there is a possibility of overloading the poles during construction. Adequate testing of the new mains and possible long periods of outage are other difficulties with the Alternate system. Therefore, the first proposed system is recommended, and it is estimated that the cost will be less than the Alternate (see the mechanical calculations in the Appendix).




A

1

1

-SECTION 500-COST ESTIMATE A UTILITY STUDY FOR

THE COURTHOUSE BAY AREA



15 February 1979

# BASES OF CONTRACTOR MARKUPS

#### USED IN THIS COST ESTIMATE

A single markup of 29 percent was used for all work performed by the General Contractor and 49 percent for all work performed by Subcontractors. These markup percentages were based on 44 percent of the ECC being labor and 56 percent being materials.

The markups used include the following:

GENERAL CONTRACT WORK; markup= 29 %

4

•

•

J. E. SIRRINE COMPANY

A.	Ins. & Tax on Labor	20	%								
Β.	Sales Tax on Material	4	%								
с.	General Contr. OH&P	15	%	=	5	%	OH	+	10	%	Ρ
D.	Bond	1	%								

Formula –  $A \times B \times C \times D = Markup$ 

 $1.088 \times 1.022 \times 1.15 \times 1.01 = 1.289$  or 29 %

SUBCONTRACT WORK ; markup = 49 %


Α.	Ins. & Tax on Labor	20	%							
Β.	Sales Tax on Material	4	%							
с.	Subcontractor OH&P	25	%	=	10%	OH	+	15	%	Ρ
D.	General Contractor Profit	6	%							
Ε.	Bond	1	%							

Formula –  $A \times B \times C \times D \times E = Markup$ 

 $1.088 \times 1.022 \times 1.25 \times 1.06 \times 1.01 = 1.488$  or 49 %

The 1.088 represents 44 percent of the Ins. Tax on Labor, and the 1.022 represents 56 percent of the Sales Tax on Materials.

Since this is a study and the design is not complete enough to do an accurate material takeoff a contingency of 10 percent has been added in at the end of each takeoff.




				SI	IEET 1 OF 47
Estimate of Contract Cost for Contrac Utility Study Title & Location <u>MCB</u> , Camp Leje	C-		C-3675 e Bay Area		<u>TYPE OF ESTIMATE</u> No Design Prelim Fine) (A)(B)(C)_X
J. E. Sirrine			ille S.C	Estimator	J. E. Sirrine Co.
Date Prepared Jan. 31, 1979 Esc					<u> </u>
Contractors		1.	,		
is%	of	project	SYS.OUAN.	COST/SYSTEM	TOTAL COST
EXISTING WELLS					· · · · · · · · · · · · · · · · · · ·
	ShSh	2	_ <u>L.s</u>		\$ 11,800
NEW WELL	Sh	5	_L.S		147,100
WATER DISTRIBUTION SYSTEM	Sh	11	12	606.63	7,300
SAN. SEWER COLL. SYSTEM	STr	ist when the			7,500
	Sh	13	1,355	33.09	. 44,800
CLEAN OF SAN.SEW. COLL. SYSTE	M ShSh	15	9,200	5.33	49,100
SAN. SEW. LIFT STATION	Sh_				
(COURTHOUSE BAY AREA)	_Sh_	17	L.S.		21,900
SAN. SEW. LIFT STATION	Sh `Sh				
(AMTRAC AREA)		20	L.S.		7,500
WATER TREAT. PLANT	ShSh	22	1000 0 5	491.07	639,600
the second s	Sh		1280 S.F.	491.07	628,600
WASTEWATER TREATMENT PLANT	Sh	34	153000 GAL	6.59	1,007,800
	_Sh				
	Sh_				
	_5h_				
	_ShSh		e en landered.		·
	Sh_			·	
- f	ish				
	Sh				
	Sh ·				
		<u></u>			
	Sh_				······
	_Sh				
			· · ·		
성원이 김 결혼합니? 말을 날			Bose Bid	Item a.	\$ 1,925,900
한 것이 같은 것을 알았다. 방법을 했다.				Item b.	
Total Estimated Contract C	Cost		B Additive	Item c. Bose Bid.	\$ 1,925,900
	r÷.		Additive		

TOTAL ESTIMATED CONTRACT COST

\$ 1,925,900


Additive Item 3. Additive Item 4.




•					
	SHEET_	2	OF	47	

CTIVITY & LOCATION: MCB &E FIRM & ADDRESS: J. E. P. O.	Sirrine Box 545	Comp.	any	CONST.	CONTRAC	T A	0. N6:	2470-78-
	ville, S							3675
PRELIMINARY ESTIMATE ( )			ESTIMAT	E ( )			L EST	IMATE (x
HEADING EXISTING WELLS	1		MATOR	COX	CHECK	DU	TTON	
SUMMARY MATERIAL DESCRIPTION	NO. UNITS	UNIT	PERI	TOTAL	PER UNIT	TERIAL TOTAL		TOTAL
EQUIPMENT	· _	LS	-	_	-	_	\$	10,200
ELECTRICAL	-	LS	-	-	-	-		1,000
SUBTOTAL								11,200
SIOH	5.5%							616
TOTAL	-	LS	-	-	-			11,816
								a series
	La la la	14 - 1994 - 20 - 10			14.57	e dad gå je Liden og Ag		
	- A Kas							
							-	
					1			

....



ROJECT TITLE: Utility St	udy - C	ourth	ouse Baj	y Area	DA'	TE PREPARE	N Jan. 31, 19
CTIVITY & LOCATION: MCB,						1 ko 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
		1.1					
	Sirrine Box 545 Mille, S	6		CONST. NO.	CONTRAU	CT A&I NO	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	١	FINAL	ESTIMAT	Е()	REV	ISED FINAL	ESTIMATE (x)
HEADING EXISTING WELLS		ESTI	IMATOR	DUTTON			DX
EQUIPMENT	QUANTI			ABOR		TERIAL	
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
WELL NO. BB-220	·						
VERTICAL TURBINE							
PUMP STAGE	2	EA	350.	700	250.	500	\$ 1,200
REPLACE EXIST. MOTOR		ļ!					
W/MOTOR FROM WELL		ļ!					Ĺ
NO. BB-221	1	EA	400.	-		-	400
WELL NO. BB-221							
VERTICAL TURBINE							
PUMP STAGE	1	EA	650.	650	250.	250	900
REPLACE EXIST.							
PUMP IMPELLERS	4	EA	100.	400	150.	600	1,000
15 H.P. VERT. MOTOR	1	EA	400.	400	1700.	1,700	2,100
SUB-TOTAL							5,600
CONTRACTOR MARK-UP	49%						2,744
SUB-TOTAL							8,344
CONTINGENCY	10%			1			834
SUB-TOTAL							9,178
ESCALATION TO 1-1-80	11%						1,010
SUB-TOTAL							10,188
TOTAL							10,200



SHEET 4 OF 47

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND

PROJECT TITLE: Utility Study - Courthouse Bay Area

DATE PREPARED Jan. 31, 1979


ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C.

A&E FIRM & ADDRESS: J. E. Sirrine Company P. O. Box 5456 Greenville, S.C. 29606

CONST. CONTRACT NO.


A&E CONTRACT NO. N62470-78-C-3675

HEADING EXISTING WELLS	e	ESTI	MATOR	сох	CHECK	ED BY CUT	TON	
ELECTRICAL	QUANTI		the second se	BOR		TERIAL		
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST	
WELL NO. BB-220	•							
3P, 70A BREAKER	1	EA	11.	11	37.	37 \$	48	
SIZE 2, 3P, STARTER	1	EA	20.	20	81.	81	101	
REMOVING EXIST. BREAKER	1	EA	11.	11	-	-	11	
REMOVING EXIST. STARTER	1	EA	20.	20	-	-	20	
Kao kao aminina dia mampina								
WELL NO. BB-221		1 6						
3P, 100A BREAKER	1	EA	15.	15	41.	41	56	
SIZE 3, 3P STARTER	1	EA	30.	30	135.	135	165	
REMOVING EXIST. BREAKER	1	EA	15.	15	-	-	15	
REMOVING EXIST. STARTER	1	EA	30.	30	-	-	. 30	
REMOVE EXIST. CONDUIT & W	IRE 30	LF	.60	18	-	-	18	
1/c #6 THW	100	LF	.09	9	.13	13	22	
1/c #8 THW	35	LF	.07	2	.11	4	6	
1"C	25	LF	.95	24	.70	18	41	
SUB-TOTAL			1.3			1997 - B	533	
CONTRACTOR MARK-UP	49%						262	
SUB-TOTAL							795	
CONTINGENCY	10%						80	
SUB-TOTAL							875	
ESCALATION TO 1-1-80	11%	2.07					96	
TOTAL	-			8 0			1,000	




ATLANTIC DIVISION - NAVAL	FACILIT	IES E	NGINEE	RING COMMAN	1D		
ROJECT TITLE: Utility S	tudy - C	ourthe	ouse B	ay Area	DA1	TE PREPAR	ED Jan. 31, 1
CTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N.	с.			
	Sirrine Box 545 ville, S	6		CONST. NO.	CONTRAC	CT A	&E CONTRACT D. N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	I		the state of the s	ATE ()	REV	ISED FINA	L ESTIMATE (X
HEADING NEW WELL		ESTI	MATOR	сох	CHECK	ED BY DU	JTTON
SUMMARY	QUANT		and the second se	LABOR		TERIAL	TOTAL
MATERIAL DESCRIPTION	UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
CIVIL	· -	LS	-	-	-		\$ 56,500
STRUCTURAL	96	SF	0	30.21 L&M		-	2,900
EQUIPMENT & PIPING		LS	-	-	-	-	74,700
ELECTRICAL		LS		-	-	-	5,300
SUB-TOTAL							139,400
SIOH	5.5%						7,667
TOTAL	-	LS	-	-	-	-	147,067
		8.12					
	1						
	an sing i				1.2.6.1		
	1000	1					
		1					
							L

۰.




SHEET	6	OF	47
SULLI	U	UI	41

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. N62470-78-NO. Greenville, S.C. 29606 C-3675 45 PRELIMINARY ESTIMATE ( ) FINAL ESTIMATE ( ) REVISED FINAL ESTIMATE (x) ESTIMATOR COX HEADING CHECKED BY NEW WELL DUTTON OUANTITY LABOR MATERIAL CIVIL NO. UNIT PER PFR TOTAL MATERIAL DESCRIPTION UNITS MEAS. UNIT TOTAL UNIT TOTAL COST **CLEARING & GRUBBING** TREES TO 6"DIA.CUT & CHIPS .10 AC 507. 50 456. 45 \$ 95 GRUB STUMPS & REMOVE .10 AC 93 10 305. 30 40 TOPSOIL: STRIPPING & STOCK PILING 120 CY .40 50 70 .60 120 SPREADING 120 CY .50 70 60 .60 130 **GRADING:** EXCAVATION 100 CY .25 25 .35 35 60 ON SITE FILL CY 100 .90 90 1.00 90 180 COMPACTION 100 CY .75 75 .25 25 100 SEEDING: AROUND BLDG. FINE GRADING & SEEDING INCL. LIME, FERTILIZER W/EQUIPMENT 400 165 SY .41 .17 70 235 18"ØRCP CL III W/GASKETS 28 LF 2.54 70 5.80 160 230 TRENCH EXCAVATION 10 CY .85 10 .90 10 20 **BACK & COMPACTION** 10 CY .75 .25 5 10 15 STONE DRIVEWAY 4" CRUSHED STONE 126 SY .54 70 1.15 145 215 PREPARE & ROLL BASE 126 SY .33 40 --40 6"ø CIP CL 250 60 LF 1.73 105 6.80 410 515 8"ø CIP CL 250 2.000 LF 2.66 5,320 7.90 15,800 21,120 TRENCH EXCAVATION .85 2,000 CY 1,700 .95 1,900 3,600 BACKFILL & COMPACTION 2,000 CY .75 1,500 ,25 500 2,000 SEEDING: ALONG PIPE LINE FINE GRADING & SEEDING 3,300 SY .40 1,320 .17 560 1,880




ROJECT TITLE: Utility St					DAT	E PREPAREI	Jan. 31, 1
CTIVITY & LOCATION: MCB			the second s				
&E FIRM & ADDRESS: J. E. P. D. Greenv	Sirrine Box 545 ville, S	Compa 6 .C. 29	any 9606	CONST. NO.	CONTRAC	CT A&I NO	CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	FINAL ESTIMATE ( )			REVISED FINAL ESTIMATE (x			
HEADING NEW WELL	ESTIMATOR			CHECKED BY DUTTON			
		QUANTITY LABOR			MATERIAL		
CIVIL MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
6"ø GATE VALVE & BOX	. 1	EA	75.	75	225.	225	\$ 30
CONC. THRUST BLOCK	3	EA	10.	30	40.	120	150
SUB-TOTAL							31,04
CONTRACTOR MARK-UP	49%						15,212
SUB-TOTAL							46,25
CONTINGENCY	10%						4,62
SUB-TOTAL							50,88
ESCALATION TO 1-1-80	11%					A.	5,59
SUB-TOTAL	er y hade ters						56,48
TOTAL				<u></u>			56,50
					1.1.1		


I



B, Camp L	ejeune	e, N. C	•			<u></u>
. Box 545	6		CONST. NO.	CONTRAC	CT A&E NO.	CONTRACT N62470-78- C-3675
) F	INAL	ESTIMA	TE ( )	REV	ISED FINAL	ESTIMATE (X
	ESTI	MATOR	MVFDS	CHECK	ED BY DU	TTON
OUANTI	TY			MA		TION
NO.	UNIT	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
			1. 1. A.			
96	SF	.63	60	,63	60	\$ 120
320	SF	.95	305	1.00	320	625
100	SF	.95	. 95	1.05	105	200
150	ĻF	.27	40	1.27	190	230
. 8	CY	40.	320	40.	320	640
		1000 M				1,815
29%						526
						2,341
10%						234
				-		2,575
11%						283
		· · ·				2,858
						2,900
96	SF	0	30.21 L&M	=		2,900
		1				
	1	1		1		
	. Sirrine . Box 545 nville, S ) F QUANTI NO. UNITS 96 320 100 150 8 29% 10% 10%	. Sirrine Compa . Box 5456 nville, S.C. 29 ) FINAL QUANTITY NO. UNIT UNITS MEAS. 96 SF 320 SF 320 SF 100 SF 150 LF 8 CY 29% 10% 10%	. Sirrine Company . Box 5456 nville, S.C. 29606 ) FINAL ESTIMA QUANTITY L NO. UNIT PER UNITS MEAS. UNIT 96 SF .63 320 SF .95 100 SF .95 100 SF .95 150 LF .27 8 CY 40. 29% 10% 10%	. Box 5456 NO. nville, S.C. 29606 FINAL ESTIMATE () ESTIMATOR MYERS QUANTITY LABOR NO. UNIT PER UNITS MEAS. UNIT TOTAL 96 SF .63 60 320 SF .95 305 100 SF .95 95 150 LF .27 40 8 CY 40. 320 29% 10% 10% 11%	. Sirrine Company Box 5456 nville, S.C. 29606 FINAL ESTIMATE () REV ESTIMATOR MYERS QUANTITY LABOR MA NO. UNIT PER UNITS MEAS. UNIT TOTAL UNIT 96 SF .63 60 .63 320 SF .95 305 1.00 100 SF .95 95 1.05 150 LF .27 40 1.27 8 CY 40. 320 40. 29% 10% 10% 11%	. Sirrine Company       CONST. CONTRACT       A&E         . Box 5456       NO.       NO.       NO.         nville, S.C. 29606       FINAL ESTIMATE ()       REVISED FINAL         ESTIMATOR       MYERS       CHECKED BY       DU         QUANTITY       LABOR       MATERIAL       DU         QUANTITY       LABOR       MATERIAL       DU         NO.       UNIT       TOTAL       PER       UNIT         96       SF       .63       60       .63       60         320       SF       .95       305       1.00       320         100       SF       .95       95       1.05       105         100       SF       .95       95       1.05       105         29%



SHEET 9 OF 47 ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT NO. N62470-78-P. O. Box 5456 NO. C-3675 Greenville, S.C. 29606 REVISED FINAL ESTIMATE (x) FINAL ESTIMATE ( ) PRELIMINARY ESTIMATE () CHECKED BY ESTIMATOR HEADING DUTTON COX NEW WELL EOUIPMENT AND MATERIAL OUANTITY LABOR PIPING TOTAL PER NO. UNIT PER COST TOTAL UNITS MEAS. UNIT TOTAL UNIT MATERIAL DESCRIPTION 3/4"ø SCH. 40 STEEL 10 .80 5 \$ 15 5 LF 1.82 **ON HANGERS** 10 5.10 25 35 4"ø CIP 5 LF 1.58 255 1 EA 75. 75 180. 180 6"ø CK. VALVE 205 280 EA 75. 75 205. 1 6"ø GATE VALVE 1 EA 50. 50 160. 160 210 4"ø GATE VALVE 12,500 25,000 L.S. 12,500 WELL BORING 1,700 7000. 7,200 5,500 200. PUMP & MOTOR 1 EA 25 50. 50 75 3/4" Ø AIR RELEASE VALVE 1 EA 25. 8,000 L.S 4,000 4,000 PILOT HOLE 41,070 SUB-TOTAL 20,124 49% CONTRACTOR MARK-UP 61,194 SUB-TOTAL 6,119 10% CONTINGENCY 67,313 SUB -TOTAL 7,404 ESCALATION TO 1-1-80 11% 74,717 SUB-TOTAL TOTAL 74,700 Well boring price from Mr. Lee McCown, with Sydnor Hydro Dynamic, Oct. 25, 1978 (See enclosed Tele. Con.)



LOCA	LL.D	X PLACED	X REC'D	DATE October 25, 1978
	Lonnie Dutton			Mr. Lee McCown
0F	Sydnor Hydro Dy	namic	ON SIRR	INE JOB NO. A-1086
Ut	ility Study for	Courthouse Ba	y, Camp Lejeune,	, North Carolina

The writer asked Mr. McCown for estimated cost for the following items:

A. Pilot hole 10"ø at a depth of 200 feet with a series of electrical logs.

Price: \$8,000 (this figure includes mobilization)

B. Drilling a well to a depth of 200 feet, with 40 feet of 18"ø outer casing and 8"ø inner casing.
 Price: \$25,000

T. Lonnie Dutton Civil Department


TLD:es

S. E. SIRRINE COMPANY


1

1


1



SHEET 10 OF 47 ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. NO. N62470-78-Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE () FINAL ESTIMATE () REVISED FINAL ESTIMATE (x) ESTIMATOR TCF HEADING CHECKED BY NEW WELL BRUNS OUANTITY LABOR MATERIAL ELECTRICAL NO. UNIT PER PFR TOTAL MATERIAL DESCRIPTION UNITS MEAS. TOTAL UNIT TOTAL UNIT COST 10 KVA, 120/208V TRANSF 3 EA 75. 225 300. 900 \$ 1,125 100A PANEL MDP 1 EA 150. 150 275. 275 425 SIZE 2 STARTER 1 25. FA 25 85. 85 110 **#1 DIRECT BURIAL CABLE** 820 LF .27 221 .52 426 647 4" PVC DUCT 20 LF .85 17 1.75 35 52 2" RIGID STEEL CONDUIT 30 LF 1.90 57 1.25 37 94 **1 POLE SWITCH** 2 3 2.00 1 EA 3.00 5 **3 W DUPLEX RECPT** 1 EA 3.00 3 2.00 5 200 #8 THW 30 LF .13 4 .10 3 7 3/4" RIGID CONDUIT 30 LF 1.05 31 .44 13 44 1" RIGID CONDUIT 25 LF 1.25 31 .60 15 46 1/c #12 THW 350 LF .10 35 .04 14 49 LIGHT FIXTURE 12. 1 EA 12 15. 15 27 MOTOR CONNECTION 1 EA 15. 15 12. 12 27 DITCHING, BACKFILL, 205 LF 1.30 266 . 266 COMPACTION FOR DIRECT BURIAL CABLE SUB-TOTAL 2.929 CONTRACTOR MARK UP 49% 1,435 SUB-TOTAL 4,364 CONTINGENCY 10% 436 SUB-TOTAL 4,800 ESCALATION TO 1-1-80 11% 528 SUB-TOTAL 5,328 TOTAL 5,300



PROJECT TITLE: Utility St	udy - C	ourth	ouse Ba	y Area	DA <sup>-</sup>	TE PREPARE	D Jan. 31
ACTIVITY & LOCATION: MCB,	Camp L	ejeun	e, N. C	•			
	Sirrine Box 545 Mille, S	6		CONST. NO.	CONTRA	CT A8 NC	&E CONTRAC D. N62470- C-3675
PRELIMINARY ESTIMATE ( )	<b>F</b>	INAL	ESTIMAT	re ( )	REV	ISED FINA	L ESTIMATE
HEADING WATER DISTRIBUTI	ON	ESTI	MATOR	DUTTON	CHECK	ED BY COX	<b>(</b>
SUMMARY	QUANTI			ABOR		TERIAL	Torn
MATERIAL DESCRIPTION	UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
LEAKAGE TEST, SUB-TOTAL	. 12	EA	0	575	=		\$ 6,
SIOH	5.5%						
TOTAL	12	EA	0	606.63			7,
							<u> </u>
							1
이 지지 않는 것을 가지 않는 것							



ROJECT TITLE: <u>Utility S</u> CTIVITY & LOCATION: MCB					DAT	E PREPAREL	Jan	<u>. 31,</u> 1
&E FIRM & ADDRESS: J. E.	Sirrine	Compa	any		CONTRAC	CT A&E NO.	CONT N624 C-36	TRACT 70-78- 75
RELIMINARY ESTIMATE ( )	F	INAL	ESTIMAT	Ε()	REV	ISED FINAL	ESTI	MATE (x
HEADING WATER DISTRIBU SYSTEM	TION	ESTI	MATOR	UTTON	CHECK	ED BY COX		
LEAKAGE TEST	QUANTI		LA	BOR	and the second se	TERIAL		
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	C T	OTAL OST
LEAK TEST ON								
DISTRIBUTION LINES	12	EA	300.	3,600	100.	1,200	\$	4,800
	1							
SUB-TOTAL								4,800
CONTRACTOR MARK UP	29%							1,392
SUB TOTAL	· ·							6,192
ESCALATION TO 1-1-80	11%			1000				683
SUB TOTAL								6,873
TOTAL							\$	6,90
		1						
				s geograf				
	1.1							
		-						
			128					
		de l'acti	1999 - C. 1		121,23	and the factor		<u> </u>

þ

-


I

1

1


•

1



					SH	EET 13 0	F47
TLANTIC DIVISION - NAVAL	FACILIT	IES E	NGINEE	RING COMMA	ND		
ROJECT TITLE: Utility S	tudy - C	ourth	ouse B	ay Area	DA	TE PREPARE	D_Jan. 31, 19
CTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. (	с.			
&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 ville, S	6		CONST. NO.	CONTRA	CT A8 NO	E CONTRACT N62470-78- C-3675
RELIMINARY ESTIMATE ( )		INAL.	ESTIMA	TE ( )	REV	ISED FINAL	ESTIMATE (X)
HEADING SANITARY SEWER ( TOR SYSTEM	COLLEC-	ESTI	MATOR	COX	CHECK	ED BY	UTTON
SUMMARY	QUANT NO.		Contract of the second s	ABOR		TERIAL	
MATERIAL DESCRIPTION		MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	COST
CIVIL SUB-TOTAL	1,355	LF	0	31.37	=		\$ 42,500
біон	5.5%						2,338
TOTAL	1,355	LF	0	33.09			44,838
			and and a				
	10000						
•							
· · · · · · · · · · · · · · · · · · ·							
		1.3					
	1.1.1.1						
							10 10 July # 2 4

.



SHEET 14 OF 47

ACTIVITY & LOCATION: MCB, A&E FIRM & ADDRESS: J. E. P. O. Greenv		Compa 6	any		CONTRAC	T A& NO	E CONT . N624 C-36	TRACT 70-78-
PRELIMINARY ESTIMATE ( )				TE ( )	REVI	ISED FINAL	and and a set	
HEADING SANITARY SEWER			MATOR	DUTTON	CHECKE	ED BY		
TOR SYSTEM	QUANTI	ITY		ABOR	MAT	COX TERIAL	F T	
MATERIAL DESCRIPTION	NO.	IUNIT	PER	TOTAL	PERUNIT	TOTAL	T( C(	OTAL OST
10" ø P.V.C.	1,355	LF	1,50	2,035	3,95	5,350	\$	7,385
TRENCH EXCAVATION	3,970	CY	.85	3,375	.95	3,770		7,145
BACKFILL & COMPACTION	3,970	CY	.75	2,980	.25	995		3,975
SAN. SEWER MANHOLES								
STD 4' ø (10-12)	3	EA	275.	825	380.	1,140		1,965
FRAME & COVER	3	EA	30.	90	100.	300		390
TIE INTO EXIST. M.H. & REFORMING M.H. BOTTOMS SEEDING INCL. LIME &	2	EA	250.	500	150.	300		800
FERTILIZER W/EQUIP	3,010	SY	.40	1,205	.17	510		1,715
SUB TOTAL								23,375
CONTRACTOR MARKUP	49%							11,454
SUB TOTAL								34,829
CONTINGENCY	10%							3,483
SUB TOTAL								38,312
ESCALATION TO 1-1-80	11%							4,214
SUB TOTAL								42,526
TOTAL								42,500
TOTAL	1,355	LF	0	31.37	=			42,500

-

6


I

1

1

•

I



ROJECT TITLE: Utility S					DAT	E PREPARE	D Jan.	31, 1
CTIVITY & LOCATION: MCB	, Camp L	ejeune	e, N. C					
&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 ville, S	Compa 6 .C. 29	iny 9606	CONST. NO.	CONTRAC	CT A8 NC	E CONT ). N624 C-36	RACT 70-78- 75
PRELIMINARY ESTIMATE ( )	- F	INAL	ESTIMAT	Έ()	REV	ISED FINA	L ESTI	ATE (x
HEADING CLEANING OF SAN SEWER COLLECTOR SYSTEM	ITARY	ESTI	MATOR		CHECK	ED BY	20.22	
and the second	QUANTI	and the second se	L. LA	BOR		TERIAL	I	
SUMMARY MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	T( C(	DTAL DST
LEANING & GROUTING	- 9,200	LF	9	5,05			\$	46,500
SIOH	5.5%							2,558
TOTAL	9,200	LF	0	5.33			\$	49,058
						· · · ·		
	La prime a la	1		C			1	

Ξ

1


•

I

I

-

-




PROJECT TITLE: <u>Utility S</u>		1. 1. 1. 1.			DAT	E PREPARE	D Jan. 31, 1
ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. (				
A&E FIRM & ADDRESS: J. E. 'P. O. Green	Sirrine Box 545 ville, S	Comp. 6 .C. 2	any 9606	CONST. NO.	CONTRAC	T A& NO	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	I	INAL	ESTIMA	TE ( )	REV	ISED FINAL	ESTIMATE (X
HEADING CLEANING OF SAN COLLECTOR SYSTEM	. SEWER	ESTI	MATOR	DUTTON	CHECK	ED BY CO	X
COLLECTOR STSTEP	QUANT			ABOR	TA1	TERIAL	
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
T.V. JOINTS AND	•	Sec. Salt			1.000		
GROUTING 25% OF			ell'armi	e estério de	and the second second		
THE JOINTS	L.S.						\$ 32,500
CONTRACTOR MARKUP	29%					·	9,425
SUB TOTAL							41,925
ESCALATION TO 1-1-80	11%						4,612
SUB TOTAL							46,537
TOTAL	9,200	LF	0	\$5.05		=	\$ 46,500
•							
	- 535 13		12.2				
		10.000					
	1.1.1						
			1.192				
	1 1 1 1						ALC ST ST.

6

I

I

•



## TELEPHONE CALL CONFIRMATION

LOCAL	L.D	Х	PLACED	Х	REC'D		DATE	January	30,	1979
	Lonnie Du	tton		TA	LKED WITH_	Mr.	Bi11	McAndrew		
0F	IcCullough a	nd Ass	ociates		ON SIRR	INE JO	OB NO.	A-1086		
Utilit	ty Study for	Court	house Bay,	Camp	Lejeune, I	Vorth	Carol	ina		

The writer asked Mr. McAndrew for an estimated cost of T.V. joints and grouting 25 percent of the joints on approximately 9200 linear feet of a sanitary sewer collection system.

Mr. McAndrew stated that this work could be accomplished for \$32,500. This price includes mobilization, overhead and profit.

T. Lonnie Daitte


T. Lonnie Dutton Civil Department

TLD:es


4

1

I. E. SIRRINE COMPANY




	C. Carlo		y Alea	UA	TE PREPAR	ED Jai	1. 31
, Camp L	ejeun	e, N. C	•				
Box 545	16		CONST. NO.	CONTRAC	CT A	0. N62	470-
	FINAL	ESTIMA	TE ( )	REV	ISED FINA	L ESTI	MATE
LIFT BAY	ESTI	MATOR	сох	CHECK	ED BY	TTON	
QUANTI			The second se	and the state of t	and and and and and an an and and and an		
UNITS	MEAS.	UNIT	TOTAL	UNIT	TOTAL		OTAL
-	LS	-	- 10	-	-	\$	15,
1	LS	-		-	<u>e e e e</u>	- Andre	5,
				- 40.2		\$	20,8
5.5%							1,
-	LS	-	-	-		\$	21,
						<u> </u>	
							1000 - 1000 1000 - 1000
							<u>.</u>
						1.27	
	Box 545 ville, S LIFT BAY QUANTI NO. UNITS - - 5.5%	Box 5456 ville, S.C. 2 FINAL LIFT ESTI BAY UNITY NO. UNIT UNITS MEAS. - LS - LS 5.5%	Box 5456 ville, S.C. 29606 FINAL ESTIMATOR BAY QUANTITY L/ NO. UNIT PER UNITS MEAS. UNIT - LS - - LS - 5.5%	Box 5456 NO. ville, S.C. 29606 FINAL ESTIMATE () LIFT ESTIMATOR BAY COX QUANTITY LABOR NO. UNIT PER UNITS MEAS. UNIT TOTAL - LS - LS 5.5%	Box 5456     NO.       ville, S.C. 29606       FINAL ESTIMATE ()       REV       LIFT     ESTIMATOR       COX     CHECK       QUANTITY     LABOR       NO.     UNIT       PER     PER       UNITS     MEAS.       UNITS     PER       -     LS       -     LS       -     -       -     -       -     -       -     -       -     -       -     -       -     -       -     -       -     -	Box 5456     NO.       ville, S.C. 29606       FINAL ESTIMATE ()       REVISED FINA       LIFT     ESTIMATOR       BAY     COX       QUANTITY     LABOR       MO.     UNIT       VIIT     PER       UNITS     MEAS.       UNITS     PER       VIIT     TOTAL       UNIT     PER       UNIT     OUANTIT       S.5%     Image: Construct of the second secon	ville, S.C. 29606 C-3 FINAL ESTIMATE () REVISED FINAL ESTI LIFT ESTIMATOR COX CHECKED BY DUTTON QUANTITY LABOR MATERIAL NO. UNIT PER TOTAL UNIT TOTAL - LS \$ - LS \$ 5.5% 5.5%



PROJECT TITLE: Utility St					DA1	TE PREPARE	D Jan. 31, 1
ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. C	•			
	Sirrine Box 545 ville, S	6		CONST. NO.		CT A8 NC	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	Έ()	REV	ISED FINAL	ESTIMATE (x
HEADING SANITARY SEWER L STATION, COURTHOUSE B	IFT AY	ESTI	MATOR	DUTTON	CHECK	ED BY COX	· · · · · · · · · · · · · · · · · · ·
	QUANT			ABOR	and the second se	TERIAL	
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
REPLACE EXISTING PUMPS		100-000	1999	1999			
AND MOTORS WITH TWO 700							
gpm PUMPS WITH 25 H.P.							
MOTORS	L.S.	LS	1600.	1,600	LS	7,510	\$ 9,110
SEE ATTACHED							
CONFIRMATION LETTERS FROM	ENVIRON	MENTA	PRODU	CTS, INC.			
SUB TOTAL							9,110
CONTRACTOR MARKUP	49%						4,464
SUB TOTAL							13,574
ESCALATION TO 1-1-80	11%						1,493
SUB TOTAL		<u> </u>					15,067
TOTAL							\$ 15,100
							the in some
		1	1 1				1

•

..



## WATER AND WASTE WATER EQUIPMENT, SALES AND SERVICE

## ENVIRONMENTAL PRODUCTS, INC

P. O. BOX 2385 • HICKORY, N. C. 28601 • 704/322-7003

December 21, 1978

J. E. Sirrine Company AE Division SCN Bank Building Eighth Floor Greenville, South Carolina 29601

Attention: Mr. Lonnie Dutton

Subject: Fairbanks Morse Sewage Pumps

Dear Lonnie:

The best pump we can offer for conditions of 700 GPM @ 50' and 625 GPM @ 80' is our Fairbanks Morse 4" Figure 5413K with a bladeless impeller.

We can offer a pump that has a steeper curve, but both conditions hit the far left side of the curve. I feel that it would be better to throttle the pump we are recommending.

The cost for two (2) pumps complete with 25 HP motors, motor bases, flexible shafting, shaft guard, etc. is \$7,510.

We are enclosing data covering the equipment recommended. If you need additional information, or if we can be of service at any time, please call on us.

Very truly yours,

ENVIRONMENTAL PRODUCTS, INC.


M. Wilkinson

R. M. Wilkinson Sales Manager

RMW/jk

CC: Kip Lyon

Enclosure:



SHEET 19 OF 47

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND

PROJECT TITLE: Utility Study - Courthouse Bay Area

DATE PREPARED Jan. 31, 1979


ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C.

A&E FIRM & ADDRESS: J. E. Sirrine Company P. O. Box 5456 Greenville, S.C. 29606

CONST. CONTRACT


A&E CONTRACT NO. N62470-78-C-3675

HEADING SANITARY SEWER LI STATION, COURTHOUSE BA	FT Y	ESTI	MATOR	TCF	CHECK	ED BY DUTT	ON
	QUANTI		and the second se	ABOR		TERIAL	La construction de la constructi
ELECTRICAL MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
4" PVC	. 30	LF	.85	25	1.75	52	\$ 77
4" RIGID STEEL CONDUIT	30	LF	2.25	67	4.60	138	205
#410 CABLE, 600V	200	LF	.25	50	.96	192	242
#2 CABLE, 600V	100	LF	.21	21	.33	33	54
100A FUSE SWITCH, 3P	2	EA	25.	50	100.	200	250
SIZE 3 STARTER	2	EA	30.	60	135.	270	330
#4 CABLE, 600V	200	LF	.11	22	.20	40	62
#6 CABLE, 600V	60	LF	.09	5	.13	8	13
1坫" CONDUIT	60	LF	1.28	77	.95	57	134
25KVA POLE TYPE TRANSF	3	EA	35.	105	475.	1,425	1,530
REMOVE EXIST TRANSF'S	3	EA	25.	75			75
REMOVE EXIST FUSE SWITCH	2	EA	20.	40			40
REMOVE EXIST STARTERS	2	EA	20.	40	- 24-		40
REMOVE EXIST CONDUIT & WIR	E 60	LF	.60	36			36
TRENCHING, BACKFILL,	30	LF	1.30	39		•	39
COMPACTION ECT FOR 4" DUCT							
SUB TOTAL							3,127
CONTRACTOR MARKUP	49%						1,532
SUB TOTAL							4,659
CONTINGENCY	10%	i sh					466
SUB TOTAL							5,125
ESCALATION TO 1-1-80	11%						564
SUB TOTAL							5,689
TOTAL							5,700
ALL EQUIP REMOVED TO BE	URNED (	VER T	O GOVE	RNMENT. TI	HE ASSUM	PTION IS M	ADE
THAT THE 2400V PRIMARY POL							C.E. Barage 1



PROJECT TITLE: Utility St	udv - C	ourth	ouse Ba	v Area	DAT	F PREPARE	D Jan	. 31
ACTIVITY & LOCATION: MCB,					U/(			
	Sec.	1.4 See.			001170.0			
A&E FIRM & ADDRESS: J. E. P. O.	Box 545	i6	any	NO.	CONTRAC	LI AS NO	LE CON 0. N624 C-36	70-
	ille, S	1.1.1		······································	DEV	ACED ETNA		
PRELIMINARY ESTIMATE ( )			MATOR	E()		ISED FINA	LESII	MATE
HEADING SANITARY SEWER LI STATION AMTRAC AREA	OUANT	QUANTITY LABOR			MATERIAL DUTTON			
SUMMARY MATERIAL DESCRIPTION		UNIT	PER	TOTAL	PERUNIT	TOTAL	T C	OTAL OST
STRUCTURES SUB-TOTAL		LS	-		-	-	\$	7,1
SIOH	5.5%							
TOTAL	-	LS	-	-	-	-	\$	7,
							-	
	<u> </u>							
		2						
				*****			<u> </u>	

I



SHEET 21 OF 47

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND

PROJECT TITLE: Utility Study - Courthouse Bay Area

DATE PREPARED Jan. 31, 1979


ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C.


A&E FIRM & ADDRESS: J. E. Sirrine Company P. O. Box 5456 Greenville, S.C. 29606

CONST. CONTRACT

A&E CONTRACT NO. N62470-78-C-3675

HEADING SANITARY SEWER LIFT STATION AMTRAC AREA			MATOR	YERS	CHECKED BY DUTTON			
	QUANTITY		and the second s	BOR	MATERIAL			
STRUCTURES MATERIAL DESCRIPTION	NO. UNIT UNITS MEAS		PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST	
WET WELL								
REINF. CONC.	10	CY	40.	400	100.	1,000	\$ 1,400	
EXCAV & BACKFILL	25	CY	4.00	100	-	-	100	
MANHOLE	8	CY	40.	320	100.	800	1,120	
MH COVER & RING	1	EA	25.	25	275.	275	300	
12" Ø RCP CL V	20	LF	2.25	45	5.75	115	160	
TIE INTO EXISTING	•		100	5.1.2.1.1.6				
S.S. LIFT STATION	1	EA	450.	450	100.	100	550	
DEWATERING	4	DAY	200.	800	25.	100	900	
SUB TOTAL							4,530	
CONTRACTOR MARKUP	29%						1,314	
SUB-TOTAL							5,844	
CONTINGENCY	10%						584	
SUB TOTAL		1.00	·				6,428	
ESCALATION TO 1-1-80	11%						707	
SUB TOTAL							7,135	
TOTAL							7,100	
					- 1664. - 1664.		- Annal	
en desert sacriti	and foreign							





A ON BOL


1


DATE 12/28/78

COURTHOUSE


BAY

LIVE LOAD PER BTRUCTUR 1.1.11 SQUARS 10'-0" PROPOSED 13'-4" WET-WELL STORAGE TANK 8-0" 2. 3. 4.3: : 0 -12" RCP (PROPOSED) A A 2'-0"CLR 4 EXISTING 12"\$ 0 .... .... ·.' p COMPUTED BY WORKING STRES EXISTING SANITARY SEWER LIFT STATION AMTRAC AREA AHG LAN P 21






NOV 75-JES 22



ATLANTIC DIVISION - NAVAL PROJECT TITLE: <u>Utility S</u>						TE PREPAR	ED Jan. 31, 1
ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N.	с.			
A&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 wille, S	Comp 6 .C. 2	any 9606	CONST. NO.	CONTRAC	CT A N	&E CONTRACT 0. N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIM/	ATE ()	REV	ISED FINA	L ESTIMATE (x
HEADING WATER TREATMENT	PLANT	ESTI	MATOR	COX	CHECK	ED BY DU	TTON
SUMMARY							
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
DEMOLITION	• -	LS	-	-	-	(	\$ 1,900
SITE PREP. & IMPROV.		LS	-	-	-	-	41,000
BUILDING	1,280	SF	0	34.22	=		43,800
STRUCTURE <sup>(250,000 GAL.</sup>	250000	GAL	9	.33	=		81,900
EQUIPMENT	270	GPM	0	1548.52	=		418,100
INSIDE BLDG. PIPING	155	LF	9	30.46	·		4,700
ELECTRICAL	1,280	SF	0	3.44	=	la Pàrra	4,400
SUB-TOTAL							595,800
SIOH	5.5%						32,769
TOTAL	1,280	SF	0	491.07			628,569
			195.0	- Andrews			
							11 10.001

•


1



ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. N62470-78-NO. Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE ( ) FINAL ESTIMATE ( ) REVISED FINAL ESTIMATE (x)HEADING WATER TREATMENT PLANT | ESTIMATOR CHECKED BY COX DUTTON LABOR OUANTITY MATERIAL DEMOLITION PER NO. UNIT PER TOTAL UNITS MEAS. UNIT MATERIAL DESCRIPTION TOTAL TOTAL COST UNIT EA \$ DEMOLITION OF M.H. 1 100. 100 50. 50 150 DEMOLITION OF .45 ASPHALT PAVEMENT 120 SY 55 .65 80 135 REMOVAL OF 6' HIGH .36 .49 FENCE TO BE REUSED 260 LF 95 130 225 REMOVAL OF 18" RCP LF 1.35 67 90 .62 40 130 TRENCH EXCAVATION 80 CY .85 70 .90 75 145 BACKFILL & COMPACTION CY .75 .25 80 60 20 80 OPENING IN EXISTING WALL 110 SF 1.50 165 ... 165 -SUB TOTAL 1,030 CONTRACTOR MARKUP 505 49% SUB TOTAL . 1,535 CONTINGENCY 10% 154 SUB TOTAL 1,689 ESCALATION TO 1-1-80 186 11% SUB TOTAL 1,875 TOTAL 1,900

.


SHEET 23 OF 47



TLANTIC DIVISION - NAVA	FACILI	TIES E	NGINEER	ING COMM	AND		
ROJECT TITLE: _Utility S	Study - (	Courth	ouse Ba	y Area	DA	TE PREPARE	D Jan. 31, 1
CTIVITY & LOCATION: MCH							
	Sirrine Box 54 wille, S	56		CONST NO.	. CONTRA	CT A8 NC	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	re ( )	REV	ISED FINAL	L ESTIMATE (x
HEADING WATER TREATMENT			MATOR	COX			TTON
SITE PREPARATION AND	QUANT	J.	F FA	ABOR	MA	TERIAL	
IMPROVEMENTS MATERIAL DESCRIPTION	NO.	UNIT	and the second se	TOTAL	PERUNIT	TOTAL	TOTAL COST
PRECAST MANHOLE							
4' ø (6' - 8')	2	EA	120.	240	240.	480	\$ 720
FRAME & COVER	2	EA	30.	60	100.	200	260
TIE-IN TO EXISTING							
MAN HOLE	2	EA	100.	200	100.	200	400
18" Ø RCP CL III	130	LF	2.54	330	6.5	845	1,175
12" Ø RCP CL III	60	LF	1.30	78	4.00	240	318
TRENCH EXCAVATION	190	CY	.85	160	.90	170	330
BACKFILL & COMPACTION	190	CY	.75	145	.25	50	195
6' HIGH CHAIN LINK	tor inches						
FENCE W/BARBED WIRE	110	LF	1.00	110	:50	495	605
REUSE 6' HIGH FENCE	260	LF	1.00	260	.75	195	455
PAVEMENT						10.1	
PREPARE & ROLL BASE	285	SY	.33	95	-	-	95
CRUSHED STONE 6"	285	SY	.40	115	1.70	485	600
PRIMER & SEAL COAT	285	SY	.10	30	.10	30	60
2" WEARING SURFACE	285	SY	.74	210	2.25	.640	850
OFF SITE FILL	1,070	СҮ	2.00	2,140	2.50	2,675	4,815
COMPACTION	1,070	CY	.75	800	.25	270	1,070
SEEDING, INCL. LIME,							
& FERTILIZER	1,970	SY	.40	790	.17	335	1,125
10" ø DIP (M.J.)	200	LF	3.20	640	10.31	2,060	2,700
12" ø DIP (M.J.)	140	LF	4.00	560	12.29	1,720	2,280
TRENCH EXCAVATION	340	СҮ	.85	290	.90	305	595
BACKFILL & COMPACTION	340	СҮ	.75	255	.25	85	340
12" G.V. W/BOX	3	EA	190.	570	575.	1,725	2,295

ŧ


.



					SHI	EET 25 0	F
ATLANTIC DIVISION - NAVAL	FACILIT	TES E	NGINEER	ING COMMA	ND		
PROJECT TITLE: Utility St	udy - C	ourth	ouse Ba	y Area	DAT	TE PREPARE	D_Jan. 31, 191
ACTIVITY & LOCATION: MCB,	Camp L	ejeun	e, N. C				
	Sirrine Box 545 ille, S	0		CONST. NO.	CONTRAC	CT A& NO	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	e a construction	FINAL	ESTIMAT	Έ()	REV	ISED FINAL	ESTIMATE (x)
HEADING WATER TREATMENT P	LANT	EST	MATOR	сох	CHECK	ED BY	UTTON
SITE PREPARATION	QUANT			BOR	MA	TERIAL	- and the second second
AND IMPROVEMENTS MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
CLEARING & GRUBBING	-						
TREES TO 6" DIA.		1.09					
CUT & CHIPS	.33	AC	507.	170	456.	150	320
GRUB STUMPS & REMOVE	.33	AC	93.	30	305.	100	130
TOPSOIL							
STRIPPING & STOCK							
PILING	265	CY	.40	105	.60	160	265
SPREADING	265	CY	.50	135	.60	160	295
CONC. THRUST BLOCKS	5	EA	10.	50	40.	200	250
SUB-TOTAL		lη ν					22,543
CONTRACTOR MARK-UP	49%						11,046
SUB-TOTAL							33,589
CONTINGENCY	10%						3,359
SUB-TOTAL	10%					· · · ·	
ESCALATION TO 1-1-80	11%						36,948
SUB-TOTAL	11/0				a de la compañía de la	Geographies I. I.	4,064
	1. 1892 B						
TOTAL							41,000
					5.0		
		, in gi					
							NA 2011년 1월 18일 - 19일 - 19 19일 - 19일 - 19g - 19g - 19g - 19g 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 - 193 193 - 193 193 - 1 193 - 19


-

1




PROJECT TITLE: Utility St					DA	IE PREPAREI	Jan. 31
ACTIVITY & LOCATION: MCB,	, Camp L	ejeun	e, N. C				
	Sirrine Box 545 ville, S	6		CONST. NO.	CONTRA	CT A&E NO.	CONTRACT N62470-7 C-3675
PRELIMINARY ESTIMATE ( )					REV	ISED FINAL	ESTIMATE
HEADING WATER TREATMENT F	PLANT	ESTI	MATOR	MYERS	CHECK	ED BY DUT	TON
BUILDING MATERIAL DESCRIPTION	QUANT.	ITY IUNIT	PER 1	ABOR TOTAL	PER UNIT	TERIAL TOTAL	TOTAL COST
BUILDING:				TUTAL		TUTAL	0001
FOUNDATIONS	60	СҮ	40.	2400	100.	6000	8,4
FLOOR	20	СҮ	29.	580	57.	1140	1,7
WALLS	1500	SF	1.55	2325	1.50	2250	4,5
ROOF	1280	SF	1.30	1665	1.30	1665	3,3
STRUCT. STEEL	6	TON	500.	3000	1000.	6000	9,00
GRAVEL STOP	112	LF	2.	225	1.	115	34
DOORS	24	SF	3.	75	8.	195	27
SASH	25	SF	2.	50	5.	125	1:
SUB-TOTAL							27,8
CONTRACTOR MARK-UP	29%						8,00
SUB-TOTAL							35,87
CONTINGENCY	10%					· · ·	3,58
SUB-TOTAL							39,40
ESCALATION TO 1-1-80	11%						4,34
SUB-TOTAL							43,80
TOTAL							43,80
TOTAL	1280	SF	0	34.22	=		43,80

•



ROJECT TITLE: <u>Utility Stu</u> CTIVITY & LOCATION: MCB,					DAT	E PREPARE	D_Jan. 31, 1
&E FIRM & ADDRESS: J. E. S P. O. 1		Compa 6	any	CONST.	CONTRAC	T A& NO	E CONTRACT N62470-78- C-3675
RELIMINARY ESTIMATE ( )				E ( )	REV	ISED FINAL	ESTIMATE (x
HEADING WATER TREATMENT P			MATOR		CHECK		TTON
	QUANTI NO.	ITY IUNIT	PER I	ABOR	PER UNIT	TERIAL TOTAL	TOTAL COST
WATER RESERVOIR							
REINF CONC.	276	CY	40.	11,040	100.	27600	38,640
EXCAVATION	200	CY	4.	800	-	-	800
BACKFILL	960	СҮ	8.	7680	5.	4800	12,480
GRAVEL (6" THICK AROUND SIDE OF TANK)	85	SF	.88	75	.18	15	80
SUB-TOTAL							52,010
CONTRACTOR MARK-UP	29%						15,083
SUB-TOTAL							67,093
CONTINGENCY	10%						6,709
SUB-TOTAL							73,802
ESCALATION TO 1-1-80	11%						8,118
SUB-TOTAL			· · ·			•	81,920
TOTAL							81,900

)



	SHEET 28 OF 47
ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND	
PROJECT TITLE: Utility Study - Courthouse Bay Area	_ DATE PREPARED_Jan. 31, 1979

ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C.


A&E FIRM & ADDRESS: J. E. Sirrine Company P. O. Box 5456 Greenville, S.C. 29606

0

CONST. CONTRACT


A&E CONTRACT NO. N62470-78-C-3675

PRELIMINARY ESTIMATE ( )		INAL	ESTIMA	TE ( )	REV	ISED FINAL	ESTIMATE (X
HEADING ITEM 1 - PRIMARY FACILITY	t .		MATOR		CHECK	ED BY	
WATER TREATMENT	QUANT	statement of the local division of the second se	and the second second second	ABOR	and the second se	TERIAL	and the second sec
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
670 GPM FILTER FEED	1	LS			1	\$ 3,364	
PUMP NO. 1 INCL. BASE,	160	MH	10	\$1,600			\$ 4,964
COUPLING, COUPLING GUARD,							
& 20 HP 3Ø, 60 HZ 460 V.							
MOTOR, AND INSTALLATION							
S. W. CARROUTH-CAROTEK, 704-847-4406	INC	VENDO	r quot	E DATED 12	/4/78		
670 GPM FILTER FEED	1	LS			1	\$10,876	
PUMP NO. 2, INCL. BASE	190	MH	10	\$1,900			\$12,776
COUPLING, GUARDS, &	150	1.01	10	φ <b>1</b> ,900			\$12,770
20 HP, 3Ø, 60 HZ, 460V						1.1	19-20-21-4
MOTOR AND 64 HP WATER							
COOLED DISEL ENGINE, AND							
INSTALLATION							
S. W. CARROUTH-CAROTEK, 704-847-4406	INC.	VENDO	r quot	E DATED 12	(4/78		
REPIPE AND REVALVE THREE	1	LS				\$26,000	
(3) EXISTING 7-1/2' Ø	460	MH	10	\$4,600		420,000	\$30,600
FILTERS AND CONNECT TO							1
NEW CONTROL SYSTEM INCL.				12.19			
VALVES, PIPING AND						Adda an Ba	
CONTROLS AND INSTALLATION							
BILL MORRISON-BROWN & M	ORRISON	- VEN	DOR QU	OTE DATED	2/8/78		
704-333-0774							




PROJECT TITLE: Utility St					a	DA	TE PREPARE	D Jan. 31, 1
ACTIVITY & LOCATION: MCB,	Camp L	ejeuno	e, N. (	<u>c.</u>				
A&E FIRM & ADDRESS: J. E. P. O. Greenv	Sirrine Box 545 ille, S	Compa 6 .C. 29	ny 9606	CO NO	NST.	CONTRA	CT A& NO	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	I	INAL	ESTIMA	TE ()	)	REV	ISED FINAL	ESTIMATE (x
HEADING ITEM 1 - PRIMARY FACILITY	r	ESTI	MATOR		in the second	CHECK	ED BY	an a
WATER TREATMENT	QUANT	TITY LABOR				TERIAL		
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	MEAS.	PER UNIT	тот	TAL	PERUNIT	TOTAL	TOTAL COST
4 NEW 8'Ø FILTERS INCL.	1	LS			See.		\$90,000	
FILTERS, PIPING, MEDIA,	835	МН	10	\$8,3	350			\$98,350
CONTROLS, VALVES, INTER-	1							
CONNECTING HEADER PIPING								
AND INSTALLATION								
BILL MORRISON - BROWN &	MORRIS	DN - V	ENDOR	QUOTE	DATE	12/8	78	
704-333-0774								
NEW BRINE TANK FOR	1	LS					\$ 4,100	
EXISTING SOFTENERS INCL.	120	MH	10	\$1,5	200		φ <b>4,100</b>	\$ 5,300
NEW TANK, LEVEL CONTROLS,				φ1,	200			φ 0,000
VALVES, PRESSURE GAUGES,								
ROTAMETERS, FOR EXISTING								
SOFTENERS, AND								
INSTALLATION								
BILL MORRISON - BROWN &	MORRIS	DN - 1	ENDOR	QUOTE	DATE	D 12/8	78	
704-333-0774								
REPLACE SOFTENER RESIN	1	LS					\$ 2,370	
49 CU.FT.	32	MH	10	\$ :	320			\$ 2,690
					-			

.




PROJECT TITLE: <u>Utility St</u>	udy – Co	ourthe	ouse Ba	iy Area	DA1	FE PREPAREI	) Jan. 31, 1
ACTIVITY & LOCATION: MCB,	Camp L	ejeune	2, N. C				
A&E FIRM & ADDRESS: J. E. P. O. Greenv	Sirrine Box 545 ille, S	Compa 6 .C. 2'	эпу 9606	CONST. NO.	CONTRA	CT A&I NO	E CONTRACT . N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	F	INAL	ESTIMA	TE ( )	REV	ISED FINAL	ESTIMATE (X
HEADING ITEM 1 - PRIMARY FACILITY	1	ESTI	IMATOR DECKER		CHECK	KED BY	
WATER TREATMENT	QUANTI	ITY	L	ABOR	A11	TERIAL	E
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT		TOTAL COST
2 NEW 6'Ø SOFTENER UNITS	1	LS				\$56,000	
INCL. BRINE TANK, LEVEL	290	MH	10	\$2,900			\$58,900
CONTROLS, WATER METERS, VALVES, CONTROLS,							
PRESSURE GAUGES, ROTA-							
METERS, PIPING, VALVES,							
RESIN, SUBFILL, AND							
INSTALLATION							
BILL MORRISON - BROWN &	MORRIS	0N - 1	ENDOR	QUOTE DATE	D 12/8	78	
704-333-0774							
CONTROL PANEL FOR	1	LS				\$14,000	
SOFTENERS & FILTERS INCL.	224	MH	10	\$2,240			\$16,240
TIE-IN OF PIPING AND							
CONTROLS TO EXISTING							
SYSTEM CONTROL OPERATION							
FOR MANUAL/AUTOMATIC AND							
INSTALLATION							
BILL MORRISON - BROWN & 704-333-0774	MORRIS	<u>DN - N</u>	ENDOR	QUOTE DATE	D 12/8	78	
		and the					
							ana an

.




ALIFET	-	AF	
CHILL I	21	11L	17
SHEET	31	OF	47
	51		

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. NO. N62470-78-Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE ( ) FINAL ESTIMATE ( ) REVISED FINAL ESTIMATE (x) HEADING ITEM 1 - PRIMARY FACILITY ESTIMATOR T. HUECKER CHECKED BY WATER TREATMENT QUANTITY LABOR MATERIAL EOUIPMENT NO. UNIT PER PER TOTAL MATERIAL DESCRIPTION UNITS MEAS. TOTAL ' UNIT UNIT TOTAL COST SUBTOTAL \$23,110 \$206,710 \$229,820 SUBCONTRACTOR MARKUP @ 49% 11,324 101,287 112,611 SUBTOTAL 34,434 307,997 342,431 3,787 ESCALATION TO 1 JANUARY 1980 @ 11% 33,880 37,667 SUBTOTAL 380,098 38,221 341,877 CONTINGENCY @ 10% 3,822 34,188 38,010 \$42,043 \$376,065 TOTAL \$418,108 270 GPM EXPANSION FROM 400 GPM TO 670 GPM .




PROJECT TITLE: Utility S	tudy - C	ourth	ouse Bay	/ Area	DA1	TE PREPARE	D Jan. 31,
CTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. C.				
	Sirrine Box 545 ville, S	6		CONST. NO.	CONTRAC	CT A& NO	E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	E ( )	REV	ISED FINAL	ESTIMATE ()
HEADING WATER TREATMENT	PLANT	ESTI	MATOR	DUTTON	CHECK	ED BY C	OX
INSIDE BUILDING	QUANT	ITY		BOR	MA	TERIAL	
PIPING MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
3/4" Ø SCH. 40 STEEL	. 50	LF	1.30	65	.60	30	9
6" Ø SCH. 40 STEEL	25	LF	7.60	190	11.40	285	47
8" Ø SCH. 40 STEEL	80	LF	9.32	745	16.00	1280	202
SUB-TOTAL							259
CONTRACTOR MARK-UP	49%						127
SUB-TOTAL							386
CONTINGENCY	10%						38
SUB-TOTAL							425
ESCALATION TO 1-1-80	11%	1.131					46
SUB-TOTAL							472
TOTAL						12	470
TOTAL	155	LF	9	30.46	=		470
				garan -			
	1.8.1						
				**************************************			



ROJECT TITLE: <u>Utility St</u> CTIVITY & LOCATION: MCB,					UA1	E PREPARE	U Jan. 31, 19
	well-the				CONTRAC	- 80	
	Box 545 ille, S	6		NO.	CONTRAC	T A& NO	E CONTRACT . N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	E ( )	REV	ISED FINAL	ESTIMATE (x)
HEADING WATER TREATMENT	PLANT	ESTI	MATOR	TCF	CHECK	ED BY	and a second
	QUANT		LA	BOR	MAT	ERIAL	
ELECTRICAL MATERIAL DESCRIPTION	the second se	UNIT	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
SIZE 2 MAGNETIC STARTERS	. 4	EA .	45.	180	140,	560	\$ 740
1" RIGID STEEL CONDUIT	60	LF	1.25	75	.70	42	117
#8 THW	180	LF	.13	23	.11	8	31
#10 THW	80	LF	.10	8	.06	4	12
FLEXIBLE CONDUIT & FITTIN		EA	20.	40	12.	24	. 64
50A, 3P, CIRCUIT BREAKERS	2	EA	15.	30	90•	180	210
LIGHTING FIXTURES	2	EA	13.	26	17.	34	60
1/2" RIGID STEEL CONDUIT	and the second sec	LF	1.10	44	.42	16	60
1 1/4" PVC	550	LF	.15	82	.17	94	175
1 1/4" R.S. CONDUIT	75	LF	1.30	98	.95	71	169
3 POLE RELAY	1	EA	10.	10	55.	55	65
FLOAT CONTROL	1	EA	100.	100	257.	257	357
1/C #10 THW .	2400	LF	.10	240	.06	144	384
SUB-TOTAL			·				2444
CONTRACTOR MARK-UP	49%						1198
SUB-TOTAL							3642
CONTINGENCY	10%						364
SUB-TOTAL		19.00					4006
ESCALATION TO 1-1-80	11%						441
SUB-TOTAL							4447
TOTAL							4400
TOTAL	1280	SF	0	3.44			4400
						and the second	

ī


•



SHEET	34	OF	47
SUCCI	34	U	4/


CTIVITY & LOCATION: <u>MCI</u> &E FIRM & ADDRESS: J. E. P. O. Green	. Sirrine . Box 545 nville, S	Compa 6 .C. 29	any 9606	CONST. NO.		NC	. N62470-78- C-3675
RELIMINARY ESTIMATE ( )	and a state of the second s	the second second second second second	and the second diversion of th	CONTRACTOR OF A DESCRIPTION OF A DESCRIP			
HEADING WASTEWATER TREATMENT PLAN	NT	ESTI	MATOR	ОХ	CHECK	ED BY	UTTON
SUMMARY	QUANTI	LTY	LA	BOR	MA	TOTAL	
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
DEMOLITION	153000	GAL	0	.46	z		70,200
SITE PREP & IMPROV.	153000	GAL	0	.69	=		105,400
STRUCTURES	153000	GAL	0	1.47	=		224,200
EQUIPMENT	153000	GAL	0	3,60	=		550,300
ELECTRICAL	153000	GAL	0	.03	=		5,200
SUB-TOTAL	153000	GAL	0	6.24	=		955,300
SIOH	5.5%						52,541
TOTAL	153000	GAL	0	6.59			\$ 1,007,842
				Laboration of			
ning programs	1.10.40						
		12 - 12 ()					

.....




SHEET	35	OF	47	
-------	----	----	----	--

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. N62470-78-NO. Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE ( ) FINAL ESTIMATE ( ) REVISED FINAL ESTIMATE (x) HEADING WASTEWATER ESTIMATOR CHECKED BY TREATMENT PLANT DUTTON COX QUANTITY LABOR MATERIAL DEMOLITION NO. UNIT PER PER TOTAL MATERIAL DESCRIPTION UNITS MEAS. UNIT TOTAL UNIT TOTAL COST IMHOFF TANKS 1014 CY 18.20 18,455 11.50 11,660 30,115 CHLORINE CONTACT CHAMBER 113 CY 18.20 2,055 11.50 1,300 3,355 CY 18.20 11.50 620 CHLORINATION M.H. 21 380 240 CY 9 18.20 11.50 270 CLARIFIER EFFLUENT BOX 165 105 18.20 11.50 415 14 CY 255 160 IMHOFF EFFLUENT BOX 1660 8" Ø PIPE (CIP) 1.89 1145 .85 515 605 LF .47 85 275 10" Ø PIPE (VCP) 180 LF 1.06 190 .52 55 175 4" ø PIPE (CIP) 105 LF 1.14 120 .95 570 1080 TRENCH EXCAVATION 600 CY .85 510 **BACKFILL & COMPACTION** 600 CY .75 450 .25 150 600 SUB-TOTAL 38,565 49% CONTRACTOR MARK-UP 18,897 57,462 SUB-TOTAL 10% 5,746 CONTINGENCY 63,208 SUB-TOTAL ESCALATION TO 1-1-80 11% 6,953 70,161 SUB-TOTAL 70,200 TOTAL



TLANTIC DIVISION - NAVAL	FACILIT	TIES E	NGINEER	ING COMMAN	٧D		
ROJECT TITLE: Utility S	tudy - C	ourth	ouse Bay	Area	۲۵٦		Ian 31 1
CTIVITY & LOCATION: MCB			1				<u> </u>
					Geographica		
&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 ville, S	Comp. 6 1.C. 2	any 9606	NO.	CONTRAC	NO.	CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT		the second se	and the second	ESTIMATE (x)
HEADING WASTEWATER		ESTI	MATOR	00V	CHECK	ED BY	
TREATMENT PLAN SITE PREPARATION	QUANT		1	BOR	P1A <sup>-</sup>	DUTT TERIAL	014
AND IMPROVEMENTS MATERIAL DESCRIPTION		UNIT	PER	TOTAL	PER UNIT	TOTAL	TOTAL
4" ø C.I.S.P.	. 110	LF	3.28	360	3.06	337	697
6" Ø C.I.S.P.	290	LF	3.78	1100	4.75	1380	2480
10" ø C.I.S.P.	50	LF	6.84	340	13.43	670	1010
12" ø C.I.S.P.	600	LF	7.88	4730	18.87	11,322	16,052
3" ø C.I.P. (CL52)	50	LF	1.40	70	4.20	210	280
4" ø C.I.P. (CL52)	385	LF	1.50	580	5.10	1965	2545
8" Ø C.I.P. (CL52)	45	LF	2.66	120	7.90	355	475
10" ø C.I.P. (CL52)	35	LF	3.20	110	10.31	360	470
TRENCH EXCAVATION	1525	CY	.85	1295	.90	1375	2670
BACKFILL & COMPACTION	1525	СҮ	.75	1145	.25	380	1525
4" ø G.V. W/BOX C.1.	3	EA	55.	165	175.	525	690
6" ø G.V. W/BOX C.1.	4	EA	70.	290	225.	900	1190
8" ø G.V. W/BOX C.1.	2	EA	115.	230	305.	610	840
10" ø G.V. W/BOX C.1.	1	EA	145.	145	460.	460	605
12" ø G.V. W/BOX C.1.	14	EA	190	2660	575.	8050	10710
PRIMARY CLARIFIER							
SLUDGE PUMPS				- 24			
3" Ø GATE VALVE	4	EA	45.	180	115.	460	640
3" Ø CHECK VALVE	4	EA	45.	180	155	620	800
EFFLUENT RECIRCULATION							
PUMPS	1.1.1535						
3" Ø GATE VALVE	2	EA	45.	90	115	230	320
3" Ø CHECK VALVE	2	EA	45.	90	Ī 55-	310	400


Ĩ



TLANTIC DIVISION - NAVAL	FACILIT	TIES E	NGINEER	ING COMMAN	ID		
ROJECT TITLE: Utility S	tudy - C	ourthe	ouse Bay	/ Area	DAT	E PREPARED	Jan. 31, 1
CTIVITY & LOCATION: MCB	, Camp L	ejeune	e, N. C.				
&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 ville, S	Compa 6 5.C. 29	any 9606	NO.	1. <u>1</u>	CT A&E NO.	CONTRACT N62470-78- C-3675
RELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	and the second state and the second se	REV	ISED FINAL	ESTIMATE (x
HEADING WASTEWATER TREATMENT PLANT	Service Sec.	ESTI	MATOR	сох	CHECK	ED BY Dut	TON
SITE PREPARATION	QUANT	ITY	LA	BOR	MA	TERIAL	TUN
AND IMPROVEMENTS MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
TRICKLING FILTER							
LIFT PUMPS							
4" ø GATE VALVE	3	EA	45.	1 35	155,	465	600
4" Ø CHECK VALVE	3	EA	45,	1 35	165,	495	630
GRAVITY THICKENER							
SLUDGE PUMPS							
3" Ø GATE VALVE	2	EA	45.	90	115.	230	320
3" Ø CHECK VALVE	2	EA	45,	90	155.	310	400
AEROBIC DIGESTER							
AIR BLOWERS							
3" Ø GATE VALVE	2	EA	45.	90	115,	230	320
3" Ø CHECK VALVE	2	EA	45.	90	155.	310	400
6' HIGH CHAIN LINK	ev fright th		a	a station of			
FENCE W/BARBED WIRE	120	LF	1.00	120	4.50	540	660
REUSE 6' HIGH FENCE	280	LF	1.00	280	.75	210	490
PAVEMENT							
PREPARE & ROLL BASE	225	SY	.33	75	-		75
CRUSHED STONE 6"	225	SY	.40	90	1.70	385	475
PRIMER & SEAL COAT	225	SY	.10	25	.10	25	50
2" WEARING SURFACE	225	SY	.74	165	2.25	505	670
SEEDING INCL. LIME &							
FERTILIZER W/EQUIP.	2700	SY	.40	1080	.17	460	1540

T


•



&E FIRM & ADDRESS: J. E. P. O. Greenv	BOX 242	00	any 9606	CONST. NO.	CONTRAC	NO.	E CONTRACT . N62470-78- C-3675
RELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	E ( )	REV	ISED FINAL	ESTIMATE (x)
HEADING WASTEWATER TREATMENT PLANT		ESTI	MATOR	сох	CHECK	ED BY	JTTON
SITE PREPARATION	QUANT		LABOR		and the second se	TERIAL	
AND IMPROVEMENTS MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
CLEARING & GRUBBING:							
TREES TO 6" Ø CUT & CHIPS	.24	AC	507,	120	456.	110	230
GRUB STUMPS & REMOVE	.24	AC	93.	20	305+	75	95
OFF SITE FILL	1025	CY	2.00	2050	2.50	2,565	4,615
COMPACTION	1025	СҮ	.75	770	.25	255	1,025
TOPSOIL:							
STRIPPING & STUCK							
PILING	450	CY	.40	180	.60	110	290
SPREADING	450	CY	.50	225	.60	135	360
CONC THRUST BLOCK	10	EA	10.	100	40.	400	500
SUB-TOTAL					$\square$		58,144
CONTRACTOR MARK-UP	49%						28,491
SUB-TOTAL							86,288
CONTINGENCY	10%						
SUB-TOTAL	10%						<u>8,629</u> 94,917
ESCALATION TO 1-1-80	11%						10,441
SUB-TOTAL							105,358
TOTAL							105,400


•

SHEET 38 OF 47



SHEET 39 OF 47

ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED Jan. 31, 1979 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. NO\_ N62470-78-Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE ( ) FINAL ESTIMATE ( ) REVISED FINAL ESTIMATE (x) HEADING WASTE WATER TREATMENT ESTIMATOR CHECKED -BY PLANT MYERS DUTTON QUANTITY LABOR MATERIAL STRUCTURES NO. UNIT PER PER TOTAL MATERIAL DESCRIPTION UNITS MEAS. UNIT TOTAL UNIT TOTAL COST **2 PRIMARY CLARIFIER** REINF. CONC. 150 CY \$ 40. 6,000 100. 15,000 21,000 EXCAV. & BACKFILL 250 CY 4. 1,000 1,000 -... CHLORINE CONTACT REINF CONC 75 CY 40. 3,000 100. 7,500 10,500 **EXCAV & BACKFILL** 125 4.00 CY 500 -500 DIGESTER **REINF CONC** 100 CY 40. 4,000 100. 10,000 14,000 EXCAV. & BACKFILL 150 CY 4. 600 600 FLOW BOXES & PITS REINF. CONC. 40 CY 40. 1,600 100. 4.000 5,600 EXCAV. & BACKFILL 60 CY 4. 240 240 ----TRICKLING FILTER REINF. CONC. CY 230 50. 11,500 100. 23,000 34,500 4. EXCAV. & BACKFILL 600 CY 2,400 ..... 2,400 LADDER & STEPS 15 EA 3. 45 8. 120 165 GRATING 25 SF 2. 4. 50 100 150 SECONDARY CLARIFIER REINF. CONC. CY 40. 100 4,000 100. 10,000 14,000 EXCAV. & BACKFILL 4 150 CY 600 600 \_ PUMP BASES CONC. 40 CY 40. 1,600 100. 4,000 5,600 EXCAV. & BACKFILL 40 CY 4. 160 -160 -BARMINUTORS REINF. CONC. 9 CY 40. 360 100. 900 1,260 EXCAV. & BACKFILL 10 CY 4. 40 ..... 40 PUMP & CHLORINE BLDG. 600 SF 20. 12,000 30. 18,000 30,000




PROJECT TITLE: Utility S	tudy - C	ourth	ouse Bay	y Area	DAT	TE PREPAR	ED Jan. 31, 1
ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. Ć	•			
A&E FIRM & ADDRESS: J. E. P. O. Green	Sirrine Box 545 ville, S	Comp 6 .C. 2	any 9606	CONST. NO.	CONTRAC	CT A	SE CONTRACT 0. N62470-78- c-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMAT	E ( )	REV	ISED FINA	L ESTIMATE (X
HEADING WASTEWATER TREATMENT PLANT	e a construction	ESTI	MATOR	YERS	and the second second second	ED BY	UTTON
STRUCTURES MATERIAL DESCRIPTION			PER UNIT	BOR TOTAL	PER UNIT	TERIAL TOTAL	TOTAL
SUB TOTAL							\$ 142,315
CONTRACTOR MARKUP	29%						41,271
SUB TOTAL							183,586
CONTINGENCY	10%			in the second			18,359
SUB TOTAL				i - Lange		و المحالية و الم	201,945
ESCALATION TO 1-1-80	11%			an a			22,214
SUB TOTAL							224,159
TOTAL							224,200
· · · · · · · · · · · · · · · · · · ·							
		- The Sec.					
							L
		1.1					
				1			1

6

I

•





QUOTATION J. E. SIRRINE COMPANY P. O. BOX 5456 GREENVILLE, SC 29606

5069 NO.

DECEMBER 4, 1978 DATE

ATTENTION: MR. TOM HUECKER

SUBJECT: ALLIS-CHALMERS 8000 SERIES HORIZONTAL SPLIT-CASE PUMP

## DEAR TOM.

PER OUR EARLIER TELEPHONE CONVERSATION AND LETTER WE HAVE SELECTED THE 6x4x12L AXIAL SPLIT-CASE PUMP FOR YOUR 670 GPM AT 80' TDH. PER YOUR REQUIREMENTS, ONE PUMP HAS BEEN SELECTED WITH A WATER COOLED DIESEL ENGINE AS WELL AS A 20 HP, 3 PHASE, 60 CYCLE, 460 VOLT MOTOR. THE PRICE FOR THIS UNIT COMPLETE WITH WATER COOLED DIESEL ENGINE AND ELECTRIC DRIVE WOULD BE \$10,876.00. AS AN ALTERNATIVE, THIS SAME ARRANGEMENT SUPPLIED WITH AN AIR COOLED DIESEL WOULD BE \$8,521.00. FOR YOUR ONE ELECTRICALLY DRIVEN PUMP ONLY, THE PUMP QUOTED WITH BASE, COUPLING, COUPLING GUARD AND 20 HP, 3 PHASE, 60 CYCLE, 460 VOLT MOTOR WOULD COST \$3,364.00.


DELIVERIES WOULD BE APPROXIMATELY 18 TO 20 WEEKS; HOWEVER, SHOULD YOU REQUIRE QUICKER DELIVERIES PLEASE ADVISE AND WE MAY BE ABLE TO SPEED UP THIS DELIVERY. WE TRUST THIS LETTER WILL FURNISH YOU WITH THE NECESSARY INFORMATION BUT SHOULD YOU HAVE ANY QUESTIONS OR DESIRE ADDITIONAL INFOR-MATION PLEASE DO NOT HESITATE THIS OFFICE.

VERY TRULY YOURS.

A time Carrouth / fu

STEVE W. CARROUTH SWC/fw

Your order will be received subject to the acceptance of seller's home office at Charlotte, North Carolina, upon and subject to the terms stated on the reverse side hereof.



POWER & PROCESS EQUIPMENT.



## BROWN & MORRISON

1900 EAST 7TH STREET P. O. BOX 4307 CHARLOTTE, N. C. 28204 December 8, 1978

J. E. Sirrine Company Post Office Box 5456, Station B Greenville, South Carolina 29606

DWIGHT W WESSLER

GARY F. MORRISON

GARY H. JONES

DONALD G. MORRISON

Mr. T. C. Huecker Attention S. C. Division

Gentlemen

Í

HAROLD K. COUCH

DONALD H. JONES

ED B. MONTAGUE

Subject U. S. Marine Base Courthouse Bay Camp Lejeune, North Carolina Your A-1086 Cochrane Equipment

Our Quotation No. 23220


We are pleased at this time to confirm our verbal pricing on the several items we have discussed on the updating of the Cochrane water treating equipment at this installation. We tabulate .. as follows:

### Item #1 Modification of Existing Filters

There are three (3) existing pressure filters, 7'6" diameter by 6'0" straight side. These are arranged at the present time to be backwashed in sequence but with all units off the line. It appears desirable to repipe these so that each unit could be backwashed individually with the balance of the load to be handled by the remaining units. To do this, we would propose the following equipment to be furnished:

- New valve nest for each filter complete with butterfly valves (6"), actuators, (a) with manual override.
- (b) New front piping for each filter.
- New interconnecting headers for the three (3) filters (c)
- (d) Semi-automatic push button control for backwashing
- (e) Pressure gauges for each unit, total of six (6)
- (f) Sample cocks for each unit, total of three (3)
- Rotameters for each unit, total of three (3) (g)
- (h) Manual isolating valves for each unit, total of six (6)

AREA CODE 704 333-0774



## J. E. Sirrine Company Greenville, South Carolina

ESTIMATED COST of the above would be-----\$26,000.00

### Item #2 New Filters

Under this arrangement we would offer the following:

- (a) Four (4) new pressure filters, 8'0" diameter by 6'0" straight side, 75 psi, non-code construction.
- (b) Four (4) automatic valve nests with manual override
- (c) Semi-automatic push button control for backwashing
- (d) Interconnecting headers for the four (4) units
- (e) Pressure gauges for each unit, total of eight (8)
- (f) Sample cocks for each unit, total of four (4)
- (g) Rotameters for each unit, total of four (4)
- (h) Manual isolating valves for each unit, total of eight (8)

ESTIMATED COST of the above would be------\$90,000.00

## Item #3 Modification of Existing Softeners

There are two (2) existing softeners each 5'0" diameter by 6'0" straight side. We would propose to add the following equipment:


- (a) Two (2) pressure gauges for each unit, total of four (4)
- (b) Sample cocks for each unit, total of two (2)
- (c) Rotameters for each unit, total of four (4)
- (d) New brine combination salt storage and measuring tank of fiberglas construction.
- (e) New set of brine level controls.

ESTIMATED COST of the above would be-----\$ 4,100.00 In this figure is approximately \$2,000.00 for brine tank and controls.

#### Item #4 New Softeners

Under this arrangement we would offer the following:

(a) Two (2) new Zeolite water softeners each 6'0" diameter by 6'0" straight side, 100 psi ASME code construction.



## J. E. Sirrine Company Greenville, South Carolina

December 8, 1978 Page 3

(b) Two (2) automatic valve nests with manual override

(c) Semi-automatic push button control for regeneration

(d) Front piping and interconnecting piping.

(e) Pressure gauges for each unit, total of four (4)

(f) Rotameters for each unit, total of two (2)

(g) Manual isolating valves for each unit, total of four (4)

(h) Brine regeneration system.

(i) Skid assembly of the above.

ESTIMATED COST of the above would be -----\$56,000.00

## Item #5 New Control System

A new control panel to house all controls for filters and softeners including timers, switches, push button semi-automatic control for softeners with interlock and automatic brine tank refilling

ESTIMATED COST of the above would be-----\$14,000.00

## Item #6 Additional Resin

This would include forty-nine (49) cubic feet of cation resin for Softener #1.

ESTIMATED COST of the above would be ------\$ 2,370.00

All the above prices are current as of December 1, 1978. Freight charges are included.

We have not included start-up service. This could be furnished at a cost of \$250.00 per day plus living and travel expenses from Philadelphia, Pa., to Jacksonville, N.C., and return.


Please advise if we have overlooked anything. Thank you.

Yours very truly, BROWN & MORRISON, District Representatives For: COCHRANE ENVIRONMENTAL SYSTEMS

Yauson


W. C. Morrison

WCM: jb



					SH	IEET 41 0	F_47
ATLANTIC DIVISION - NAVAL	FACILIT	TIES E	NGINEE	RING COMMAN	ND		
PROJECT TITLE: Utility St	udy - C	Courth	ouse Ba	ay Area	DA	TE PREPARE	D Jan. 31, 19
ACTIVITY & LOCATION:MCB,	Camp L	ejeun	e, N. (	с.			
A&E FIRM & ADDRESS: J. E. P. O. Greenv	Sirrine Box 545 ille, S	Comp 6 5.C. 2	any 9606	CONST. NO.	CONTRA	ACT A& NO	E CONTRACT . N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	an a	FINAL	ESTIMA	TE ( )	RE	VISED FINAL	ESTIMATE (x)
HEADING WASTEWATER TREATMENT PLAN	NT	ESTI	MATOR	FDT	CHEC	KED BY	
general and second states of the second second second second	QUANT	ΙΤΥ	L			ATERIAL	1
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
BARIMUTER .	2	EA	320	\$ 640	13,000	\$26,000	\$26,640
ESHELMAN CAROLINAS INC. 704-376-6408	- MR. 1	TOBIN	- VEND	OR QUOTE D.	ATED 12	/19/78	
PRIMARY CLARIFIER			999 A.4 2010 - 10				
PRIMARY COLLECTOR W/ SKIMMER, WEIR AND							
BAFFLES - 22'Ø	2	EA	6,240	12,480	18,500	37,000	49,480
ROBERT L. CARLSON INC	CHARLE	5 R.	HUNTER	JR VEND	OR QUO	TE DATED 1	0/19/78
704-332-9031							
SECONDARY CLARIFIER							
SECONDARY COLLECTOR							
W/SKIMMER, WEIR &						- 4 · · · ·	
BAFFLES - 29'Ø	1	EA	6,240	6,240	22,000	22,000	28,240
ROBERT L. CARLSON INC.	- CHARLI	SR.	HUNTER			TE DATED 1	
704-332-9031							
ROTARY DISTRIBUTOR							
62'Ø, 200 - 800 GPM	1	EA	1,120	1,120	25,000	25,000	26,120
ROBERT L. CARLSON, INC.	- CHARL	ES R.	HUNTE	and the second state of th		OTE DATED	and the second product of the second s
704-332-9031							


.




ROJECT TITLE: Utility St	udy - Co	ourthe	ouse Ba	y Area	DAT	TE PREPARET	) Jan. 31, 19
CTIVITY & LOCATION: MCB,	Camp L	ejeun	e, N. C				
	ille, S	6 .C. 29	9606	NO.	e san de la participa El contra composito de la composito de la composito de la composito de la composito de la El composito de la composito de	NO.	N62470-78- C-3675
PRELIMINARY ESTIMATE ()				and the second	REV	ISED FINAL	ESTIMATE (x)
HEADING WASTEWATER TREATMENT PLAN	IT T	ESTI H D	IMATOR LIENE	PT	CHECK	ED BY	
EQUIPMENT	QUANTI	ITY	LA	ABOR	the state of the s	TERIAL	
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
GRAVITY THICKENER							
STEEL TANK, 7.5'Ø THICKENING RAKE,	1	EA	3,000	3,000	6,300	6,300	9,300
WEIR, & BAFFLES	1	EA	3,200	3,200	18,700	18,700	21,900
ROBERT L. CARLSON INC.				the other water water and the second s		OTED 10/28	The second s
704-332-9031							
AEROBIC DIGESTER							
BRIDGE, SUPPORTS,	•						
DIFFUSER ASSEMBLY,							
(2) AIR BLOWERS, 15 HP,							
CONTROL PANEL & TIMER	1	EA	2,560	2,560	25,000	25,000	27,560
JOHNSTON, INC MAC JO							
704-377-3785							
TRICKLING FILTER LIFT							
PUMPS							
VORTEX PUMPS, TWO (2)							
3 HP, ONE (1) 1 HP							
COMPLETE W/PANELS,							
FLOATS & STARTERS	3	EA	320	960	-	12,000	12,960
ROBERT E. MASON COMPANY	- TERRE	L C00	K - VEN	IDOR QUOTER	0 10/23/	78	
704-375-4464							
				1			

.

.




	a sure					IEET 43 01	F47
ATLANTIC DIVISION - NAVAL	FACILIT	TIES E	NGINEE	RING COMMAN	ND		
PROJECT TITLE: Utility St	udy - C	Courth	ouse B	ay Area	DA	TE PREPARE	D Jan. 3
ACTIVITY & LOCATION: MCB,							
A&E FIRM & ADDRESS: JE			1		CONTRA	CT A0	CONTRA
P. O.	Box 545	6	0404	NO.	CONTRA	NO	N62470
		an shear and	Section and a	a contract of the second states	and the second	and the second second second second	and the second
PRELIMINARY ESTIMATE ( )				an and the strength of the strength of the		ISED FINAL	ESTIMAT
HEADING WASTEWATER TREATMENT PLAN		the distance of the second	MATOR LIEN	IERT	CHECK	KED BY	
EQUIPMENT	QUANT NO.			LABOR		ATERIAL	TOTA
MATERIAL DESCRIPTION	UNITS	MEAS.	UNIT	TOTAL	PER UNIT		TOTA COST
PRIMARY CLARIFIER SLUDGE.							
PUMPS							
PROGRESSIVE CAVITY							
COMPLETE W/TIMER, PANEL							
MOTOR STARTERS TWO (2)							
3 HP, 280 RPM 22 GPM	4	EA	320	1,280	3,070	12,280	13,560
THE GREENLESS COMPANY -	PETER	ETERS	ON - V	ENDOR QUOT	E DATED	11/6/78	
404-261-1781							
GRAVITY THICKENER							
SLUDGE PUMPS							
PROGRESSIVE CAVITY							
COMPLETE W/TIMER, PANEL,							
MOTOR STARTERS TWO (2)							
1.5 HP, 210 RPM, 10 GPM	2	EA	480	960	2,885	5,770	6,730
THE GREENLESS COMPANY -	PETER	ETERS	ON – V	ENDOR QUOT	E DATED	11/6/78	
404-261-1781							
EFFLUENT RECIRCULATION							
PUMPS - VERTICAL DRY PIT,							
1.5 HP, 1150 RPM,				1.28			
50 GPM PANEL, W/TIMER,							
MOTOR STARTERS	2	EA	320	960	1,500	3,000	3,960
EQUIPMENT SALES COMPANY,	INC	VANC	E MORR	OW - VENDO	R QUOTE	12/21/78	
803-787-6342							




PROJECT TITLE: Utility St	1				D/	ATE PREPARE	D_Jan. 31, 19
ACTIVITY & LOCATION: MCB							
A&E FIRM & ADDRESS: J. E. P. O. Greenv	Sirrine Box 545 Ville, S	Comp 6 .C. 2	any 9606	CONST. NO.	CONTRA	ACT A8 NC	E CONTRACT ). N62470-78- C-3675
PRELIMINARY ESTIMATE ( )	Conference of	FINAL	EST IM	ATE ()	RE	VISED FINAL	ESTIMATE (x)
HEADING WASTEWATER TREATMENT PLA	NT	EST H. L	IMATOR	VERT	CHEC	KED BY	
EQUIPMENT MATERIAL DESCRIPTION	QUANT NO. UNITS	UNIT	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL
RECYCLE & SLUDGE UNDER-							
ONE (1) 6" KENNISON							
NOZZLE TWO (2) 6" HALF							
SECTION KENNISON NOZZLES							
FOUR (4) TRANSMITTERS							
FOUR (4) RECEIVERS		1.000					
TWO (2) TOTALIZERS							
FOUR (4) SEDIMENT TRAPS	1	EA	2,000	2,000	17,000	17,000	19,000
THE TAULMAN SALES COMPA 704-554-7013	NY – PAI	UL WH	TE -	1			
FLOAT PIPE & PIPING FOR							
KENNISON NOZZLES	4	EA	200	800	300	1,200	2,000
TRICKLING FILTER MEDIA							
ROCK (2.5" - 4.0"∅)	840	C.Y.	2.50	2,100	30	25,200	27,300
TRICKLING FILTER							
UNDERDRAIN BLOCKS	352	S.Y.	1.50	528	22	7,744	8,272
THE BOWERSTON SHALE COM 614-269-2921	PANY -	FRANK	H. MII	LIKEN, JR.	- VEN	DOR QUOTE I	ATED 10/26/78

.




ROJECT TITLE: <u>Utility St</u>	udy - C	ourth	ouse Bay	y Area	DA	TE PREPARE	D_Jan. 31, 1
CTIVITY & LOCATION: MCB,	and the second se						
&E FIRM & ADDRESS: J. E. P. O. Greenv	Sirrine Box 545 ille, S	Comp. 6 .C. 2	any 9606	CONST. NO.	CONTRA	NCT A8	E CONTRACT . N62470-78- C-3675
PRELIMINARY ESTIMATE ( )							
HEADING WASTEWATER TREATMENT PLAN	٧T	ESTI H. D	MATOR . LIENE	RT	CHECI	KED BY	
EQUIPMENT MATERIAL DESCRIPTION	NO.	UNIT	PER UNIT	BOR	PER UNIT	TERIAL	TOTAL COST
ACUUM-FEED CHLORINATOR 1 TON C12 CYL. SYSTEM							
AUTO SWITCHOVER							
C12 RESIDUAL SAMPLER & RECORDER	2	EA	2,800	5,600	6,950		19,500
ROBERT E. MASON COMPANY	- TERRE	L C00	K - VEN	DOR QUOTE	DATED	10/23/78	

.




ROJECT TITLE: <u>Utility St</u> CTIVITY & LOCATION: MCB,					DA	ATE PREPARE	D Jan. 31,
E FIRM & ADDRESS: J. E. P. O. Greenv	1998 A 1997 A				CONTRA	ACT AE	ME CONTRACT ). N62470-78 C-3675
RELIMINARY ESTIMATE ( )	the second second second second	ALL ALL AND ALL ALL ALL		and the second	i en	anto material distance i la ser	L ESTIMATE (
HEADING WASTE WATER TREATMENT PLANT		ESTI	LIENER	A STATE OF A STATE OF A STATE OF A STATE		KED BY	
	QUANTI	ITY	E L	ABOR	ti	ATERIAL	L
EQUIPMENT MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS.	PER UNIT	TOTAL	PER UNIT	T	TOTAL COST
SUBTOTAL .				\$ 44,428		\$258,044	\$ 302,472
SUB-CONTRACTOR MARKUPS	49	%					148,211
SUBTOTAL							450,683
CONTINGENCY	10	%					45,068
SUBTOTAL							495,752
ESCALATION TO 1 JAN. 19	80 11	%					54,533
SUBTOTAL							550,284
						COST/SYSTE	М
TOTAL	153,000	GAL.				3.60	\$ 550,284
ADDITIONAL WASTE WATER PLANT CAPACITY		T					

.



ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. (				D_Jan. 31, 1
A&E FIRM & ADDRESS: J. E. P. O. Greenw	Box 545	6	ner national construction and Realization of the state of the Realization of the state of the st	NO.	anten de la composition de la	NC	E CONTRACT 1. N62470-78- C-3675
PRELIMINARY ESTIMATE ( )		FINAL	ESTIMA		REV		ESTIMATE (
HEADING WASTEWATER TREAT			And the second second second	and the second	CHECK		
PLANT	QUANT		1	ABOR	E PIA	TERIAL	
ELECTRICAL MATERIAL DESCRIPTION	and the subscription of th	UNIT	PER	TOTAL	PERUNIT	TOTAL	TOTAL COST
SIZE O MAGNETIC STARTERS	. 7	EA	50.	350	165.	1155	\$ 1,50
1" PVC CONDUIT	425	LF	.55	233	.30	127	360
3/4" PVC CONDUIT	120	LF	.48	57	.20	24	81
#10 THW	1,750	LF	.10	175	.06	105	280
#12 THW	500	LF	.09	45	.04	20	6!
DITCHING BACKFILL	265	LF	1,30	344			344
COMPACTION FOR BURIAL							
OF PVC CONDUIT							
FLEXIBLE CONDUIT & FITTIN	GS 7	EA	20.	140	12.	84	224
	i i Lin A Sector						
SUB TOTAL	Contractory of			1,344		612	2,859
CONTRACTOR MARK UPS	49%						1,401
SUB TOTAL	4570						4,260
CONTINGENCY	10%					<u>.</u>	4,200
SUB TOTAL	10%						4,686
ESCALATION TO 1-1-80	11%						4,000
SUB TOTAL							5,201
TOTAL	153000	GAL		0		29.42	5,200
and the set for the second second	a transfer						
	t i star						Sec. Sec. Sec. Sec. Sec. Sec. Sec. Sec.





# ROBERT L. CARLSON, INC. - Manufacturers' Representative

WATER, WATER POLLUTION AND INDUSTRIAL PLANT EQUIPMENT

October 19, 1978

. O. BOX 11031 CHARLOTTE, N. C. 28209 TEL.: 704-332-9031 -527-56444

Mr. Howard LinertJ. E. Sirrine CompanyP. O. Box 5456, Sta. BGreenville, South Carolina 29606

Subject: Sirrine Job # A-1086 Camp LeJune, N.C.

Dear Howard:

Confirmed estimating prices given to you today as follows:

One(1) Walker Process Rotary Distributor 62 foot diameter 200 gpm min. 800 gpm max.size 10 M-center column 4-6" arms Estimate: \$25,000.00

- One(1) Walker Process Type C primary collector with skimmer and weir plates and baffles 27 foot diameter Estimate: \$22,000.00
- One(1) Walker Process Type C secondary collector (complete as above) Estimate: \$22,000.00
- Two(2) EPI floating aerators 10 HP complete with mooring hardware Estimate: \$ 8,500.00


Please let me know if you need any more information.

Thank you for your interest in our products.

Sincerely yours, ROBERT L. CARLSON, INC. Charles R. Hunter, Jr.

CRH:bl

Designed by those who know the best - for those who want the best.



Mr. Howard Linert J. E. Sirrine Company P.O. Box 5456, Sta. B Greenville, South Carolina 29606

Exclusive Sales Representative ROBERT L. CARLSON, INC. P. O. BOX 11031 CHARLOTTE, NORTH CAROLINA 28209 Phone: (704) 332-9031

Job #A-1086 Camp LeJune, N.C. BJECT:

DATE: Oct. 23, 1978

FOLD

Dear Howard:

Confirming estimate on a 7.5 foot diameter WALKER PROCESS poly-thickener of \$25,000.00 with steel tank. Deduct \$6,300.00 for the outer tank.

If you need any further information, please let us know.

Very truly yours,

ROBERT L. CARLSON, INC.


411 Unc Charles R. Hunter, Jr.

CRH:bl


PLEASE REPLY TO SIGNED

REPLY

ATE:



your Reply Date JOHNSTON, INC. SUITE 108 / 611 TEMPLETON AVE. CHARLOTTE, N.C. 28203 Telephone: (704) 377-3785 Noward Lievent - 9. E. SIRRINE Ref: Camp Le Jeune Job # A- 1086 Preselectimate of 12/21/18 2/5/19 Our Message Confirming estimate of \$25,000 for aenobic digester, 20' diameter × 18' SLD. Course te taukage. Qual blowere, 15 HP, 300 CFM. Solids landing = . 1 # volatile solide /cu. ft. / day. To gom / efm Ain. Norreles @ 12' subtacequice. 700 # day Oz - 304/ bour. Manufacturer - Sepurbia Systems. Heat regarde - Mac Jolunton



# THE BOWERSTON SHALE COMPANY Drainage Material Specialists

BOWERSTON, OHIO 44695

614/269-2921

October 26, 1978

FACTORIES BOWERSTON · HANOVER OHIO

Howard Lienert J. E. Sirrine Co. Box 5456 Station B Greenville, South Carolina 29606

Subject: Sewage Treatment Plant - Camp LeJeune, Beaufort, South Carolina

Dear Mr. Lienert:

•

Thank you very much for your request for information on Bosco Trickling Filter Underdrain Block for the 62 foot filter to be constructed at Camp LeJeune, Parris Island, South Carolina.

352 Square Yards BOSCO ASTM C159-63 Type I-H Airflow High Rate Underdrain Block fob jobsite, truck delivery, if available to the truck under it's own power \$22.00 per Sq. Yd.

A 62 foot diameter trickling filter requires 335 square yards of block. Adding a 5% allowance for breakage would bring this to 352 square yards of block for the job.

This quotation includes the  $7\frac{1}{2} \times 10 \times 14$  full size underdrain block required, half and quarter spacer block, angle block at the periphery of the filter and cover block up to 30 inches in length over a center effluent channel. It does not include reducer block for channels through concrete walls.

Bosco block are hard burned block which exceed the requirements of ASTM C159 in every way. They have been tested regularly for crushing strength and test at over 1100 lbs. per square inch while the standard asks for a minimum of 600 lbs. per square yard.

This quotation would be for shipment in 1979, and if shipment would be for 1980 or later as discussed an escalation should be added.


Please contact us if further information is desired.

Sincerely,

THE BOWERSTON SHALE COMPANY

Frank H. Milliken, Jr. di

FHMjr/nb





## ROBERT E. MASON COMPANY

PROCESS AND CONTROL EQUIPMENT FOR CAROLINA INDUSTRY 1726 NORTH GRAHAM STREET, P. O. BOX 1903 CHARLOTTE, NORTH CAROLINA 282.33 TELEPHONE 704 375-4464

November 8, 1978

Mr. Howard Lienert J. E. Sirrine Company P. O. Box 5456 Greenville, SC 29606

Subject: Camp Lejuene Project

Dear Howard:

ł

This letter is to confirm our discussions on the chlorination system, influent pumping system, and the floating aerator for the above project.

## Chlorination System

The chlorination system will be a flow proportioning system with automatic switchover capable of supplying up to a maximum of 200 ppd of chlorine to a wastewater contact basin. The system will be ADVANCE Model 842 described in the enclosed Bulletin 1840-5 and specification No. 2840-4, including the following equipment:


- 2 Manifold-mounted vacuum regulators
- 2 Wall manifolds
- 1 Wall mounted ejector
- 1 Automatic switchover module
- 1 Open channel diffuser

Total Budgetary Price - \$4,100

## Pumping System

The pumping system will be a tri-plex pump setup with two-speed motors on each pump and complete with sequencing control panel actuating from mercury float switches. Characteristic curves for the pumps and a brochure on the Series 8000 pump configuration are enclosed. The pumping system includes the following equipment:

(Cont'd on Page 2)





Page 2 November 8, 1978

•

- 1 Model MS-3, 3 HP, two-speed pump
- 2 Model MM-3, 5 HP, two-speed pumps
- 1 NEMA 4 tri-plex control panel
- 6 Mercury float switches

Total Budgetary Price - \$12,000

#### Floating Aerator

1 - LIGHTNIN Model LAR-90 floating aerator complete with 20 HP drive and floating platform. The unit is described further on the enclosed Drawing No. DS-E-338.

Total Budgetary Price - \$23,000

We certainly appreciate the opportunity to work with you on this project. If you have any questions or need additional information, please do not hesitate to contact our office.

Very truly yours,


ROBERT E. MASON COMPANY

llCooks 110

Terrell Cook

TC/lhb

Enclosures





## Robert E. Mason Company

PROCESS AND CONTROL EQUIPMENT FOR CAROLINA INDUSTRY 1726 NORTH GRAHAM STREET, P. O. BOX 1903 CHARLOTTE, NORTH CAROLINA 28233 TELEPHONE 704 375-4464

December 18, 1978

Mr. Howard Lienert J. E. SIRRINE COMPANY P. O. Box 5456 Greenville, South Carolina 29606

Subject: Camp Lejuene Project Chlorine Residual Analyzer

Dear Howard:

ł

Enclosed is Bulletin 1870-3 which describes the ADVANCE Series 870 Chlorine Residual Analyzers and Recorders. A typical installation for an application such as yours is shown on the third page of the brochure. In this type of installation, a sample is picked up from a chlorine contact chamber or from a suitable point at your discharge and pumped up to the analyzer. The analyzer measures the chlorine residual and sends a signal to the circular chart recorder for a permanent record of the residual level. Also, the recorder has switches for use with high and low level alarms.

As I mentioned during our telephone conversation, a budget price of \$2,850.00 would cover the complete system. Included in this system would be a wall mounted analyzer, and initial supply of the reagent and buffer chemicals, a wall mounted recorder, and the sample pump.

I trust this information will be helpful to you. If you have any questions, please do not hesitate to give me a call.


Yours very truly,

ROBERT E. MASON COMPANY

Serrell Cook, cp)

Terrell Cook-

TC/cp Enclosure



#### THE TAULMAN SALES COMPANY A DIVISION OF THE TAULMAN COMPANY



Suite 512, Two Fairview Plaza 5950 Fairview Road Charlotte, North Carolina 28210 704/554-7013

November 2, 1978

Mr. Howard Lienert J. E. Sirrine Company Post Office Box 5456, Sta. B Greenville, South Carolina 29606

SUBJECT: U. S. Navy, Camp LeJeune Jacksonville, North Carolina Recycle Flow Indication J. E. Sirrine #A1086

Dear Mr. Lienert:

Confirming our phone conversation, I propose the following standard BIF equipment;

- One 6" Kennison Nozzle for the new trickling filter. Maximum rate: 200 gpm/290,000 GPD.
- Two 6" half section, Kennison Nozzle for the two new clarifiers. Maximum rate: 90 GPM/130,000 GPD.
- Four "Chronoflo", time-pulse, float actuated flow transmitter for the existing and new trickling filters and new clarifiers.
- Four "Chronoflo" receivers with the function of indicating the flows from the above transmitters.
- Four Sediment traps, but no piping from Nozzle to stilling chambers for the float-flow transmitters.

I have arrived at a budget price for the above equipment which will include freight, FOB shipment point, service, recommended spare parts, and operative and maintenance manuals.

Budget Price . . . . . . . . . . . . . . . . \$16,500


I have enclosed recommended specifications for the above equipment. Please do not hesitate in calling if I may be of further assistance.

Yours very truly,

Dawl M. R. White

Paul M. R. White

PMRW/sh Attachment



# THE TAULMAN SALES COMPANY



Suite 512, Two Fairview Plaza 5950 Fairview Road Charlotte, North Carolina 28210 704/554-7013

November 21, 1978

Mr. Howard Lienert J. E. Sirrine Company Post Office Box 5456, Sta. B Greenville, South Carolina 29606

SUBJECT: U. S. Navy, Camp LeJeune Jacksonville, North Carolina Recycle Flow Indication J. E. Sirrine #A1086

Dear Mr. Lienert:

Please pardon the lateness of this confirmation. This letter confirms the addition of two totalizers for the two clarifier recycle flow indicators at a budget price of \$500.00. Referring to my letter to you dated ll-2-78, the revised total budget price is \$17,000.


Please call if I may be of further assistance. Thank you.

Yours very truly,


THE TAULMAN SALES COMPANY Paul White

Paul M. R. White

PMRW/sh



Mr. Howard Lienert ES (() Equipment Sale's Company, Inc. Pg. of O. Box 31181 P. O. Box 15291 EQUIPMENT SALES CO. INC. Raleigh, N. C. 27607 Phone (919) 781-5670 Charlotte, N. C. 28210 P. O. BOX 6321 Phone (704) 525-7909 COLUMBIA, S. C. 29260 12/21/78 Subject: U.S. Navy Date: Camp Leivene, N.C. A-1086 Bid Due: Engineer: J.E. SIRRINE CO. GENTLEMEN: We are pleased to quote on the above subject job as follows subject to the engineers approval. Duplex Weil Pump Con Bull, C- good Vertical enclosed shaft non-clog pumps. 756PM × 17' TOH Unit consists of: 2 - pumps for 5 deep sump complete with 20" dia, ploor plates. [Sump by others] 2- 1/2 H.P., 1150 rpm, 230-460/3/60 dripproof motors. 1 - High water alarm float with switch 115 V 1 - 4", 115V, alarm bell 48" steel sump cover with openings for floor plates; inspection plate; Mounting holes for high water alarm float 1 - Duplex motor controller consisting of - Magnetic Starters - Disconnect switches Automatic alternation Terminal Strip Contractors COST, FOB Chicago, Ill., -- \$2758 Approx WTo 1570# Approx Freight -NO TAXES INCLODED BRANCH OFFICES RICHMOND, VA / CHARLOTTE, N. C. / RALEIGH, N. C. / CHARLESTON, S. C.





#### ROBERT L. CARLSON, INC. - Manufacturers' Representative

WATER, WATER POLLUTION AND INDUSTRIAL PLANT EQUIPMENT

December 28, 1978

P. O. BOX 11031 CHARLOTTE, N. C. 28209 TEL: 70

204 527-5644

Mr. Howard LienertJ. E. Sirrine CompanyP. O. Box 5456, Station BGreenville, South Carolina 29606

Subject: Job A-1086 Camp LeJeune, N.C.

Dear Howard:

Confirming estimates given you today on WALKER PROCESS equipment, we offer the following:

 WALKER PROCESS Primary Collector, Type CP-22 foot diameter, 8 foot SWD, bridge supported; complete with 14" worm gear, bridge and floor plate, collection arms, influent well and skimmer and scum box.

Estimate Price \$18,500.00

 WALKER PROCESS Rollaer for 20' diameter 15' SWD. Use a 24" tube, 85 SCFM @ 7.5 psig Rollaer unit complete with 20 foot bridge and 24" tube for 15 SWD.

Estimate Price \$12,500.00

Howard, for air supply I'd recommend a positive displacement blower. I do not have this type equipment, but I would guess they would be about \$3,500.00 each.

If you have any questions, let me know. .

Sincerely yours,


WALKER PROCESS

Larles A

Charles R. Hunter, Jr. ROBERT L. CARLSON, INC.

CRH:bl

Designed by those who know the best - for those who want the best.



## ESHELMAN CAROLINAS, INC.

1127 COMMERCIAL AVE. P-O-BOX 12645 CHARLOTTE, N.C. 28205 Phone 704/376-6408

December 28, 1978

J. E. Sirrine Company P. O. Box 5456 - Station B Greenville, SC 29606

Attention: Mr. Howard Lienert

SUBJECT: Camp Lejeune, North Carolina Your Project Job# A-1086

Dear Mr. Lienert:

We are confirming our telephone discussion December 19, 1978.

Estimating price for FMC Environmental Division (Chicago Pump Co) Barminutor Model C-18, \$13,000.00 each. This will include the Barminutor as described in the catalog, plus the special reversing type starter with the controls.

The Model C-18 unit is recommended for the flow conditions as given to us which were 350,000 GPD minimum and 1,400,000 gallons per day peak or maximum flow.

The above estimate does not include stop gates.


Very truly yours,

ESHELMAN CAROLINAS, INCORPORATED

u

David Tobin


DT/NEK




▲

1

<u>- EXHIBIT A -</u> EXISTING SANITARY SEWER SYSTEM





and the second second

- ·

. 1997 - C. 1997 -

. A state of the sta •

•.

•• · .

• • • •

•

· · · · 

· ·

# 


,


• • • .

\* • 

Þ

<u>- EXHIBIT B -</u> PROPOSED SANITARY SEWER SYSTEM





· · · · ·

. • 

• 

.

الت الله

Δ

9

1


1

t

1

## - EXHIBIT C -

### SANITARY SEWER SYSTEM DATA CHARTS



EXISTING SANITARY SEWER SYSTEM DATA FOR COURTHOUSE BAY AREA

8

		S	ERIAL		INVERT ELEVATION		ED	z	ă¥.	×.	
MANHOLE NUMBER		_	AND MATERIAL SLOPE	UP STREAM	DOWN STREAM	TOP OF MANHOLE ELEVATION	CALCULATED MAX. EXISTING FLOW	EXISTING	TOTAL FLOW DURING PEAK DISCHARGE	MAXIMUM DESIGN FL	
412	FEET		S FT/F	FEET -0.88	FEET	_	G.P.M.	G.P.M.	G.P.M.		
	94.2	10 V.C.	P0023		- 1.22	9.92	390	25.1	415.1	471	
413	765.4			-0.66	-0.56	11.34				1	
414	355.4	10 V.C.	P0019	0.05	0.04	12.38	335	24.2	359.2	432	
	428.7	10 V.C.I	.0029		0.04	12.36	270	21.0	291.0	529	
415	705.0			1.34	1.28	12.73					
416	365.8	10 V.C.	P0035	2.64	2.63	11,17	120	17.2	137.2	579	
•	378.0	B V.C.F	.0040		1.00		68	13.9	81.9	343	
417	391.5	8 V.C.I	1 007	4.09	4.16	10.94					
418		<u>a v.o.</u>	.0031	5.35	5.31	12.43	68	10,5	78,5	G.P.M. 471 472 529 579 343 302 326 307 326 307 481 519 519 326 307 282 343 326 369 282 343 328 249 654 438 820 592 343 249 654 438 820 592 343	
	388.1	8 V.C.F	.0036			12.70	53	7.0	60.0	326	
419	385.3	B. 1/2-	0070	6.78	6.73	12.82					
425	000,5	8 V.C.F	.0032		8.01	10,81	47	3.5	50.5	GPM. 471 432 529 579 343 302 326 302 326 307 519 519 519 326 519 282 326 369 282 343 249 654 438 820 592 592 592	
										<ul> <li>G.P.M.</li> <li>4771</li> <li>4771</li> <li>4771</li> <li>4771</li> <li>4771</li> <li>529</li> <li>579</li> <li>3433</li> <li>302</li> <li>326</li> <li>307</li> <li>326</li> <li>307</li> <li>326</li> <li>307</li> <li>326</li> <li>307</li> <li>326</li> <li>302</li> <li>326</li> <li>369</li> <li>282</li> <li>3433</li> <li>249</li> <li>6554</li> <li>364</li> <li>592</li> <li>364</li> <li>220</li> <li>220</li> </ul>	
412				0.00							
	402.0	10 V.C.F	.0024	-0.88 ·	-1.22	9.92	302	58.8	360.8*	401	
422				0.18	0.08	15.50		36.6	360.8	481	
423	399.0	10 V.C.P	.0028	122			302	55.2	357.2*	519	
	402.4	IO V.C.P	.0028	1.22	1.28	11.44	302	51.6	353.6*	EIO	
428				2,48	2.34	11.84		01.0	333,6	519	
429	428.6	8 V.C.P.	.0036	4.03	407	17.07	302	48.0	350.0*	326	
	245.1	8 V.C.P.	.0046	4.03	4.03	13.03	302	44.1	346.1*	369	
1000	175.0			5.23	5.16	14.03	002		540.1	369	
431	175.0	8 V.C.P.	.0027	5.88	5.70	17.07	195	40.2	235.2*	282	
	129.7	8 V.C.P.	.0040	3.00	0.10	13.83	195	386	233.6*	343	
43I-A	000.0	0.110.0		6.47	6.40	15.60				G.P.M. 471 432 529 579 343 302 326 307 481 519 519 326 369 282 343 249 654 438 820 592 343 249 654 438 820 592 343 249 654 438 820	
438	226.6	8 V.C.P.	.0021	6.91	6.95	15.95	372	21.8	393.8	249	
	101.3	8 V.C.P.	.0145	<u> </u>	0.95	15.85	363	19.8	382.8	654	
663				8.87	8.38	18.15					
664	66.2	8 V.C.P.	.0065	10.33	9/3	10.03	363	18.9	381.9	438	
	250.9	8 V.C.P.	.0228		9.43	18.23	308	6.1	314.1	820	
665	28F 7		0110	16.12	16.06	22.20					
666	285.7	B V.C.P.	eiro.	20.79	19.51	27.01	308	3.8	311.8	592	
		6 C.I.P.					275		275		
IFT ST	ATION										
666	107 -			19.62	19.51	27.01					
667	127.5	8 V.C.P.	.0045		20.20	35.00	33	1.2	34.2	364	
					20.20	25.08					
412	94.8	10 V.C.P.	.0005	-0.27	-1.22	9.92					
672	0.10	10 1.U.F.	.0005	0.20	-0.32	7.57	·  ·	3.1	3,1	220	
	96.0	10 V.C.P.	.0066					2.2	2.2	798	
673	139.7	ID V.C.P.	.0212	0.91	0.83	8.99					
674					3.87	10.97		1.3	1.3	1430	

9

10

	<u> </u>	~ <u> </u>									<u> </u>	-ı
1				IN IN	ELE	IVERT EVATION			gg	7	> ×	
	MANHOLE NUMBER	DISTANCE	MANHOLES PIPE DIAMETER	AND MATERIAL SLOPE	UP STREAM	DOWN	TOP OF MANHOLE	ELEVATION	CALCULATED MAX. EXISTING FLOW	EXISTING INFILTRATION	TOTAL FLOW DURING PEAK DISCHARGE	MAXIMUM DESIGN FLOW
	2 Z											
	1000	FEET	INCHE	S FT/FT	FEET 5.65	FEET	FEE		G.P.M.	G.P.M.	. <u>G.P.M.</u>	G.P.
		140.8	3 8 V.C.	P0063	5.65	5.16	14.0	3	180	1.7	181.7	
	1001				6.56	6.54	11.5	9				43
ł		41.4	1 8 V.C.	P0186						0.4	0.4	740
	1002		_			7.33	, 11.5	9				
t			-									
· [	43I-A				7.11	6.40	15.6	0				
-	1003	245.0	8 V.C.	P0053					180	2.7	182.7	395
	1003	55.1	8 V.C.		8,54	8,40	12.57	4				
	1004				1-	8.98	13.55	5		0.5	0.5	485
											-	
-	43⊢A		_	-			_	_				
F	4JFA	215.8	6 V.C.F	8010, 9	6.57	6.40	15.60	2	65	12,9		-
Ľ	496				8.24	8.89	18.28	3		12,3	77.9	262
+		288.1	6 V.C.F	_					62	11.0	73.0	319
┢	497	248.1	8 V.C.F	2 .0090	16.31	12.89	23,25	5				
	497-A		0 4.0.1		18.51	18.55	25.22	2	. 52	8.4	60.4	515
		175.2	8 V.C.F	.0144					27	3.9	30.9	651
$\vdash$	497-8		0.10		21.04	21.04	28.14					
H	1005	40.3	8 V.C.F	.0238	22.10	22.00	29.37	_	13	2.3	15.3	837
		205.0	8 VC.P	_		22.00	23.51		13	1.9	14.9	656
	497-C					25.10	32.10					000
┝												
F	497-A				18.95	18.55	2522					
Ľ		252.5	6 V.C.P.	.0044	10.00	10.00	LULL		42	2.3	44.3	167
-	1006			-		20.06	24.23					
$\vdash$		<u> </u>										
	664				9.43	9.43	18.23	_				
Ľ		313.2	B V.C.P.	.0039	0.110	0.10	10.20		72	12.0	84.0	339
	668				10.67	10.65	16.93					
	669	318,7	8 V.C.P.	.0041	12.4.4		10.07	+	72	9.2	81.2	348
÷	000	280.3	8 V.C.P.	.0047	12.44	11.99	16.97	+	42	2.5	445	372
	670					13.75	17.90	+			44.5	- 512
	669			3	12.52	11,99	16.07	-				
		278.8	8 V.C.P.	.0084	12.05	11.35	16.97		55	3.8	58.8	497
	1007				14.85	14.86	20.32			0.0		491
+-	1008	149.1	6 V.C.P.	.0085					42	1.3	43.3	231
	1000					16.11	21.42	-				
-												
								-				
-						!						
<u> </u>	1											

•

•

8.

9

.

7

6

,

• • • • • •

7

أبيأ . 

.

. بال

•

DURCHA.PLENTELL, INC., CHARLETTE CO

· •

. .

	- <b>-</b>	-1	4		EXIS	STING				R SYS			FOR	· ,, ,			PRO	POSED		ITARY		
EXISTING INFILTRATION			-	MANHOLE NUMBER	DISTANCE BETWEEN MANHOLES	PIPE DIAMETER AND MATERIAL	SLOPE	UP STREAM <sup>™</sup> Z	VERT VATION SIREAM	TOP OF MANHOLE ELEVATION	CALCULATED MAX. EXISTING FLOW	EXISTING INFILTRATION	TOTAL FLOW DURING PEAK DISCHARGE	MAXIMUM DESIGN FLOW THRU PIPE		MANHOLE NUMBER	DISTANCE BETWEEN MANHOLES	PIPE DIAMETER AND MATERIAL		iN	VERT VATION NMOQ	
G.P.M.	G.P.M.	G.P.M.		366	FEET	INCHES		FEET	FEET 6.60	FEET	G.P.M.	G.P.M.	G.P.M.	G.P.M.		22	FEET	INCHES		5 S FEET	FEET	FEE
1.7	181.7	431	-	365	185.3	8 V.C.P.	.0034	5.98			28	4.15	32.15	315	-	1011	340	8 P.V.C.	.0039	-	9.96	14.75
0.4	0.4	740		364	254.5	8 V.C.P.	.0036		5.97	13.33	47	9.85	56.85	326		1012	175	8 P.V.C.	.0039	8.63	8.53	14.5
				1009	165.2	8 V.C.P.	.0150	5.06	5.03	8.49	47	13.55	60.55	662	-	1013	395	10 P.V.C.	.0030	7.85	7.75	14.50
2.7	182.7	395		1010	370.1	8 V.C.P.	.012.4	2.56	2.33	11.76	47	21.84	68.84	602		1014	300	IO P.V.C.	.0030	6.56	6.46	12.25
0.5	0.5	485			264.3	12 V.C.P.	.0064	-2.24	-2.24	10.54	47	27.76	74.76	1208	· ·	1015	80	10 C.I.P.	.0030	5.56	5.46	11.00
0.0	0.0			LIFT ST				-3.93						_		1016				5.22	5.12	12.00
																1017	350	IO P.V.C.	.0030	4.07	3.97	12.00
12,9	77.9	262													2	1018	250	IO P.V.C.	.0030	3.22	3.12	12.00
11.0	73.0	319														1019	100	10 P.V.C.	.0030	2.82	2.72	12.00
8.4	60.4	515							· · · ·							428	80	IO P.V.C.	.0030	2.48	2.34	11.84
3.9	30.9	651														1020	400	10 P.V.C.	.0023	1.42	1.32	00.11
2.3	15.3	837														1021	400	IO P.V.C.	.0023	0.40	0.30	11.00
1.9	14.9	656										vi -				1022	255	io p.v.c.	.0023	-0.29		
												h.				412	300	IO P.V.C.	.0023		-0.39	9.00
																				-1.08	-1.22	9.92
2.3	44.3	167										81	t									
												aî.				1023					6.21	14.50
12.0	84.0	339													•	1013	40	8 P.V.C.	.0052	8.00	7.75	14.50
9.2	81.2	348	ļ							·												
2.5	44.5	372	-								_	:				1024	105	8 .P.V.C.	.0052	_	7.25	12.25
			-													1014		0 .F.W.O.	.0052	6.70	646	12.25
			-																			
3.8	58.8	497	-									+										
1.3	43.3	231	ſ																			
			ŀ																			
-			L					L														
				•																		
															•							
															· .							
															•.							
		-														J.I	E. SIRR	INE CO		EPARTMEN		ANTIC

		STR				RE	VISIO	NS		DATE	APPRIYED	
											ATTICLE	
	Į		<u> </u>									_
												G
	PR	OP	OSEC	) SAN	IITARY	SEW	ER SY	STEM	DATA	FOR		7-
				COL	IRTHO	USE	BAY /	AREA				
_	T		 ד			VERT					<u> </u>	-
1.1		പ്പ	PIPE DIAMETER AND MATERIAL		ELE	VATION	z	CALCULATED MAX. EXISTING FLOW	_ No	EAK OW	MAXIMUM DESIGN FLOW THRU PIPE	
ER LE	ANCE	ЧG	ETE Mat	щ	AM	AM	OF ATIO	EXIS	IATE	E FL		
MANHOLE NUMBER	DISTANCE BETWEEN	MANHOLES	PIPE DIAMETER AND MATE	SLOPE	UP STREAM	DOWN STREAM	TOP OF MANHOLE ELEVATION	CALCULATED MAX. EXISTIN FLOW	ESTIMATED INFILTRATION	TOTAL FLOW DURING PEAK DISCHARGE	MAXIMUM DESIGN F THRU PIP	
	FEET	_	INCHES	FT/FT	FEET	FEET	FEET	G.P.M.	G.P.M.	GP.M.	SO⊢ G.P.M.	1
1011	340	-	0 010	0070	-	9.96	14.75					1
1012	340	╉	8 P.V.C.	.0039	8.63	8.53	14.50	180	1.3	181.3	440	
	175		8 P.V.C.	.0039				180	2.0	182.0	440	
1013	395	+	10 P.V.C.	.0030	7.85	7.75	14.50	288	3.9	2010	600	F
1014					6.56	6.46	12.25		5.9	291,9	699	
015	300	_	IO P.V.C.	.0030	E FC	E 40	11.00	380	5.9	385.9	699	
	80		0 C.I.P.	.0030	5.56	5.46	11.00	380	62	386.2	540	
016	750	_			5.22	5.12	12.00					
017	350	+	O P.V.C.	.0030	4.07	3.97	12.00	380	7.6	387.6	699	
	250	1	0 P.V.C.	.0030			.2.00	380	8.5	388.5	699	
018	100	-	O P.V.C.	.0030	3.22	3.12	12.00	700		2020		
019		÷	0 1.4.0.	.0030	2.82	2.72	12.00	380	8.9	388.9	699	
128	80	1	0 P.V.C.	.0030				380	9.2	389.2	699	
720	400	ī	O P.V.C.	.0023	2.48	234	11.84	380	10.8	390.8	612	
020		_			1.42	1.32	00.11					Ε
021	400	+"	<u> </u>	.0023	0.40	0.30	11.00	380	12.4	392,4	612	
	255	1	O P.V.C.	.0023				380	13.4	393.4	612	
022	300		P.V.C.	.0023	-0.29	-0.39	9.00	700		7040	-	
112		Ť	5 111.01	.0020	-1.08	-1.22	9.92	380	14.6	394.6	612	
								-				
		+										
		1										
		+										
23						8.21	14.50					
013	40	8	P.V.C.	.0052	0.00	222	14 5 5	180	0.16	180.2	509	
		1-			8.00	7.75	14.50					D
-		_								_		0
24	105	8	.P.V.C.	.0052		7.25	12.25	180	0.41	180.4	500	
014		Ē			6.70	646	12.25	100	0.41	180.4	509	
		-										
		-										
												—
		-								·		
		$\vdash$										
		<u> </u>	<u> </u>				I	L,	I			

2

1



5 4	3	A EPD FOR COMMANDER HAVPAC	EALT . PPEG.	XHIBIT 'C' 1	-
		PROVED DATE	CONS	атя. CONTR. NO. N62470-78-C-3675	
		FICER IN CHARGE	віхк соютк і вийнт но. F <b>8009</b> 1	NAVFAC DRAWING NO.	1
		PROVED DATE	SANITARY SEWE	ER SYSTEM DATA CHARTS	;
	70		COURTHOUSE	BAY & AMTRAC AREA	A
	PR	NOJ. MGR. JMD CH. ENGR. JWM	UTIL		`
		GREENVILLE, S. C. IS. TLD   DR. DPC   CHK.	MCB CAMP LI	EJEUNE, NORTH CAROLINA	_
		J. E. SIRRINE CO. Architects - Engineers	ATLAN	ITIC DIVISION	<u>_</u>
					- 1

, .

6

5

4

3

B

14

i Å

•

1 :

.

.

. . .

· · ·

-

.

. •

Д

þ

l

1

1

1

1

ļ


F


## <u>- EXHIBIT D -</u> EXISTING WATER DISTRIBUTION SYSTEM

A UTILITY STUDY

FOR

#### THE COURTHOUSE BAY AREA





n de la composition de

.

.

A


l


## <u>– EXHIBIT E –</u> PROPOSED WATER DISTRIBUTION SYSTEM

#### A UTILITY STUDY

FOR

THE COURTHOUSE BAY AREA





•

.

.

•

•

•

•

ς.

a second and the second se 

A


7


1

1

Î

# <u>– EXHIBIT F –</u> PROPOSED WATER TREATMENT PLANT YARD PIPING





· · ·

.

• • •

1

1

1

1

1

l

Î


### - EXHIBIT G -


WATER TREATMENT FLOW DIAGRAM


A UTILITY STUDY

FOR

THE COURTHOUSE BAY AREA WATER TREATMENT PLANT







•

I

1

1

1

1

61

1


1


l


### - EXHIBIT H -

WATER TREATMENT PLANT GENERAL ARRANGEMENT

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA WATER TREATMENT PLANT







•

1

1

I

1

1


I

Î

•

# <u>– EXHIBIT I –</u> WATER SAMPLE ANALYSES

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA WATER TREATMENT PLANT



J.E. SIRRINE COMPANY Engineers GREENVILLE, S. C.

1

1






## WATER ANALYSIS

12			Linkent		Contraction (Sec.	Job M	No. A-108	36-02		
CLIEN	TU.S.	. Navy				Date Received 9/22/78				
ADDR	<sub>ESS</sub> , Court	thouse Bay, Ca		Date Completed 10/09/78						
						Date Transn	Date Transmitted			
ample	Analysis No.			Identifica	tion					
I	36578	Well BB-221	Vell BB-221, Raw Water Taken 9/20-21/78							
II	36579		43, Raw Water taken 9/20-21/78							
III	36580		No. 44 Raw Water taken 9/20-21/78							
IV	36581	Well No. 220 Raw Water taken 9/20-21/78								
v	36582	Combined We					aken 9/20	-21/78		
		АРНА	Standard N	fethods used u	nless otherwise n	oted.				
Const	ituents, ppm		as	I	11	III	IV	V		
	Calcium	Ca	CaCO <sub>a</sub>	132	291	133	151	223		
CATIONS	Magnesium	Mg		1	2 1	_5	1.			
	Sodium	Na Z		30.1	19.1	23	23.2	30.2		
	Potassium	к 5			2018-0					
0						6				
	Total Cations			163.1	312.1	161	175.2	254.2		
Hereit	Bicarbonate	HCO:		146	265	127	157	214		
ANIONS	Carbonate	CO <sub>3</sub>		0	0	0	0	0		
	Hydroxide	OH		0	0	0	0	0		
	Chlorides	Cl		15	15	21	15	18		
	Sulfates	SO.		2	32	13	3	22		
	Nitrates	NOs		0.14	0.10	0.04	0.17	0.17		
	- Andreas									
	Total Anions			163.1	312.1	161	175.2	254.2		
Total Hardness				133	293	138	152	224		
Alkalinity Methyl Orange				146	265	127	157	214		
Alkalinity Phenolphthalein ""				0	0	0	0	0		
pH				7.3	7.2	7.5	7.3	7.15		
Total Solids (By Evaporation)				360	402	253	264	345		
Free (	Carbon Dioxide		CO.	15 ·	36	8.2	16	29		
Silica		and subscription in	SiO,	19	12	13	17	15		
Total Iron			Fe	2.9	3.1	1.8	1.6	1.9		
Manganese			Mn	0.06	0.03	0.05	0.06	0.06		
Alumi	num		Al			<u>, 61 (8)</u>				
			PO.	0.20	0.20	0.21	0.074	0.17		
Sulfite			SO:			<u> 1997 - 1998</u>		1		
Chemical Oxygen Demand (COD) O		0			<u> 1998</u>					
Turbidity				21	41	9.0	5.0	9.0		
Color			30	55	22	25	35			
Specific Conductivity mmhos/cm <sup>2</sup>			290	550	290	310	450			
Tota	1 Dissolve	ed Solids	and the second	251	388	253	264			
Dissolved Iron			0.01	0.01	0.01	0.01	0.017			

Remarks:

By\_



J.E. SIRRINE COMPANY Engineers GREENVILLE, S. C.




Job No. A-1086-02 Date 9/22/78 Received CLIENT U. S. Navy Date 10/09/78 Courthouse Bay, Camp LeJeune, N. C. Completed ADDRESS Date Transmitted Identification Sample | Analysis No. Detention Tank after Lime Addition Surface, 9/20-21/78 I 36583 II After Detention Tank before Filter Pumps, 9/20-21/78 36584 III Combined Filter Effluent after Backwash, 9/20-21/78 36585 Softener No. 1 Effluent before Regeneration, 9/20-21/78 IV 36586 Softener No. 1 Effluent after Regeneration, 9/20-21/78 v 36587 APHA Standard Methods used unless otherwise noted. I п III IV v 28 Constituents, ppm CaCO. 0 Calcium Ca 207 225 202 18 - 3 22 9 5 0 Magnesium Mg ..... CATIONS 29.2 35.1 211.1 Na 51.1 321.1 Sodium .. .. K Potassium ..... ..... 258.2 269.1 261.1 234.1 321.1 Total Cations ..... 204 Bicarbonate HCO: . . 216 223 216 196 28 Carbonate CO: 0 0 0 0 .. .. 0 0 0 Hydroxide OH 0 0 .... ANIONS Chlorides 22 66 Cl 21 22 22 11 11 23 16 23 Sulfates SO. 21 24 .. .. 0.12 0.14 Nitrates NO<sub>3</sub> 0.15 0.13 0.14 11 11 .. .. 258.2 269.1 321.1 261.1 234.1 **Total Anions** ..... 0 Total Hardness .... 229 234 210 23 232 216 223 216 196 Alkalinity Methyl Orange ..... 14 0 0 Alkalinity Phenolphthalein 0 0 ..... 7.7 7.8 8.7 7.8 pH 7.8 442 574 Total Solids (By Evaporation) 352 334 381 11 \$1.0 CO<sub>3</sub> 7.6 Free Carbon Dioxide 8.8 7.2 SiO, Silica 14 14 15 15 15 Fe Total Iron 1.8 0.76 3.3 2.9 0.13 0.04 Mn (0.01 0.07 0.01 Manganese 0.06 Al Aluminum 0.11 PO. 0.20 0.095 0.028 0.028 Phosphate SO: Sulfite 0 Chemical Oxygen Demand (COD) 0.20 0.58 1.4 7.5 Turbidity 8.2 Color <5.0 12 35 < 5.0 35 Specific Conductivity mmhos/cm<sup>2</sup> 450 400 560 460 450 547 371 417 Total Dissolved Solids 333 334 0.45 0.01 0.042 Dissolved Iron 0.011 0.03

Remarks:

By\_

Analyst



J.E. SIRRINE COMPANY Engineers GREENVILLE, B. C.




						Job N	io. A-10	86-02			
CLIEN	TTU.S	Date Received 9/22/78 Date Completed 10/09/78									
ADDR	ess Cour										
						Date Transm	itted				
Sample	Analysis No.		ion								
I	36588	Softener	r No. 2 Effluent, taken 9/21-22/78								
Ш	36589	Plant Effluent Combined Flows, taken 9/21-22/78									
III											
IV											
v			PHA Standard N	(athada wood um	loss othomaiss n	atad					
Carat		A	as as	I I	II II	III	IV	v			
Const	ituents, ppm Calcium	Ca	CaCOa	0	75						
	Magnesium	Mg				Sec. (2)	Acres 2 R	T. Shaled			
SNC	Sodium	Na 7		259.2	152.1						
CATIONS	Potassium	кЗ		Second Second							
CA	·	N. 62									
	Total Cations			259.2	231.1						
1	Bicarbonate	HCO:		214	193						
	Carbonate	CO <sub>8</sub>		0	0						
ANIONS	Hydroxide	OH		0	0						
	Chlorides	Cl		22	22						
IN	Sulfates	SO4		23	16						
V	Nitrates	NO <sub>8</sub>		0.15	0.09						
								CV.			
	Total Anions			259.2	231.1						
Total Hardness				0	79						
Alkalinity Methyl Orange				214	193						
	nity Phenolphtha	alein		0	0						
pH Total Solids (By Evaporation)				7.85	7.90						
	Carbon Dioxide	oration)	CO <sub>2</sub>	497	301			100			
Silica	arbon Dioxide		SiO	15	17		1.20.1.23	1.000			
Total Iron			Fe	0.23	0.27						
Manganese			Mn	0.02	0.01						
Aluminum			Al								
Phosphate			PO.	0.046	0.025	A State of the second					
Sulfite			SO <sub>8</sub>								
Chemical Oxygen Demand (COD)			0	10 10 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1							
Turbid	lity			0.28	0.33	1999 B		Part and			
Color				(5.0	<b>Հ5.0</b>	1. 2. 1. 1.					
Specifi	ic Conductivity		mmhos/cm <sup>2</sup>	480	390						
Tota	l Dissolve	d Solids		494	364			hand a start in			
Disso	olved Iron	0.113.53		0.024	0.024	26.00	1. S	L. Linder			

Remarks:

•

Babb and Davidson

By\_



A

1

I

I

1


1


I


1

<u>– EXHIBIT J –</u> WASTEWATER TREATMENT FLOW DIAGRAM

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA WASTEWATER TREATMENT PLANT







<u>– EXHIBIT K –</u> WASTEWATER TREATMENT PLANT GENERAL ARRANGEMENT

A


1


ł

1


J. E. SIRRINE COMPANY

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA WASTEWATER TREATMENT PLANT





~ DRYING AIR BLOWERS AEROBIC DIGESTER GRAVITY THICKENER NO.S. 1+2 NEW ---- TO BE REMOVED EXISTING EXHIBIT J.E. SIRRINE CO.





A

•

<u>- EXHIBIT L -</u> EXISTING STEAM DISTRIBUTION

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA





فوبوما

· ·

A


I


Ī

P

<u>- EXHIBIT M -</u> PROPOSED STEAM DISTRIBUTION

A UTILITY STUDY FOR THE COURTHOUSE BAY AREA





5.....

· • .

•

· . ·

• • • ;

.

.

.

,

• •

-

•

.....

ر ب L Ĺ  $\Box$ 

.


.


.


ŝ

T

-<u>APPENDIX I</u>-WATER AND SANITARY SEWER DISTRIBUTION AND COLLECTOR SYSTEM A UTILITY STUDY FOR THE COURTHOUSE BAY AREA







### APPENDIX I

4

ł

6


-

-

J. E. SIRRINE COMPANY

## INDEX

	그는 일을 얻는 것이 같아. 것 같아. 집 문서 방법을 가 있을	PAGE
1.	SOIL REPORT	1
2.	FIELD MEASUREMENT SKETCHES OF EXISTING SANITARY SEWER MANHOLES	4
3.	INFILTRATION RATE CALCULATIONS	28
4.	EXISTING SANITARY SEWER COLLECTOR SYSTEM CALCULATIONS	32
5.	PROPOSED SANITARY SEWER COLLECTOR SYSTEM CALCULATIONS	46
6.	EXISTING SANITARY SEWER LIFT STATION CALCULATIONS	50
7.	CALCULATION FOR THE RECOMMENDATION TO THE EXISTING SANITARY SEWER LIFT STATION	55
8.	EXISTING WATER DEMAND CALCULATIONS	59
9.	PROPOSED WATER DEMAND CALCULATIONS	66
10.	EXISTING RAW WATER SUPPLY CALCULATIONS	69
11.	PROPOSED RAW WATER SUPPLY CALCULATIONS	75
12.	FIRE PROTECTION REQUIREMENT FOR COURTHOUSE BAY AREA	78
13.	FIRE PROTECTION REQUIREMENT FOR AMTRAC AREA	81
14.	FIRE PROTECTION CHARTS	82
15.	FIRE PROTECTION CALCULATIONS	87






# Soil Systems, Inc.

# ". Soll Report

SUBSURFACE INVESTIGATION AND ENGINEERING EVALUATION BEQ PROJECT P-613 CAMP LEJEUNE, NORTH CAROLINA SIRRINE JOB NUMBER A-1085

OUR PROJECT NUMBER SSC-359



Page 7

from that encountered at the remainder of the site in that a 2.5-foot thick lens of stiff clay is sandwiched within the upper sands at 3 to 5.5 feet below existing grade.

In the proposed parking areas serving the facilities at Hadnot Point, loose to firm sands (N = 6 to 39 blows per foot) were encountered in the 5-foot depth investigated.

Ground Water: The ground water table at Hadnot .. Point generally stabilized at 5 to 7 feet below the existing ground surface, or elevation 19.5 to 21.5. A tabulation of ground water table depths and elevations is presented on Table 1.


Additional subsurface data concerning Hadnot Point is summarized on Table 1 and presented on Subsurface Profile Sections A-A and B-B.

### Courthouse Bay

Site Location and Description: The new BEQ facilities to be located at the Courthouse Bay site will be constructed on the west end of Grace Lane to a point as close as 300 feet to the bay. The site was generally heavily wooded at the time of our field investigation, with numerous power lines and unpaved roads crossing it, and several small structures scattered about the area. The ground surface within the proposed construction area ranges from elevation 18 to elevation 6, sloping downward toward the west end of the bay.

Subsurface Conditions: The subsurface conditions at the locations of Building #4/Solar Facility #4A, Building #5/Solar Facility #5A, and Building #6/Solar Facility #6A, were investigated by borings CH-7; CH-41 through CH-44, by borings CH-12; CH-37 through CH-40, and by borings CH-18; CH-45 through CH-48, respectively. The subsurface conditions at the Mechanical Building are described by boring CH-9, while in the access road and parking areas, the subsurface conditions are shown on Test Boring Records CH-1 through CH-5, CH-17, CH-21 through CH-23, CH-6, CH-8, CH-14, CH-15, CH-19, and CH-20. The steam line was investigated by borings CH-10, CH-11, CH-13, CH-16, and CH-23 through CH-36.

1OFZ




Soils: The borings drilled at the locations of the buildings/solar facilities and Mechanical Building generally encountered an upper sand zone which averages 10 to 12 feet in thickness and is underlain by an 8 to 25-foot thick strata of plastic clay soils. Sands are then again present below the clay soil strata.


Sands were also generally encountered to the depth of penetration of the steam line, access road and parking area borings.


The sands are very loose to very dense in consistency (N = 2 to 50 blows per foot), while the clays generally exhibit consistencies in the soft range (N = 2 to 4 blows per foot).


Ground Water: The ground water table at Courthouse Bay generally stabilized at 3 to 6 feet below existing grade but at elevations varying widely from 3 to 2.5 feet above sea level.


Additional subsurface data concerning Courthouse Bay is summarized on Table 2 and presented on Subsurface Profile Sections C-C through P-P.























SANITARY SEWER	MANHOLE	NUMBER _41	3
TOP OF MANHOLE ELEV. 11.3 DEPTH OF MANHOLE 12.4 PIPE SIZE 12 TYPE OF MATERIAL VC DEPTH OF FLOW 26 TIME MEASURED 26	2FT. 2_IN. 2_IN. 2_IN. IE-0.6		1 A
PIPE SIZE TYPE OF MATERIAL DEPTH OF FLOW TIME MEASURED COMPARED	5 IN.	(4) (3) IE 5.23	3
PIPE SIZE TYPE OF MATERIAL DEPTH OF FLOW TIME MEASURED 06:	2_IN		
PIPE SIZE TYPE OF MATERIAL_VO DEPTH OF FLOW TIME MEASURED 06:	2IN		
A-E CONTRACT NO. NG2470-78-C-3675	J. E. SIRRINE	E COMPANY	PAGE 4 OF 24
	7		




#### SANITARY SEWER MANHOLE NUMBER 412 TOP OF MANHOLE ELEV. 9.92 DEPTH OF MANHOLE \_\_\_\_\_AFT. PIPE SIZE 1E-1.19 10 IN TYPE OF MATERIAL VCP 1E -0.27 DEPTH OF FLOW 31/2 IN. 1F. -1.22 TIME MEASURED 05:58 1E 6.26 1E 2.67 10 IN PIPE SIZE TYPE OF MATERIAL VCP IE -0.88 DEPTH OF FLOW \_\_\_\_IN. 05:58 TIME MEASURED SPIPE SIZE PIPE SIZE 12 IN 10 IN TYPE OF MATERIAL CIP TYPE OF MATERIAL VCP Z/2 IN PEPTH OF FLOW 7/4 IN DEPTHOFFLOW TIME MEASURED 05:58 TIME MEASURED 5:58 PIPE SIZE \_12\_IN PIPE SIZE 6 IN TYPE OF MATERIAL CIP TYPE OF MATERIAL VCP DEPTH OF FLOW \_O\_IN DEPTH OF FLOW OIN TIME MEASURED 05:58 TIME MEASURED 5:58 SANITARY SEWER MANHOLE NUMBER 672 TOP OF MANHOLE ELEV. 7.57 7.89 FT. DEPTH OF MANHOLE PIPE SIZE 10 IN NE 0.20 TYPE OF MATERIAL VCP \_\_\_\_ IN. DEPTH OF FLOW TIME MEASURED 10 IN 1.E. -0.32 PIPE SIZE VCP TYPE OF MATERIAL \_\_\_\_ IN. DEPTH OF FLOW TIME MEASURED


A-E CONTRACT NO. NG2470-78-C-3675 J. E. SIRRINE COMPANY PAGE 5 OF 24








SANITARY	SEWER	MANHOLE	NUMBER	674
DEPTH OF I TIME MEASU	HOLE _7.14 TERIAL _VC FLOW IRED TERIAL _VC FLOW	2.FT. IN. IN. IN.	(1) IE 4.04 IE 3.87	4
A-E CONTRACT NG2470-78-C		J. E. SIRRINE	E COMPANY	PAGE 6 OF 24
		9		




















































# SANITARY SEWER MANHOLE NUMBER 497-A


















TYPE OF MATERIAL VCP


DEPTH OF FLOW


TIME MEASURED


\_O\_IN


10:37











NG2470-78-C-3670

(20)


A-E CONTRACT


NO.

J. E. SIRRINE COMPANY

PAGE

17 OF 24







## SANITARY SEWER MANHOLE NUMBER 667


1


A-E CONTRACT NO. NG2470-78-6-3675	J. E. SIRRINE COMPANY	PAGE 18 OF 24
TYPE OF MATERIAL	0_IN	
DEPTH OF FLOW	8 IN IE 22.47 3 0 IN. 5:00	
PIPE SIZE TYPE OF MATERIAL DEPTH OF FLOW	88FT. 6_IN.	N 1.20

(IS











A-E CONTRACT NO. NGZ470-78-C-3675 J. 1

J. E. SIRRINE COMPANY


23

PAGE 200F 24






SANITARY	SEWER	MANHOLE	NUMBER .	366
DEPTH OF F TIME MEASU	OLE 4.72 FERIAL VER TERIAL VER TERIAL VER	E_FT. IN. IN. IN.	( BE	7.02
TYPE OF MI DEPTH OF	ATERIAL_VC FLOW SUREP _14	IN IN		-
DEPTHOF	ATERIAL VC FLOW 1/4 SURED 19:	_IN		
A-E CONTRACT NGZ470-78-C-		J. E. SIRRINE	E COMPANY	PAGE ZI OF Z4
		(24)		




## SANITARY SEWER MANHOLE NUMBER \_365




25

22 OF 24

N62470-78-6-3675





4


\$


N


ł

SANITARY SEWER	R MANHOLE	NUMBER	1010
TIME MEASURED	278 FT. 8 IN 100 12 IN 12 IN 190 12 IN 190 10	IE-2.24	-2.24
TIME MEASURED	4:40		
A-E CONTRACT NO.			Y PAGE


66)








NOV 75-JES 22 J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A -1086 DATE 12/20/78 JOB AMTIPAC AREA TUD B. INFILTRATION RATE CALCULATIONS S.S.M.H. #1009 1/2" ) ''." SLOPE = (2.56'-2.33') = 0.0575 5'' = (0.0575)'' = 0.2398 $\frac{d}{D} = \frac{0.5}{8} = 0.06$  FROM CHART  $\frac{WP_2}{WP_4} = 0.16$ WP3 = WP3 (0.16) =2758(0.16) = 0.33 FT.  $= \frac{h}{65} \left( 3h^2 + 95^2 \right) = \frac{0.5}{6(3.85)} \left[ 3(0.5)^2 + 9(3.85)^2 \right]$ A2 = 1.2969 IN2 OR 0.0090 FT2  $= \frac{0.009}{0.33} = 0.0273 \quad R^{23} = (0.0273)^{661} = 0.0905$ R = X-SECT WP V = 1.486 R<sup>2/3</sup> 5<sup>1/2</sup> = 1.486 (0.0905) (0.2398) = 2.481 FT/SEC Q= VA; = (2.481) (0.0090) = 0.0223 CFS × 4499pm = 10.029pm SENCE THEIR WAS NO RAIN, ASSUME A FACTOR OF 1.35 10.02 gpm × 1.35 = 13.53 gpm NFILTRATION RATE PER LENGTH OF PIPE = 13.539pm 605.0 FT = 0.0224 gpm/L.FT. OF PIPE 1 OF 4



**NOV 75-JES 22** SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 12-19-78 JOB COURTHOUSE RAY S.M.H. #428 SLOPE = (2,48-2.34)/4' = 0.035 5"2= (0.035)" = 0.1871 = 1" = 0.10 FROM CHART WP2 = 0.20 P= WPf (0,20) = 2 TT (0,4167) (0,20) = 0,524 FT  $H = \frac{h}{65} (3h^{2} + 4s^{2}) = \frac{1.0}{6(5.95)} [3(1)^{2} + 4(5.95)^{2}] = 0.028 [3 + 14.61]$ A= 4.0491 IN2 OR 0.0281 FT2  $\frac{R}{WP} = \frac{0.0281}{0.524} = 0.0536 \quad R^{2/3} = (0.0536)^{667} = 0.1421$ = 1.486 R<sup>2/3</sup> 5<sup>1/2</sup> = 1.486 (0.1421) (0.1871) = 3.0391 FT/SEC D=VA = (3.0391) (0.0281) = 0.0855 CFS × 49.99pm/CFS = D= 38.37 gpm OR 55,280.88 gpd


29




<b>NOV 75-JES 22</b>	NOV	75-JE	S 22
----------------------	-----	-------	------

		NOV 75-JES 22
JOB <u>COURTHOUSE</u> BAY STRUCTURE	DESIGN SHEET	JOB NO <u>A-1086</u> DATE <u>12-19-</u> 78 COMPUTED BY <u>TLO</u> WORKING STRESS
INFILTRATION	RATE	
YOW AT MANHOLE NUMBE FROM ENGINEERING BL	06 #255 - 3,3 , #250 - <u>3,0</u> 32,0	29pm Egpm 19pm
SENCE THEIR WAS NO	RAIN, ASSUM	E A FACTOR OF 135
32,01 gpm x 1.35 =	43.21 g.pm	
LENGTH OF S.S. PIPE, U. 1877.80 + 300,70 427,90 = 4	+ 1172.50+ 2	
NFILTRATION RATE P	PER LENGTH OF	$PIPE = \frac{43.219pm}{4821.7FT}$
= 0,0090 gpm/L.F.	T. OF PIPE	
1		
1		Barris and State


30



**NOV 75-JES 22** J E SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 12-19-78 JOB COURTHORSE BAY TON DAD PER SQUARE FOOT MINIMULT FLOW FROM ENGINEERING BARRACK FRUM M.H. 1001 TO 1000 r8"\$ SLOPE = 0.0063 5"2=(0,0863) 5= 0.0794  $\frac{d}{D} = \frac{0.5}{8"} = 0.06 \quad FROM \quad CHART \quad WP_a = 0.16$  $WP_2 = WP_f(0,16) = 2\pi r(0,16)$ = 2(m)(0.333)(0.16) = 0.33 FT  $A = \frac{h}{65} \left( 3 h^{2} + 4 s^{2} \right) = \frac{0.5}{6(3.85)} \left[ 3 \left( 0.5 \right)^{2} + 4 \left( 3.85 \right)^{2} \right]$ Ja= 1.2969 INZ OR 0.0090 FTZ  $R^{2/3} = (0.0223)^{667} = 0.0905$  $P = \frac{X - SECT}{WP} = \frac{0.0090 FT^2}{0.333FT} = 0.0273$ V = 1.986 R<sup>2/3</sup> 5<sup>12</sup> = 1.986 (0.0905) (0.0799) = 0.82 FT/SEC Q = VA = (0.82)(0.0090) = 0.0074 CFS × 4999pro/CFS = 3,32-9pro 4,781.58 9pd FROM M.H. 1003 TO 431-A SLOPE = 0.0053 512 (0.0053)' = 0.0728 N= 1.486 R<sup>243</sup> S<sup>1/2</sup> = 1.486 (0,0905) (0,0728) = 0.75 FT/SEC Q = VA = (0,75)(0,009) = 0.0068 CFS × . 449, pm/CFS = 3,04 gpm 40F4 OR 4,382 gpd.




	()	(	NOV 75-JES 22
J. E. SIRTINE COMPANY JOB COURTHOWSE BAY TRUCTURE SEINER	DESIGN S	301-H_ON BOL	36 <sub>DATE</sub> 10-4-78
7. EXISTING SAN	ITARY SEWER C	WORKING STRESS	CALCULATIONS
SANITARY SEW	IER PLANT IMG/mo	inar las	MG /MO DIFF
<b>1</b>		iMG/m	2.027
	→ J,983 7,927	1978 → 12.010 11-174	3-247
FEB	9.545	13.031	3.486
PAR.	9.182	12.596	3.414
이는 10. THE METERS IN THE CASE OF A COMPANY AND A	9.328	13.662	4.334
NAY NU	9,709	12.953	3.294
	10.389	13.206	2-81)
YUCY	10.000	10,000	
AV6	= 9.438	AVG = 12.662	AV6: 3. 229
ASSUME AN AVE THIS TIME.	10. 30.29 DAXS =		DURING
106,438 gpl /	Construction of the second		
TO ADD SOME	SAFETY FACTO	IR, USE ZZS gp	cd/NEW DURTS.
1			
6			
	32		1 OF.14



2 OF 14

A-1086 DATE 10/19/28


TUD



H. 1008 TO M.H. 1007

(33)

881/2 F.U. = 42 9 pm




30F14

DE STRAINE COMPANY JOE<u>COUTRTHOUSE</u>BAY STRUCTURE<u>SEWER</u> LIVE LOAD PER SQUARE FOOT\_\_\_\_\_

DESIGN SHEET EXISTING CALCULATED FLOW

-1086 DATE 10/19/28

M.H. 1007 TO M.H. 669 88% F.V. + 56% F.V. = 145 F.V. = 559 pm M.H. 669 TO M.H. 668 195 F.V. + 881/2 F.U. = 233,5 F.V. = 729017 M.H. 668 TO M.H. 669 72gpm M, H, 667 TO M, H, 666 56 1/2 F.V. + 6. F.V. = 62 1/2 F.V. = 339pm M.H. 666 TO M.H. 665 33,9pm + LIFT STA. 17, H. 665 TO M, H. 664 339pm + CIFT STA. M.H. 664 TO M.H.663 621/2 F.U. + 233.5 F.U. = 296 F.U. = 88 9 pm + LIFT STA. MH, 663 TO 17, H.438 889pm + LIFT STA M. H. 438 TO M. H. 431-A 296 F. U. + 62.5F. U. = 358.5F. U. = 97 gpm + LIFT STA.



4 OF 14



J. E. SIRRINE COMPANY

EXISTING CALCULATED FLOW

r	7-1086 DATE 10/19/78
JOB NO	DATE 10/19/18
COMPUTED BY	TLD
WORKING STR	E\$8

M.H. 1003 TO M.H. 431-A.

892 F.U. = 1959pm

M.H. 431-A TO M.H. 431

3585 F.U. + 1975 F.U. + 892 F.U. = 195 gpra + LIFT STA.

IT SHOULD BE NOTED THAT THE PEAK DISCHARGE OCCURS AROUND S:45 TO 7:30 O'CLOCK A.M., AT THIS TIME THE STUDENTS ARE IN THE BARRACKS OK MESS HALL,

M.H. 431 TO M.H. 1000

26 5 F.U. + 892 F.U. = 1959PIN + LIFT STA.

M. H. 1001 TO M.H. 1000

892 F.U. = 1959PIN + LIFT STA.

M.H. 1000 TO M.H. 429

892 F.U. + 892 F.U. = 1784 F.U. = 302 9pm + LIFT STA.

M.H. 429 TO M.H. 428


302 gpm + 98 gpm + LIFT STA

M.H. 428 TO M.H. 423

400 gpm + LIFT STA.

M.H. 423 TO M.H. 422

400gpm + LIFT STA.



JOB<u>COURTHOUSE</u>BAY STRUCTURE\_\_\_\_\_\_\_


J. E. SIRRINE COMPANY

EXISTING CALCULATED FLOW


JOB NO A -1086 DATE 10/19/78 TLD COMPUTED BY WORKING STRESS

M.H. 422 TO M.H. 412


400 gpm + LIFT STA. M.H. 425 TO M.H. 419 54 F.U. + 54 F.U. = 108 F.U. = 479pm M, H, 419 TO M, H. 418 108 F.U. + 27 F.U. = 135 F.U. = 539pm 17.H. 418 TO M.H. 417 135 F.U. + 59 F.U. + 27 F.U. = 216 F.U. = 6890M M.H. 417 TO M.H. 416 68,9pm M, H, 416 TO M, H, 415 216 F.U. + 182 F.U. + 72. F.U. + 64 F.U. = 470 F.U. = 120 9pm M, H. 415 TO M. H. 414 470 F.U. + 512.5 F.U + 512.5 F.U. = 1495 F.U. = 270 gpm M.H. 414 TO M.H. 413 1495 F.U. + 50 F.U. + 512.5 F.U. = 2057.5 F.U. : 335900 M.H. 413 TO M.H. 412 2057.5 F.U. + SIZS F.U. = 2570 F.U. = 390 9pm 50F14




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 9/28/78 JOB COURTHOUSE BAY # MAXIMUM DESIGN FLOW THRU PIPE -#412 TO 413:  $D = 10^{"} S = 0.0023 \qquad S''_2 = (0.0023)^{S} = 0.048$  $A = 0.545 \qquad R^{\frac{1}{2}}(0.208)^{.617} = 0.351 \qquad m = 0.013$ Q=VA = 1.986 R213 52A  $Q = \underbrace{1.486}_{0.013} (0.351) (0.595) (0.098)$ Q= (21.866) (0.048) = 1.050 CFS × 449 = 471.45 pm Q=VA = Z1.866 512 = (Z1.866) (0.099) = 0.962 CFS OR 432.0 gpm 414 70 415:  $\frac{4/4}{D=10^{"}} = 0.0029 = 5''^2 = (0.0029)^{-5} = 0.054$ Q=VA = 21.866 5'2 = (21.866) (0.054) = 1.178 CFS OR 528.71 0PM m= 0.013  $Q=VA=\frac{1.486}{0.013}(0.351)(0.545)5''^2$ Q= 21.866 5'2 = 21.866 (0.059) = 1.29 CFS OR 579-9PM  $\frac{416}{D=8''} \frac{73}{5=(.004)} \frac{5''}{5} = 0.063$ Q = 12.088 5"2 = 12.088 (2063) = 0.765 CFS or 343.279pm 6 OF 14




NOV 75-JES 22 DESIGN SHEET JOB NO A-1086 DATE 9/28/28 COMPUTED BY TED JOB COURTHOUSE BAY  $\frac{417 \ 70 \ 418}{D=8'' \ 5'' = (0.031)^{.5} = 0.056}$ Q= 12.088 5"2 = 12.088 (0.056) = 0.673 CFS OR 302.199pn  $D = 8'' 5'' = (0.0036)'^{5} = 0.060$ Q=12.088 5'2 = 12.088 (0.060) = 0.725 CPS DR 325.659pm  $\begin{bmatrix} \frac{\pi}{419} & \frac{\pi}{19} & \frac{\pi}{425} \\ D = B'' & S''^2 = [0.0032]^5 = 0.057 \end{bmatrix}$ Q=12.0885"2 = 12.088(0.052) = 0.684 CFS OR 307.039pm #<u>412 To #422:</u> D= 10" 5"2 2 (0.0029).5 = 0.049 Q= 21.866 5"2 = 21.866 (0.049) = 1.071 CFS OR 480.979pm  $\begin{array}{c} \# \\ 422 & 70 \\ \hline 423 \\ \hline D = 10'' \\ S''2 = (0.0028)'^{5} = 0.053 \end{array}$ Q=Z1.8665"2 = Z1.866 (0.053) = 1.157 CFS OR 519.119p17 Q= 1.157 CFS OR 519,119 pm 7 OF 14



**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET A-1086 DATE 9-28-78 JOB COURTHOUSE BAY AD PER SQUARE  $\frac{\frac{4}{428}}{D=8''} \frac{5''2}{5''2} = (0.0036)^{-5} = 0.060$ Q= 12.083 5"2 = 12.088 (0.060) = 0.725 CRS OR 325.65 pm  $\frac{\#_{429 \ 70}\#_{1000}}{D=8'' \ 5''_{2}=(0.0096)'^{5}=0.068}$ Q=12,088 5"2 = 12.088 (0.068) = 0.820 CFS OR 368.119pm  $\begin{array}{c} \frac{\#}{1000 \ 70^{\#}431} \\ D = 8'' \ 5''^{2} = (0.0027)^{5} = 0.052 \end{array}$ Q= 12,088 5"2 = 12,088 (0.052) = 0.628 CFS OR 282,029PM  $\frac{\#_{431}}{D=8''} \frac{\pi_{431}}{5''^2} = (0.004)^{5} = 0.063$ Q= 12,088 512 = 12,088 (0,063) = 0.765 CFS OR 343.279 PM  $\frac{^{\#}431-A \ T0^{\#}438}{D=8'' \ 5''2=(0.0021)^{.5}=0.046$ Q= 12.088 5"2 = 12.088 (0.046) = 0.554 CPS OR 248.729pm  $\frac{\#438}{D=8''} \frac{70\%663}{5''2} = (0.0145)^{15} = 0.120$ Q= 12.088 512 = 12,088 (0,120) = 1.456 CFS OR 653.56 8 OF 14




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 9-28-78 JOB COURTHOUSE BAY AD PER SQUARE  $\frac{663}{D} = 8'' \quad 5''z = (0.0065)^{15} = 0.081$ Q=12.088 512 = 12.088 (0,081) = 0.975 CFS OR 437.58 9pm  $\frac{\frac{1}{664}}{D=8^{*}} \frac{5^{*}}{5^{*}} = (0.0228)^{5} = 0.151$ Q=12,088 512=12.088 (0.151)= 1.825 CFS OR 819.53 9pm  $\frac{*_{665}}{n=8"} \frac{_{70}^{*}}{_{5'12}} = (0.0119)^{15} = 0.109$ Q=12,088 51/2=12,088 (0,109) = 1,319 CFS OR 592,07 9PM  $\frac{{}^{\#}_{666}}{D=8"} \frac{5''_{2}}{5''_{2}} = (0.0095)^{5} = 0.067$ Q= 12.088 5"2= 12.088(0.067)= 0.811 CFS OR 369.099PIN #412 TO #672: D=10" 5"2=(0.0005)" = 0.022 Q = Z1.866 512 = Z1.866 (0,022) = 0.489 CFS OR Z19.539 PM #672 TO #673 ; D=10" 5"2=(0.0066)'5 = 0.081 Q= 21.866 512 = 21.866 (0.081) = 1.776 CFS OR 797.61 gpm 9 OF 14




**NOV 75-JES 22** DESIGN SHEET JOB NO A-1086 DATE 9-28-78 JOB COURTHOUSE BAY OAD PER SQUARE FOOT  $\frac{\frac{1}{673}}{D=10''} \frac{\frac{1}{674}}{S''_{2}=(0.0212)'^{5}=0.146}$ Q= Z1,866 512 = Z1,866(0,146)=3.184 CFS OR 1429,50 gpm  $\frac{\#_{1000 T0} \#_{1001}}{D = 8''} = 5''_2 = (0.0063)^{15} = 0.079$ Q= 12.088 S12 = 12.088 (0.079) = 0.959 CRS OR 430.79 9pm  $\frac{\#_{431-A \ T0} \ \#_{1003}}{D = 8''} = (0.0053)^{15} = 0.0728$ Q= 12.088 5"2= 12.088(0.0728)=0.880 CFS OR 395, Rg An  $\frac{\frac{1}{1003}}{D=8''} \frac{\frac{1}{1004}}{5''^2} = (0.0080)^{.5} = 0.089$ Q= 12.088 5"2 = 12.088 (0.089) = 1.081 CFS OK 485.9590 # 431-A TO 496:  $D = 6'' \qquad S''_{2=} (0.0108)'^{5} = 0.104$  $A = 0.196 \qquad R^{2}_{3=} (0.125)'^{607} = 0.250 \qquad m = 0.013$ Q= VA = 1.486 (0.250) (0,196) 5"2 Q= 5.601 512 0= 5.601 (0.104)= 0.583 CPS OR 261.55 9pm

41


10 OF 14



**NOV 75-JES 22** I. E SIRRINE COMPANY DESIGN SHEET NO A-1086 DATE 9/29/28 JOB COURTHOUSE BAY  $\frac{\#496 \ To^{\#}497}{D=6''} = (0.0161)^{15} = 0.127$ Q=5.601(0.127)= 0.711 CFS or 319,10 gpm  $\frac{\#}{497 \ 70} \frac{\#}{497 \ A}:$   $D = 8'' \ 5''z = (0.009)^{.5} = 0.095$ Q=12.0885"2=12.088(0.095)=1.197 CFS OK 519.909pm  $\begin{array}{c} & \# \\ 497-A & \tau_0 \\ \hline 497B \\ \hline 0 = 8'' \\ S''_2 = (0.0149)'^{5} = 0.120 \end{array}$ Q=12,088 5"2 = 12.088 (0,120) = 1.951CFS OR 651.30 gpm  $\frac{\#_{497B}}{D=8''} \frac{70'1005}{5''^2 = (0.0238)} = 0.154$ Q= 12.088 5"2 = (12.088)(0.159)= 1.865 CFS OR 837.329pm  $\frac{\#}{1005 + 10^{\#} 497c}{D = 8'' + 5'' 2 = (0.0146)^{5} = 0.121$ Q= 12.088 512 = 12.088 (0.121) = 1.46/CFS OR 655.819pm #<u>497A TO #1006:</u> D= 6" 5"2=(0.0044)<sup>5</sup>= 0.066 Q= 5,601 (0.066) = 0.372 CFS OR 166,82 gpm. 11 OF 19




**NOV 75-JES 22** J. E SIRRINE COMPANY DESIGN SHEET 108 NO A -1086 DATE 9/29/78 JOB COURTHOUSE BAY #<u>664 TO #668</u>; D= 8" S"2=(0,0039)<sup>5</sup> = 0.062 Q= 12.088 5 = 12.088 (0.062) = 0.755 CHS UR 338.959pm # 668 TO #669: D= 8" 5"2= (0.0041).5= 0.064 Q=12.088 5"2 = 12.088(0.069)= 0.174 CFS of 397.539pm # 669 TO #670: D: 8" 5"2=(0.0047) 5= 0.069 Q=12.088 5"2 = 12.088 (0.069) = 0.829 CFS OR 372.09 9 pm #669 TO #1007: D= 8" 5"2= (0.0084)'5= 0.092 Q= 12,088 512 = 12.088 (0.092) = 1.108 CPS of 497.449pm #1007 TO #1008: D=6" 5"= (0.0085)" = 0.092 Q=5.601 512 = 5,601 (0.092) = 0.515 OR 231.37 ypm #1001 TO 1002 ! D=8' 5"= (0.0186) = 0.136 Q=12,088 51/2=12,088 (0.136) = 1.649 CFS OR 740.219pm 12 OF14




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET AMTRAC AREA A-1086 DATE 10/20/78 JTED BY TLD - MAXIMUM DESIGN FLOW THRU PIPE -7336 70 365:  $D = 8'' \quad S = 0.0034 \qquad S''_2 = (0.0034)'^5 = 0.058 \\ A = 0.349 \qquad R^{2/3} = (0.167)'^{60} = 0.303 \qquad m = 0.013$ Q=XA = 1.486 R2/3 512 A  $Q = \frac{1.486}{0.013} (0.303)(0.058)(0.349)$ Q = 0.701 CFS × 449 = 315 9pm #365 TO #364:  $D = 8'' \leq = 0.0036 \qquad 5''_2 = (0.0036)^5 = 0.060$   $A = 0.349 \qquad R^2 = 0.303 \qquad n = 0.013$ Q = 1.486 (0.303)(0.060)(0.349)Q= 0.725 CFS × 449 = 326.9pm #364 TO 1009:  $D = 8'' \quad S = 0.0150 \quad S''_2 = (0.0150)'^5 = 0.122$   $A = 0.349 \quad R^{2/3} = 0.303 \quad m = 0.013$ Q = 1.486 (0.303)(0.122)(0.349)Q= 1,475 CFS × 449 = 662 9 pm 44

13 OF 14




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB AMTRAC AREA JOB NO A-1086 DATE 10/20/78 COMPUTED BY TUN LIVE LOAD PER SQUARE FO -MAXIMUM DESIGN FLOW THRU PIPE-# 1009 TO # 1010:  $D = 8'' \quad 5 = 0.0124 \quad 5''_2 = (0.0124)^5 = 0.111 \\ A = 0.349 \quad R^{2/3} = 0.303 \quad m = 0.013$ Q = 1.986 (0.303)(0.111)(0.349)• Q= 1.342 CFS × 449 = 602.9pm #1010 TO LIFT STA. :  $D = 12'' \quad S = (0,0069) \quad S''^2 = (0,0069)^{15} = 0.080$  $A = 0.785 \quad R^{2/3} = (0,250)^{160} = 0.397$ Q = 1.486 (0.397)(0.080)(0.785)0.013 Q= 2,850 CFS × 449= 1,2809pm 14 OF 14





AAUDTHANT	0 1.
OB COURTHOUSE	DAY

JOB NO A-1	086	DATE 2	-5-79
COMPUTED BY			
WORKING STRESS			




DESIGN SHEET





NOV 75-JES 22 J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 2-5-79 JOB COURTHOUSE BAY COMPUTED BY \_\_\_\_\_ TUD OAD PER SQUARE FO WORKING STRESS INFILTRATION FOR NEW LINES: ASSUME 30,000 gpd/MICO 30,000 god x MILE X DAY X HR MILE SZEOFT ZAHR GOMM = 0.003959pm/FT SOLVE FOR MIN, SLOPE TO MAINTAIN A Z.S FPS, VELOCITY. TRY D=8" (n:0.010) Vf = 1.486 R2/3 5/2 R=(24)  $2.5 = \frac{1.486}{0.62} (0.62)^{60} 5^{1/2}$ 2.5 = 148.6 (0.303) 5 2 Q=V&A = 2.5 (0.349) = 0.873 COR 0,00308 = 5 391.8901 TRY D=10"(n=0.010) Z.5 = 1.486 (0.208) 512 2.5 = 148.6 (0.351) sh 0.00230 = 5 Q==V=A=2.5(0.545)= 1.3625 CFS OR 611.7900 TRY 1)= 3" (m=0.013) 2.5 = 1.486 (0,167) .667 512 2,5= 34,64 5 2 poszl = SQf=VfA=2~5(0349)=0.872 CFS OR 391.75 9PM (47

ZOF4




**NOV 75-JES 22** 

JOB COURTHOUSE BAY
STRUCTURE

JOB NO A-	1086	DATE_	2-6-79
COMPUTED BY			

TRY D=10" (n=0.013) 2,5 = 1.486 (0,208) -667 1/2 0.013 2.5= 40,107 5 12 Q=V\_AB=2.5(0.545)= 1.36 CF5 OR 0.0039 = 5 6129pm GIVEN: S= 0.39% 8"\$ PVC Q= 1829pm n: 0.01 V1= 1.486 R2/3 512  $V_{f} = \frac{1.486}{0.01} (0.167)^{667} (0.0039)^{5} = 148.6 (0.303) (0.062)$ Vy = 2.812 FPS Qf = Vf Af = (2.812)(0.347) = 0.981 CFS OR 440.6 9PM  $\frac{Q_2}{Q_1} = \frac{182}{490} = 0.41 \quad FROM \quad CHART \quad \frac{V_2}{V_2} = 0.95 \quad V_2 = 0.95(2.812) \\ V_4 \qquad \qquad = 2.67 \, FR$ = 2.67 FPS GIVEN: 5= 0.30% 10" & PVC Q= 291.9 9pm n=0.01 V7 = 1.986 R352  $V_{f} = \frac{1.486}{0.208} (0.208)^{-667} (0.003)^{-5} = 148.6 (0.351) (0.055)$ Vg = 2.857 FPS Qf = Vg Ag = (2.857) (0.545)= 1.557 CFS OR 699 9pm Q2 = 292 = 0.42 FROM CHHAT V2 = 0.96 Va=(0.96)(2,857) = 2.74 FPS 3OF4

DESIGN SHEET




JOB COURTHOUSE	BAY
IVE LOAD PER SQUARE FOOT	112


JOB NO A - 1086 DATE	2-12-79
COMPUTED BY TUD	
WORKING STRESS	S

GIVEN: S=0.30% 10" \$PUC Q=380 9PM Q2 = 380 = 0.54 FROM CHART Va = 1.02 Q4 699 Va=(1.02) (2.857) = 2.91 FPS GIVEN: 5=0.23% 10" & PUC Q= 3809PM n=0.01 Vy = 1.986 R 33 5 12 Vf= 1.986 (0.209) (0.0023) = 198.6 (0.351) (0.048) Vg = 2.501 Qg = Vg Ag = (2.501) (0.595) = 1.363 CFS OR 612 9pm Q2 = 380 = 0.62 FROM CHART V2 = 1.05 Q1 612 V2=(1.05)(2.501)=2.63 CFS GIVEN: S= 0.52% 8"\$PVC Q= 1809pm m= 0.01 Vy = 1.486 (0.167) -607 (0.0052) = 148.6 (0.303) (0.072) = 3.25 FPS Q1 = V1 Ag = (3.25) (0.349) = 1.134 CFS OR 509 9PM Q2 = 180 = 0,35 FROM CHART Va = 0,90 Va=(0.90)(3.25)= 2.93 FAS (49) 4.0F4

DESIGN SHEET




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A - 1086 DATE 12/27/28 JOB COURTHOUSE BAY TLD VE LOAD PER SOUARE 6. EXISTING SANITARY SEWER LIFT STATION CALCULATIONS #422 360.83pm 8" F.M. LIFT (S.S.M.H.) 12'4CIP #412 48' STA 144. -1.22 INU-1,69 × 415.6pm 1-3.00 9pm PUMP 1-500 gpm PUMP #413 FIND MAX FLOW OF 12" & CIP Q=VA = 1.486 R23 52 MD2 5 = 0.41' = 0.0098 5 2 = (0,0098)2 = 0.099 R<sup>2</sup>/3=(0.25)<sup>.667</sup>=0.397 A=0.785' Q=<u>1,486</u> (0,397)(0.099)(0.785) = 3.53 CFS OR 1583.5 gpm  $\frac{Q_2}{Q_1} = \frac{415,1+360.8}{1583.5} = \frac{775,9}{1583.5}$ = 0.49 FROM CHART Va = 0.98 Va = 4.49 (0.98) = 4.40 FPS ASSUME BOTH PUMPS ARE ON AND PEAK DISCHARGE occurs. 776 6003pm DIFF 776-600 = 17.6 REMAIN IN WET WELL IME TO TAKE WET NELL TO FILL UP, UNDER THESE CONDITIONS 6,600901/1769pr = 37,50 MIN. 1 OF 5



	NOV 75-JES 22
DESIGN SHEET	JOB NO A - 1086 DATE 10/29/28 COMPUTED BY
VOLUME OF PIT AT SANITARY	SEWER LIFT.
STATION	
12.0' 12	EL-9.0 EL-11.0 TON
WET WELL	
VOL, = 1/2(9)(7)(15,5) + (1,5)(7)(15,5) + 1	0(1.5)(15.5)
= 488.25 + 162.75 + 232.50 = 883.50 FT3	
$1 F T^3 = 7.98 or 21$	
: 883.5 FT3 × 7.98901/FT3 =	6,608.58901

51



C		(	NOV 75-JES 22
I E SIRRIAE COMPANY	DESIGN SHEET	JOB NO <u>A-1086</u> COMPUTED BY <u>TE</u> WORKING STRESS	DATE 12/27/78
#422 410.8 / 394.6		5 2 2	
(s.s.194) 12"\$C1. #412 B1.0 # 413	p STA.		
Q2 = 410.8 + 394.6 + 8,			24.4


BASSUME BOTH PUMPS ARE ON AND PEAK DISCHARGE OCCURS

886:4 600 DIFF. = 886-600 = 2.8.6 9PM RETHIN IN WET WELL

TIME TO TAKE WET WELL TO FILL UP, UNDER THESE CONDITIONS


6,600901/2869pm = 23 MIN.

RECOMPENDATION: TAKE OUT THE <u>300 9PM</u> \$ 500 9PM PUMPS AND REPLACE THEM WITH TWO <u>2009PM</u> PUMPS.




()		()	NOV 75-JES 22
JOB <u>COURTHOUSE</u> BAY STRUCTURE	DESIGN SHEET	JOB NO <u>A-10</u> COMPUTED BY WORKING STRESS	86 DATE 12/27/78
SANITARY SEWER	LIFT STATION	AT COURT	THOUSE BAY
EL,-0.5 R-EL8.0	8 <sup>°</sup> фС, <i>I, J?</i> EL 10.6	IMOFF TH	ЯNК
TOTAL LENGTH OF PIN		OFT =	1100FT
- 6"×9" REDUCER	1 × .6'		GFT
1- 6" CHECK VALUE	1. x 40'	-	40 FT
- 1- 6" GATE VALUE	1 × 20'	-	ZO FT
■ 1-8" GATE VALUE	1 × 26'	=	Z6 FT
3-45° BEND B"PIPE	= 3 × 10'	÷	30 FT.
1- 8'X6" REDUCER	1 × 10'	=	10 FT
2-90°BEND 6"PIPE		=	ZZ FT
4 - 90 BEND 8" PIPE		=	56 FT
			1310 FT.
PIPE FRICTION	0 = 8+15 = Z3 1 = 1.16/100' × 13	310 = 15,2	2 2 8 - 47 0 FT-40
25775.2 - 5	8.20 + (38.20 × 10)	(a) = 30, c +_	3.0 - <u>12.0 /1-40</u>
PIPE FRICTION	7009PM D = 8+15 = 23 A = 1.54'/100' × 131 43,17 + (43,17× 10%)		- 4,32= <u>47,49 FT-HL</u>
MPING HEAD FOR	BOD 9 pm		


STATIC HEAD = 8+15 = 23' PIPE FRICTION = 2.46/100' × 1310 = 32.23 23+32.23 = 55.23 + (55.23×10%)=55.23+552= 60.75 FT-HD 53 4 OF 5



	75-JES 22
I. E. STRAINE COMPANY      JOB COURTHOUSE BAY      STRUCTURE      LIVE LOAD PER SQUARE FOOT      O	/zา/28
SANITARY SEWER LIFT STATION AT COURTHOUSE BAY	
PUMPING HEAD FOR 1250 9PM STATIC HEAD = 8+15 = 23 PIPE FRICTION = 4.52'/100' × 1310' = 59,15 23 + 59,15 = 82,15 + (82,15 × 10%) = 82,15 + 8,21 = 90.36	FT-HD
600 gpm - APPROXIMATE MAXIMUM PUMPING DISCHAR OF EXISTING PUMPS	86
700 9pm - PUMPING RATE OF PROPOSED PUMP	
<u>900 9pm</u> - WHAT THE LIFT STATION WILL SEE FOR F.Y. 1986	
1250 9PM - HYDRAULIC DESIGN OF PROPOSED WASTEWATER TREATMENT PLANT,	


54






188	5	0.	76×60 SEC	2	146SEC
275-27.8			(55)		


10F4





**NOV 75-JES 22** I. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 12/29/18 JOB COURTHOUSE BAY COMPUTED BY TO AMTRAC STRUCTURE IVE LOAD PER SQUARE FOOT WORKING STRESS\_ AREA ADDITIONAL STORAGE FOR SANITARY SEWER LIFT STATION IN AMTRAC AREA. (SEE ATTACHED SHEETS) (INSIDE DIMENSIONS) VOL. OF STORAGE = 3'X 10'X 8' = 240 FT3 25FT3 YOL. OF MANHOLE = 265 FT3 1 FT3 = 7.98 921. 265 FT3 × 7.48 gal/FT3 = 1982.20 GALLONS 1982 GALLONS 8.02 MIN. FOR EXISTING 275 90M = (275-27.8) PUMP TO PUMP STORAGE DOWN TO CUT OFF LEVEL. 1982 GALLONS = 71,29 MIN. FOR INFILTRATIONS ALONE TO FILL LIFT STATION 27.89pm UP


(56)












	( )	( NOV 75-JES 22	
JOB <u>COURTHOUSE</u> BA SUCTURE <u>H2</u> O IVE LOAD PER SQUARE FOOT		JOB NO <u>A-1086</u> DATE <u>10/5/78</u> COMPUTED BY <u>TCD</u> WORKING STRESS	
8. EXISTING	WATER DEMAND CAL	CULATIONS	
EXISTING FU	OWS BEFORE ENGIN	IEERING BARRACKS	
WERE ADDEL	2		
AMTRAC	664 × 150 gpd	= 99,600	
ENGINEERING	500 × 509pd	= 25,000	
OFFICERS	30 × 150 gpd	= 4,500	
RESIDENT	25 × 100 9 pd	2,500	
OFF BASE	665 × 509pd	= 33,250	
POWER PLANT	승규는 문화적 전화를 받았는	= 6,000	
MOTOR NEHICLES		= 12,000	
LAWN SPRINKLIN		= 30,000	
RESTAUKANT	4.092//MEAL X 3ITEALS		
	4.0gal/IYEAL XI "	x 800 = 3,200	
FEB 9. PAR, 9,	AVG. DAILY DEMI, 883 MGD/MO, 297 594 414	m = 224, 4509pd	
DAY 10.	473		
JUNE 10.	480		
PULY 10.	.3 89		
AV6 = /	10.076		
10,076,000 gal/30.29 DAXS = 332,651gal - 13,680 gal			
ACTURAL AVG. D.	AILY DEITAND= 318,83	979pd	
1	59	1 OF 7	



NOV 75-JES 22 L. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 10/5/78 JOB COURTHOUSE BAY COMPUTED BY TLD STRUCTURE H20 WORKING STRESS IVE LOAD PER SQUARE FOOT. EXISTING FLOWS BEFORE ENGINEERING BARRACKS WERE ADDED MAXIMUM 24 - HOUR DEMAND 229,100 X 2,25 AMTRAC 99,600 = 56,250 25,000 × 2,25 ENGINEERING = 4,500 10,125 OFFICERS x 2.25 2 5,625 2,500 X 2.25 RESIDENT 2 74,815 X 2,25 OFF BASE 33,250 =

MOTOR VEHICLES '50 gol/CAR X 300 LAWA SPRINKLING 14,000 gol/AL X 3AC RESTAURANT

445,51519pa

6,000

15,000

42,000

11,600

(224,450+445,515)/2 = 334,982.59pd

(60)

CALCULATED AVERAGE !

POWER PLANT


DAILY DEMAND = 334,9829pd.

-

z


=

=



•		( NOV 75-JES 22
JOB <u>COURTHOUSE</u> BAY STRUCTURE <u>H2</u> O	DESIGN SHEET	JOB NO <u>A-1086</u> DATE <u>10/5/78</u> COMPUTED BY <u>TCD</u> WORKING STRESS
EXISTING CONDIT ARE ON BASE.	TIONS WHEN A	MTRAC PEOPLE
ENGINEERING 500 OFFICERS 30 RESIDENTS 25 OFF BASE 665 POWER PLANT MOTOR VEHICLES 40 LAWM SPRINKLING RESTAURANTS 4.09	10,000gal/ACX31	200 = 19,400
	AVG, DAILY DEMANIL	o = 323,9509pd
1978 AN 12.010 1 FEB 11.396 AR. 12.344 APR. 11.764 MY. 12.484 JUNE, 12.208 VLY 12.376 AV6 12.083 (2,083,000901/30.25 2	$D_{AYS} = 398,9$ = $_{3}385,2$	FICTERS 10gal - 13,680gal 30gal pER DAY AVG. UAILY DEMAND.

61




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A - 1086 DATE 10/5/73 JOB COURTHOUSE BAY COMPUTED BY TUD STRUCTURE H20 WORKING STRESS IVE LOAD PER SQUARE FOOT EXISTING CONDITIONS WHEN ANTRAC PEOPLE ARE ON BASE MAXIMUM 24-HOUR DEMAND × 2.25 = 224,100 AMTRAC 99,600 = 253,125 112,500 × 2.25 ENGINEERING 10,125 × 2,25 OFFICERS 4,500 -

5,625 2,500 × 2,25 RESIDENT -33,250 × 2.25 74,815 OFF BASE = 6,000 POWER PLANT = 25,000 50901/CAR × 500 MOTOR VEHICLES -42,000 LAWN SPRINKLING 19,000 gal/ACX3AC -15,600 -RESTAURAMT

656,390gpd


THEY HAVE HAD A DAYS WHEN THE DEMAND EXCEEDED 600,000 gpd.

62




**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A -1086 DATE 11/7/28 JOB COURTHOUSE BAY COMPUTED BY TLD STRUCTURE 1120 LIVE LOAD PER SQUARE FOOT RKING STRESS CALCULATIONS BASED ON EXISTING CONDITIONS (a) SOURCE OF SUPPLY: THE SUPPLY SHALL MEET THE MAXIMUM DAILY CONSUMPTION. SUPPLY SOURCE : WELL # 43 - 1759pm (DESIGNED) # 99 - 190 gpm #220 - 150 gpm # 221 - 300 9pm 8159pm MAXIMUM DAILY CONSUMPTION = 656,390 gpd 656,390 gpd/1490 = 455,8 gpm AT PRESENT THE WELLS ARE DESIGNED TO SUPPLY 815.9pm OF RAW WATER TO THE TREATISENT PLANT. THIS IS GREATER THAN THE 456 9PM NEEDED FOR THE MAX. DAILY CONSUMPTION, THEREFORE THE SUPPLY IS O.K. TREATMENT PLANT: THE TREATMENT PLANT SHALL 6) BE DESIGNED TO MEET THE MAXIMUM DAILY DEMAND. = 656, 390 gpd. AT PRUSUNT IT CAN ONLY PRODUCE 525,000 gpd. (C) TRANSMISSION MAINS: (LINES FROM WELLS TO PLANT) (P.P. 5-9-63 MAX. VEL. = 15 FRS) THESE LINES MUST BE ABLE TO HANDLE MAX. DAILY DEMAND.

50F7




( NOV 75-JES 22
J. E SURVINE COMPANY         JOB COURT HOUSE RAY         STRUCTURE H2.0         LIVE LOAD PER SQUARE FOOT    DESIGN SHEET          JOB NO       A - 1096         DATE       11/2/28         COMPUTED BY       TCO         WORKING STRESS
CALCULATIONS BASED ON EXISTING CONDITIONS
(d) DISTRIBUTION SYSTEM (MUST MEET THE FOLLOWING)
() PEAK TRANSIENT DOMESTIC
324,000 × 5.0 = 1/25 gpm
(2) MAXIMUM FIRE DEMAND + 50% OF AVG. DOMESTIC I DEMAND.
MAXIMUM FIRE DEMAND = 17509pm For Two Hours = 1750 × 120 = 210,000901
219,000 gpd + <u>329,000</u> = 372,000 gpd. 2
LINE SHALL BE CAPABLE OF HANDLING
1750 gpm + 162,000 gpd x /1940 = 1862.50 gpm
8"\$ C.I. VEL = 11.9 FPS LOST = 9.1. /100' 10"\$ C.I. VEL = 7.6 FPS LOST = 3.18' JIDO' (3) REPLENISHMENT OF NORMAL STORAGE VOLUME WITHIN 98 HOURS OF NORMAL CONSUMPTION AFTER A FIRE,
2 <u>10,000</u> gpd + 324,000 = 429,000 gpd
AT PRESENT PLANTIS OPESIGNED TO HANDLE. 525,000 60F7




NOV 75-JES 22
DESIGN SHEET JOB <u>COURTHOUSE</u> BAY STRUCTURE <u>H2.0</u> LIVE LOAD PER SQUARE FOOT DUB DESIGN SHEET DESIGN SHEET DUB DESIGN SHEET DUB DESIGN SHEET DUB DESIGN SHEET JOB NO <u>A-1086</u> DATE <u>11/7/18</u> COMPUTED BY <u>TCO</u> WORKING STRESS
CALCULATIONS BASED ON EXISTING CONDITIONS V SQ. TAMIL THAT HOLDS WELL HZO, BEFORE IT IS TREATED. (C) EQUALIZING RESERVOIRS: THESE RESERVOIRS SHALL HAVE A MINIMUM CAPACITY EQUAL TO ONE DAY'S AVELAGE CONSUMPTION
AVG. DAILY CONSUMPTION = 329,000 gpd EQUALIZING RESERVOIR = , 25,000 gpd
(f) DISTRIBUTION RESERVOIRS : (MUST MEET THE FOLLOWING)
(I) TOMS
(2) MIN. STORAGE FOR FIRE PROTECTION PLUS 50% OF AVE DAILY CONSUMPTION
219,000 + 324,000 = 372,000 gpd
STORAGE CAPACITY = 450,000 9pl.

65

D



	(	( NOV 75-JES 22
S. E. SIRBINE COMPARY	DESIGN SHEET	
JOB COURTHOUSE BAY		JOB NO A-1086 DATE 10/5/78
STRUCTURE H2 O	· · · · · · · · · · · · · · · · · · ·	COMPUTED BY TCO
9. PROPOSED	WATER DEMAND C.	ALCULATIONS
CALCULATIONS	BASED ON MAXIM	UM POPULATION
FOR YEAR I	986	
AMTRAC	882 × 225 gpd	= 198,450
ENGINEERING	659 x 225 gpd	= 147,150
OFFICERS	30 × 150 gpd	= 4,500
RESIDENT	25 × 100 9pd	= 2,500
OFF BASE	615 × 50gpd	= 30,750
POWER PLANT		= 6,000
MOTOR VEHICLES	40921/cne × 600	= 24,000
LAWN SPRINKLING	10,000 gol /ACX 3AC	: 30,000
RESTAURANT	4901/MEALX3MEALS X 1500	= 18,000
	" ×1 " ×415	= 1,660
and the second	1	
	AVG. DAILY DEM	AND = 462,950 gpd
MAXIMUM 24-	HOUR DEMAND	
AMTRAC	198,450 × 2.25	= 446,515
ENGINEERING	147,150 × 2,25	= 331,090
OFFICERS	4,500 × 2.25	= 10,125
RESIDENTS	2,500 × 2.25	= 5,625
OFF BASE	30,750 × 2.25	= 69,190
POWER PLANT	-	2 6,000
MOTOR VEHICLES	50921/cmx × 600	= 30,000
LAWN SPRINKLING	19,000 gallALX 3AC	2 42,000
RESTAURANTS		= 19,660
- Harrison and the second second	and a descent and and	
		960,205 gpd
	(66)	10F3



NOV 75-JES 22

ZOF3

	J. E. SIKKINE CUMPANT	
	OURTHOUSE	RAV
	STRUCTURE H20	
100	LIVE LOAD PER SQUARE FOOT_	

DESIGN SHEET

A-1086 DATE 11/7/78 TLA

CALCULATIONS BASED ON YEAR 1986

(a) SOURCE OF SUPPLY:

MAX DAILY CONSUMPTION = 960,205 gpd or 670gpn SUPPLY FROM WELLS = 815gpm × 1440 = 5,173,600 gpd

(b) TREATMENT PLANT:

DESIGNED FOR MAX DAILY DEMAND = 960,205gpd (C) TRANSMISSION MAINS:


THE LINES CAN HANDLE THE MAXIMUM DAILY DEMAND OF 6709PM

(d) DISTRIBUTION SYSTEM : (MUST MEET THE FOLLOWING)


(1) PEAK TRANSIENT DOMESTIC

962,950 × 510 = 1607,59pm. 1440


8" LINE = VELOCITY OF 10.2 FRS LOSS = 7.12/100"



NOV 75-JES 22 J. E. SIRRINE COMPANY DESIGN SHEET JOB NO A- 1086 DATE 11/7/78 COMPUTED BY TLD JOB COURTHOUSE BAY STRUCTURE 14 9 0 LIVE LOAD PER SQUARE FOOT\_ WORKING STRESS CALCULATIONS BASED ON YEAR 1986 (2) MAX. FIRE DEMAND + SO% AVG. DOMESTIC DEMAND 1750 gpm + 462,950 gpd = 1910,75 gpm 2×1440 8"\$ C.I. V= 12.2 FPS LOSS: 9.85/100' 10" \$ C.I. V=7.8 Loss = 3.32'/100' (3) REPLENISHMENT OF STORAGE WITHIN 48 HOURS AFTER FIRE. 210,000 gpd + 462,950 gpd = 567,950 gpd PLANT WILL BE DESIGNED TO HANDLE 960,2059pd. (e) EQUALIZING RESERVOIRS: AVG. DAILY CONSUMPTION = 462,950 gpd EQUALIZING RESERVOIRS = 25,000 gpd. ACCORDING TO THIS WE NEED AN ADDITION DE 437,950 GALLONS. (f) DISTRIBUTION RESERVOIRS ; (MUST MEET THE FOLLOWING) MIN. STORAGE (FIRE PROTECTION + 50% AVG. DAILY CONSUMPTION) 210,000 + 462,950 441, 475 gpd Ξ 30F3 STORAGE CAPACITY (3) = 450,000 gpd.




10. EXISTING RAW (WATER SUPPLY CALCULATIONS NOV 75-JES 22 P. E. SIRRINE COMPANY DESIGN SHEET JOB NO A-1086 DATE 10/6/78 JOB COURTHOUSE BAY WORSE CASE STRUCTURE RAW WATER TUD COMPUTED BY LIVE LOAD PER SQUARE FOOT WORKING STRESS - EXISTING 18" 1315' 6" VAL VE (45') (3009pm) f = 0.322'/100' Y = 1.91 FPS BB 220 (150 gpm) BBZZI (DESIGNED) (3009pm) G"VALVE (50' OF G" PIPE FROM OUTSIDE OF HOUSE) (DESIGNED) 58" (3659pm) 20 f=0.464'/100' V= 2.34 FPS BB 44 (19) 9pm) 8"(50') DESIGNED B"VALVE . (365 9PM) f = 0.464 '/100' 080 V= 2.34 FPS N BB 4-3(1759pm) DESIGNED 6 "(30') VALVE 8" VALVE r0" 5 (8"VALVE 8" VIJLVE 69 1 OF G 270'



a J. E. SIRRINE COMPANY		NOV 75-JES 22
JOB COURTHOUSE E	BAY DESIGN SHEET	JOB NO A-1086 DATE 11/7/78
STRUCTURE		COMPUTED BY TCO
	- RAW WATER SUPPL	ry -
	(EXISTING)	
WELL NO.'S	PUMP DESIGNED CAPACITY	! C
43	1.75 gpm	
1 44 220	190	
221	300	
	815 gpm	
ACTURAL AVG.	DAILY DEIMAND = 385,	230 gallour OR 267. Sopin
MAX, PLANT	DESIGN. 525,000 901/2	bay or 3659pm
RAIN 365900 (MAX.)	TREATED 36590M (MAX.)	
	A RAW WATER GOING . LESS SAY 400 gpr	
THE DAILY A	IVERAGE IS 267.59pm	SAY 2809pm.
WORSE CAS	E IN TRANSMISSION	MAINS
ASSUMPTION	IS: ME IDDET DE PIPE PE	- PILMA HAUSE

(1) ASSUME 100 FT, OF PIPE PER PUMP HOUSE FOR VALVES & TURNS.

(2) THE AVERAGE STATIC HEAD SHOULD BE AROUND 35 FT. (10) 20F6



NOV 75-JES 22

IOB COURTHOUSE	BAY
TRUCTURE	

JOB NO A-1036 DATE 1/29/29 COMPUTED BY \_\_\_\_\_ TLD NORKING STREES

RAW WATER SUPPLY (EXISTING CONDITIONS) PUMP IN WELL HOUSE NO, ZZO WILL SEE THE FOLLOWING HEAD, = 35.00 STATIC HEAD LOSSES DUE TO PIPE FRICTION = 17.52 (3650pm) 3775 × 0.964/100' 52.52 FT-HD


DESIGN SHEET

PUMP IN WELL HOUSE NO. 221 WILL SEE THE FOLLOWING HEAD.


2035ES DUE TO PIPE FRICTION 300 9pm 1915' × 0.332'/100' = 4.70

57.22 FT-HD.

THE EXISTING PUMPS IN THE WELL HOUSES SHOULD HAVE NO PROBLEM PUMPING 365 9PM TO THE WATER TREATMENT PLANT



1 NOV 75-JES 22 A E SIBRINE CONFERT DESIGN SHEET JOB COURTHOUSE BAY JOB NO A-1086 DATE 10/6/78 WORSE CASE STRUCTURE RAW WATER TUD COMPUTED BY LIVE LOAD PER SQUARE FOOT WORKING STRESS EXISTING 18" 1315' 6" VAL VE (45') (300 gpm) BB220(15090M) DESIGNED 7=0.322'/100' BBZZI V= 1.90 (300gori) G"VALVE (50' OF G" PIPE FROM OUTSIDE OF HOUSE) DESIGNED 58" (4509pm) N f= 0.631'/100' M V= 2.87 BB 44 (1909pm) DESIGNED B"VALVE -8"(50') (640 9pm) 8f=1.300 '100' OV=4.09 BB 43 (1759pm) DESIGNED 6 "(30') VALVE 18" VALVE (6709pm) 18" 5 f= 1.42'/100' 3 4.28 8"VALVE 8"VALVE 4 OF 6 10



NOV 75-JES 22

D	E	SI	G	N	SI	-	E	ET	•

JOB <u>COURTHOUSE</u> BAY STRUCTURE\_\_\_\_\_\_ IVE LOAD PER SQUARE FOOT\_\_\_\_\_

J. E. SIRRINE COMPANY

JOB NO A -1086 DATE 1-29-79 COMPUTED BY TLD WORKING STRESS

RAW WATER SUPPLY (EXISTING CONDITIONS)

PUMP IN WELL HOUSE NO. 43 WILL SEE THE FOLLOWING HEAD.

STATIC HEAD LOSSES DUE TO PIPE FRICTION (6709pm) 405 × 1.920'100'

PUMP IN WELL HOUSE NO. 44 WILL SEE THE FOLLOWING HENDA

> LOSSES DUE TO PIPE FRICTION (690 9pm) 2230 × 1-300/100'

= 35.00

= 5.25

40.75 FT-HD

= 28.99

69.79 FT-HD

PUMP IN WELL HOUSE NO. 220 WILLSEE THE FOLLOWING HEAD

> LOSSES DUE TO PIPE FRICTION (4509pm) 1970 × 0.681'/100'

= 10.01


79.75 FT-HD

PUMP IN WELL HOUSE MO. 221 WILLSE THE FOLLOWING HEAD

> LOSSES DUE TO PIPE FRICTION (300 gpm) 1460 X 0.322 /100'

50F6

= 4.70 84.95 FT-HD.




NOV	75-J	ES	22
-----	------	----	----

					01	
C	00	RI	HOR	E	BA	Ζ


JOB NO A - 1086	DATE	-29	-79
	0		
WORKING STRESS	The second	1.1	1.1

IT APPEARS THAT THE EXISTING SYSTEM COULD HANDLE THE DEFINID OF 670 90M, BUT THE SYSTEM WOULD HAVE NO STAND BY WELL SENCE IT WILL TAKE ALL FOUR EXISTING WELLS PUMP-ING AT THE SAME TIME. IF ANY ONE OF THE EXISTING WELLS WERE DOWN DURING THE GTO 90M DEMAND, THE WELLS COULD NOT MEET THIS DEMAND.

DESIGN SHEET



1. PROPOSED RAW WATER SUPPLY CALCULATIONS NOV 75-JES 22 A. E. SIRRINE COMPANY DESIGN SHEET JOB COURTHOUSE BAY JOB NO A-1086 DATE 10/6/78 WORSE CASE STRUCTURE RAW WATER COMPUTED BY TUD LIVE LOAD PER SQUARE FOOT WORKING STRESS -F.Y. 1986 1315' 6" VAL VE (45') r8" (6009pm) f= 1-16 1100' BB220 (1509pm) BBZZI .8. V=3.83 DESIGNED (300 gar) G"VALVE (50' OF G" PIPE FROM OUTSIDE OF HOUSE) DESIGNUD 2000 \$8" (300 9pm) f = 0.322/1 (6709pm) V=1.91 f = 1.42'1100' V = 4.28 FPS NEW WELL (300 gAM) DESIGHED BB 44 (1909pm) B"VALVE -DESIGNED 8"(50') (nu) f=1.92'/100' 0 v= 4.20 N BB 43 (1759 PM) DESIGNED 6 "(30') VALVE 8" VALVE r8" 5 (8"VALVE S"VALVE 1.200 -75 1 OF 3 270'



J. E. SIRGINE CUMPANI	
JOB COURTHOUSE	BAY
STRUCTURE	
LIVE LOAD PER SQUARE FOOT	

IOB NO A-	1086	DATE	10/16/28
COMPUTED BY			
WORKING STRESS			

-RAW WATER SUPPLY-(F.Y. 1986)

DESIGN SHEET

WELL NO.'S

PUMP DESIGNED CAPACITY

1759pm 190 " 150 " 300 " 300 " 111159pm

CAL: AVG. DAILY DEMAND = 462,95093/DBY OR 321.5 9PM MAX. PLANT DESIGN 960,200931/DAY OR 666.8 9PM  $\frac{RAW}{6709PM}$ TREATED

6709pm.

THE MAXIMUM RAW WATER GOING THRU THE B" PIPE 15 670,9pm


THE DAILY AVERAGE IS 325 9pm

WORSE CASE IN TRANSMISSION MAINS

ASSUMPTIONS:

(1) ASSUME 100 FT. OF PIPE PER PUMP HOUSE FOR VALVES & TURNS.

(76)



DESIGN SH	E	E	
-----------	---	---	--

JOB COURTHOUSE	BAY
IVE LOAD PER SQUARE FOOT_	

I. E GIRRINE COMPANY

JOB NO	A	-1086	-29-	79
		720		
WORKING ST				

RAW WATER SUPPLY (NEW WELL ADDED)

PUMP IN WELL HOUSE NO. 220 WILL SEE THE FOLLOWING HEAD.

STATIC HEAD LOSSES DUE TO PIPE FRICTION (6709pm) 3725' × 1.42'/100' = 35.00

= 53.61

88.61 FT-HD

PUMP IN WELL HOUSE NO, ZZI WILL SEE THE FOLLOWING HEAD

> LOSSES DUE TO PIPE FRICTION (600 gpm) 1415' × 1.16'/100'

= 16.41 FT-HD

105.02 FT-110


THE NEW WELL HOUSE WILLSEE THE FOLLOWING HEAD

LOSSES DUE TO PIPE FRICTION (3009pm) ZIOU'X 0.322/100'

= 6.76

111.78 FT-HD

THESE HEADS ARE HIGH FOR THE EXISTING PUMPS, THEREFORE, THE SYSTEM CAN NOT HANDLE THE WORSE CASE.




## 12. FIRE PROTECTION REQUIREMENT FOR COURTHOUSE BAY AREA (UNDER FAVORABLE CONDITIONS)

NUMBER	USE	HOSE STREAMS GPM	DURATION MIN.
S-BB-1	SEWAGE PUMPING STATION NO. 7	750	60
BB-2	THEATER	1000	75
BB-3	MARINE CORPS EXCHANGE	1250	90
BB-3A	MARINE CORPS EXCHANGE STOREHOUSE	1250	90
BB-5	ADMINISTRATION BUILDING	750	60
BB-6	ST CO/ ORG/OTH	750	60
BB-7	MESS HALL	1000	75
BB-8	FIRE STATION	750	60
BB-9	CENTRAL HEATING PLANT	1000	75
BB-10	DISPENSARY	750	60
BB-11	BARRACKS FOR AMTRAC	750	60
BB-12	BARRACKS FOR AMTRAC	750	60
BB-12	BARRACKS FOR AMTRAC	750	60
BB-13 BB-14	BARRACKS FOR AMTRAC	750	60
BB-14 BB-15	ST CO/ ORG/OTH	750	
		750	60
BB-16			60
BB-17	OFFICERS QUARTERS, MARRIED	750	60
BB-18	OFFICERS QUARTERS, "	750	60
BB-19	UFFILERS QUARTERS,	750	60
BB-20	UFFICERS QUARTERS,	750	60
BB-21	UFFICERS QUARIERS,	750	60
BB-22	OFFICERS QUARIERS,	750	60
BB-23	UFFICERS QUARTERS,	750	60
BB-24	UFFICERS QUARTERS,	750	60
BB-25	(100,000 GAL) ELEVATED WATER TANK		-
BB-26	HEATING PLANT	1000	75
BB-27	STAFF NCO CLUB	750	60
BB-28	ADMINISTRATION BUILDING	750	60
BB- 30	APPLIED INSTRUC. BUILDING	750	60
BB-31	STORAGE, OFFICE & CLASSROOM	750	60
BB-32	APPLIED INSTRUCTION BUILDING	750	60
BB-34	MAINTENANCE SHOP	1000	75
BB-36	STORAGE	750	60
BB-37	APPLIED INSTRUCTION BUILDING	750	60
BB-38	GUARDHOUSE	750	60
BB-43	PUMP HOUSE FOR WELL - W	750	60
BB-44	PUMP HOUSE FOR WELL - V	750	60
BB-45	BACHELOR OFFICERS QUARTERS	750	60
BB-46	BOAT HOUSE	750	60
BB-47	STORAGE BUILDING	750	60
BB-48	ACADEMIC & GENERAL INST. BUILDING	750	60
BB-49		750	60
BB-50	APPL. INST. BLDG.	750	60
BB-50 BB-51	HEAVY EQUIP. & MAINT. TRANSPORT BLDG.	1250	and the second s
BB-51 BB-52	APPL INST BLDG.		90
BB-52	AFFL INST DLDG.	750	60

78


Page 1 of 3



# FIRE PROTECTION REQUIREMENT FOR COURTHOUSE BAY AREA (UNDER FAVORABLE CONDITIONS)

	FIRE PROTECTION RE FOR COURTHOUSE BAY (UNDER FAVORABLE CO	AREA	
NUMBER	USE .	HOSE STREAMS	DURATIO MIN.
S-BB-54	E M SERVICE CLUB	750	60
BB-57	VOLLEY BALL COURT		-
BB-58	TENNIS COURT		1 <u></u>
BB-59	BADMINTON AND HANDBALL COURT	750	60
BB-60	TENNIS COURT	-	
BB-66	IMHOFF TANK	-	<b>_</b>
BB-67	SLUDGE DRYING BEDS		-
BB-68	STORAGE	750	60
BB-69	TELEPHONE EXCHANGE BUILDING	1000	75
BB-71	APPLIED INSTRUCTION BUILDING	750	60
BB-72	TOILET	750	60
BB-73 BB-80	APPL INST BLDG	750	60
BB-82	ACADEMIC & GEN. INST. BUILDING TRNG BLDG/OTH	750	60
BB-83	ACD/GEN INS BLDG	750	60
BB-84		<u>750</u> 750	60
BB-93	н н н	750	<u>     60</u> 60
BB-94	LUBRICATION FACILITY	750	60
BB-95	ACD/GEN INS BLDG	750	60
BB-100	ACAD. & GEN. INSTR. BLDG.	750	60
BB-136	ACADEMIC & GEN. INSTR. BLDG.	750	60
BB-137	ADMIN BLDG	750	60
BB-138	ACD/GEN INS BLDG	750	60
BB-139	п п п п	750	60
BB-140	BRIDGE STORAGE SHED	1000	75
BB-166	ST COV ORG/OTH	750	60
BB-170	ST COV ORG/OTH	750	60
BB-177 BB-183	SERVICE STATION	1750	120
BB-185 BB-189	SAWMILL STORAGE BLDG	1750	120
BB-190	WATER TREATMENT PLANT	750	60
BB-191	RESERVOIR (350,000 GALS)	750	60
BB-204	SEW PUMP STA	750	60
BB-205	SEW TREAT PLANT	750	60
BB-206	U U U	750	60
BB-207	п п п	750	60
BB-208	REC BLDG	750	60
BB-209	PLAYING COURT		
BB-210	SNACK BAR	1250	90
BB-213	LUMBER STORAGE	1000	75
BB-219	BANK	750	60
BB-220	PUMP HOUSE FOR WELL	750	60
BB-221	성실 방법 것 같은 것 같아요. 이번 것	750	60
BB-222	TRAINING SUPPLY BLDG	750	60
	: '영화' 같이 있는 것은 바람이 있다. 가격 가격하는 것은 가격을 가지 않는 것이 있다. 이 가격 가격하는 것이 있는 것이 있는 것이 있다. 이 가격 가격하는 것이 있는 것이 있는 것이 있는 것이 같이 같이 있는 것이 같이 있는 것이 같이 있는 것이 없는 것이 없다. 것이 있는 것이 있는 것이 있는 것이 있는 것이 없는 것이 있는 한		Page 2 of
	그는 이번 방법에서 그는 이렇게 했다.		
	$\overline{79}$		

79



#### FIRE PROTECTION REQUIREMENT FOR COURTHOUSE BAY AREA (UNDER FAVORABLE CONDITIONS)


NUMBER	USE	HOSE STREAMS GPM	DURATION MIN.
S-BB-229	PICNIC SHELTER	750	60
BB-230 BB-231	STORAGE BLDG	750	60
BB-237	STORAGE BLDG	750	60
BB-250	BARRACKS FOR ENG. STUDENTS	1000	75
BB-255	BARRACKS FOR ENG. STUDENTS	1000	75

80

Í

I

ł



### 13. FIRE PROTECTION REQUIREMENT FOR AMTRAC AREA (UNDER FAVORABLE CONDITIONS)


Ì


Ĩ


1


NUMBER	USE	HOSE STREAMS GPM	DURATION MIN.
A-1	AUTO VE MNT FAC	1750	120
A-2	AMPHIBIOUS TRACTOR SHOP	1750	120
A-3		1750	120
A-4	WATER BALANCING TANK & CNTL. BLDG.	750	60
A-5	PUMP HOUSE WELL V	750	60
A-7	ST. COV. ORG/OTH	750	60
A-8	и и и и	750	60
A-9		750	60
A-10		750	60
A-11	AUTO VE MNT FAC	1750	120
A-12	ST COV ORG/OTH	750	60
A-13	MAINT FAC/OTH	1250	75
A-14	ST COV ORG/OTH	750	60
S-A-21	FUEL DISPENSING FACILITY	2250	135
A-25	BOAT HOUSE	750	60
S-A-26	GREASE RACK	날아가 말 감독 모두 모두 가는 것을 했다.	<b>-</b> 3
S-A-27	WASH RACK		- St. 1
S-A-28	BOAT HOUSE	750	60
S-A-29	LVT WASH RACK		1.4.8.9 19- 2.4.11
S-A-30	FUEL DISP. FAC	2250	135
A-33	GATE/SENTRY HOUSE	750	60
S-A-34	GREASE RACK		- 200 - 200
S-A-35	BERTHING PIER		-
A-37	STORAGE BLDG	750	60
S-A-38	SEWAGE PUMPING STATION	750	60

(81)














FIRE HYDRANT NUMBER (7.32.4)


















JOB <u>COURTHOUSE</u> BAY STRUCTURE	DESIGN SHEET	JOB NO <u>A-1086</u> DATE <u>10/12/7</u> . COMPUTED BY <u>TCD</u> WORKING STRESS
15. FIRE PROTECT	ION CALCULATIO	PNS
- FIRE (EXIST	PROTECTION TINGS	· · ·

THE FOLLOWING EQUATION CAN BE USED BECAUSE THE RATE OF FLOW IS APPROXIMATELY PROPORTIONAL TO THE SQUARE ROOT OF THE PRESURE DROP.



Q= MAX. FLOW OUT OF THE HYDRAMT AT ZOPSI Qz= FLOW OUT OF THE HYDRAMT WITH A CERTAIN RESIDUAL PRESSURE

PI : PRESSURE DROP BETIMEEN STATIC PRESSURE THE REQUIRED 20 PSI

P2 = PRESSURE DROP BETWEEN STATIC AND RESIDUAL.

HYDRANT 7.1.8 STATIC = SS PSI RESIDUAL = 32 PSI FLOIM = BZD gp19

$$\frac{Q_1}{820} = \frac{55-20}{\sqrt{55-32}}$$


Q1 = 10129pm

**NOV 75-JES 22** 


HYDRANT 7.32.4 STATIC = 55PSI RESIDUAL = 36 PSI FLOW = 820 gpin

Q= 1113 9pm


1OF6




	NOV 75-JES 22
DEST	IGN SHEET JOB NO <u>A -1086</u> DATE <u>10/12/</u> 28 COMPUTED BY <u>TCD</u> WORKING STRESS
HYDRANT 7.11.8 STATIC =55 PSI RESIDUAL = 50 PSI FLOW = 980 gpm	
$\frac{Q_1}{980} = \frac{\sqrt{55-20}}{\sqrt{55-50}}$	Q1 = 2593 gpm
HYDRANT 7.22.6 STATIC = 50 PSI RESIDUAL = 31 PSI FLOW = 7.90 9 PIM	
$\frac{Q_{1}}{790} = \frac{\sqrt{50-20}}{\sqrt{50-31}}$	Q1= 9939pm
HYDRANT 7.28.8 STATIC = 50 PSI RESIDUAL = 37 PSI FLOW = 980 gpm	
$\frac{Q_1}{980} = \frac{\sqrt{50-20}}{\sqrt{50-37}}$	Q1= 1489 gpm
2008년 2017년 - 1928년 1월 2017년 2017년 2018년 2018년 2017년 2017년 2017년 2017년 2018년 2018년 2018년 2018년 2018년 2018년 2018	동생과 전화에서는 '영양 전'을 위해 가는 것을 것을 했다. 것을 다 가는 것을 가지 않는 것을 가지 않는 것을 가지 않는 것을 가지 않는 것을 하는 것을 하는 것을 하는 것을 하는 것을 하는 것을 가 하는 것을 수 있다. 가지 않는 것을 하는 것을 하는 것을 하는 것을 수 있다. 것을 하는 것을 하는 것을 수 있다. 가지 않는 것을 하는 것을 수 있다. 것을 하는 것을 수 있다. 가지 않는 것을 수 있다. 가지 않는 것을 수 있다. 것을 하는 것을 수 있다. 가지 않는 것을 수 있다. 것을 하는 것을 수 있다. 가지 않는 것을 수 있다. 것을 것을 것을 것을 하는 것을 수 있다. 것을 것을 수 있다. 것을 것을 것을 것을 수 있다. 것을 수 있다. 것을 것을 것을 것을 수 있다. 것을 것을 것을 것을 수 있다. 것을 것을 것을 것을 것을 것을 수 있다. 것을 것을 것을 것을 것을 수 있다. 것을



**NOV 75-JES 22** J. E. SIRRINE COMPANY DESIGN SHEET JOB COURTHOUSE BAY JOB NO A-1086 DATE 10/12/78 COMPUTED BY TLD STRUCTURE LIVE LOAD PER SQUARE FOOT - FIRE PROTECTION -(EXISTING) COURTHOUSE BAY & AMTRAC AREA WILL FALL WITHIN THE FOLLOWING OCCUPANCY CLASSIFICATION OCCUP. CLASS GPM DURATION LIGHT HAZARD 750 60 MIN ORDINARY HAZARD GROUPI 75 1000 11 90 1. " 2 1250 " 1. 3 120 11 1750 11 THE FIRE PROTECTION WILL BE UNDER FAVORABLE CONDITIONS DUE TO THE EARLY RESPONSE BY A WELL TRAINED FIRE DEPARTMENT. THE PRESSURE REQUIRED IS 20 POUNDS PER SQUARE INCH. MINIMUM. STORAGE REQUIREMENTS, THE REQUIREMENTS FOR FIRE PROTECTION WATER STORAGE ARE BASED ON THE ASSUMPTION THAT THERE WILL BE DALY ONE FIRE AT A TIME. TOTAL STORAGE CAPACITY: STORAGE REQUIRED TO SUPPLY THE PEAK FIRE FLOW DEMAND PLUS 50% OF THE PEAK DAILY DOMESTIC CONSUMPTION, PEAK DAILY = 656,390 gal FIRE MAX = 1750 gpm For 120 MIN = 210,000 gal TUTAL STURAGE = 656,390/2 + 210,000 = 538,195921 STORAGE AVAILABLE = 450,000gal 30F6



NOV 75-JES 22
LE STRAINE CONFANT JOB <u>COURTHOUSE BAY</u> STRUCTURE LIVE LOAD PER SQUARE FOOT DESIGN SHEET UNDESIGN SHEET DESIGN SHEET MORKING STRESS WORKING STRESS
FIRE PROTECTION
REPLENISHMENT OF STORAGE: IT SHALL REACH REQUIRED VOLUME DURING NORMAL CONSUMPTION WITHIN 48 HOURS AND WITHIN 24 HOURS BY CURTAILING NORMAL CONSUMPTION.
CAL: AVG. DAILY DEMIAND = $385,230gal/DAY$ FIRE PROTECTION = $210,000gal/DAY$ 595,230gal/DAY
AT PRESENT THE DESIGN CAPACITY OF THE HID PLANT IS 550,000 gal/DAY
DURING A 48 HOUR PERIOD, THE SYSTEM APPEARS TO BE ABLE TO. REPLENISHING STORAGE
DISTRIBUTION RESERVOIRS : 50% OF AVERAGE DAILY CONSUMPTION PLUS FIRE PROTECTION
$\frac{385,230}{2} + 210,000 = 402,615 gals.$
AT PRESENT, STORAGE CAPACITY = 450,000gals.
· 2017년 1월 2



JOB COURTHOUSE	BAY
STRUCTURE	

JOB NO A-1086 DATE 10/16/28 COMPUTED BY TCO

DESIGN SHEET

COURTHOUSE BAY & AMTRAC AREA WILL FALL WITHIN THE FOLLOWING OCCUPANCY CLASSIFICATION

. occur.	CLASS	1	GPM	DURATION
LIGHT H	AZARD		750	60 MIN
ORDINARY			1000	75 "
1 11		" 2	1250	90 "
	"	3	1750	120 "

THE FIRE PROTECTION WILL BE UNDER FAVORABLE CONDITIONS DUE TO THE EARLY RESPONSE BY A WELL TRAINED FIRE DEPARTMENT.

THE PRESSURE REQUIRED IS 20 POUNDS PER SQUARE INCH. MINIMUM.

STORAGE REQUIREMENTS, THE REQUIREMENTS FOR FIRE PROTECTION WATER STORAGE ARE BASED ON THE ASSUMPTION THAT THERE WILL BE DALY ONE FIRE AT A TIME.


TOTAL STORAGE CAPACITY: STORAGE REQUIRED TO SUPPLY THE PEAK FIRE FLOW DEMAND PLUS SO % OF THE PEAK DAILY DOMESTIC CONSUMPTION.

 PEAK DAILY = 960,200 gal.

 FIRE MAX = 1750 gpm For 120 MIN = 210,000 gal.

 TOTAL STORAGE REPOR = 960,200 + 210,000 = 690,100 gal.

 STORAGE AVAILABLE = 91



NOV	75-JES	22
-----	--------	----

CONDENDUCE	DAV
JOB COURTHOUSE	DAY
STRUCTURE	
LIVE LOAD PER SQUARE FOOT	

J. E. SIRRINE COMPANY

11-11	226	DATE 10/16/7
JOB NO 17 10	100	_DATE / DITO
COMPUTED BY	TCL	0

-FIRE PROTECTION -(F.Y. 1986)

DESIGN SHEET

REPLENISHMENT OF STORAGE: IT SHALL REACH REQUIRED VOLUME DURING NURMAL CONSUMPTION WITHIN 48 HOURS AND WITHIN 24 HOURS BY CURTAILING NORMAL CONSUMPTION.

CAL, AVG, DAILY DEMAND = 462,950 gollOAYFIRE PROTECTION = 210,000 gollOAY672,950 gollOAY


THE HO PLANT WILL BE DESIGNED FOR A CAPACITY OF 960,200 gal/DAY

THEIR SHOULD BE NO PROBLEM IN REPLENISHING STORAGE,


DISTRIBUTION RESERVOIRS: 50% OF AVERAGE DAILY CONSUMPTION PLUS FIRE PROTECTION.

462,950 + 210,000 = 441,475 gals

AT PRESENT, STORAGE CAPACITY = 450,000 gals.



-<u>APPENDIX II</u>-WATER TREATMENT PLANT DESIGN CALCULATIONS A UTILITY STUDY FOR THE COURTHOUSE BAY AREA




#### J. E. SIRRINE COMPANY

4

1

# APPENDIX II INDEX

	PAGE
DESIGN ASSUMPTIONS	1
HYDRAULIC CONSIDERATIONS, SOFTENERS	2
HYDRAULIC CONSIDERATIONS, FILTERS	3
WATER CONSUMPTION	5
SOFTENER RESIN VOLUMES	5
SOFTENER CAPACITIES	6
SERVICE TIMES	9
WASTEWATER FLOWS FROM WATER TREATMENT PLANT	10
SALT USAGE	11
FILTER ALTERNATE NO. 1	. 12
FILTER ALTERNATE NO. 2	13
LANGELIER INDEX DETERMINATION	15



			~.		-	
DE	510	iN	SI	-11	-	FT

JOB	
STRUCTU	JRE
LIVE LO.	AD PER SQUARE FOOT

I

I. E. SIRRINE COMPAN

OB NO	DATE	-
OMPUTED BY		1 3
ORKING STRESS		

## DESIGN Assumptions

Assum 960,200 GAL/DAT REQ'D - 667 5pm use 670 qpm

THis is Treated Water NOT INCL. BACKWASH s Softener regeneration 'HARDNESS OF Wells #43 - 293 ppm As Calog #44 138 # 220 152

# 221 133


Assume total hardiness of row water to be 200 ppm. And Any new wells to be in same range of hardness. Abandon #43 due to low flow rate of 50 gpm. DESIRE plant effluent to have soppose total hardness which will be Achieved by bypassing filtered water around Softener system.

200 (x) = 50 x = 50/200 = 25% hyprosed flow

DEsign criteria flow loading -

Jofteners - 6to 8 9pm / ft2


filters - may of 2 spm/f+2



#### DESIGN SHEET


I. E SIRRINE COMPANY

COMPUTED BY IVE LOAD PER SQUARE FOOT WORKING STRESS Hydrauic Considerations, Softeners Hydraulic Considerations for Softeners having treated effluent of 670 spm - 75% = 503 ggm  $\frac{503 gpm}{X 59.F+} = 6 Spm/f+2$ Sg f+ reg'd = 83.8 var 84 sg f+ presently have 2 5'\$ vessels -> 2 × 19.635 f+2 = 39.3 + 284 - 39.3 = 44.7 59 ft Additional Softener Area regid. 44.7 f+2 can be met by 2 6'\$ vessels w/28.2744 f+2 each (56.55 sq f+ totel) This yields a system w/ 2 5'd i 2 6'd tonles Total surface area = 39,3 + 56.5 = 95,8 ft2 503 gpm / 95.8 ft = 5.25 spm | ft 2 with all units on line 5¢ offline with one 503 gpm / 19,635 + 56.549 sift = 6.6 gpm/f+2 with one L'& offline 503 gpm/39,3+28-274+ s,ft = 7.44 sym/f+2




I. E. SIRRINE COMPANY

DESIGN SHEET COMPUTED BY OAD PER SQUARE FOOT\_ Hydraulic Considerations, FILTERS # With one 5' & i one 6' fonk offline 503 gpm / 19.635 + 28.27++ f+2 = 10.5 gpm to. fast system to consist of 2 s'\$ and 2 6'\$ vessels interlocked to prevent simultaneous regenerations. \* HYDRAVIC Considerations FOR FILTERS effluent of 670 gpm Require 2 gpm/ft2 maximum flows loading 670 gpm/2 gpm/ft2 = 335 sq ft present system has 3 71/2 & vessels = (3 x 44.1787 = 132.5 sg ft) 335 - 132.5 = 202.5 additional 59 Ft regid. Achieved with 3 - 10'\$ = 3 × 18.54 = 235.6 Can be 3 - 9'\$ = 3 × 63.6174 = 190.85 3 - 9'-L" \$= 3 x 70. 88.23 = 212.4 Assume F12 & vessels is system would consist of 3 71/2'\$ \$ 391/2'\$ filters with all units on line 670 gpm / 3 x 44.1787 + 3 x 70.8823 = 1.94 5pm ok 3)




DESIGN SHEET	
JOB	JOB NODATE
VE LOAD PER SQUARE FOOT	WORKING STRESS
· _ · · · · · · · · · · · · · · · · · ·	
WITH one 71/2 \$ unit off \$ 670 gpm / (2x 44.1787) + (3x 70.8 88.36 + 212.6	beckwasit
610 gpm / (2x 44, 1787) + (3x 70, 8	823) = 2.23 gpm
55.56 T 212.	F+2
with one 91/2'd vessel off	for backwasit
670 gpm/(132.5) + (2x 70.8823)	
	/* /++
Consider 3 all'- 1 with with	Le as restants
Consider 3 additional 10 \$ unit	, Ea. 10.ST SEFT
with all units on line	
670 gpm / (3x +++ 1787) + (3x 78.54) sc	ft = 1.82 gpm/ft2 64
670 gpm/(3×44.1787)+(3×78.54) sj: 132.5 235.6	
with one 71/2 \$ offline ba	
670 gpm/(2× 44.1787)+(3×1	8.54) 55f+ 2.07 gpm
88.4 + 235.6	fiz
with one 10'\$ offline b	ackwasting
670 gpm /12 44, 1787 )+ (24	78.54) = 2,31 sem
670 ggm / (3×44,1787) + (2× 132.5 + 157.	
	τ'
	F-
SEE ALTERNATE 7	≠ 2 ´)
· · · · ·	
(4)	



### FSIGN SHEET

J. E SIRRINE COMPANY

UNE Loss He solver for Weter Consumption Lost Water due to backwash & Kegeneration 2-5'\$ softenens - 4480 gallons/Regeneration/soften 3-71/2\$ filters - 4560 gallons/Regen/softener (13,000 gallons / Regen/softener (13,000 gallons - 7'\$ vessel w/3' be 3 10'\$ filters - 17,000 gallons / Regen/softener (13,000 gallons / Regen/softener 4 8'\$ filters - 17,000 gallons / Regen/filter 4 8'\$ filters will be backwashed daily softener regenerated on basis of hardness break through. 2 5'\$ existing softeners - 49 ft3 Resin each of 17.6355517 - 58.9 ft3 resin each of 3' depth 2 6'\$ softeners - 4/212' depth - 70.7 ft3 28.2744 35ft w/ 3' depth - 84.8 ft5	JOB		DESIGN SH		DATE
Lost Water due to backwast & Regeneration 2-5'\$ softeners - 4480 gallons/Regeneration/softe 3-71/4 filters - 4560 gallons/Regen/softener (13,000 gallons / Regen/softener (13,000 gallons - 7'\$ vessel w 3'} 3 10'\$ filters - 17000 gallons/Regen/filter 4 8'\$ filters - 4600 gallons/backwast/filter Assume filters will be backwasted daily softeners regenerated on basis of hardness break through. 2 5'\$ existing softeners - 49 ft3 Resin each of 17.035's ft 2 5'\$ softeners - 49 ft3 resin each of 3'\$ depth 2 6'\$ softeners - 4/21/2' depth - 70.7 ft3		· ·		COMPUTER	BY
Lost Water due to backwast & Regeneration 2-5'\$ softeners - 4480 gallons/Regeneration/softe 3-71/4 filters - 4560 gallons/Regen/softener (13,000 gallons / Regen/softener (13,000 gallons - 7'\$ vessel w 3'} 3 10'\$ filters - 17000 gallons/Regen/filter 4 8'\$ filters - 4600 gallons/backwast/filter Assume filters will be backwasted daily softeners regenerated on basis of hardness break through. 2 5'\$ existing softeners - 49 ft3 Resin each of 17.035's ft 2 5'\$ softeners - 49 ft3 resin each of 3'\$ depth 2 6'\$ softeners - 4/21/2' depth - 70.7 ft3	LIVE LOAD PER SQUA	RE FOOT		WORKING	STRESS
Lost Water due to backwast & Regeneration 2-5'\$ softenans - 4480 gallons/Regeneration/softe 3-71/4 filters - 4560 gallons/Regen/softenar (13,000 gallons/Regen/softenar (13,000 gallons - 7'\$ vessel w 3'} 3 10'\$ filters - 17000 gallons/Regen/filter 4 8'\$ filters - 4600 gallons/Backwaste/filter Assume filters will be backwasted daily softenars regenerated on basis of hardness break through. 2 5'\$ existing softenars - 49 ft3 Resin each of 12.6'\$ softenars - 49 ft3 resin each of 3 5'\$ existing softenars - 49 ft3 resin each of 3 5'\$ existing softenars - 49 ft3 resin each of 3 5'\$ softenar - 400 gallons - 70.7 ft3		Water	· Consumpt	67	
3-71/4 filters - 4560 gallons/regeneration/filte 2-64 softeners - 9,000 gallons/regen/softener (13,000 gallons - 74 vessel w/31 ke 3 104 filters - 17,000 gallons/Regen/filter 4 84 filters - 4600 gallons/backwasth/filter Assume filters will be backwasthed daily softeners regenerated on basis of hardness break through. 2 54 existing softeners - 49 ft3 Resin each ed 12.67 depth - 58.9 ft3 pesin each e 31 dapth 2 64 softeners - 4/ 21/2' depth - 70.7 ft3	٨	ost water	due to	backwash ;	é Regenerato
2-6'\$ softeners - 9000 gellons/Regen/softener (13,000 gellons - 7'\$ vessel w/3' be 3 10'\$ filters - 17,000 gellons/Regen/filter 4 8'\$ filters - 4600 gellons/backwasth/filter Assume filters will be backwasthed daily softeners regenerated on basis of hardness break through. 2 5'\$ existing softeners - 49 ft3 Resin each et 17.035's bt - 58.9 ft3 pesin each et 3' depth 2 6'\$ softeners - 4/ 2'/2' depth - 70.7 ft?	2	5'¢ softeners	- 4480	gallons/Re	generation /soft
<ul> <li>3 10'\$ filters - 17,000 gellons/Regen/filter</li> <li>4 B'\$ filters - 4600 gellons/backwasted filter</li> <li>Assume filters will be backwasted daily softeners regenerated on basis of hardness break through.</li> <li>2 S'\$ existing softeners - 49 ft3 Resin each et 17.635 sg It</li> <li>2 S'\$ existing softeners - 49 ft3 resin each et 3' depth</li> <li>2 S'\$ softeners - 0/ 21/2' depth - 70.7 ft3</li> </ul>	3-	7½¢ filters	- 4560	gallons / reg	eneration/filte
<ul> <li>3 10'\$ filters - 17,000 gellons/Regen/filter</li> <li>4 B'\$ filters - 4600 gellons/backwasted filter</li> <li>Assume filters will be backwasted daily softeners regenerated on basis of hardness break through.</li> <li>2 Si\$ existing softeners - 49 ft3 Resin each et 17.635 sg ht</li> <li>2 Si\$ of teners - 49 ft3 resin each et 31 depth</li> <li>2 Si\$ of teners - 49 ft3 resin each et 31 depth</li> </ul>	2 -	· 6'¢ softener	· - 9,000 (13,000	gallons / Reg gallons - 7'	en/softener \$ vessel w/312
<ul> <li>4 β'\$ filters - 4600 gellens/backwasth/filter - Assume filters will be backwasthed daily softeners regenerated on basis of hardness break through. <u>Softener Resin Volumes</u> 2 5'\$ existing softeners - 49 ft3 Resin each d 17.635's ft - 58.9 ft3 resin each a 3' depth 2 6'\$ softeners - 4' 21/2' depth - 70.7 ft3 2 6'\$ softeners - 4' 21/2' depth - 70.7 ft3</li> </ul>					
2 5'\$ existing softeners - 49 ft3 resin each es 2 5'\$ existing softeners - 49 ft3 resin each es 17.635's st 2'6'' depth - 58.9 ft3 resin each e 3' depth 2 6'\$ softeners - 49 ft3 resin each es 2'6'' depth	4				
Softener Resin Volumes 2 5'\$ existing softeners - 49 ft3 Resin each el 17.635's; It 2'6'' depth - 58.9 ft3 presin each e 3' depth 2 6'\$ softeners - u/ 2'/2' depth - 70.7 ft3		Assume filte Softeners rea break throu	rs will be generated o igh.	backwasHed ~ basis o.	daily hardness
2 5'\$ existing softeners - 49 ft3 Resin each est 17.63555 Lt 2'6'' depth - 58.9 ft3 presin each e 3' depth 2 6'\$ softeners - w/ 21/2' depth - 70.7 ft3					
17.635 sg Lt. - 58,9 ft <sup>3</sup> pesin each a 31 d×pth 2 6'\$ softeners - w/ 21/2' depth - 70.7 ft <sup>3</sup>		Softene	- Resin	Volumes	
2 6'\$ softeners - w/ 21/2' depth - 70.7 ft?	2			- 49 ft3 2'6" d	Resin each el epth
2 6'\$ softeners - w/ 21/2' depth - 70.7 ft? 28.2744 syft w/ 3'depth - 84.8 fts					
28,2744 3577 w/ 3'depath - 84,8 f+ 5	2	6'\$ softener	$- \nu/$	21/2' depth	- 70.7 St 3
에는 것에 가지 않는 것을 알려야 한다. 이렇게 가지 않는 것이 있는 것이 없는 것이 없 같이 없는 것이 없 같이 없는 것이 없		28,2744 35+7	w/ 3	'depth -	- 84,8 f+s
				Real Property	




$(\cdot)$	NOV 75-JES 22
JOB	DATE
STRUCTURE	COMPUTED BY
Softener Capterties Determination of Capterty	of Softwars
Existing Softeners - 49 ft3 21/2'	
1275 Kgr between 176,000 ge	regeneration regeneration ellons treated/regen.
cochrane capacity of resin -	hardness (12+ ppm total hardness) 26 Kgr/ft <sup>3</sup> resin
SIRRINE CAPACITY of resin -	18 kgr /fts resin
water to have 200 ppm to opposed to 124 ppm And opposed to 256 gpm.	stel hardness as 503 gjome 4s
FLOW proportioning (assuming Same Ap 9pm/f+2)	, same resin depth, , same flow load,
	1.635 + 2 × 28.2744 3 + 56.5 8 sg ft
Assume all 4 units on line 503 gpm X 5'q $95.8 sqff = 19.635X = 103.1 gpm5.25 gpm/ff = 2$	$6' \phi = \frac{5039pm}{95.8s_{5}4} = \frac{x}{28.274}$ x= 148.5 gpm
5.25 5pm/f+2	

ъ.

•

5

5,259,20 f+2




	NOV	75-J	ES	22
--	-----	------	----	----

= 70.7 f+>

J E SIRRINE COMPANY	HEET
JOB	JOB NODATE
STRUCTURE	COMPUTED BY
LIVE LOAD PER SQUARE FOOT	WORKING STRESS
when 1 5'\$ vessel	. Sclin !
when I Sp Vesser	
5'\$	
503 gpm - X	$\frac{503gpm}{74.17} = \frac{x}{28,2744}$
76.17 sgf+ 19.635	76.17 28,2744
양성 - 영양 - 양성 방송 방송 - 감독 문양 - 영양 관계 영양 - 영양	그 승규님은 그 옷에 다른 것을 하는 것이 없는 것이 없다.
X = 129.7 5pm	X = 186.7 gpm
	신 것은 방법에 많은 것은 것은 것은 것이 있는 것이 같은 것이라는 것은 것이 있는 것이 없다. 것은 것이 없는 것이 없다.
6.6 5pm/f+2	6.6 gpm/f+2
	홍정하는 방송을 다 아름다는 날 것이 같이 가지?
when I 6' vessel o.	Efline:
1994년 - 1995년 1997년 1 1997년 - 1997년 19	한 경험에서 영화 가지 않는 것 같은 것 같아요.
5'\$	6' p
3 4	• P
	and the second
503 gpm X	503 gpm X
503 gpm = <u>X</u> 67.5 sqft 19.635	503 gpm = X 67.5 sgft = 28,2744
11:600	0,11 - 1,11 - 1,11
X = 146.3 9pm	۳ مر ۲ X = 210.7
그는 그는 것을 다 가슴을 흘러야 한다. 그는 것을 가장하는 것	
7.45 910-15+2	7.45 Gpm
	f+~
H	
김 씨가는 물건이 다는 성상에 물지 못했다. 물건 바람이 가 여기었어?	
Softener Exchan	se Capacities
	Cochrone - 26 kgr/f+3
w1 211 1 100 1 10	SIRRINE - 18 Kgr/ft?
w1 21/2' deep resin beds	e siderine 18 kg-/ft3
5'\$ tank	6'& tonk
(200 ppm)(103.1)(x) - 49 F+?	(200 joy ~) ( H8.5 Xx)
(17.1)(1000)(18)	(17.1)(1000)(18)
V moul	Vr 732 7
X = 731.4 min	X= 732,7 min 12.2 hrs
12.2 hrs.	12.2 hrs


7

.c∆₁




L E SIRRINE COMPANY	
DESIGN SI	
STRUCTURE	COMPUTED BY
LIVE LOAD PER SQUARE FOOT	WORKING STRESS
Calculate time of S Cochrane Capacity of	ERVICE RUN Using 26 Kg-/f+s é 21/2' bed depth
5'\$	6'\$
$\frac{(200)(103.1)(x)}{(17.1)(1000)(26)} = 49ft3$	$\frac{(200)(148.5)(x)}{(17.1)(1000)(26)} = 70.7$ f+3
X = 1057 min	X= 1058 min
17.6 hrs	17.6 hrs
77.6 71.7	110 143
Using 3' resin deprit é	SIRRINE 18 Kgr/ f+3
5'\$	6'\$
$\frac{(200)(103.1)(x)}{(17.1)(1000)(18)} = 58.9ft$	$\frac{(200)(148.5)(x)}{(17.1)(1000)(18)} = 84.8$
X= 879.2 min 14.7 hrs	X = 878.8 min 14.7 hrs
Using 3' resin depath & G	ochrone 24 kg-1 ft >
514	6'\$
(200)(1031)(x) =	(200)(148.5)(*)
(200)(103.1)(x) = 58.9f+3	= = 0 4 0
(17.1)(1000)(26)	(17.1)(1000)(24) = 84.8 f+ >
X = 1270 min	
한 그 것이 가 이것 것은 것 같은 것 같은 것 이렇게 잘 많은 것이 같은 것을 다 같아	X= 1269 min
21 hrs	21 hours

NOV 75-JES 22



I. E. SIRRINE COMPANY DESIGN SHEET JOB NO DATE STRUCTURE COMPUTED BY\_\_\_\_ LIVE LOAD PER SQUARE FOOT\_ WORKING STRESS SERVICE TIMES Summary OS SERVICE TIMES 18 Kgr 21/2' resin deptit 26 Kgr 21/2' resin deptit 12.2 hours 17.6 hours 18 KSr 3' resin dep TH -14.7 hours 21 hours 26 Kgr 3' resin depty -Each Unit will regenerate after 12.2 to 17.6 hours operation will 21/2' resin based on 200 ppm total hardness assumption Hetal hardness w/o 0343 - 138+152+133 = 141 ppm total hardness  $\frac{200}{141} = \frac{x}{14.7}$  $\frac{200}{141} = \frac{X}{21}$ X= 29.8 hours X = 20.8 hours Actual run times w/ 3' resin treds 200 × 141 17.6  $\frac{200}{141} = \frac{X}{12,2}$ X = 24.5 hrsX = 17.3 hrs Avg 21.1 hours Actual run times w/ 21/2' resin beds. a 141 ppm hardness

**NOV 75-JES 22** 



#### DESIGN SHEET

JOB	
STRUCTU	RE
LIVE LOA	D PER SQUARE FOOT


I

1

OB NO	DATE	
OMPUTED BY		
VORKING STRESS		

Wester Water FLOWS FROm Water Treatment Plant Frequency: FILTEr backwash - 1 backwash softener regen. - 21 hours once / day / pe - wit 71/2 4 FILTERS - 4560 ×3 = 13,680 gallons 3 8'\$ FILTERS - 4600 ×3 = 18,400 " 4 5'\$ softeners - 4480 ×2 = 8960 " 2 6'\$ softeners - 10,000 x 2 = 20,000 " 2 Adsume 65,000 gpd. would require additional 45 gpm to make -p lass. i. Assume losses to be made up at night during low flow demand. 65,000 gel/670 gpm = 97 minutes ~ 11/2 hours. Assume system to consist of:

7 filters -  $3_{7}^{7}/24$  H,  $2_{4}^{7}/4$ H softeners - 2, 5'4, 2, 4'4



		DESIG	N SHEET		
40L	-	- All we will be			DATE
STRUCTURE	1.			COMPUTED BY	
		5 . I . II			
		Salt U	sige		
	Sa	17 Usag	e Calc-	lations	
5	¢ vesse	.ls - 40	g ft " en		
			.7 f+3 ea	<b>.</b>	
)). 7 )	16s salt e- day	/cu.fr re = 2	sin x 2 800 163	39,4 cu.ft salf/day	resin total
	2800 ×	30 = 8		rac = 42 for $rac = 42$	30 day
p	esent a	Capacity -	- 23 tom	Supply / bin x 2	L bis
		=	the ton	Capacity	
200	enla,	-gement	of sel	t storage	necessary

J. E SIRRINE COMPANY


1

Î


1

1

Ī



• ()	0	NOV 75-JES 22
	EET	
JOBSTRUCTURE	JOB NO	DATE
LIVE LOAD PER SQUARE FOOT	WORKING STRESS	
FILTER ALTERNATE #1		
DESIGN FILTERS ON basis O 2.0 gpm may FT2	f 3-4 opm/.	f+2 not
$\frac{670 \text{ gpm}}{3 \text{ gpm/f+2}} = 224 \text{ sft}$	resid	
Present system 3 71/2'	$ \phi _{5} = 132$	.5 sqf+
224-132.5 = 91.5 Ada	titional sq ft	resid
Con he met ky 2	additional 7	1/2'\$ tonks.
5 71/2 4 vessels - 5x	44,1787 = 220	0.9 ssf+
670 gpm / 220.9 = 3.0 units	3 gpm/sgft on line.	with ell
With one whit backwa	shing	
670 gpm 4x 44.1787 59 ft = 3.5	8 gpm /f+2	Ole
ALTERNATE #1 - add	2 more 7!	lz' & filters



## DESIGN SHEET

JOB	
JOB	
STRUCTURE	E
LIVE LOAD	PER SQUARE FOOT

1

I

1

I

1

J. E. SIRRINE COMPAN

JOB NO	DATE	
COMPUTED BY		-
WORKING STRESS		1

FILTER ALTERNATE # 2

Consider all additional filters to be 71/2 \$ units or close to it to hold down water consumption during backwash, less effect on on line units while backwashing one unit, al retain some backwash piping size and drain pipe size:

670 gpm / 2 gpm / f+2 = 335 sq f+ req'd presently have 3 71/2'd units: 3x44.1787 f+2 = 132.5 sq f+

335 - 132.5 = 202.5 edditional sg f+ regid if 71/2' & units

202.5 55f+/44.178755f+ = 4.58 71/2 4 units needed

if 8'& units

202.5 55 ft / 50.2656 = 4.03 8'd units needed.


Assime &' & mits (4) will be added

13

th


670 gpm /(3x 44,1787) + (4x 50.2656) = 2.008 <u>fg</u>-132.5 + 201.06 ft<sup>2</sup>

all with on



NOV	75-JES	22
-----	--------	----

JOB			DESIGN	SHEET	JOB NO	DATE
STRUCTURE	QUARE FOOT				COMPUTED BY	
	with	one 7	1/2' ¢	alfline		
	670 4	)9m/(2	× 44,178 88,36	17) + (4 + 201.00	x 50.2656) =	2,31 gpm f+2
	いっち	one	819 of	Slime		
	670 9	pm / (3 x	44,1787 )	+(3×50	0,2654)	
		= 7	2,36 gpm	/ f+2		
		$\subseteq$	+			
1	Filters	will be	- 3-	71/2'\$	3-84	units
			+			
		Pipe line		ties (	pumped) 8"	
400	99-	4.5	is fps		2.56 493	
670 .	gpm-	(65	· ogpm) 7, 1	3s fps	(650 gpm) 4	his for
		no pr	iping c casons.	changes	tor siz	•



## DESIGN SHEET

JOB	 10.000	 
STRUCTURE	-	
LIVE LOAD PER SQUARE FOOT		

J. E. SIRRINE COMPANY

I


1

1

JOB NO	DATE
COMPUTED BY	
WORKING STRESS	

Row water TDS - 345 Total Alkalinity - 214 ppm 41 Calcon Calcium - 223 ppm as Calcon

- Calcium as Ca = 223 × . 4 = 89.2 ppm as Ca
  - 25°C 30% 20°0 temp. 86°F 68º F 77°F pHs 7.4 7.25 7.3 7,2 pHactual 7.2 7.2 Sat. Index -0.2 - 0.1 -0.05 corrosive InDex Chem. Engg
  - sat. Index -0.2 -0.06 O corrosive index pH after lime add. 7.8 7.8 7.8
  - Sat. Index +.4 +.5 +.55



Δ

•

1


-<u>APPENDIX III</u>-WASTEWATER TREATMENT

PLANT

A UTILITY STUDY

FOR

THE COURTHOUSE BAY AREA



## APPENDIX III

J. E. SIRRINE COMPANY

-

þ

I

1

1


I

1


111

1


	INDEX	Page
1.	J. E. SIRRINE COMPANY SEWER STUDY RESULTS	1
	J. E. SIRRINE COMPANY SAMPLE ANALYSIS	5
2.	COURTHOUSE BAY WASTEWATER TREATMENT PLANT MONITORING DATA	6
	STATISTICAL ANALYSIS OF MONITORING DATA	14
3.	NPDES PERMIT CONDITIONS	15
4.	DESIGN CALCULATIONS	16




NOV 75-JES 22 A. E. SIRBINE COMPART DESIGN SHEET . JOB COURTHOUSE BAY JOB NO A-1086 DATE 10-4-79 TRUCTURE SEINER TOD OAD PER SQUAR J.E. SIRRINE COMPANY SEWER STUDY RESULTS 14 SANITARY SEWER PLANT M60/140 IMG/MO iMG/Mas DIFF AN 1977 3.923 1918 - 12.010 2.027 11-174 7.927 3-247 MAR 9.595 13.031 3= 4-86 PP 9.182 12.596 3.414 4.334 MAY 9.328 13.662 UNE 9,709 12.953 3-244 JUCY 10.389 2-817 13.206 AV6 = 9.438 AUG = 12.667 AV6: 3. 229 AVG. DAYS PER MO. = 30.29 DAYS 3,224,000 gpm. 30.29 Dars = 106,438 gpd. ASSUME AN AVERAGE OF 500 ENG. STUDENTS DURING THIS TIPE 106,432 gal / 500 STUDINT = 212.88 gpcd TO ADD SOME SAFETY FACTOR, USE ZZS good / NEW DIER  $\mathbb{O}$ 




	(	And his	NOV 75-JES 22
JOB <u>COURTHOUSE</u> BAY STRUCTURE		DB NO <u>A-108</u> OMPUTED BY <u>7</u>	36 DATE 10/4/78
	COMPANY SEWER	STUDY F	RESULTS 44
EXISTING FLOW BE	an a	NANDER AN AL MENNING AND LEAD CHARLEN AND AND AN AND AN AND AN AND AN AND AND	
WERE ADDED.			
AMTRAC 664 × 1	50 gpd		99,600
	50 g pd		25,000
	50 gpd	-	4,500 2,500
	50 gpd	= 、	32,750
POWER PLANT	91-1	-	6,000
INFILTRATION			0 28,05
	EALX 3 HEALS X700		4,200
Zypd/m	EAL X I MEAL X800		1,600
1977	AVG, DAILY FLO	W = 3.	07,100gpd
JAN 9.983	M6/M0.		
FEB 7.927			
MAR 9.545			
APR 9,182	승규는 가슴이 걸었다.		
MAY 9,328 JUNE 9.709	an a		
BULY 10.389			
AVG = 9.438			
9,438,000 9P MO. / 30.2	91001×/mo = 311,5	90 gp.	A ACTURAL AV6. DAILY FLOW
	$\sim$		



	NOV 75-JES 22
DESIGN SHEET	<u>A-1086</u> DATE <u>10/4/78</u> D BY <u>TCD</u> STRESS3/2
EXISTING CONDITIONS WHEN AMTRAC ARE ON BASE	PEOPLE .
AMTTRAC 664 × 150 gpd ENGINEERING 500 × 2259pd OFFICERS 30 × 150 gpd RESIDENTS 25 × 100 gpd OFF BASE 655 × 50 gpd (1115-1320) POWER PLANT	= 99,600 $= 112,500$ $= 4,500$ $= 2,500$ $= 32,750$ $= 6,000$
RESTAURANT Zgal/MEAL X 3 MEALS X 1200 Zgal/MEAL X 3 MEAL X 300 INFILTRATION	$= 7,200 \\ = 600 \\ = 130950$
AVG, DAILY FLOW	= 396,600 gpd
1978 JAN 12.010 MG/MO FEB 11.174 MAR 13.031 APR. 12.596 MAY. 13.662 JUNE 12.953 JUNE 12.953 JUNE 13.206	
AV6 = 12,662 OR 12,662,000 gpra/3	30.29 MY/HD = 418,0259pd
3	



NOV 75-JES 22
DESIGN SHEET JOB <u>COURTHOUSE BAY</u> STRUCTURE <u>S.SEWER</u> IVE LOAD PER SQUARE FOOT VE LOAD PER SQUARE FOOT IVE LOAD PER SQUARE F
CALCULATIONS BASED ON MAXIMUM POPULATION FOR YEAR 1986.
AMTTRAC $882 \times 225 gpd$ = 198,450         ENGINEERING $654 \times 225 gpd$ = 147,150         OFFICERS $30 \times 150 gpd$ = 4,500         RESIDENT $25 \times 100 gpd$ = 2,500         OFF BASE $615 \times 50 gpd$ = 30,750         POWER PLANT       = 6,000
RESTAURANT 2921/MEAL X 3 MEALS X 1560 = 9,360 2921/MEAL X 1 MEAL X 300 = 600 INFILTRATION = 130950 AMTRAC WASH RACK = 0 AVG. DAILY FLOW = 557,260 gpd
NOTE: FOR MAX DAILY FLOW I WOULD MULTIPLY
THE INFILTRATION BY A FACTOR OF $1.25$ = 590,000 gpd $\approx 600,000$ gpd AMTRAC WASHIRACK AVG. DAILY FLOW = 650,000 gpd
BOD CONTAININATED WASTEWATER FLOW = 393,3109pd NON - CONTAININATED WASTEWATER FLOW = 284,5889pd
AVG. DAILY FLOW - $(393,310) + (289,588) = 678,0009pd$ MAX. 24 HR. FLOW - $(393,310)(2.7) + (289,588) \approx 1,346,5009pd$ PEAK FLOW - $(393,310)(3.8) + (284,588) \approx 1,779,2009pd$ MIN. FLOW - $(393,310)(.23) + (284,588) \approx 375,0009pd$
<b>(</b>








## WASTE ANALYSIS

		WASIE A	NALISI		Job No.	A-1086-03
CLIENT	1.000				Sample Received	9/22/78
	S. Navy				Analysis Complete	ed 9/28/78
	rthouse Bay - Camp Le	june, N. C.	Sec. 1		Transmittal	
Analysis No.	Sample Description		0/00 01/	70		
<u>36574</u> 36575	Chlorine contact Trickling filter	effluent, take	en 9/20-21/	/78		
36576	Imhoff effluent,					
36577	Inlet stream, ta	ken 9/20-21/78				
Results in milligram	ms per liter (parts per million) u	inless noted. APHA or	EPA Std. Met	thods unless not	ed.	
	Component	Reported as	36574	36575	36576	36577
Biochemical Oxygen	n Demand, 5-Day	O <sub>s</sub>	30	23	36	61
Chemical Oxygen I	Demand	O <sub>3</sub>	125	55	82	137
Immediate Oxygen	Demand	O:	Carl in the	1		
Dissolved Oxygen		O2	<u> 1 4 6</u>		All Contractions	
pH		and the		Sec. Sec.		
Alkalinity, Methyl	Orange	CaCO <sub>3</sub>	2. 318	1. 1. 1. 1. 1. 1.		- Contraction
Alkalinity, Phenolph	hthalein	22				
Carbon Dioxide		CO2		. sal		
Mineral Acidity		CaCO <sub>a</sub>	Assess a series	Sec. 1	12 14 19 124	
Total Dissolved Sol	ids by Evaporation					
Suspended Solids			9.4	13	16	27
blatile Suspended	Solids					
Specific Conductant	ce at 23° C	MMHOS/CM				
Temperature		°C		in the second		
Color						
Turbidity						
Settleable Solids: 30	Min., 1, 6, 24 Hr.	ml/L			2. 1	
Chlorides		Cl				
Chromium, Total		Cr				
Copper	al day - Kanada	Cu		and the second	点:(************************************	
Phosphate		P				
Fluoride		F				
Nitrogen Kjeldahl	and the second second	N				
Nitrogen (Ammonia)	)	N				
Nitrogen (Nitrate)	Contraction of the second second second	N	and the set			
Oil & Grease, Hexa	ne Soluble			12	1. 1. J.	
Surfactants		ABS or LAS	See and			
Lead		Pb				
Mercury	and the second second	Hg		Section Section		
Zinc	a name and a second	Zn	Second State	a Maria		


arks:

Holding Time for Samples was 22 hrs.



		'SI		LOW	
-	DATE	MAXIMUM M. 6.PD)	MINIMUM.M.C.	TOTAL DAILY X 1000 GPD)	
78 NAME OF PLANT H & 1	1	37:	27.8	396	17
-	2	H31	407	435	17
11 1	3			342	17
	4	420	288	348	17
0	5	360	3600	345	12
CHB	1 2 3 4 5 6 7 8 9	120	336	339	7774794777 77 7777777 P.7 7477777
1-01	7	-360	2110	340	17
NAME OF PLANT	8	431	300	36/2	1
d l	9	514	192	328	1%
OF	10 11 12 13 14 15 16 17 18	384	312_	384	12
WW	11	402	336	444	Z
A N	12	488	512	400	12
	13	72.0	220	.390	12
	14	425	205	374	17
	15	40%	312	33/	F
	16	384	3/2	370	1
	17	504	330	545	10
	18	+0'1	3360	587	14
	19	780	240	424	12
	20	HO.	3100	410	1
	21	725	340	372	14
	22	420	JET	4/6	12
	23	120	3,5	HALL	1
	22 23 24 25	121	319	LAT	77777
00	25	407	360	1120	17
0	27	101	200	200	11
	27 28	450	295	254	1
-	28	UUL	210	453	+
13	30	431	3/00	437	1
フィナン	31	431	200	400	1
b	тот.	Tol	Start Consult Supplier	10.2	
HT		13711	9411	12081	3:
MONTH	AVE.	411	303.	389	17


	'SE	EWAGE	LOW	F	РН	MG/ 1)	1	1		5 - D.	AY 20°C	BOD	SUSP	ENDED	SOLIDS	1				0
DATE	MAXIMUM <del>M. G.D.</del> )	MINIMUM.M.G.	TOTAL DAILY X 1000 G PD)	RAW	EFFLUENT	CHLORINE RESIDUAL (MG/	EFFLUENT D.O. (MG/	RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	C.O.D. (MG/ 1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	Chlorine Fee
	37:	27.8	396	7.2	6,3	3,2	8.5	0,5	0,0											40
	431	407	435	7.0	6,3	311	10,0	1,4	6.0	105	53	\$ 8	35%	2.4	(74)	2	6		0	40
3		-	34-2-	70	62	215	17.8	1.0	0,0											40
	120	288	348	70	4.6	3,0	8.6	1.5	0.0											50
5	360	3600	345	20	10,0	21	11	1.2	0,0							-				50
7	360	21/2	340	7.1	4.5	3.0	8.5	0.8	0.0											30
8	431	300	761	7.1	6.5	3.0	8.1	1.0	0.0											50
9	314	192	328	21	6.10	3,0	80	10	0,0	. 80	11	2.6	600	15	98	2	18		0	50
10	384	312_	384	72	6.4	3.1	8,4	0.9	0.0	1		1					100			50
11	402	336	444	7.2	6.6	3.0	8,2	1.0	0,0	1										50
12	488	312	400	7.2	6.0	2,8	8,6	1.2	OR											150
13	TR.C	200	390	2.2	195	3.0	23	1.4	0.0											50
14	425	205	374	7.1	4.5	13.5	7.9	1.2-	0.0											50
16	2911	310	390	7.0	6.0	120	5 A	1:4	0.0	150	48	(1.8)	68		(75)	210	35			50
	384	330	395	71	GL	2.8	8.4	1.4	0,0	120 1	9	(10	00	7	(2)	18	20		0	50
8 4	HO'7	336	389	20	6.5	3.0	8.2	0,9	0,0			1	154							50
9 8	180	240	424	7.1	6.5	3.0	7.2	0,5	0.0											30
0	420	360	410	7.0	6.6	3,0	2,6	1.5	0,0											50
21	425	340	392	7.0	6.3	20	7.8	1.0	0.0											50
22	120	544	4/6	20	6.4	3.3	8.2	40	0.0			00	0.2		Fin	177	5			50
24	431	312	HOLF	72	10,10	3.0	Sich	1.2	0.0	60	8	82	92	9	90	14	-		0	50
	431	312	HAI	7.2	6.7	3.0	8.0	1.5	0,0											50
	407	360	420	7,2	6.7	2,9	8,2	1.0	0.0											50
27	410	295	354	72-	6,9	2.8	81	1.0	0.0											50
	450	220	436	12	6.8	3.0	8.5	1.0	0.0		_									30
29	445	310	453	7.0	65	3,3	8.0	1.0	0.0			1					1			50
Tour baller in		3100		12	6,6	3,0	8.3	1.2	CiC Di C	60	10	(3.3)	210	13	(62)	2	15		0	50
OT			A DO DEA PER SUSTRICUS			1														20
-	13771	9411	12081	3375	5087	133		352	00	415	85	412	874	73	399					520
VE.	411	303.	389	7.3	6.7	29	33	1.1	00	83.0	17	82.4	174.8	14.6	(79.8)				1	49




.

MCBCL 11345/2 (REV 10-74)

		'SI	EWAGE I	LOW	F	н	4G/1)	11		EABLE	5 • D	AY 20°C	BOD	SUSP	ENDED S	OLIDS	1)				×
12041	DATE	MAXIMUM <del>M.C.D.</del> )	((2,000 1))	с Тотан ранцу (X 1000 GPD)	RAW	Ъ ЕFFLUENT	CHLORINE RESIDUAL (MG/1)	ZEFFLUENT D.O. (MG/1	, RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	С.О.D. (МС/ 1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	Chlorin Ferd
1	1	431	336	399	7:0	6.7	3.0+	8.6	0.9	0.0											50
캐	2	407	288	411	7.1	6.6	3.0	84	1.0	0.0											50
1	3	408	336	393	7.0	6.6	3.0.	801	1.3	0.0											50
54	4	420	300	391,1	7.0	6.4	2.5.	9.2	1.0	0.0											50
۶H	6	432	269	410, 2	7.2	6.6	3.0	9.8	1.3	0.0	30	2	93	38	2	94	16	DUT -		0	50
SH-	7	509	3.38	4.22	7.2	6.8	3.0	9.6	1.8.	0.0											50
1	8	407	338	394,8	7.1	6.7	3.5	10.0	1.0	C.D											50
I	9	372	242	473,7	7.2	6.7	35	9.4	2.0	0.0											. 50
	10	meti		402.7	6.8	6.7	4.4	9.3	1.2	0.0	1										50
H	11	437	312	374	7,1	6.8	3.5	9.3	2.0	0.0											50
H	12		316	3.55	7.2	6.7	3.3	9.2	4.0	0.0	11.5	15	1011	1. 15		197 .1	10	,		0	50
H		360	288	343.8	7.0	6.7	3.1.	8.1.	2.0	0.0	110	18	84	68	11	(84)	31	2		0	50
H	14	374	33/	331.4	71	6.6	3.3	7.2	1.8	0.0											50
H	16	384	:288	395	7,3	6.8	3.3	95	2.0	0.0	1		-								50
H	17	.07	384	386.1	7.2	6.9		9.0	4.0	0.0		1.									52)
h	18		and the second designed to the second designed to the second designed as the second designe	370,8.	7,0	66	3.0.	9.0	1.0	0.0											50
I	19	1		173,5	7.1	6-4	3.6.	9.5	1.0	0.0			-								50
4	20			387 '	7.0	6.8	3.5	9.6	1.5	0.0	40	8	(80)	108	4	96	1:	29		0	50
H	21	11-		396	7.0	6.6	3.5	8.8	1.9	0.0											50
+	22			424.7	7.1	6.8	3,5	9.0.	1.0	0.0											50
V	24	+		453.2	7.2	6.8	3.3	9.6	1.1	0.0											50
1	25	11	11	1118.1	7.1	6.8	44.1	9,1	1.8	0.0	14			1					1		50
1	26	T		4.34.5	7.0	6.6	5.5	8.5	1.2	0.0	Sec.		Sec. Sec.								50
24	27	T		402.9	70	6.6	5.2	6.7	1.8	0.3	.50	17	8.6	40	7	83				0	50
22	28	1		415	7.0	6.6	4.7	6.9	21	0.1											50
2	29																				
4	30 31		+	1																	
1+	тот.	1	1.	11,173.9	198,6	186.7	97.6	246,2	471	0,4	230	35	343	254	24	357					1400
+	AVE.			399.1	7.1	6.7				0.014	1	8.8		63.5		89.3					50




	WINIMUM W.C.P.	X 10		ENT ,	RESIDUAL (MG/ 1)	D.O. (MG/		=							=		1	1	01
3		111 11	1 RAW	EFFLU	CHLORINE	EFFLUENT D	4 RAW (MG/1)	UENT (MG/	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/1)	FFLUENT (MG/1)	ERCENT REMOVAL	TOTAL SOLIDS (MG/	.o.D. (MG/1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	Alound Feer
3		416.1	1.1	6.8	5.6	6.7				1	-		ш		4	Ů			10
4		and the second s	7.2	6.9	5,5	7.5	3.0	2 0.0		1									2.5
		and the second designed in the second designe	7.1	6.9	5.8	7.4		0.0			1								40
5	1	and the second sec	7.0	6.9	4,6	7.9	2.0												40
6			7.2	6.6	4.1	7.6	1.0	0.0				1.	1	1					40
7			7.3	6.8	4.7	7.6	2,3		55	9	(84	161	2	97					40
8			7.7	7.0	4.9	6.0	3.1	0.0			- 4. ( Dime							-12	10
9	_	States of the local division of the local di	7.6	7.1	4.5	7,2	3.5	0.0		1	-							1.1.1	43
10		4/22.0	7.3	7.0	6.2	6.2	4.0	0.0											40
11		428.0 1	7.3	7.0	4.6	8.0	2.5	0.0	1										40
12				6.8	21.1	7.9	20	0.0	1	1					1.1				40
14				6.8	3,8	86	2.1	0.0	50	6	-								2.5
15				6.6	4.2	6.0	4.1	0.0	1		89	70	·?	89					40
16			Contraction of the local division of the loc	.9	5.5	5:2	5,0	0.0											110
17				6.8	5.1		20	0.0		1									35
18		374.6 7			5,0	6.6	3.5	0.0	1. AND									-	35
19				and the second s	4.8	5.6	2.5	0.0											5
20		398.7 7	-		4.5	7.6	20	0.0											15
21		and the same of th			3.8	6.2	3.4	0.0	55	10	(82)	36	3	92					5
22		415,17	- and the same of the same	1	4.8	6.6	3.1	0.0			- and the			- 4.1		-			5
23		399.47	2-16		and the second of the second of the second s	5.8	1.0	0.0											5
24			.2 6	e		8,3	41.3	0.0						-		-		3	
25						8,1	1.7	0.0										the second s	0
27		444.6 7	11		2.8	8,0	2,1/	0,0											0
28	1	437.1 7.	16	.8 1	4.8	8.1	3,3	0,0	125	8	0.1							3	
29	1	426,2. 7.		8 9	16	Y.2	5,2	0,0		7	94	74	3	96				02	0
30		4391 7	27	10	3,8 8	1	20	O.D										3	0 1:
31	1	4391 7.	5 7	4/ 4	4.0	p .		0.0										12	012
тот.	1	and the second s	ALL MARK PROPERTY.				3.5	O.D										3	OB
AVE.	-1		1.	2.914	15.3 2	30,09	1.7	0.0										108	
		420.4 7,	3 6.	6 4	17 7	.4 3	1	0.0				-						35	




MONTHLY REPORT OF WASTE TREATMENT PLANT OPERATION MCBCL 11345/2 (REV 10-74)

		'SI	EWAGE	FLOW	1	PH	(WG/ 1)				5 - D	AY 20°C	BOD	SUSP	ENDED	SOLIDS	=				0
aci	рАте	MAXIMUM M.G.D.	MINIMUM M.G.D.	тотан раіцу ( X 1000 GPD)	RAW	EFFLUENT	CHLORINE RESIDUAL (	EFFLUENT D.O. (MG/	RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	C.O.D. (MG/ 1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	
0	1			404,4	7.0	7.1	3.50	7.9	1.9	0.00											137
.1	2			438.3	7.1	6.9	3.30	18.5	1.0	0.00			1	1							127
2	3			438.0	7.4	7.2	4.83	8.6	2.0	0.00	135	8	94	186	17	99				0	27
del	4			414,3	7.5	7.2	5.85	8,2	.3.0	0.00	1		1 1	1.46		1					127
X	5			420,1	7.3	7.1	5.38	8.0	3.0	0.00						1					27
X	6			432.0	7.3	7.1	4.35	8.0	3.0	0.00		1. K									27
X	7		and the second	415,2	7.3	7.1	5.65	7.7	4.8	0.00					S. S. Sal	1					27
7	8			416,0	7.2	6.8	4.38	7.7	13.2	0.00			1.1.1.2	100			1.1.1	1944 - A. 197			27
111	9			1/26,9	7.2	7.1	4.09	7.5	2.8	0.00						de la composition de la compos	1.1.1.1				27
CA	10	-		121,0	7.1	6.8	4.68	7.7	2.0	0,10	570	17	97	2860	4	99	20	DOI		0	1.27
4	11			409.4	7.3	7.2	5.83	80	4.8	0.00						1					27
1	12			489.4	7.2	6.9	5,17	7.5	2.8	0.05											2
-	13			490.7	7.1	7.2	5,21	4.0	4.0	0.10					·						2
4	14			397.2	7.4	7.2	5,36	5.0	5.0	0.00					Sec. Sec. As						2-
4	15			375,3	7.2	6.6	5,01	5.1	3.4	0,00											1.27
H	16	1		397.5	7.1	6.8	5.45	5.5	2.9	0.00											.27
H	17	-		410.3	7.3	7.1	6.85	4.5	.5.0	0.05	780	23	97	220	15	93	2	167		0	2-
H	18 19		-	428.7	7.1	6.9	6.32	4.5	4.7	0.05											27
H	20			424.6	7.4	7.2	6.61	5.1	4.5	0.10											1.27
H	21			443,1	7.6	7.1	6.92	5.2	2.5	010											1.7
H	22			4.32,0	7.2	7.0	5.64	5.0	.3.6	0.05											.2
2	23			419.8	7.2	6.8	5.51	5:2	4.1	0.05			-								2
7	24			415,1	7.3	7.1	6.08	5.0	5.7	0.02	340	19	94	650	13	78	11	72		0	1.37
2	25			476.1	7.3	7.2	4.94	5,6	4.6	0.02	5-10		1-1-1-	10.00	10	110		100		~	.5
Y	26			446.5	7.3	7.2	5.84	6.0	.5.1	0.01											5
t	27			444.2	71	7/0	6.01	6.0	46	0.03			1 3.9								12-
0)	28			432,5		7.0	5.57	5.7	2	-			-				1				1.27
d	29			398,3	7.0	7.0	7.71		29	0.00	1				1			1			12-
4	30			451.2	7.0/	17.0	6.62	4.4	3.2	0.00										1. Z	1.37
T	31				1/	7				p.											
1	тот.	100		13590.5	216.7	2105	1655.77	18:16	ically	0.73	1835	67	382	3916	49	389	,	1.1	1. Ale 1.	1	81
	AVE.			47835	and the second second		,		1	1				979		9725				are a	




	1
-	1
-	1
2	1
-	1
4	I
10-74)	1
-	1
>	1
	1
w	1
(REV	4
11	1
-	3
2	1
~	3
10	1
-	1
-	1
64	1
-	1
11345/2	
	1
	2
-	1
U	ł
-	1
-	1
MCBC	
~	-1
2	1
_	

		'SE	WAGE	FLOW	F	ч	(MG/ 1)	8	1		5 - D/	AY 20°C	BOD	SUSP	ENDED S	OLIDS	1				0
t	DATE	MAXIMUM <del>M.C.B.</del>	WINIMUM M.C.D.	TOTAL DALLY (X 1000 GPD)	RAW	EFFLUENT	CHLORINE RESIDUAL (I	EFFLUENT D.O. (MG/	RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	C.O.D. (MG/ 1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	CHLORINE FEE 165/day
3	1			435.7	7.4	7.2	5.48	512	9.1	0.0	280	14	95	5.50	22	96				0	1,23
0	2		1	13:10	7.3	7.2	4.51	5.5	8.0	0.05							1				23
1	3			421.6	7.2	7.2	5.27	6.5	70	010			1			10 C 10		1			1.3
2	4			2155.0	7.3	7.1	6.26	5.8	8.8	0.10					-					-	25
4	5			1.38.11	7.4	7.0	6.48	6,0	6.0	0.00			-				1				25
S	6	1	-	444.2-	7.0	7.0	7,15		7.2	0,00			-								.25
- 1	7		_	115.7	7.4	7.2-	585	6.3	6.3	1300											-25
OF PLANT	8			1140.4	7.3	7.2	5.59	4.5	6.9	0110	1.10	8	93	27	4	85				0	25
P P	9	-		470.2	7.1	6.9	121	-1.1	41	Cilio											25
10 2	10		-	44.18,2	7,2	7.0	5.00	5.6	6.9	C.10											25
N N	11			444/11	73	71	484	578	5.17	0.05											25
NAME	12			155.2	7.2	6.9	5.56	6.0	5.0	005											25
	13			434.9		6.4	5.93	6.9	6.3	000					<u></u>				1	-	2.5
	14			463.4	72	7./	5.01	6.3	28	005	22-		92	1.2.	.2	GN	0	K		0	25
1.1.1	15			434.7	7.1	6.0	1.1.6	and a statements	3.1	010	225	18	76	412	8	98	0	16		0	25
	16			158.7	1.1	6.9	5.00	61	3.4	2.10											25
	18				1-1.7	71	3,71	5.2.	25	000											25
	19			1.22.0	7.1	2.0	3.8'0	6.17	22	0.00									1.0		12:5
-	20		1	411.2	7.1	7.2	197	1.2	11.0	0.00									1.7.7		25
	21			145.5	7.3	7.1	4.84	6.0	18	2.00											25
	22			444,3	7.0	6.8	3.73	77	2.6	0.18	1:35	13	90	266	22	92			1	0	25
	23	6.00		44413	7.0	6.8	4.30	7.2	3.0	0.00				aue	- CF						25
	24			453.1	72	7.1	11.12	6.5	11.5	6.00											.25
A	25			410,2-	7.3	7.1	:155	6.8	5,0	0.000			19.00	1. 18 5.44		- Preferre		<u>-</u>	1.00	-	35
2	26			4.56.7	73	7.1	5,16	7.0	5.0	0.00									1		25
1	27		No. of Street	415,3	7.4	7.1	4.81	7.0	50	0.00				1	1000			0.100	1		25
	28			404.2		7.0	4.54		5.0	0,00											25
	29		'a	434,2	7.0	6.8	3,0%	7.1	3.4	0,00	115	9	92	318	7	98			-	120	25
-	30			452,5	120	6.5	3 08	7.1	4.1	0.00				· · ·							.25
3	21			468.3	7./	70	4.94	1		000											25
20	тот.			1325140	Bito	207.7	013.8	1957	1459	,90	865	67	462	1573	63	469	an ar				175
MONTHMOMER	AVE.		1	440,7	6.9	6.7	5.04	1	1	and the second	173	1	924	2,46	12.6	93.8	aley.				




		`SI	EWAGE	FLOW	Р	чн	MG/ 1)		1		5 - D.	AY 20°C	BOD	SUSP	ENDED S	OLIDS	1				
act	DAFE	MAXIMUM M.C.D.	MINIMUM M.C.B.	TOTAL DAILY (X1000 GPD)	RAW	EFFLUENT	CHLORINE RESIDUAL (MG/	EFFLUENT D.O. (MG/1	RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	C.O.D. (MG/ 1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	Alleria 10a
V	1			1.39.5	7.4	7.2	4.50	7.0	4.5	0.0	1					1					2
. 1	2			1442.7	73	· ?. D	:1.21	6.7	25	00											17
आ	3			449.7	7.2	7.1	21.20	20	2.5	0.0	1	14 C		-					1.2.2		12.
1	4			1191.5	7.4	73	2,10		3.0	00	-						1.000		-		2
RI	5	1		164.4	72	6.5	3.40		31	120	135	16	88	138	4	97				4	2
A I	6			504.7	7.1	20	12.10		3.3	0.0											2
, H	7			4.38.5	7,2	6.8	3.54		20	00			-				2000		-		2
21	8			-163.3	22	20	2.63	Last	6.5	0.0											2
100	9		-	1:9.5	2.0	6.8	3.42	a property of the second se	3.1	00		-			-						N No
2	10			435.1	70	2.0	316	6.3	.575	00											NN
C	11		-	44814	20	7.2	282	60	35	00	135	17	27	212	8	96				0	
H	12			409.2.	-21	7.0	3.73		2.9	00	122	11	81	#1h	0	170				0	2
H	14			404. 2.	77	6.1	3.50		2.4	00					<u>`</u>						2
H	15			4436	20	6.8	3.44	1.5	2.9	00									1		2
Ħ	16			401. 2	-1	210	4.10		3.2	0.0						1.					2
t	17			416.7	21	6 5'	4.20	6.3	29	0.0							S. 3			1	2
Ĭ	18		13	414.5	7.0	1.9	3.00	6.1	32	00					ker -						1.2
I	19	1.1.1		2107.41	7.1	6.9	3.30	The second day and the second day is a second day of the second da	34	20	160	7	90	256	5	98				10	12
(I	20			421.3	21	6.7	1.53	1.7	3.9	0.0					12 N						2
1	21			451.7	S.F	his	3.51	6.3	3.5	00		2									12
1	22			416.5	7.1	7.0	6.90	5.8	3.0	00										-	2
04	23			404.9	7.0	6.8	4.72	6.0	3.4	00											3
V	24			3695	7.0	6.5	3.15	5,5	4.3.	0.0											2
N	25			4041	7.2	6.6	2.95	54	6.0.	00	111 -	1-	90	15/	5	97				0	12
V	26			423.1	7.1	le. h	3.78	6.1	3.3		145	15	90	176	3	191				10	2
	27 28	-		371.3	7.0	6.8	4 06	1. 5:	13,9	00											2
21	29			442.8	27	69	3.33	60	35	0.0											3
5	30			417.2-	17.11	6.8	+.33	517	3.4	0.0											225
Y	79			1	14				(你我了	1 .											
D	тот.			12952.9	2137	207.1	10.67	1921	1	0.0	515	55	355	782	22	3583					6
	AVE.			431.8	1		3:76	1,	3.4	0.0	144	13.8	38.8	1	5.5	97.0					22

E




(MG/1) SETTLEABLE SEWAGE FLOW 5 - DAY 20'C BOD PH SUSPENDED SOLIDS SOLIDS (MG/1) (MG/1) (.N.P.N.) 62 (WG/ 1) RESIDUAL GPD ERCENT REMOVAL REMOVAL = EFFLUENT (MG/1) EFFLUENT (MG/1) 5 V FFLUENT (MG/ EFFLUENT D.O. MAXIMUM M.C.B -MINIMUM M. 6.D TOTAL SOLIDS TOTAL DAILY KJELDAHL (MG/ COLIFORM 0001 X chiori 2 EFFLUENT = -1 CHLORINE ERCENT (MG/ (MG/ FECAL RAW (MG/ Kund C.O.D. DATE RAW RAW AW ш R 0 ۵. 22 315 22 8 3/2 5,5 20 5 0.0 1 6 6.9 371.1 431 5.9 2 7.2 3.2 O.D 52 3.12 0.0 22 3 380.3 73 7.0 5.0 7.0 14 98 ~ 96 0 700 172 4 Y 76 40 n.n 22 4 7.1 1.31 . 100. 5 20 5 8.5 0.0 51/ 17 305 22-22 8.5 6 7.0 4.70 0.0 5 .7. 4.0 22 7.1 0.0 7 2 2 5.60 7 4.5 390 NAME OF PLANT 22 8 6.8 33 0.0 2 TI 5.72 147 22 9, 1.4 0.0 20 36 4344 5.61 61 5.0 22 6.0 10 1.9 11 32 590 98 73 63 98 6 417. 7.5 12 0.0 11 6.9 22 73 7.1 5.00 6.0 7.0 00 22 12 133 3 4138 5 4.0 28 13 0.0 2 5 503 7 12 20 7 7 14 UL? 5 0,0 5.4 0.0 15 0 3.0 28 16 6 7 6.9 OrD 405 5,63 812 17 3 0.0 28 4 650 9 99 716 98 0 11 00 28 18 7. 6,0 5.0 2 19 20 3 28 170 3 9 O, 0.0 0 6.5 28 20 20 330 7.0 0.0 ish 5 28 35 1.51 50 0.0 21 17 1131 28 7.1. 22 Sr. 437 DU 422 6.4 0.0 23 Ch 28 0 4.47 60 20 0.0 28 7. 2 62 0.0 0 24 10.0 4 99 66 620 17 97 1332 28 3.5 5,0 0.0 0 25 9 28 26 6.8 6.0 5.2 0.0 1,26 10-745 0.0 20 6.9 27 3 4.82 6D 311. Ø y 15 28 7 458 0 0.01 28 4.0 (REV 6.9 3.2 28 368 5-60 5.9 0.0 70 29 0 28 0.0 30 329.0 7.1 .9 30 531 3 11347/2 21 317 370 5.1 M.O 96 20 12 1.00 :1 7 7.3 50 3:0 4 03 C 64 -3531 1.270 488 214 5 440 TOT. 00 70 5 0 1 12.8 1 W 1 1566 35 10. 4.6 No. 2 4 1211 AVE C .72 12 U 2





MONTHLY REPORT OF WASTE TREATMENT PLANT OPERATION MCBCL 11345/2 (REV 10-74)

		'SE	EWAGE	FLOW	F	РΗ	MG/1)		1	EABLE LIDS	5 - D	AY 20°C	BOD	SUSP	ENDED	SOLIDS					A
()	DATE	MAXIMUM M.S.B.	MINIMŮM MierD?	тотак раку (X 1000 GPD)	RAW	EFFLUENT	CHLORINE RESIDUAL (MG/ 1)	EFFLUENT D.O. (MG/1)	RAW (MG/1)	EFFLUENT (MG/1)	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	RAW (MG/ 1)	EFFLUENT (MG/1)	PERCENT REMOVAL	TOTAL SOLIDS (MG/	C.O.D. (MG/1)	KJELDAHL NITROGEN (MG/1)	FECAL COLIFORM (M.P.N.)	CHLORINE FEED
3	01			412.1	7.3	6.9	3.86	60	5.4	0.0	1	1			and the sector sector	1			1		31
0	2	1		424.1	7.3	7.0	3.92	64	48	00		1	1								3/
1	3	\$ ·		390,9	7.2	7.0	2.86	60	3.5	00					1	1					3/
19	4	1		1892	7.2	6.9	331	6.4	3.5	0.0			1 1 1		- sympton						31.
2	5			689.7	7.1	6.4	4,81	6.1	3.4	0.0											31.
X	6			3705	26	7.1	6.95	7.1	40	00											31
1	7			403,5	2.3	7.1	4.12	5.9	3.6	00	275	14	95	400	6	199				8	31
C.L	8	1		383.8	2.4	7.0	3.54	6.5	3.2	0.0											31
: 5	9			394.2	7.3	6.8	5.63	5.9	3.1.	00											23
CL	10			.380.0	7.2	21	5.74	4.2	5.8	0.0											35
	11			3605	7.2	69	2.54	6.0	5.0	00											30
	12			375.3	2.1	70	3.97	5.9.	4.8	00											38
-	13	hut	by	360,1	28	72	5.88	15	25	0.0	20.0		02			00					38
ł	14	the		47.3.1	7.1	20	4.45	6.2	3.2	0.0	235	16	93	206		99			-	0	38
1	16			pictor and a spectrum	7.0	68	4.55	60	3.3	0.0											38
-	17			383.8	7.2	66	3.08	64	3.2	0.6											38
ł	18			388.6	7.1	66	5.31	60		0.0											38
1	19			388.6	7.2	6.2	4.47	6.0	4.0	0.0											37
1	20			95.0	7.3	6.7	8.38	8.8	2.5	0.0								- 20		-	37
t	21			142.5	7.1	6.7	5.51	2.8	3.4	0.0	125	11	91	245	8	97				0	37
t	22			237.5	71	6.8	463	71	3.1	0.0	1000		1				1.5			~	37
1	23		6	304.0	7.0	7.2	4.79	6.5	2,0	0.0											17
	24			367.7	7.3	6.6	5.40	6.8	45.	0.0											37
Z	25			3620	7.2	6.6	6.92	20	3.0	0.0	1.8000		1.0		6		1. C. S. S.	- Alton at the			37
6	26		Sec. Sec.	322.12	22	66	6.29	20	4.0	0.0											37
V	27			363,9	7.5	6.8	637		3.8	0.0							1	and the second	-	-	37
N	28		-	37/5	7.0	6.8	5.38	8.0	35	0.0	105	14	87	182	9	95				0	37
0	29			3392	7.0	69	585	7.4	3.2	0.0											37.
11.4	30			357.2	75	4.9	585 4.40 6.15	3.0	40	0.0					· · · ·						37.50
Z	31 TOT.									0.0											
Y				20123	221.5		166.14		1282		740	55	366	1033	2.4	390				-	10.13
	AVE.				7.2	6.9	5.36	6.1	4.1	0.0	185	138	91.5	258	6	97.5					34

m







PART I

D Page 4 of 29 Permit No.: NCC003239

## A. (1) EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (FINAL)

During this period beginning Modification Effective Date and lasting through Permit Expiration, the permittee
is authorized to discharge from outfall serial number 004 - Courthouse Bay STP.

Such discharges shall be limited and monitored by the permittee as specified below:


#### PARAMETER

## DISCHARGE LIMITATIONS


## MONITORING REQUIREMENTS

	kg/day(1b	s/day)	Other Units	(Specify)	Measurement	Sample		Sampling
	Monthly	Weekly	Monthly	Weekly	Frequency	Туре		Point
	Average	Average	Average	Average				TEL
FFow, M <sup>3</sup> /day (MGD)	1987(0.525)				Daily	N/A	or	InfluentZ EffluentO
Biochemical Oxygen Demand (5 day)	59.7(131.4)	89.5(1971.1)	30mg/1	45mg/1	1/week.	Composite	8	Influent Mi Effluent
Suspended Solids	59.7(131.4)	89.5(1971.1)	30mg/1	45mg/1	1/week	Composite		Influent RR
Fecal Coliform Bacteria, Geometric Mean			200/100 ml	400/100 ml	1/week	Grab		Effluent
Chlorine Residual <sup>(1)</sup>	)				Daily	Grab		Effluent
								17


- In addition to the specified limits, the monthly average effluent BOD<sub>5</sub> and suspended solids concentration shall not exceed 15 percent of the respective monthly average influent concentrations.
- 3. The pH of the effluent shall not be less than <sup>6.0</sup>standard units nor greater than <sup>9.0</sup>standard units and shall be monitored by grab sample lweek.
- 4. There shall be no discharge of floating solids or visible foam in other than trace amounts.
- 5. The effluent shall not cause a visible sheen on the receiving water.



	DESIGN SHEET	I & 12
LIVE LOAD PER SQUARE FOOT	Design Calculation	US
Calculatio	NS Based ON Max. Popu	lation for 1986
EN R OFF Ree	water Charactoriza taminated Wastewater Fl AMTRAC - 198,450 apol giweering - 147,150 gpd Officers - 4,500 gpd esidents - 2,500 gpd Base - 30,750 gpd straunt - <u>9,960 gpd</u> 393,310 gpol <u>BOP5</u> Assume 200 mg/l	
T		
	165. BOD5 = (200 mg/l = 656 165 B	)(8.34)(6.393MGD) 3005/day
(1.25)		pol pol
	Assume No B	00D5-
3) <u>Total</u> Avg. Da Max 24 Peak	Flows	2.84, 588 $_{qpd} = 678,000 qpd = 471 qp$ (1) = 1, 346,500 $_{qpd} = 935 qp$ (1) = 1, 79, 200 $_{qpd} = 1, 236 qp$



NOV 75-JES 22 2 0/ 12 J. E. SIRRINE COMPANY DESIGN SHEET DATE JOB NO STRUCTURE\_ COMPUTED BY LIVE LOAD PER SQUARE FOOT\_ WORKING STRESS 3) BODS loadings & Conc. 165 BODs / day = 656 (Based on DM-5 criteria for contaminated fraction of flow) mg/R BOD5 = <u>656 lbs BOD5/d</u> (0.678 MGD)(8.34) BOD5 = 116 mg/l I I. Unit Process Design Calculations 1) Primary Clarifiers 6 a) Design Criteria from DM-5 Two(2) Primary Clarifiers Overflow rate @ 24hr. Max Flow w/ one unit down = 3600 gpd/ft2 Overflow rate @ Ava. Daily Flow w/ all UNITS IN Operation = 1200 gpd/ft= 1 b) Surface Area Required & Size @ Max 24 hr flow w/ one unit down Area = 1,346,500 gpd/3600 gpd/ft<sup>2</sup> = 374 ft<sup>2</sup> 1 @ Avg. Daily flow is all units in operation Area = (678,000 gpd/1200 gpd/ft²)/2 = 283 ft² 1 . Max flow condition controls




	NOV 75-JES 22
J. E. SIRRINE COMPANY	30/12
DESIGN SHEET	
JOB	JOB NODATE
STRUCTURE	
	WORKING STRESS
Surface Area = 374 ft2	Overflow Rate @ Ave
	daily Flow (678,000/2)/(374) = 906 gpcl/sqf
$1r^2 = 374$	(678,000/2)/(374)
⊢ = 11 £+	= 906 apr//saf
r = 11 ft Diameter = 22 ft.	31 1
w/ 8ft Side Water i Volume = 2992 c	Depth uft = 22,380 gal
[월] (124) : [12] (12] (12] (12] (12] (12] (12] (12] (	
Detention Time @ Avg. Da	ily Flow = 48 min.
DR I ECC C R	CI C
c) Removal Eff. for Prima	ry Claritiers
	철왕은 가격을 만들는 것이 물건이 많아 없는 것같이 괜찮았다.
From DM-5 60% 30%	
30%	6 0005
2) Trickling Filter	
An additional T.F. is to to the existing unit	be installed identical
a) loadings (at Avg. Dan Diameter = 62 f Surface Area = 0.0	
Volume = 22,6	도신 김 것 사람 생각에 가지 않는 것은 것 같아요. 그는 것 것 것 같아요. 가지 않는 것 같아요. 것
Media Droth = 7.4 St	2001 removed during Princip
copin and	30% removed during Primary Two filters
BOD 1 = line = (IFI II-1	1)(07)(5) /27/ W13. P1
LOUF LOOIDING (606 105/0	$2(0.7)(.5)/22.6 \times 10^{3} \text{ cuft}$
- 10 105 13	30D5/1000 cuft


•

B

Hydraulic Load wg= (0.678 MGD)(.5)/0.07 acre = 4.8 MGD/acre b) loadings @ Avg. Daily Flow w/ Series operation 0% recycle 1ST STAGE 2nd STAGE 2 Nd STAGE 9.6 MGD/acre 9.6 MGD/acre 20 105/1000 cutt 0.4 105/600 Hydraulic Loading BODS Loading 0.4 165/000



. E. SIRRINE COMPANY	DESIGN SHEET	( 4) of 12
JOBSTRUCTURELIVE LOAD PER SQUARE FOOT		JOB NODATE COMPUTED BY WORKING STRESS
() 	Existing Trickling Filter Av Flow - 525,000	
1	Hydralic Loading = (.5 = 7.5	25)/.07 MGD/acre
1	165 BOD = 434 16 = 304 16:	5-130 lbs (removed in Primary Clarifier) 5
I	BOD Loading = (304 16) = 13,5 16	5)/22.6 5 BOD/1000 cuft
<b>d</b> )	NRC Equation	
•	$E_{1} = 1$ 1+0.0085 $\left(\frac{\omega}{VF}\right)^{V_{2}}$	X 100
	$E_2 = \frac{1}{1 + 0.0085 \left(\frac{\omega'}{vF}\right)^{\frac{1}{2}}}$	× 100
1	F=(1+R)/(1+R/10)	2
	50% Recycle $F = 0\%$ " $F = 1\%$ V = 0.52 acre W = (656  lbs)(.7)	(.5) = 2.30  lbs/day
1	0% 85%	of dual Filters <u>Influent BOD</u> <u>Effluent BO</u> 116 mg/2 17.4 mg/2 116 mg/2 14.0 mg/2
	2) Sieries eperation of <u>Recycle Overall % BoD Remo</u> 0% 98 % 50% 99 %	dual Filters wed Influent BOD Effluent BO 116 mg/l 2.3 mg/l 116 mg/l 1.2 mg/l



NOV	75-JES	22
-----	--------	----

5 0 12

## DESIGN SHEET

LIVE LOAD PER SQUARE FOOT

STRUCTURE\_

I

6

1

I

I. E. SIRRINE COMPANY

JOB NO	DATE	_
COMPUTED BY		-
WORKING STRESS		_

3) Secondary Clarifier

a) Existing S.C.

26' dameter Area = 530 sq.ft Surface Loading @ Existing Design Flow (.525, MGD) =990gpd/sq.ft.

From DM-5 Ava Daily Flow - 800 gpd/sq.ft @ Max 24 hr Flow w/ one unit down - 2000 gpd/sq.ft.

c) New S.C.


24 hr. Max Flow - 1, 346, 500 gpd Area required = 1,346, 500 gpd/2000 gpd/sqft. =673 sq. ft.

 $Tr r^2 = 673 eq. ft$ r = 14.6

diameter = 29 ft.


d) Overflow on New & Existing S.C. at Aug. Daily Flow

Overflow (New 5.C.) = (.678160)(.5)/673 59.1 = 503 gpd / Sq. ft




6 of 12 J. E. SIRRINE COMPANY DESIGN SHEET \_\_DATE\_ JOB NO STRUCTURE \_\_\_\_ COMPUTED BY\_\_\_ LIVE LOAD PER SQUARE FOOT WORKING STRESS Overflow (Existing S.C.) = (678)(.5)/530 39.ft. = 639 gpol / so, ft. e) Max flow Existing S.C. can accomidate = (800 gpal/sq. ft) (530 sq. ft.) = 424,000 gpd Elow should be split between the S.C. up to 848,000 appl at which point any additional Flow should be diverted to the New S.C. 4) <u>Chlorine Contact Chamber</u> N Design Criteria: 30 min. Detention Time @ Peak Flow b Peak Flow = 1,236 gpm I Volume = (1,236 gpm) (30 min.) = 37,080 gal I Use dual contact chambers Volume = 185400al = 2479 auft Water Depth = 4ft. Area = 620 saft DIMENTIONS = 20'X 31' X4'SWD b) Dosage (Chemical Usage) DM-5 = 10 mg/l @ Avg. Daily Flow 678,000 gpd= 2566,510 liters/ C12 used/day = (2,566,510 L) (10mg/R)=256650/ = 57165/d 5.) <u>Sludge</u> Quantities DM-5: 72% of total Suspended Solids are Volatile 50% of total Dissolved Solids are Volatik

**NOV 75-JES 22** 



**NOV 75-JES 22** 7 of 12 J. E. SIRRINE COMPANY DESIGN SHEET JOE JOB NO STRUCTURE\_ COMPUTED BY LIVE LOAD PER SQUARE FOOT. WORKING STRESS 165 solids (based on domestic flows) = (0.393 MGD) (8.34) (200 mg/R) = 656 lbs / day DM-5 - 60% solids removed in primary clarifier 165 solids removed in primary clarifier = (656 165/d)(.6) = 393,6 lbs/day removed This leaves 262.4 165/day to be removed by the Secondary Clarifiers DM-5 - 95% solids removed IN. S.C. b 165 solids temoved IN S.C. = (262.4 165/d)(.95) = 249.3 Ibs/day removed This leaves 13.12 Ibs/day to pass through the plant in the effluent at a concentration of: 1 (13.12 lbs/day)/(-678)(8.34) = 2.3 mg/l Mass of solids removed = 643 165/d Assume: 5.G. = 1.02 Sludge Solids = 3% Volume of Sludge = 643 165/day (1.02X62.4163/uft.)(.03) = 337 cuft/day = 2,520 ypd 82




NOV 75-JES 22
DESIGN SHEET
JOB         JOB NO         DATE           STRUCTURE         COMPUTED BY
LIVE LOAD PER SQUARE FOOT
6) Gravity Thickener
a) Design Criteria (DM-5)
Overflow Rate = 600-800 gpd/sq.ft Select 700 gp
Max solids loading (dry solids) = 15 16 dry solids/ft2/d Min. SWD = 10 ft Min. D.T. = 6 hrs.
b) Size - based on overflow Rate
Req. Area = (2520 gpd)/ (500 gpd / sq.ft.) = 3.6 sq.ft.
Req. Vol. = (2520 gpd/24 hr/day) (6 hrs.) = 630 gal = 84 cuft
Assume 20 gpm. flow through Gravity Thickener (constant)
Area required = (20gpm)(1440)/760 gpd/sq.ft = 411. 3q.ft.
T = 3.6 F +
$d_{iameter} = 7.5 \text{ GH},$ s WD = 10  GH, $V_{01}. = 442 \text{ cuft} (3,305 \text{ gal})$ D.T. = 1.3  days
23


1

6

I



NOV 75-JES 22 9 of 1
JOB         JOB NO         DATE           STRUCTURE         COMPUTED BY
LIVE LOAD PER SQUARE FOOT
C) Size - based on solids loading (15 lbs dry solids/42/
643 16 solids/15 16s/St2/2 = 43 ft
$T + t^2 = 4/3  sq.ft$ t = 3.7 diameter = 8 ft.
d.) Select 10 St diameter Gravity Thickener
Solids content of Primary & Seconary Clarifiers
= 3% Solids content of Gravity Thickener Underflow = 9% by weight
7.) Aerobic Digester
a). Design Criteria (DM-5)
Allowable Max 24 hr. Solids loading = 0.1 165 Volatile Solids/cuft/o D.T. = 20 days
Solids conc. IN digester 3-6% by weight Sludge Age - 25 to 30 days Max Tank Depth - 15 ft. Air. req. = 1.5 165 02/16 BOD
Air. teq. = 1.5 163 02/16 BOD
b) Volume of sludge wasted per day from G.T.
Solids are concentrated in the thickener from 3% to 9%. This corresponds to a volume reduction of 2/3 (67%)
Volume = (2520 gal/d)(0.33) = 832 gpd 29



NOV 75-JES	5 22
	10 0/12

# DESIGN SHEET

 TR	U	CT	U	R	E

I

I

LIVE LOAD PER SQUARE FOR

J E SIRRINE COMPANY

JOB NO \_\_\_\_\_DATE \_\_\_\_\_ COMPUTED BY \_\_\_\_\_\_ WORKING STRESS \_\_\_\_\_\_

Check on volume = 643 1125 (1.02) (62.4 163/arft.) (0.09)

= 840 gal/d = 112 cuft/d

c) Volume

Solids = (643 165/d) (0.72 volatile) = 463 165 volatile solids


Volume = (463 165/0.1 165/cust/d) = 4630 cust

SWD = 15 ft Area = 309 sq.ft.


 $T + r^2 = 309 \text{ sq. ft}$  r = 10 ftdiameter = 20 ft

d) O2 required = (643 lbs) (0.72) (1.5 lbs O2/16 BOD) = 694 lb/day = 29 lb/hr

e) Dosing Interval Existing Sand Bed area (1 Bed) = 1050 sq. ft. Dosing Depth = 1 ft. Volume = 1050 cuft 40% of solids oxidized Dosing Vol. = 112 cust (.6) = 67 cufl Dosing Interval = 1050 cuft/67 cuft = 15.7 days



NOV 75-JES 22 11 0/ 12 J. E. SIRRINE COMPANY DESIGN SHEET JOB NO \_DATE\_ STRUCTURE \_\_\_ COMPUTED BY\_ LIVE LOAD PER SQUARE FOOT WORKING STRESS 8) Sludge Drying Beds a) Design Criteria (DM-5) Per capita allowance - 1.5 sqft/cap 3 Beds b) Existing Beds 3 Beds Total Area = 3150 sq, ft. EACH Bed = 1050 sq. ft. c) <u>Size Required</u> b Total future billeting capacity = 1566 people Off base personel = 615 (daytime) adjusted to full time = 615/3 = 205 people Total personel to be served = 1566 + 205 = 1771 people Required Bed area = (1771 cap.) (1,5 sq.ft. /cap.) = 2,657 sq.ft. . No additional sludge drying beds required. I 9) Lift Pumps (sludge) a) Primary Clarifier Sludge Pumps Two (2) pumps per clarifier in a lead lag configuration w/ Timer Fbw = 2, 520 gpd



NOV	75-JES	22	
	12	4	12

# DESIGN SHEET

JOB


Ь

STRUCTURE \_\_\_\_\_

J. E. SIRRINE COMPANY


JOB NO \_ DATE COMPUTED BY WORKING STRESS

	12 pump cycles /day (levery 2 hrs.)
	Volume to be pumped/cycle = 210 gal
	@ 20 gpm pump for 10.5 minu/cycle
•	b) Gravity Thickewer Sludge Pumps
	Two(2) pumps Lead Lag consiguration w/ Timer
	Flow - 840 gal/day
	6 pump cycles/day (ievery 4 hrs.)
	Valume to be pumped / cycle = 140 gal
	@ 10 gpm pump for 14 min. /cycle
10)	Effluent Recirculation Pumps
	Two (2) pumps Lead Lag configuration w/ Timer
	Recirculate 50 gpm from Chlorine Contact Chamber to Gravity Thickener to prevent Septic conditions



•

-<u>APPENDIX IV</u>-STEAM GENERATION AND DISTRIBUTION SYSTEM A UTILITY STUDY FOR THE COURHOUSE BAY AREA APPENDIX IV



Δ

•


-

I

# APPENDIX IV

# INDEX

	경험 가슴 것 같은 것 같이 있는 것 않는 것 같은 것 같은 것 같은 것 같은 것 같이 있다. 것 같은 것 같	Page
1.	BOILER HOUSE BLDG - 9 INFORMATION	3
2.	BUILDING STEAM REQUIREMENTS	7
3.	STEAM LINE DISTRIBUTION PRESSURE LOSSES	13
4.	ALTERNATIVES - COST ESTIMATE	25



I. E. SIRRINE COMPANY JOB STEAM STUDY STRUCTURE COURTHOUSE BAY LIVE LOAD PER SQUARE FOOT\_

JOB NO A-1086 DATE 9-78 COMPUTED BY MIC WORKING STRESS


20F29

REFERENCES

DESIGN SHEET

A. DESIGN MANUAL - NAVFAC B. ASHRAE- FUNDAMENTALS

DM-3 1972




JOB NO A-1086	DATE_	9-78
COMPUTED BY MK		
COMPUTED BY	129	1997

3 OF 29

# 1. BOILER HOUSE BLDG-9

**DESIGN SHEET** 

INFORMATION



NOV 75-JES 22

#### DESIGN SHEET

JOB STEAM STODY	
STRUCTURE COURTHOUSE BAY	-
LIVE LOAD PER SQUARE FOOT	

JOB NO A-1086 DATE 9-78 CDT COMPUTED BY

WORKING STRESS\_\_\_\_\_

BOILERS

40F 29

BLDG-9

ļ

J. E SIRRINE COMPANY

BOILER No-53: 15,000 Ibs/HR WATER TUBE - NEBRASKA 100 PSI OPERATION: 3 MONTHS STEAM A TOMIZATION (14000 Ibs/HR TITUSVILLE ROTARY) REPLACED


BOILER No. 54: 8,000 Ibs/HR ORR-SEMBOWER-FIRE TUBE OPERATIONAL! SINCE 1952 STEAM ATOMIZATION

BOILER No. 55: 12,000 165/HR ERIE CITY - WATER TUBE OPERATIONAL: SINCE 1957 TODO ROTORARY 8,000/10,000 165/48

FUEL STORAGE; 3-10,000 GAL ONDERBROUND STORAGE TANKS #6 BUNKER - C-

NOTES FROM USING ABENCE:

- · BOILER NO.54 USED ONLY IN EMERGENCYS
- · BOILER No. 55 RETUBED, EXPECTED LIFE 12-15 YRS



J. E. SIRRINE COMPANY

NOV 75-JES 22

### DESIGN SHEET

JOB STEAM STUDY STRUCTURE CODETHOUSE BAY


LIVE LOAD PER SQUARE FOOT

JOB NO A-1086 DATE 9-78 COMPUTED BY MIC WORKING STRESS

5 OF 29

	BOILER HOUSE	E RECORDS - BLDG	9 MAX HOURLY
DATE	USED (GALS)	GENERATED	USAGE (LBS)
JAN. 77	85,576	9,413,360	19,350
FE8.77	67,608	7,436,880	17,910
MAR. 77	56,855	6,254,050	14,190
APR. 77	34,366	3,789,260	9,555
MAY. 77	27,142	2,985,620	12,405
JUN 77	20,048	2,205,280	9,900
JUL 77	22,916	2,520,760	9,915
AUG 77	22,438	2,468,180	7,290
SEPT 77	22,632	2,489,520	8,040
OCT 77	39,007	4,290,770	11,205
NOV 77	55,889	6,447,790	12,780
DEC 77	73,720	8,109,200	17, 385
JAN 76	83,551	9,190,610	17,610
FEB 76	64,629	7,109,190	13,750
MAR 76	63,943	7,033,730	15,400
APR 76	42,696	4,696,560	13,900
MAY 76	27,729	3,050,190	8,360
JUN 76	28,143	3,095,730	7,150
JUL 76	20,665	2,273,150	5,960
AUG 76	20,707	2;277,770	4,935
SEP 76	19,863	2,184,930	5,060
OCT 76	34,750	3,822,500	11,550
NOY 76	60,467	6,651,370	19,365
DEC 76	75,822	8,349,420	30,585
	The State of California States		

\* INFORMATION SUPELIED BY USING AGENCY (B. LANKER)



the fair that the second second second	100410			
	1881 40	SIRKINE	COMPANY	

1

1

I

ł

I

NOV 75-JE5 22


# DESIGN SHEET

JOB STEAM STUDY STRUCTURE CODET HOUSE BAY

DATE 9-78 JOB NO A-1086 COMPUTED BY\_ M WORKING STRESS

60F29

DATE	OIL BOILER HOU	SE RECORDS-BLDC.	9 CONT'D HOURLY MAX HOURLY USAGE (LBS)
JAN 75		<u>GENERATED</u> 6,567,330	14,780
FEB 75	59,703 53,713	5,908,870	21,475
MAR 75	55,086	6,059,460	13,305
APR 75	34,738	3,821,180	10,095
MAY 75	25,943	2,853,730	8,620
JUN 75	22,778	2,506,480	13,510
JUL 75	24,571	2,702,810	8,205
AUG 75	26,186	2,880,460	5,610
SEP 75	24,884	2,737,240	4,400
OCT 75	30,262	3,328,820	9,600
NOV 75	55,013	6,051,430	17,170
DEC 75	73,068	8,037,480	15,090



6

1


DESIGN SHEET

JOB NO <u>H-1086</u> DATE 10-78 COMPUTED BY M/C WORKING STRESS

70F29

NOV 75-JES 22


# 2. BUILDING STEAM REQUIREMENTS



STRUCTURE COL	M STUDY URTHOUSE BAY REFOOT CAMP LES		JOB NO <u>A-1086</u> DATE <u>10-78</u> COMPUTED BY D WORKING STRESS
BLDG	40 × 8.3 × 952 BTU/	$\frac{100^{\circ}}{4\times80} = 43.6$ $\frac{100^{\circ}}{4\times80} = 43.6$ $\frac{100^{\circ}}{100} = 43.6$ $\frac{100^{\circ}}{100} = 43.6$ $\frac{100^{\circ}}{100} = 43.6$	없는 것 말 못 한 것 줄 다 가는 것 같은 것 같은 것이다.
BLD4	BB-30 HTG + HW PIPING LOSSES TOTAL	762 #/HR	CHECK) 15 PSI
BLDG	BB-208 HTG PIPING LOSSES TOTAL	(ON SITE 67 #/HR 7 74 #/HR	CHECK) 15 PSI
BLDG		$512 - 4 = 128$ ASSUME $40GPH$ $100^{\circ} = 43.6$ $X.8^{\circ} = 171.6$	#/HR
BLDĘ	BB-31 UH. PIPING Lass To		CHECK) (DWG 248169) HR 1HR 15PSI

J. E. SIRRINE COMPANY

1




**NOV 75-JES 22** 

1. E SIRRINE COMPAN DESIGN SHEET JOB STEAM STUDY BTRUCTURE COURTHOUSE BAY A-1086 DATE 10-78 COMPUTED BY LOAD PER SQUARE FOOT CAMP LEJEUNE RKING STRESS BLDG BB.SA PHOTO LAB 1 424.4 #14R 90F29 (Dug, 387181) 44 -RAD 312,8 -4 78,2 HW. GEN 43.6 #HR 40 GAH X 8.3 × 100 -952BTU/# X.8 546.2 PIPING LOSSES 546 601 #/HR - 15 PSI TOTAL 668.4#/HR (Dasg. 647044) BLDG BB-SI 473:44 RAD 473:4 118.0 786.4 PIPING LOSSES 78.6 865 #/HR BB-52 SHOP (Dava. 647045) BLDG 385,3 #/HR 66.5 #/HR 451.8 RAD 266\$ - 4 45.2 497 #/HR PIPING LOSSES 15PSI TOTAL STATION DE-GREASING 1/2"PIPE 600 #/HR ESTIMATED (Dag. 765456) BLDG BB-50 269.8 #/HR 417 -104.7 - 4 RADS 26.2 356.3 TEMP COILS HWGEN 136.2 1256PH × 8.3 × 100 788,5 952 X,80

TOTAL 867 #/HR

(ISPSI)



NOV 75-JES 22

#### DESIGN SHEET

STRUCTURE COURTHOUSE BAY


STEAM STUDY

I. E. SIRRINE COMPANY


A-1086 DATE 10-78

10 OF 29

(FROM · BEQ 250 HTG. 798 #1HR HW. <u>730</u> #1HR 1528 # HR. PIPING LOSSES 153 TOTAL 1681 #/HR 25 PSI BEQ 255 TOTAL 1681 #14R -25 PSJ BLDG - 16 LAUNDRY / CHAPEL (ON SITE CHECK) 36 #/HR 50 86 UH RAD (6) PIPING LOSSES 9 TOTAL 95 H/HR 15 PSI BLDG 48 \* BOILER: 836,800 BTOH - 952 BT = 879 #/HE PIPING \_88 H/HR 967 #1#12 - 25PSI BLDG \* BOILER: 870, 272 BTUH - 952 BTY = 914 #/HR PIPING LOSSOS 92 +748 1006 #/HIZ -25 PSI \* FUEDISHEB BY BED LANIER 11/28/78 WITH TELEPHORE CONVERSATION WITH ALC



**NOV 75-JES 22** DESIGN SHEET A-1086 DATE 10.78 JOB STEAM STUDY DES STRUCTURE COURTHOUSE BAY IVE LOAD PER SQUARE FOOT CAMP LESEUNE WORKING STRESS 110F 29 BLDG. BB-45 BOQ (LESS GALLEY) (DWG. 304717) RAD 3034 -4 758 #/HR 500 GPH × 8.3 × 100°F= 570 #/HR 910.BTU/# X.80 NO GALLEY 1328 #/HR PIPING LOSSES 133 1461 #/He BLDG BB.5 BATALION HDQ (DWG. 162625) RAD 975#-4= 244 #/48 HW GEN. ASSUME 100 GPH. 100 × 8.3 × 100°= 112.8 920 × 18 356.8 393 #/HR 50 (Dwg 162603) BLDG BB-10 INFIRMARY RAD 780,75 -4 195.2 \$14R 150 STER 125 470.2 #HAR 50 PSI HW GEN 470 517 #THR PIPING LOSSES (TO BE REMOVED) - 1992 BB-11. - 1978 BB-12 - 1978 BB-13 BB-14 - 1992 7940 TOTAL / 6352



STEAM STUDY	DESIGN	SHEET
TRUCTURE COURTHOUSE BAY.		
IVE LOAD PER SQUARE FOOT CAMP LEVEU	WE	

JOB NO A-1086 DATE 10.78 COMPUTED BY WORKING STRES

120F29 (Daug. 162565)

BLDG BB-7 MESS HALL

DIRECT RAD INDIRECT " GALLEY I+W. GEN

111 ###R 781 2953 556 4401 #/HR. 440 4841

50 PSI

BLDG BB-2 THEATER RAD 579.6 7 -4 BLAST COR

PIPING LOSSES

PIPING LOSSER

(DWG, 162652)

144,9 #/HR 1687.0 1831.9 18 3.2 15PSI 2013.1

BLDG BB-3 PX

(ON SITE CHECK)

410 # HR 451 #/HR.

50 PSI

BLDG BB-15

BLDG BB-8

100 #HR 10 #/1HR


50 PST

(DWG 387181)

UH -INDIREG

205,5 39.4 244,9

30PSI.



I

•


1

13 OF 29

# 3. STEAM LINE DISTRIBUTION

PRESSURE LOSSES

DESIGN SHEET




J.F SIRRINE COMPANY Engineers - Architects

JOB STEAM STU	DY ,		ESIGN S	HEET
STRUCTURE COURTHOUS	AMP LE	LEUNE	PPH	
PSI.	PD/100'		#/HR	FPM
23 7037		1/2"	18	1400
DM-3 - FI		3/4	40	1700
· · · · · · · · · · · · · · · · · · ·		1	25	2000
		14	150	2400
		12	240	2700
		2	470	3200
		22	700	3500
		3	1300	4000
		456	2800	4900
		3	5000	5600
		6	8000	6400
		8	17000	7600
40 0060	,5	1/2	27	1400
40 TO 60 DM-3 FIG. 11	1(5)	3/4	52	1650
		1	100	2000
		14	210	2400
		14:12	300	2600
		2 22	580	3000
		22	980	3400
		1045	1700	4000
anter e e e e e e e e e e e e e e e e e e		4	3700%	4600
		3	6400	5300
		6	10000	6000
		8	23000	7000
85 70 125	1.0	1/2	50	1600
DM-3 Fig. 11	1.2(a)	3/4	100	1850
	./		180	2200
		14	400	2600
		1-14-11	600	2850
		2	1200	3400
		22	2000	3800
		3	3500	4500
		4	7000	5100

JOB NO <u>A-1086</u> DATE 10-78 COMPUTED BY <u>E</u> WORKING STRESS

140F21 MAX, PPH OPTIMUM RECOMMENDED MAX PD PST



J.F SIRRINE COMPANY Engineers - Architects


## DESIGN SHEET


JOB STEAM STUDY STRUCTURE COURTHOUSE STRUCTURE COURTHOUSE BAY


A-1086 DATE 10.78 JOB NO COMPUTED BY\_ WORKING STRESS


150=29


(CONT.)	#/	UD	EDIA
CONTIT OF IDE ID			FPM
BS-125 1.0 DM-3 Fig 11-2(2)	4"	7000	5100
	6	22000	6700
	8	4400	8000
	10	80,000	9200
127 TO 180 1.0 DM-3 FIG 11-2(b)	1/2	55	1200
DM-3 FIG 11-2(b)	3/4	130	1600
	14	230	1800
	14:2	500	2200
	22	700	2400
	22	1400 2360	2800
	3	4000	3200
		8000	4000
	4	15000	5000
	6	26000	5500
	8	50,000	7000
	10	90000	8000

















DM-3 3-11-11











Fig. 5 .... Basic Chart for Weight-Flow Rate and Velocity of Steam in Schedule 40 Pipe Based on Saturation Pressure of 0 Psig

(With Multiplier Charts for Obtaining Weight-Flow Rates and Velocities of All Saturation Pressures Between 0 and 200 Psig)



NOV 75-JES 22

#### DESIGN SHEET



J. E. SIRRINE COMPANY

Þ


JOB NO A-1086 DATE/2-13-78 MIC COMPUTED BY

210529

PRESS. IN LINE (NEW B.E.Q)

	РРН	PD*		PSIG
BOILER	And States			100
NON-RET. YA	15,000	5		95
IO" HDR	24,442	0.1		94.9
6" MAIN	16,398	-6		94.3
6 MAIN TO FUT PX	16,322	.6	300x.6x1.2= 2.16	92.1
6 MAIN TO BARP. T.O.	15,522	.6	5007.6x2.0: 6.	86.1
5" MAINTO BLOG 6	8,302	.5	1900 × .5× 1.2 - 11.4	74.7
5" MAINTO BLDG 5	7,660	.5	400 x.5 x 1.2 = 2.4	72.3
5" MAIN TO BLOG 48	7017	.4	150 X.4 X1.2 = .72	71.6
5"TO TEE (BLDS9\$, 49)	6243	.5*	100 X ,5 X ). Z = . 6	71.0
4"TO FUT BARR 1	3494	,5	200 x, 5 x 1.4 = 1,4	69.6
4" TO FUT BARR 2	2687	.3	600 x.3 x 1.4= 2.5	67.1
2/2 TO BLDG 49	1006	.5	600 x. 5 x12= 3.6	63.5
				71.0
4" TO MECH. BLDG.	2750	,3	150 x . 3x1.2 = . 5	70.5
2" TO BLDG 4	803	1.0	200 x 1.0 x 1.2 = 2.4	68.1
				86.1
6"To BLDG 50	7220	.15	600 X.15 X 1.2= 1.1	85.0
6"To GX4 Tee	6526	.15	200 X .15 X 1.2= .4	84.6
4"To BB26	4957	.5	500 X .5 X 1.4 = 3.5	81.1
4"TO TEE	3362	.2	200 X.2 X12= .5	80.6
4"70 BLDG 250	1681	-1	400 x . 1 X 1.4 = . 6	80.0
4'To BLDG 255	1681	.1	500 X . 1 X 1.4= .7	79.3
				84.6
4"5 BLOC 51	1570	.1	500 × .1 ×1.2=16	84.0
3" To BLD652	1097	.1	200 1 11 112 = 13	83.7

\* USE FIG 11-2(2) \* USE FIG 11-1(6) DM-3 \* USE FIG DM-3



STEAM STUDY JOB\_ STRUCTURE COURTHOUSE BAY

J. E SIRRINE COMPANY

**DESIGN SHEET** 

LIVE LOAD PER SQUARE FOOT


JOB NO A-1086 DATE 12-13-78 MC COMPUTED BY\_

WORKING STRESS

	2:			
	PRESS.	IN	LINE	
	PPH	PO*		P516
BOILER				100
NOW-RET VA	15,000	5	그 같은 방송에 가지 않는 것	95
10" HDR	24,442	.15		94.9
6 MAIN	16,398	.7	200×1.2×.7=1.7	93.2
6" MAINTO PA	16,322	17	300 X112 X17= 25	90,7
6" ToBLDC 50	15,522	.6	900 × 1,2 ×,6=6,5	84.2
6" To Tee	14, 828	.6	200 × 1.2 × 16= 1,5	82.7
6" To BB-26	13,258	.4	500 x 1.4 x - 4= 2.8	79.9
6" To GXYTEE	10,991	.3	180 X16 X.3= .87	79,0
6" To BB-250	9,646	,3	100 × 1.4 × . 3 = .4	78,6
6"To BB-48	8,302	.2	1300 × 1.2 × .2= 3.1	75.5
6 To Tee	7,528	. 2	200 × 1,2 × ,2= ,5	75,0
6 "To Tee 6x4	6,243	1	200 X1.6 X.1 = ,5	74.5
4"To FUT BAP!	3494	.3	200 x 1.4 X.3 - 18	73,7
4 TO FOT BARRZ	2687	.3	600 × 1.4 ×.3 = 2.5	71.2
2% To BLDG 48	1006	,5	600 X , 5 X 1, 2 = 3.6	67.6
				75.0
3" To BLDC 5	1606	.3	50 X .3 X 1.2= .2	74.8
2/ TO BLOGG	803	.2	500 × 12 × 112= 1.2	73.6
			AND ADDRESS OF A DECK	74,5
4 To Mac BLD	2750	, 3	200 x, 3 X 1, 2 = 15	7年,0
2" To BLDG	803	1.0	200 × 1.0 ×1.2 = 2.4	716

11-2(2) \* USE FIG DM-3

2 OF 29



NOV 75-JES 22

## **DESIGN SHEET**

JOB STEAM STUDY STRUCTURE COUPTHOOSE BAY

I. E. SIRRINE COMPANY


.

JOB NO A-1086	DATE 10-78
COMPUTED BY CIT	
WORKING STRESS	

230=29

	PRESS 11	N LINE	-			
	LP (15P5I)	OUERH	EAD	SYSTEM		
		PPH	PL	2*	1 an	P516
BB-26 (PRV	STATION)					15.0
4 To 8827		1786	.1	150×1.4×.1=.2		14.8
3% TO TEE		1635	.15	150 X 1.2X.15=, 3		14.5
2% To BB31		836	.2	400 × 1.2×.2= 1.0		13.5
21/2 To BB-30		966	.35	300 × 1.3 ×.35= 1.4		12.1
21/ To BB-28		296	.03	150 × 1.2 ×.03= ,1		12.0
2" To BB-54		601	.28	100 X14 X,28=.4		14.6

\* USE FIG. 5 PAGE 502 ASHRAE GUIDE 1972 FUNDAMENTALS



DE <u>I E SITRINE COMPANY</u> JOB <u>STEAM STUDY</u> STRUCTURE <u>COURTHODSE</u> BAY LIVE LOAD PER SQUARE FOOT	DESIGN SHEET	JOB NO <u>A-1086</u> COMPUTED BY <u>XD7</u> WORKING STRESS	D-78
			24 OF 29
PRESS.	IN LINE .	• • • •	


(

PPH	PD *		PS16
			100
15000	5.		95.
24442	.1		94.9
8045	.2		94.7
8045	. 2	250X,2X1,2=.6	94.1
5984	.1	200 X. 1 X 1.4=.3	93.8
1897	-1	300 X.1 X 1.2 = ,4	93,4
1897	.1	800 X . 1 X 1.2 = 1.0	92.4
	15000 24442 8045 8045 5984 1897	15000 5, 24442 .1 8045 .2 8045 .2 5984 .1 1897 .1	15000 5, 24442 .1 8045 .2 8045 .2 250X,2X1,2=,6 5984 .1 200X.1X1,4=.3 1897 .1 300 X.1X1,2=,4

UNDERGROOND SYSTEM

USE F16. 11-2(2) DM-3

NOV 75-JES 22




A-1086 DATE 9-78 JOB NO COMPUTED BY WORKING STRESS

25 OF 29


4. ALTERNATIVES - COST ESTIMATE

DESIGN SHEET



TLANTIC DIVISION - NAVAL ROJECT TITLE: <u>Utility S</u>						ATE PREPARI	D 12/18/78
CTIVITY & LOCATION: MCB	, Camp I	Lejeun	a, N.	с.			
&E FIRM & ADDRESS: J. E. P. O.		e Comp 56	any	•	CONTRA		LE CONTRACT N62470-78 C-3675
PRELIMINARY ESTIMATE (X)				ATE ()	RE	VISED FINA	L ESTIMATE (
HEADING SCHEME A		EST	IMATOR	CROMER	CHEC	KED BY /.	NER
	QUANT	ITY		LABOR	M	ATERIAL	T
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS	PER UNIT	TOTAL	PER UNIT	1	TOTAL COST
PIPE	·				1.1.0		
5" B.S. Sch. 40	1615	FT.	8.85	14293.	10.70	17281.	31574.
3" B.S. Sch. 80	1615	FT.	5.90	9529.	6.00	9690.	19219.
4" B.S. ScH 40	1030	FT.	7.10	73/3.	5,25	5408.	12721.
2" B.S. Sch 80	1080	FT	3.14	3391.	4.01	4331.	7722.
3" B.S. ScH 40	50	FT	5.60	280.	3,50	175.	455.
2" B.S. ScH 40	950	FT	3.80	3610.	2.02	1919.	55 29.
11/2" B.S. Sc# 80	950	FT	2.34	2223,	3.80	3610.	58 33.
21/2" B.S. SCH 40	550	FT	4.70	2585	2.78	1529.	4114.
PIPE INSOLATION (STM)							
5"PIPE INSUL W/JACKET	1615	FT.	4.38	7074.	8.27	13356.	20430.
3" Thick							
PIPE INSUL. WACKET	1030	FT.	3.78	3893.	6.62	6819.	10712.
21/2" Thick							
3"PIPE INSUL WHACKET	50	FT	3,35	168.	5.48	274.	442.
21/2" Thick							
21/2" PIPE INSUL W/Jacket	550	FT	3.06	1683.	478	2629.	4312.
2" Thick							
2" PIPE INSUL WHACKET	950	FT	2.77	2632.	4.08	3876.	6508.
2" Thick							
PIPE INSULATION CONd.		1 2.36			1		
"PIPE INSOL. W/ Jocket 1/2" Thick	1615	FT	2.49	4021.	3/9	5152.	9173.
2" PIPE IN SUL WHACKET	1080	FT	2,16	2 3 3 3,	2,65	2862.	5195.
1" Thick				1.10			
			12				


b



ATLANTIC DIVISION - NAVAL PROJECT TITLE: <u>Utility S</u>						TE PREDAD	ED 12/10/20
ACTIVITY & LOCATION: MCB					Dr		CU_12/10/10
A&E FIRM & ADDRESS: J. E. P. O.		Comp	any		. CONTRA	ACT A N	&E CONTRACT 0. N62470-78- C-3675
PRELIMINARY ESTIMATE (X)		FINAL	ESTIMA	TE ()	RE	VISED FINA	L ESTIMATE (
HEADING SCHEME A		EST	MATOR	ROMER	CHEC	KED BY LI	
<u>SCHEME H</u>	QUANT	ITY		ABOR	- M	ATERIAL	VER
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS	PER	TOTAL	PER UNIT	TOTAL	TOTAL COST
RIPE INUL. COND. CONT.							
12" PIPE INSUL WURCKET 1"Thick	950	FT	1.98	18 81.	2.36	2242.	4123.
SUPPORTS	185	EA	121	22385	242	44770	67155
BRIDGES	3	EA	1833	5499.	2366		12597
PIPE GUIDES			Trease of				
5"-3" INSUL.	81	EA	21.50	1742.	55.46	44 92.	6234.
4"-21/2" INSUL.	52	EA	16.54	860.	43.54		3124.
3"-2"2" INSUL.	Z	EA	14.51	29.	38.18	76,	105.
21/2"- 2" INSUL.	28	EA	13.40	375	35.26	987	1362.
2"-2" INSUL.	48	EA	10.00	480.	26.34	1264.	1744.
SUB-TOTAL				98279		142104	240383
CONTRACTOR MARKUP	49%					7 40383	117,788
SUB-TOTAL							358,171
CONTINGENCY	10%						35817
SUB. TOTAL							393,988
ESCALATION TO- 1.1.80	11%						43,339
SUB-TOTAL							4.37,327
OTAL ROUNDED							437,300
SIDH	5.57.						24,052
TOTAL							461,400

6

Ĩ



SHEET 28 OF 29 ATLANTIC DIVISION - NAVAL FACILITIES ENGINEERING COMMAND PROJECT TITLE: Utility Study - Courthouse Bay Area DATE PREPARED 12/18/78 ACTIVITY & LOCATION: MCB, Camp Lejeune, N. C. A&E FIRM & ADDRESS: J. E. Sirrine Company CONST. CONTRACT A&E CONTRACT P. O. Box 5456 NO. N62470-78-NO. Greenville, S.C. 29606 C-3675 PRELIMINARY ESTIMATE (X) FINAL ESTIMATE () REVISED FINAL ESTIMATE ( . HEADING SCHEME B ESTIMATOR CHECKED BY OUANTITY LABOR MATERIAL NO. UNIT PER PER TOTAL MATERIAL DESCRIPTION UNITS MEAS TOTAL UNIT UNIT TOTAL COST 6"B.S. SCH. 40 750 10.45 7838. 8850. FT 11,80 16688. 40 SBS SOH 15045. 1700 F7 8.85 18190. 33,235. 10,70 4" B.S. SC:H 40 1030 FT 7313. 5408. 7.10 5.25 12,721. 3" B.S. SCH 40 75 5.60 420. 3.50 FT 263. 683. 2" B.S. SCH 40 950 FT 3.80 3610. 2.02 1919. 5529 80 3" B.S. SCH. 2500 FT 5.90 14.750. 29,750. 6.00 15.000. 2" B.S. 80 3.14 3 2,342. 4.01 SCH. 1030 4130. Ft 36472. 1% B.S. 80 SCH. 950 FT 2.34 2223. 3.80 3610. 5833. PIPE INSULATION (STM.) 6" PIPE INSUL W/JACKOT 4.92 750 7185 3690 9.5% FT 10875. 3"THICK 5" PIPE INSUL W/JACKET 4.38 7446 1700 FT 8,27 14059 21.505. 3"THICK 4" PIPE INSUL W/JACKET 3.78 1030 3893. 6.62 6819 FT 10712. 212 THICK 3" PIPE INSUL W/JACKET 75 3.35 FT 251 5.48 411. 662.

PIPE

21/2" THICK

2" THICK

1/2" THICK

1" THICK

2" PIPE INSUL W/JACKET

PIPE INSULATION (COND.)

3" PIPE TUSUN W/JACKST 2500

2" PIPE TNSUL W/JACKOT 1030

950

FT

FT

FT

7.77

2.49

1.81

2632

6225.

1864.

4.03

3.19

2.15

3829


7975:

2215.

6461.

14200.

4079.




## SHEET 29 OF 29


ATLANTIC DIVISION - NAVAL							
PROJECT TITLE: Utility St	tudy - C	ourth	ouse Ba	ay Area	DA	TE PREPARE	D12-18-78
ACTIVITY & LOCATION: MCB	, Camp L	ejeun	e, N. (	<u>c.</u>			
	Sirrine Box 545 ville, S	6		CONST. NO.	CONTRA		E CONTRACT N62470-78- C-3675
PRELIMINARY ESTIMATE ( )			ESTIMA		REV	ISED FINAL	ESTIMATE (
HEADING SCHEME B		EST	MATOR,	CROMER	CHECI	ED BY	NER
<u> </u>	QUANT	ETY	E L	ABOR	M/	TERIAL	111616
MATERIAL DESCRIPTION	NO. UNITS	UNIT MEAS	PER UNIT	TOTAL	PER UNIT	TOTAL	TOTAL COST
11/2" PIPE INSUL W/JACK	950	FT	1.18	1881.	2.36	2242:	4123.
1"THICK							
SUPPORTS	200	EA.	121	24200	242	48400	72600
BRIDGES	3	EA.	1833	5499	2366	and a state of the	12597
PIPE GUIDES	E a l'orrent	30	1999		2.30	a state in the	and the second second
6" - 3" Insul.	38	EA	21.50	817.	55,46	2108.	2925.
5"- 3" Insul.	85	EA	21.50	1828.	55.46	4714.	6542.
4" - 21/2" INSUL.	52	EA	16.54		43,54	2264.	3124,
3" - 21/2" NSUL	3	EA	14:51	43.	38,18	115,	158,
2" - 2" INSUL.	48	EA	10.00	480.	26,34	1264,	1744.
DEMOLITION							······
REMOVE EXIST 4"STM	750	LF	13,00	9750.	-	<b>.</b> .	9750,
REMOVE EXIST. 2"COND	750	LF	9.00	6750.	-	-	6750.
SUB-TOTAL				161,650,		168,068	329.718
CONTR, MARKUP	49%						161,562
SUB-TOTAL							491280
CONTINGENCY	10%						49.128
SUB-TOTAL							540408
ESCALATION	1120						59,445
SUB-TOTAL							599,853
TOTAL ROUNDED		k - 19	a kuji				599,900
SIOH	5.5%						32,995
TOTAL							632,900

I

6

Ĭ







ARCHITECTS

## ENGINEERS

PLANNERS

## ARCHITECT - ENGINEER DIVISION

P. O. Box 5456	GREENVILLE, SOUTH CAROLINA 29606		TELEPHONE 803/298-6000
P. O. BOX 27194	<ul> <li>HOUSTON, TEXAS 77027</li> </ul>	•	TELEPHONE 713/627-2050
P. O. BOX 12748 •	RESEARCH TRIANGLE PARK, NORTH CAROLINA	27709	TELEPHONE 919/541-2081
P. O. BOX 3790	<ul> <li>RIYADH, SAUDI ARABIA</li> </ul>	•	TELEPHONE 60204