


200 G.P.M. - SINGLE DRIVE, 7 1/2 H.P.
 224 " " " actual. D.D. - 134
 Pump Fdn. EL 34.4



D.T.A. WELL No. 6



SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PWSID
0 4 6 7 0 4 1

Owner Assigned Source Code

Well Name (If purchase, name of system)

606 HADNOT POINT 606

Code

S

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

Source exempt— SWTR?

Direct Influence Date

Availability

Source Begin Date: M M Y Y
Source exempt: Y N
Direct Influence Date: M M D D Y Y

P

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (If purchase, location of master meter)

SNEADS FERRY ROAD

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

3 4 3 9 4 9 . 0 7 7 1 9 1 0 .

G

G=GPS
M=Map
S=Surveyed

Q# or DOP #

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N Assessment Date M M D D Y Y

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned Entry Point Code

Entry Point Name

100 HADNOT PT WTP

C=Ground/Permanent
D=Ground/non-permanent

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? N (Y,N) If no, explain: _____

Sources of pollution/distance: 50' to Road

Surface water within 200'? N (Y,N) If yes, actual distance _____ feet If yes, bact. samples collected? _____ (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: OK

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: OK Type of freeze protection: NONE

Well: Diameter: 8" Type: GRAVE PACK Yield (gpm): 226-345 Properly sealed? Y (Y,N)

Properly vented? N (Y,N) Casing depth 80 ft. (If unknown, put 'UNK') Well depth: 210' Meter available? N (Y,N)

Concrete slab adequate? Y (Y,N) If no, explain: _____ Size: 10x12

Size of blow-off: 3" (G) Sample tap: Before treatment? Y (Y,N) After treatment? _____ (Y,N)

Pumps: Capacity: GPM: 226-345 HP: 7.5 Pump intake depth: 80 Auxiliary Power? N (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 22"

Storage at well site: Elev: _____ Hydro: _____ Ground: _____

If hydroautomatic, air volume control? _____ (Y,N) Safety valves? _____ (Y,N) Coded? _____ (Y,N)

High service pumps: 1. _____ gpm _____ hp 2. _____ gpm _____ hp 3. _____ gpm _____ hp Auxiliary Power? _____ (Y,N)

Is the water treated at this well? Y (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? _____ If treated elsewhere, where? HP-20 PLANT

If purchase, retreat? Y (Y,N) If yes, complete back of form.

- ① No vent
- ② No Meter
- ③ Pump switches for heavier use



DATE 7-25-00

PWSID 04-67-041

WELL # HP-606

WELL NAME HADNOT POINT HP-20

BLDG. HP 606

CODE G.

AVAILABILITY P.

LOCATION SNEADS FERRY ROAD

LATITUDE 34.6645

LONGITUDE 77.32002

WELL DIAMETER 8"

WELL DEPTH 210'

SCREEN INTERVAL

YIELD 197

STATIC LEVEL 20

PUMPING LEVEL 46

PUMP TYPE VERTICAL TURBINE

MOTOR HP 7.5


INTAKE DEPTH 80'

DESIGN CAPACITY 345

ACTUAL GPM 226

SIZE OF CONCRETE SLAB 10x12

HEIGHT OF CASING 22"





200

WELL NUMBER 606		BY Stevenson & Brown			DATE 10-12-94	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
80	20	50	30	45	100	
		55	35	35	133	
		60	40	25	175	
		63	43	15	210	
		65	45	10	226	

REMARKS
D/H 58

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE

11:11


11 11 11 11 11 11 11 11

WELL NUMBER 606		BY Thomas Brown			DATE 3-26-90	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
80	20	30	10	50	100.	05
		35	15	45	119	15
		40	20	35	157	25
		46	26	25	192	35
		50	30	15	230	45
		58	38	8	267	55

REMARKS

deal head @ 60 PSI
 set @ 8 PSI

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE




Dead Head 60 PSI

WELL NUMBER 606		BY Thomas Sardine			DATE 3-27-89	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
80	19	27	8	57	104	15
		33	14	52	143	25
		36	17	46	178	35
		39	20	41	192	45
		42	23	36	216	55
		46	27	27	239	05
		56	31	20	272	15
		54	35	15	290	25
		58	39	10	311	35
		60	41	7	317	45

REMARKS Dead Head 60 PSI

3-21-89 NEW Pump

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE
GOWLOS	6	MST 89037 MODEL 8 RJLO		6 ST.





WELL NUMBER		BY			DATE	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
80	21	24	3	10	100	45
		26	5	5	128	55


Dead Head 21

REMARKS

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE







WELL #606

LENGTH OF AIR LINE

STATIC LEVEL

PUMPING LEVEL

DRAW DOWN

DISCHARGE PRESSURE

CAP. PER FOOT OF DRAW DOWN

TOTAL CAP.

DATE

1-11-79

40'

23 set

115

37'

21

133

31'

17

204

30'

14

212

REMARKS:

DEPTH OF WELL:
AIRLINE ELEVATION: +
DATE INSTALLED:



606

LENGTH
OF
AIR LINE

STATIC
LEVEL

PUMPING
LEVEL

DRAW
DOWN

DISCHARGE
PRESSURE

CAP. PER
FOOT
DISCH.

TOTAL
CAP.

100
100

Start Time

1030

9-29-82

80'

31'

40

9'

39

100

1045

43

12

26

111

1100

45

14

22

130

~~1045~~

49

18

19

154

1130

51

20

16

167

1145

53

22

13

187

1155

*used direct reading gage
pvt set at 13 PSI 187 GPM*

100 - 20
100 - 10
100 - 10

10000
2000

10000
1000

PHYSICAL AND CHEMICAL ANALYSIS OF WATER

SAMPLE NO.

WH9-5

DATE

9-17-58

FROM: (Station or unit)

U.S. Marine Corps Air Facility, New River, Jacksonville, N. C.

TO: (Name and location of laboratory)

Sanitation Laboratory, DPWO, 5ND, Naval Base, Norfolk, Virginia

SAMPLE FROM (Location of sampling point)

Well #6

COLLECTED BY

Activity Personnel

DATE

9-8-58

HOUR

-

SOURCE (Designate ground, surface, raw, treated)

Ground

REASON FOR EXAMINATION

To test for chloride content

EXAMINATION REQUESTED BY

Mr. R. L. Cox

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

I. Laboratory FIELD ANALYSIS			III. ROUTINE LABORATORY ANALYSIS	
1. pH	TEMPERATURE		(CHECK ONE)	
	°F	°C 22	<input checked="" type="checkbox"/> REQUESTED	<input type="checkbox"/> NOT REQUESTED
ITEM	PPM			
2. CARBON DIOXIDE (CO ₂)			1. COLOR	
3. DISSOLVED OXYGEN (O ₂)			2. TURBIDITY	
4. HYDROGEN SULFIDE (H ₂ S)			3. ALKALINITY (CaCO ₃)	
5. CHLORINE DEMAND (Cl ₂)			P	MO
FIELD ANALYSIS BY			2.	356.
DATE OF ANALYSIS			4. TOTAL HARDNESS (CaCO ₃)	
II. SPECIAL LABORATORY ANALYSES Check (X) individual items to be included in the Special Analyses. Request determination only of those substances suspected of being present in significant amounts.			5. NON-CARBONATE HARDNESS (CaCO ₃) (By Computation)	
			6. CARBONATE HARDNESS (CaCO ₃) (By Computation)	
(X)	ITEM	PPM	7. TOTAL DISSOLVED SOLIDS	
	1. As		8. SPECIFIC CONDUCTANCE (Micromhos)	
	2. Se		ITEM	PPM
	3. Pb		9. CALCIUM (Ca)	
	4. B		10. MAGNESIUM (Mg)	
	5. Cu		11. SODIUM (Na) AND POTASSIUM (K)	
	6. Zn		12. HYDROXIDE (OH)*	
	7. Cr (Hexavalent)		13. BICARBONATE (HCO ₃)*	
	8. PO		14. CARBONATE (CO ₃)*	
	9. Cd		15. SULFATE (SO ₄)	
	10. CN		16. CHLORIDE (Cl)	120.
	11. Phenolic Compounds (PPB)		17. NITRATE (NO ₃)	
	12. Others (Specify)		18. IRON (Fe) TOTAL	
	13.		19. MAGANESE (Mn)	
	14.		20. SILICA (SiO ₂)	
	15.		21. FLUORIDE (F)	
	16.		*State whether determined or computed from P and MO alkalinity.	

REMARKS (Such as unusual appearance, taste, odor, etc.)

Note: Very faint odor of hydrogen sulfide in this sample.
 Pump in service for 2½ hours prior to the time sample was collected.
 Three (3) wells in service at time of sample collection.

LABORATORY ANALYSIS BY

George I. Earnest, Jr.

DATE OF ANALYSIS

9-19-58


DD

FORM 1 APR 53

710

REPLACES WD AGO FORM 8-125, 1 APR 45, WHICH MAY BE USED.

GPO 912375



HP-606

<input checked="" type="checkbox"/> CHECKED BOX APPLIES		<input checked="" type="checkbox"/> ORDER FOR SUPPLIES OR SERVICES		<input type="checkbox"/> REQUEST FOR QUOTATIONS NO.		PAGE 1 OF 2	
1. CONTRACT/PURCH ORDER NO. M67001-77-M-4440		2. DELIVERY ORDER NO.		3. DATE OF ORDER 77 MAY 06		4. REQUISITION/PURCH REQUEST NO. M93058-7117-W054	
6. ISSUED BY: Mr. Harris/919-451-2164 Purchasing & Contracting Office Bldg 1211, Marine Corps Base Camp Lejeune, N. Carolina 28542		CODE M67001		7. ADMINISTERED BY: (If other than 6)		8. DELIVERY FOB <input type="checkbox"/> DESTINATION <input checked="" type="checkbox"/> OTHER (See Schedule if other)	
9. CONTRACTOR/QUOTER NAME AND ADDRESS AURORA PUMP COMPANY 3048 MILLER ROAD LITHONIA, GA 30058		CODE		FACILITY CODE		10. DELIVER TO FOB POINT BY: 77 JUN 15	
14. SHIP TO: Freight Traffic Branch Bldg 1011, Camp Lejeune, N. Carolina M67001-77-M-4440		CODE		15. PAYMENT WILL BE MADE BY: Base Disbursing Officer MCB, Camp Lejeune, North Carolina 28542		11. CHECK IF SMALL BUSINESS <input type="checkbox"/> MBE	
						12. DISCOUNT TERMS NET 30	
						13. MAIL INVOICES TO: (In sextuplicate) SAME AS BLOCK #14	
						MARK ALL PACKAGES AND PAPERS WITH CONTRACT OR ORDER NUMBER	

22 July
Received 8/25/77

16. TYPE OF ORDER: DELIVERY PURCHASE

This delivery order is subject to instructions contained on this side of form only and is issued on another Government agency or in accordance with and subject to terms and conditions of above numbered contract.

Reference your TELEQUOTE 77 MAY 06, furnish the following on terms specified herein, including: for U. S. purchases, General Provisions of Purchase Order on DD Form 1155r (Except CLAUSE NO. 13 APPLIES ONLY IF THIS BOX IS CHECKED, and NO. 15 IF THIS BOX IS CHECKED); special provisions and delivery as indicated. This purchase is negotiated under authority of 10 USC 2304(a)(3) or as specified in the schedule if within the U. S., its possessions or Puerto Rico; if otherwise, under 2304(a)(6).

If checked, Additional General Provisions apply; Supplier shall sign "Acceptance" on DD Form 1155r and return copies.

17. ACCOUNTING AND APPROPRIATION DATA - ACCOUNTING CLASSIFICATION (REV. 7-65)										
ITEM NO.	APPROPRIATION SYMBOL AND SUBHEAD	OBJECT CLASS	BUREAU CONT. NO.	SUB-ALLOT.	AUTH'N ACCT'G ACTY	TRANS. TYPE	PROPERTY ACCT'G ACTY	COUNTRY	COST CODE	AMOUNT
ALL	1771106.2720	000	67001	0	067001	2D	000000		AA72343552383T	PLUS TRANS \$2748.00

18. ITEM NO.	19. SCHEDULE OF SUPPLIES/SERVICES	20. QUANTITY ORDERED/ACCEPTED*	21. UNIT	22. UNIT PRICE	23. AMOUNT
0001 606	PRIORITY 14 MML999 4320-00-C99-2993 Pump, layne vertical turbine deep well, water lubricated, complete with electric motor 220/240 volts, 7-1/2H.P., 3 phase, 1800 RPM., setting 80 ft., size 5", 4 stage, 200 GPM, 86 TDH, suction-pipe 5" X 10'	1	ea	2748.00	2748.00

F.O.B. ATLANTA, GA. TRANSPORTATION CHARGES ESTIMATED NOT TO EXCEED \$500.00. ALL TRANSPORTATION CHARGES PREPAID AND LISTED ON DEALER'S INVOICE AS A SEPARATE ITEM.

* If quantity accepted by the Government is same as quantity ordered, indicate by <input checked="" type="checkbox"/> mark. If different, enter actual quantity accepted below quantity ordered and encircle.		24. UNITED STATES OF AMERICA By: J.C. CRUMLEY		25. TOTAL \$2748.00	
26. QUANTITY IN COLUMN 20 HAS BEEN: <input type="checkbox"/> RECEIVED <input type="checkbox"/> INSPECTED <input type="checkbox"/> ACCEPTED, AND CONFORMS TO THE CONTRACT EXCEPT AS NOTED		27. SHIP. NO. <input type="checkbox"/> FINAL <input type="checkbox"/> PARTIAL		29. DIFFERENCES	
Date (Signature of authorized Government representative)		31. PAYMENT <input type="checkbox"/> COMPLETE <input type="checkbox"/> PARTIAL <input type="checkbox"/> FINAL		30. INITIALS	
36. I CERTIFY that this account is correct and proper for payment (Signature and title of Certifying Officer)		32. PAID BY 67001-SYM # 5190 MCB CLNC		33. AMOUNT VERIFIED CORRECT FOR	
37. RECEIVED AT		38. RECEIVED BY		34. CHECK NUMBER	
39. DATE RECEIVED		40. TOTAL CONTAINERS		35. BILL OF LADING NO.	
		41. S/R ACCOUNT NUMBER		42. S/R VOUCHER NO.	

THIS PARAGRAPH APPLIES ONLY TO QUOTATIONS SUBMITTED:

Supplies are of domestic origin unless otherwise indicated by quote. The Government reserves the right to consider quotations or modifications thereof received after the date indicated should such action be in the interest of the Government. This is a request for information and quotations furnished are not offers. When quoting, complete blocks 11, 12, 22, 23, 25. If you are unable to quote, please advise. This request does not commit the Government to pay any cost incurred in preparation or the submission of this quotation or to procure or contract for supplies or services.

GENERAL PROVISIONS

1. INSPECTION AND ACCEPTANCE - Inspection and acceptance will be at destination, unless otherwise provided. Until delivery and acceptance, and after any rejections, risk of loss will be on the Contractor unless loss results from negligence of the United States Government. Notwithstanding the requirements for any Government inspection and test contained in specifications applicable to this contract, except where specialized inspections or tests are specified for performance solely by the Government, the Contractor shall perform or have performed the inspections and tests required to substantiate that the supplies and services provided under the contract conform to the drawings, specifications and contract requirements listed herein, including if applicable the technical requirements for the manufacturers' part numbers specified herein.

2. VARIATION IN QUANTITY - No variation in the quantity of any item called for by this contract will be accepted unless such variation has been caused by conditions of loading, shipping, or packing, or allowances in manufacturing processes, and then only to the extent, if any, specified elsewhere in this contract.

3. PAYMENTS - Invoices shall be submitted in quadruplicate (*one copy shall be marked "Original"*) unless otherwise specified, and shall contain the following information: Contract or Order number, Item number, contract description of supplies or services, sizes, quantities, unit prices and extended totals. Bill of lading number and weight of shipment will be shown for shipments on Government Bills of Lading. Unless otherwise specified, payment will be made on partial deliveries accepted by the Government when the amount due on such deliveries so warrants.

4. DISCOUNTS - In connection with any discount offered, time will be computed from date of delivery of the supplies to carrier when acceptance is at the point of origin, or from date of delivery at destination or port of embarkation when delivery and acceptance are at either of these points, or from the date the correct invoice or voucher is received in the office specified by the Government, if the latter is later than date of delivery. Payment is deemed to be made for the purpose of earning the discount on the date of mailing of the Government check.

5. DISPUTES - (a) Except as otherwise provided in this contract, any dispute concerning a question of fact arising under this contract which is not disposed of by agreement shall be decided by the Contracting Officer, who shall mail or otherwise furnish a copy thereof to the Contractor. This decision shall be final and conclusive unless, within 30 days from the date of receipt of such copy, the Contractor mails or otherwise furnishes to the Contracting Officer a written appeal addressed to the Secretary. The decision of the Secretary or his duly authorized representative for the determination of such appeals shall be final and conclusive unless determined by a court of competent jurisdiction to have been fraudulent, or capricious, or arbitrary, or so grossly erroneous as necessarily to imply bad faith, or not supported by substantial evidence. The Contractor shall be afforded an opportunity to be heard and to offer evidence in support of his appeal. Pending final decision of a dispute hereunder, the Contractor shall proceed diligently with the performance of the contract and in accordance with the Contracting Officer's decision. (b) This "Disputes" clause does not preclude consideration of law questions in connection with decisions provided for in (a) above, provided, that nothing in this contract shall be construed as making final the decision of any administrative official, representative, or board on a question of law.

6. FOREIGN SUPPLIES - This contract is subject to the Buy American Act (41 U.S.C. 10a-d) as implemented by Executive Order 10582 of December 17, 1954, and any restrictions in appropriation acts on the procurement of foreign supplies.

7. CONVICT LABOR - The Contractor agrees not to employ for work under this contract any person undergoing sentence of imprisonment at hard labor.

8. OFFICIALS NOT TO BENEFIT - No member of or Delegate to Congress or resident commissioner, shall be admitted to any share or part of this contract, or to any benefit that may arise therefrom, but this provision shall not be construed to extend to this contract if made with a corporation for its general benefit.

9. COVENANT AGAINST CONTINGENT FEES - The Contractor warrants that no person or selling agency has been employed or retained to solicit or secure this contract upon an agreement or understanding for a commission, percentage, brokerage, or contingent fee, excepting bona fide employees or bona fide established commercial or selling agencies maintained by the Contractor for the purpose of securing business. For breach or violation of this warranty the Government shall have the right to annul this contract without liability or in its discretion to deduct from the contract price or consideration or otherwise recover, the full amount of such commission, percentage, brokerage or contingent fee.

10. GRATUITIES - (a) The Government may, by written notice to the Contractor, terminate the right of the Contractor to proceed under this contract if it is found after notice and hearing, by the Secretary or his duly authorized representative, that gratuities (*in the form of entertainment, gifts or otherwise*) were offered or given by the Contractor, or any agent or representative of the Contractor, to any officer or employee of the Government with a view toward securing a contract or securing favorable treatment with respect to the awarding or amending, or the making of any determinations with respect to the performing of such contract, provided, that the existence of the facts upon which the Secretary or his duly authorized representative makes such findings shall be in issue and may be reviewed in any competent court. (b) In the event this contract is terminated as provided in paragraph (a) hereof the Government shall be entitled (i) to pursue the same remedies against the Contractor as it could pursue in the event of a breach of the contract by the Contractor and (ii) as a penalty in addition to any other damages to which it may be entitled by law to exemplary damages in an amount (*as determined by the Secretary or his duly authorized representative*) which shall be not less than three nor more than ten times the costs incurred by the Contractor in providing any such gratuities to any such officer or employee. (c) The rights and remedies of the Government provided in this clause shall not be exclusive and are in addition to any other rights and remedies provided by law or under this contract.

11. RENEGOTIATION - This contract, and any subcontract hereunder, is subject to the Renegotiation Act of 1951, as amended (50 U.S.C. App. 1211 *et seq.*) and shall be deemed to contain all the provisions required by Section 104 thereof, and is subject to any subsequent act of Congress providing for the renegotiation of contracts.

12. CONDITION FOR ASSIGNMENT - This Purchase Order may not be assigned pursuant to the Assignment of Claims Act of 1940, as amended (31 U.S.C. 203, 41 U.S.C. 15), unless or until the supplier has been requested and has accepted this order by executing the Acceptance hereon.

13. COMMERCIAL WARRANTY - The Contractor agrees that the supplies or services furnished under this contract shall be covered by the most favorable commercial warranties the Contractor gives to any customer for such supplies or services and that the rights and remedies provided herein are in addition to and do not limit any rights afforded to the Government by any other clause of this contract.

14. PRIORITIES, ALLOCATIONS AND ALLOTMENTS DEFENSE MATERIALS SYSTEM - When the amount of the order is \$500 or more the Contractor shall follow the provisions of DMS Reg. 1 and all other applicable regulations and orders of the Business and Defense Services Administration in obtaining controlled materials and other products and materials needed to fill this order.

15. FAST PAYMENT PROCEDURE -

(a) *General*. This is a fast payment order. Invoices will be paid on the basis of the Contractor's delivery to a post office, common carrier, or, in shipment by other means, to the point of first receipt by the Government.

(b) *Responsibility for Supplies*. Title to the supplies shall vest in the Government upon delivery to a post office or common carrier for shipment to the specified destination. If shipment is by means other than post office or common carrier, title to the supplies shall vest in the Government upon delivery to the point of first receipt by the Government. Notwithstanding any other provision of the purchase order, the Contractor shall assume all responsibility and risk of loss for supplies (i) not received at destination, (ii) damaged in transit, or (iii) not conforming to purchase requirements. The Contractor shall either replace, repair, or correct such supplies promptly at his expense, *provided* instructions to do so are furnished by the Contracting Officer within ninety (90) days from the date title to the supplies vests in the Government.

(c) *Preparation of Invoice*.

(1) Upon delivery of supplies to a post office, common carrier, or in shipments by other means, the point of first receipt by the Government, the Contractor shall prepare an invoice in accordance with Clause 3 of the General Provisions of Purchase Order, except that invoices under a blanket purchase agreement shall be prepared in accordance with the provisions of the agreement. In shipments by either post office or common carrier, the Contractor shall either (A) cite on his invoice the date of shipment, name and address of carrier, bill of lading number or other shipment document number, or (B) attach copies of such documents to his invoice as evidence of shipment. In addition the invoice shall be prominently marked "Fast Pay." In case of delivery by other than post office or common carrier, a receipted copy of the Contractor's delivery document shall be attached to the invoice as evidence of delivery.

(2) If the purchase price excludes the cost of transportation, the Contractor shall enter the prepaid shipping cost on the invoice as a separate item. The cost of parcel post insurance will not be paid by the Government. If transportation charges are separately stated on the invoice, the Contractor agrees to retain related paid freight bills or other transportation billings paid separately for a period of three years and to furnish such bills to the Government when requested for audit purposes.

(d) *Certification of Invoice*. The Contractor agrees that the submission of an invoice to the Government for payment is a certification that the supplies for which the Government is being billed have been shipped or delivered in accordance with shipping instructions issued by the ordering officer, in the quantities shown on the invoice, and that such supplies are in the quantity and of the quality designated by the cited purchase order.

OUTER SHIPPING CONTAINERS SHALL BE MARKED "FAST PAY"

16. (*This clause applies if this contract is for services and is not exempted by applicable regulations of the Department of Labor.*)

SERVICE CONTRACT ACT OF 1965 - Except to the extent that an exemption, variation, or tolerance would apply pursuant to 29 CFR 4.6 if this were a contract in excess of \$2,500, the Contractor and any subcontractor hereunder shall pay all of his employees engaged in performing work on the contract not less than the minimum wage specified under section 6(a)(1) of the Fair Labor Standards Act of 1938, as amended (\$1.60 per hour). However, in cases where section 6(e)(2) of the Fair Labor Standards Act of 1938 is applicable, the rates specified therein will apply. All regulations and interpretations of the Service Contract Act of 1965 expressed in 29 CFR Part 4 are hereby incorporated by reference in this contract.

ADDITIONAL GENERAL PROVISIONS

17. CHANGES - The Contracting Officer may at any time, by a written order, and without notice to the supplier, make changes, within the general scope of this contract, in (i) drawings, designs, or specifications, where the supplies to be furnished are to be specially manufactured for the Government in accordance therewith; (ii) method of shipment or packing; and (iii) place of delivery. If any such change causes an increase or decrease in the cost of, or the time required for performance of this contract, whether changed or not changed by any such order, an equitable adjustment shall be made by written modification of this contract. Any claim by the Contractor for adjustment under this clause must be asserted within 30 days from the date of receipt by the Contractor of the notification of change provided that the Contracting Officer, if he decides that the facts justify such action, may receive and act upon any such claim if asserted prior to final payment, under this contract. Failure to agree to any adjustment shall be a dispute concerning a question of fact within the meaning of the clause of this contract entitled "Disputes." However, nothing in this clause shall excuse the Contractor from proceeding with the contract as changed.

18. TERMINATION FOR DEFAULT - The Contracting Officer, by written notice, may terminate this contract, in whole or in part, for failure of the Contractor to perform any of the provisions hereof. In such event, the Contractor shall be liable for damages, including the excess cost of reprocurring similar supplies or services; provided that, if (i) it is determined for any reason that the Contractor was not in default or (ii) the Contractor's failure to perform is without his and his subcontractor's control, fault or negligence, the termination shall be deemed to be a termination for convenience under paragraph 15. As used in this provision the term "subcontractor" and "subcontractors" means subcontractors at any tier.

19. TERMINATION FOR CONVENIENCE - The Contracting Officer, by written notice, may terminate this contract, in whole or in part, when it is in the best interest of the Government. If this contract is for supplies and is so terminated, the Contractor shall be compensated in accordance with Section VIII of the Armed Services Procurement Regulation, in effect on this contract's date. To the extent that this contract is for services and is so terminated, the Government shall be liable only for payment in accordance with the payment provisions of this contract for services rendered prior to the effective date of termination.

20. ASSIGNMENT OF CLAIMS - Claims for monies due or to become due under this contract shall be assigned only pursuant to the Assignment of Claims Act of 1940, as amended (31 U.S.C. 203, 41 U.S.C. 15). However, payments to an assignee of monies under this contract shall not, to the extent provided in said Act, as amended, be subject to reduction or set-off. (*See Clause 12.*)

ACCEPTANCE

The Contractor hereby accepts the offer represented by this numbered purchase order as it may previously have been or is now modified, subject to all of the terms and conditions set forth, and agrees to perform the same.

NAME OF CONTRACTOR	
SIGNATURE	
TYPED NAME AND TITLE	DATE SIGNED

REMARKS

WATER ANALYSIS

By N. H. Kellan

Date 12-17-41

Sample from Well No. 6 Per Area

210 ft Deep 2nd Sample

24 hrs Pumping

Total Solids 268 PPM Volatile Solids 62 PPM

Suspended Solids 32 " Dissolved Solids 236 "

Phenolphthalein Alkalinity 0 " Silica 24 "

Total Alkalinity 200 " Ferrous Iron 0 "

Chlorides 16 " Total Iron 1.2 "

Sulphates 15 " Aluminum 1.7 "

Carbonates 0 " Calcium 72.8 "

Bicarbonates 200 " Magnesium 5.8 "

Sodium 0.9 "

pH 7.3 Soap Hardness as CaCO₃ 210 "

Mineral Hardness as CaCO₃ _____ "

Odor Very slight

Turbidity 10

REMARKS Nitrites = 0

WATER ANALYSIS

Item	Quantity	Unit
Unfiltered Solids		mg/l
Filtered Solids		mg/l
Total Solids		mg/l
Total Hardness		mg/l
Total Chloride		mg/l
Total Sulfate		mg/l
Total Calcium		mg/l

Report prepared on 10/10/1968

Analyst: J. H. Smith

Checked: M. J. Jones

Date: 10/10/68

Remarks:

Water sample collected from the main line at the water treatment plant.

Analysis performed in accordance with standard methods.

PHYSICAL AND CHEMICAL ANALYSIS OF WATER

SAMPLE NO.

FROM: (Station or unit)

Well 6

DATE

8-1-57

TO: (Name and location of laboratory)

SAMPLE FROM (Location of sampling point)

COLLECTED BY

Chadwick

DATE

8-1-57

HOUR

SOURCE (Designate ground, surface, raw, treated)

Raw

REASON FOR EXAMINATION

EXAMINATION REQUESTED BY

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

I. FIELD ANALYSIS			III. ROUTINE LABORATORY ANALYSIS		
1. pH	TEMPERATURE		(CHECK ONE)		
	°F	°C	REQUESTED	NOT REQUESTED	
ITEM	PPM		1. COLOR		
2. CARBON DIOXIDE (CO ₂)			2. TURBIDITY		
3. DISSOLVED OXYGEN (O ₂)			3. ALKALINITY (CaCO ₃)		
4. HYDROGEN SULFIDE (H ₂ S)			P	MO	
5. CHLORINE DEMAND (Cl ₂)			0	154	
FIELD ANALYSIS BY			4. TOTAL HARDNESS (CaCO ₃)		
DATE OF ANALYSIS			158		
II. SPECIAL LABORATORY ANALYSES			5. NON-CARBONATE HARDNESS (CaCO ₃) (By Computation)		
Check (X) individual items to be included in the Special Analyses. Request determination only of those substances suspected of being present in significant amounts.			6. CARBONATE HARDNESS (CaCO ₃) (By Computation)		
(X)	ITEM	PPM	7. TOTAL DISSOLVED SOLIDS		
1. As			8. SPECIFIC CONDUCTANCE (Micromhos)		
2. Se			ITEM		
3. Pb			PPM		
4. B			9. CALCIUM (Ca)		
5. Cu			10. MAGNESIUM (Mg)		
6. Zn			11. SODIUM (Na) AND POTASSIUM (K)		
7. Cr (Hexavalent)			12. HYDROXIDE (OH) ⁻ CaCO ₃		
8. PO			13. BICARBONATE (HCO ₃) ⁻ CaCO ₃		
9. Cd			14. CARBONATE (CO ₃) ⁻ CaCO ₃		
10. CN			15. SULFATE (SO ₄)		
11. Phenolic Compounds (PPB)			16. CHLORIDE (Cl)		
12. Others (Specify)			17. NITRATE (NO ₃)		
13.			18. IRON (Fe) TOTAL		
14.			19. MAGANESE (Mn)		
15.			20. SILICA (SiO ₂)		
16.			21. FLUORIDE (F)		

*State whether determined or computed from P and MO alkalinity.

REMARKS (Such as unusual appearance, taste, odor, etc.)

LABORATORY ANALYSIS BY

Justice

DATE OF ANALYSIS

8-1-57



Sample No.	Volume (ml)	Temperature (°C)	Conductivity (μmhos/cm)	pH	Total Solids (mg/l)	Dissolved Solids (mg/l)	Suspended Solids (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Hardness (mg/l)
1	100	20	150	7.5	100	80	20	10	5	15
2	100	25	180	7.8	120	100	20	15	10	25
3	100	30	210	8.0	140	120	20	20	15	35
4	100	35	240	8.2	160	140	20	25	20	45
5	100	40	270	8.4	180	160	20	30	25	55
6	100	45	300	8.6	200	180	20	35	30	65
7	100	50	330	8.8	220	200	20	40	35	75
8	100	55	360	9.0	240	220	20	45	40	85
9	100	60	390	9.2	260	240	20	50	45	95
10	100	65	420	9.4	280	260	20	55	50	105

PHYSICAL AND CHEMICAL ANALYSIS OF WATER

SAMPLE NO. *W/W 2-9*

FROM: (Station or unit)

U.S. Marine Corps Base, Camp Lejeune, North Carolina

DATE

1 March 1960

TO: (Name and location of laboratory)

DPWO Sanitary Engineering Laboratory, Bldg. 4-29, Naval Base, Norfolk II, Virginia

SAMPLE FROM (Location of sampling point)

Hadnot Point Area Well No. 6, Bldg. No. 606

COLLECTED BY

Mr. R. L. Cox

DATE

3 Feb. 1960

HOUR

-

SOURCE (Designate ground, surface, raw, treated)

Ground

REASON FOR EXAMINATION

E.S.R. DPWO PROJECT NO. 09-2455

EXAMINATION REQUESTED BY

Mr. R. L. Cox

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

I. Laboratory FIELD ANALYSIS

1. pH	TEMPERATURE	
	°F	°C <i>24.</i>
ITEM	PPM	
2. CARBON DIOXIDE (CO ₂)		
3. DISSOLVED OXYGEN (O ₂)		
4. HYDROGEN SULFIDE (H ₂ S)		
5. CHLORINE DEMAND (Cl ₂)		

FIELD ANALYSIS BY

The temperature of the water at time of collection was 18°C.

DATE OF ANALYSIS

II. SPECIAL LABORATORY ANALYSES

Check (X) individual items to be included in the Special Analyses. Request determination only of those substances suspected of being present in significant amounts.

(X)	ITEM	PPM
	1. As	
	2. Se	
	3. Pb	
	4. B	
	5. Cu	
	6. Zn	
	7. Cr (Hexavalent)	
X	8. PO ₄	<i>0.0</i>
	9. Cd	
	10. CN	
	11. Phenolic Compounds (PPB)	
	12. Others (Specify)	
X	13. Aluminum (Al)	<i>0.0</i>
	14.	
	15.	
	16.	

III. ROUTINE LABORATORY ANALYSIS

(CHECK ONE)	
REQUESTED	NOT REQUESTED
X	
1. COLOR	<i>Apparent 20.</i>
	<i>True 5.</i>
2. TURBIDITY	<i>settled 1.6</i>
	<i>Shaken 3.0</i>
3.	ALKALINITY (CaCO ₃)
P	MO
	<i>0.0 170.</i>
4. TOTAL HARDNESS (CaCO ₃)	<i>172.</i>
	<i>(Ca+Mg) Hardness 171.</i>
5. NON-CARBONATE HARDNESS (CaCO ₃) (By Computation)	<i>2.</i>
6. CARBONATE HARDNESS (CaCO ₃) (By Computation)	<i>170.</i>
7. TOTAL DISSOLVED SOLIDS	<i>-</i>
8. SPECIFIC CONDUCTANCE (Micromhos)	<i>300.</i>
	ITEM PPM
	9. CALCIUM (Ca) <i>63.</i>
	10. MAGNESIUM (Mg) <i>3.33</i>
	11. SODIUM (Na) AND POTASSIUM (K) <i>**</i> <i>616</i>
	12. HYDROXIDE (OH)* <i>(as CaCO₃) 0.0</i>
	13. BICARBONATE (HCO ₃)* <i>(as CaCO₃) 170.</i>
	14. CARBONATE (CO ₃)* <i>(as CaCO₃) 0.0</i>
	15. SULFATE (SO ₄) <i>1.6</i>
	16. CHLORIDE (Cl) <i>10.</i>
	17. NITRATE (NO ₃) <i>-</i>
	18. IRON (Fe) TOTAL <i>.40</i>
	19. MAGANESE (Mn) <i>0.0</i>
	20. SILICA (SiO ₂) <i>10.</i>
	21. FLUORIDE (F) <i>0.0</i>

*State whether determined or computed from P and MO alkalinity.

REMARKS (Such as unusual appearance, taste, odor, etc.)

** Computed from P and MO alkalinity*
*** Computed*
Note: At the time of analysis, there was a small quantity of sediment in the bottom of the sample bottle. The well was in service at the time the sample was collected (discharge pressure = 22.5 psig)

LABORATORY ANALYSIS BY

George I. Earnest, Jr., Chemist

DATE OF ANALYSIS

29 Feb. 1960

DATE: SOURCE: (Describe source, name, etc.)

ANALYST: (Name)

LOCATION: (Address, City, State, Zip)

FIELD ANALYSIS

DATE OF ANALYSIS: TIME OF ANALYSIS:

WEATHER: (Temperature, Humidity, Wind, etc.)

QUALITY (Color):

TOTAL SOLIDS (ppt):

NON-CALCAREOUS SOLIDS (ppt):

ANALYST'S SIGNATURE: (Name)

REMARKS: (Notes on sample, conditions, etc.)

ITEM	RESULT
1. pH	
2. TOTAL SOLIDS (ppt)	
3. NON-CALCAREOUS SOLIDS (ppt)	
4. CHLORIDE (ppm)	
5. SULFATE (ppm)	
6. HARDNESS (ppm)	
7. ALKALINITY (ppm)	
8. TOTAL SOLIDS (ppt)	
9. NON-CALCAREOUS SOLIDS (ppt)	
10. CHLORIDE (ppm)	
11. SULFATE (ppm)	
12. HARDNESS (ppm)	
13. ALKALINITY (ppm)	
14. TOTAL SOLIDS (ppt)	
15. NON-CALCAREOUS SOLIDS (ppt)	
16. CHLORIDE (ppm)	
17. SULFATE (ppm)	
18. HARDNESS (ppm)	
19. ALKALINITY (ppm)	
20. TOTAL SOLIDS (ppt)	
21. NON-CALCAREOUS SOLIDS (ppt)	
22. CHLORIDE (ppm)	
23. SULFATE (ppm)	
24. HARDNESS (ppm)	
25. ALKALINITY (ppm)	

ANALYST'S SIGNATURE: (Name)

REMARKS: (Notes on sample, conditions, etc.)

DATE OF ANALYSIS: TIME OF ANALYSIS:

WEATHER: (Temperature, Humidity, Wind, etc.)

U.S. DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE MC	2. TYPE Q	3. LATITUDE ° ' " N 34 39 49	4. LONGITUDE ° ' " W 77 19 10	5.
-----------------------------	---------------------	-------------------------------------------	--------------------------------------------	----

6. AGENCY STATION NO. 606	7. STATION NAME HP20-606
-------------------------------------	------------------------------------

8. DRAINAGE BASIN CODE No. Letter 06 N	9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONslow
-----------------------------------------------------	----------------------------	-------------------------------	----------------------------------

12. PERIOD OF RECORD Began Discontinued 1942	Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption <input type="checkbox"/> Exceeds 1 Year	13.	14.
-----------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------	-----	-----

15. SITE <input type="checkbox"/> 101 Stream <input type="checkbox"/> 102 Canal	<input type="checkbox"/> 103 Lake <input type="checkbox"/> 104 Reservoir <input type="checkbox"/> 105 Estuary	<input type="checkbox"/> 106 Spring <input checked="" type="checkbox"/> 107 Well <input type="checkbox"/> 110 Other
---------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------

16. FREQUENCY OF MEASUREMENT <input type="checkbox"/> 201 Continuous Recorder <input type="checkbox"/> 202 Telemetered	<input type="checkbox"/> 203 Daily <input type="checkbox"/> 204 Weekly <input type="checkbox"/> 205 Monthly <input type="checkbox"/> 206 Quarterly	<input type="checkbox"/> 207 Seasonal <input type="checkbox"/> 208 Annual <input type="checkbox"/> 209 Other Periodic <input checked="" type="checkbox"/> 210 Occasional
------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

17. TYPES OF DATA AVAILABLE <i>Physical</i> <input type="checkbox"/> 311 Temperature <input type="checkbox"/> 312 Specific Conductance <input type="checkbox"/> 313 Turbidity <input type="checkbox"/> 314 Color <input type="checkbox"/> 315 Odor <input type="checkbox"/> 316 Radioactivity <input type="checkbox"/> 317 pH (field) <input checked="" type="checkbox"/> 318 pH (lab) <input type="checkbox"/> 319 Eh <input type="checkbox"/> 320 Other	<i>Chemical</i> <input type="checkbox"/> 331 Dissolved solids <input checked="" type="checkbox"/> 332 Chlorides Only <input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds) <input type="checkbox"/> 334 Common ions <input checked="" type="checkbox"/> 335 Hardness <input type="checkbox"/> 336 Radiochemical <input type="checkbox"/> 337 Dissolved oxygen <input type="checkbox"/> 338 Other Gases <input type="checkbox"/> 339 Other	<i>Organic</i> <input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.) <input type="checkbox"/> 352 Synthetic detergents <input type="checkbox"/> 353 Other <i>Biologic</i> <input type="checkbox"/> 361 Coliforms <input type="checkbox"/> 362 Other Micro-organisms <input type="checkbox"/> 363 BOD <input type="checkbox"/> 364 Other <i>Sediment</i> <input type="checkbox"/> 371 Concentration <input type="checkbox"/> 372 Particle size <input type="checkbox"/> 373 Other
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

18. SUPPLEMENTARY DATA FOR SITE <input type="checkbox"/> 421 Surface Water Station <input type="checkbox"/> 422 Ground Water Station	<input type="checkbox"/> 423 Water Stage or Level <input checked="" type="checkbox"/> 424 Water discharge	<input type="checkbox"/> 425 Time of Travel <input type="checkbox"/> 426 Drainage Area
--------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------

19. STORAGE OF DATA <input type="checkbox"/> 501 Periodic Report <input type="checkbox"/> 502 Areal Report	<input checked="" type="checkbox"/> 503 Not Published <input type="checkbox"/> 504 Data on Punchcard	<input type="checkbox"/> 505 Data on Magnetic Tape <input type="checkbox"/> 506 Other
------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------

20. OFFICE AT WHICH DATA AVAILABLE		
Office	BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION	
Street No.	MARINE CORPS BASE	City Code
City, State, Zip	CAMP LEJEUNE, N. C. 28512	0735

21. OFFICE COMPLETING FORM BASE MAINTENANCE DEPARTMENT

22. COMPILER'S NAME F. E. TEV. JR.	23. DATE Month Year SEPT. 19 66
---------------------------------------	---------------------------------------



Handwritten scribble or mark in the upper middle section of the page.

Handwritten scribble or mark in the middle right section of the page.

Handwritten scribble or mark in the lower middle section of the page.

#6 WELL

+34.4
AIR LINE 70'
- 35.6

GAGUÉ

STATIC	PUMP LID	D. D.	DIS. PRES.	G.P.M.	SEA LEVEL
42			13	est. 50 gal	
			11	108	
			9	108	
			7	122	

AIR LINE NO GOOD

SHOT OFF HEAD 18#

LINE PRESSURE 6#

RUNNING AT 9#




Well #.6

Date	Line Ft.	G.P.M.	D.D. El.	Static El.	Shut Off Head	D.D. Ft.
2-11-54	53					
			Gage Ft.			
10-14-54	55		23			
11-21-66	^{AIR} 70'	232	24	42	38	18
8-3-69		108	AIR	LINE	BAD	SEE WELL TEST.

17 FT TO WATER, 9-10-53:

as of 3/1/67 well 6 has perless pump

Air Line



W. C. Kellum

Marine Barracks
New River, N. C.

WELLS-PERMANENT WATER SUPPLY-REGIMENTAL AREA
By Layne Atlantic Company

Project P-108-4

WELL NO. 6 (6th Layne Well)
As on M. B. Drawing #251

Location: Approximately 5000' S.S.E. of intersection of
Main Access Road and Oak Street (Supply & Ind. Area).

Date Drilled: December 1941.

Drilling Equipment: Rotary Rig and Rotary Bit

Status of Well: An 18" diameter pit casing was set in a 23" diameter
hole and a depth of 23'-8", and the annular space
filled with Portland Cement Grout.

A 17" diameter hole was drilled below the casing
to a depth of 220 feet, and hydraulically underreamed
the portion of the hole below the 18" casing.
After underreaming, the hole was cleaned out with
the 17½" rotary bit. An 8" diameter casing with
silicon bronze shutter screens at various points
(see Log of Casing) to a depth of 210 feet below
the surface. The space between the 8" casing and the
limits of the underreaming in the sand strata was
filled with about 35 yds. of Cape May Gravel, by the
circulation method.

Status Water Level: 14'-6" below ground level.

Tests: Ran pump 31 hours getting constant discharge of
350 G.P.M. with a 60' D.D. - after shutting down for
for 24 hours, pumping was resumed and showed an
average of 345 G.P.M. with a draw down of 59'-6".

Water analysis dated December 4, 1941, December 15, 1941,
and December 17, 1941, were made.

WATER SUPPLY SYSTEM WITH SUBMERGED
N. C. Water Supply Company

Sheet 7-103-1

WELL NO. 2 (Old Lake Well)
As on U. S. Drawing 1031

Approximate 2000' E. 2. E. of intersection of
Main Access Road and the Street (Entry & Exit Area)

Location

December 1941

Date drilled

Water 1 1/2 and 1 1/2 ft

Drilling equipment

An 1 1/2" diameter pipe was set in a 2 1/2" diameter
hole and a length of 23' 6" and the annular space
filled with Portland Cement Grout.

Status of Well:

A 1 1/2" diameter hole was drilled below the casing
to a depth of 230 feet, and hydraulically underground
the portion of the hole below the 1 1/2" casing.
After installation, the hole was cleaned out with
the 1 1/2" casing. An 8 1/2" diameter casing was
run from the surface through various obstructions
(not too far) to a depth of 110 feet below
the surface. The space between the 8 1/2" casing and the
1 1/2" casing was filled with cement grout. The
1 1/2" casing was set in place of pipe 1 1/2" in the
circulation system.

1 1/2" below ground level

Station Water Level:

Two days after casing was installed
230' E. 2. E. after drilling down for
for 23 hours, pumping was resumed and tested an
average of 23' E. 2. E. with a flow down of 10-15 gpm.

Notes

Water analysis from December 4, 1941, December 11, 1941,
and December 17, 1941, were made.

W E L L D A T A

Well No. 6

SPECIFICATIONS

Pump Base Elevation	34.40
Ground Elevation	32.4
Static Elevation	19.4
Maximum allowed Drawdown	-22

TEST

300 G.P.M.	10 $\frac{1}{2}$ Pressure	Drawdown	-12.6
285 G.P.M.	12 $\frac{1}{2}$ Pressure	Drawdown	-10.6
275 G.P.M.	15 $\frac{1}{2}$ Pressure	Drawdown	- 8.6
260 G.P.M.	18 $\frac{1}{2}$ Pressure	Drawdown	- 6.6
250 G.P.M.	20 $\frac{1}{2}$ Pressure	Drawdown	- 5.6
210 G.P.M.	25 $\frac{1}{2}$ Pressure	Drawdown	✓ 2.4

Recovers to static in three (3) minutes.

Air line figured 70'

SECRET

SECRET

SECRET

SECRET

SECRET

SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET
SECRET	SECRET	SECRET	SECRET

SECRET

SECRET

Log of Formations:	0' - 30'	Fine white sand packed hard
	30' - 40'	Medium coarse sand
	40' - 49'	Fine grey sand
	49' - 65'	Shell rock
	65' - 73'	Sand and shell
	73' - 74'	Hard rock
	74' - 82'	Layers sand and shell
	82' - 87'	Hard and soft layers shell rock
	87' - 105'	Shell rock with sand and clay mixed
	105' - 114'	Soft shell with same sand
	114' - 131'	Shell and sand
	131' - 135'	Hard shell rock
	135' - 140'	Soft Shell
	140' - 160'	Soft shell rock with soft and pepper sand
	160' - 165'	Soft and pepper sand
	165' - 174'	Hard rock (Rough drilling)
	174' - 182'	Hard and soft layers of shell rock
	182' - 196'	Soft Rock
	196' - 204'	Medium tight sand
	204' - 220'	Hard packed soft and pepper sand

Log of Casing:	0 - 80	Blank pipe
	80 - 90	Silicon bronze screen
	90 - 110	Blank pipe
	110 - 120	Silicon bronze screen
	120 - 140	Blank pipe
	140 - 150	Silicon bronze screen
	150 - 170	Blank pipe
	170 - 180	Silicon bronze screen
	180 - 200	Blank pipe
	200 - 210	Silicon bronze screen
	210 - 220	Cement plug

John E. Womeldorf

Layer	Thickness (ft)	Description
1	0 - 10	Top of formation
2	10 - 20	Light gray sand
3	20 - 30	Medium coarse sand
4	30 - 40	Light gray sand
5	40 - 50	Shell rock
6	50 - 60	Hard sand shell
7	60 - 70	Hard rock
8	70 - 80	Layer of sand and shell
9	80 - 90	Four feet gravel and sand
10	90 - 100	Well rock with sand and clay shales
11	100 - 110	Soft shale with sand and clay shales
12	110 - 120	Hard shale rock
13	120 - 130	Hard shale rock
14	130 - 140	Soft shale rock with sand and gravel
15	140 - 150	Hard rock (brown shale)
16	150 - 160	Hard rock (brown shale)
17	160 - 170	Soft rock
18	170 - 180	Medium light sand
19	180 - 190	Hard rock (brown shale)
20	190 - 200	Hard rock (brown shale)

Layer	Thickness (ft)	Description
21	0 - 10	Top of formation
22	10 - 20	Light gray sand
23	20 - 30	Medium coarse sand
24	30 - 40	Light gray sand
25	40 - 50	Shell rock
26	50 - 60	Hard sand shell
27	60 - 70	Hard rock
28	70 - 80	Layer of sand and shell
29	80 - 90	Four feet gravel and sand
30	90 - 100	Well rock with sand and clay shales
31	100 - 110	Soft shale with sand and clay shales
32	110 - 120	Hard shale rock
33	120 - 130	Hard shale rock
34	130 - 140	Soft shale rock with sand and gravel
35	140 - 150	Hard rock (brown shale)
36	150 - 160	Hard rock (brown shale)
37	160 - 170	Soft rock
38	170 - 180	Medium light sand
39	180 - 190	Hard rock (brown shale)
40	190 - 200	Hard rock (brown shale)

Continued on next page

well
HP 606

Typed 4/27/77

PUMP, LAYNE VERTICAL TURBINE
DEEP WELL, WATER LUBRICATED
COMPLETE WITH ELECTRIC MOTOR
VOLTS, 220/440 H.P. 7 1/2 PHASE 3
RPM 1800

SETTING 80'

~~SIZE~~ SIZE 5"

STAGE 4

GPM 200

TDH 86'

SUCTION PIPE 5' X 10'

~~STRAINER~~

EA. 1 @ \$3,000.00

SS: AURORA PUMP CO.
3048 MILLER ROAD
LITHONIA GA. 30058

WORK REQUEST


Replace Deep well pump in Bldg HP-606

No labor

cost

3000.00

Utilities to Reg and maint to
install



H.P. weil 606

SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 4 9 5

PWSID
0467041

Owner Assigned
source Code

Well Name (If purchase, name of system)

607 HADNOT POINT 607

Code

G

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

Source exempt—
SWIR?

Direct Influence Date

Availability

Source Begin Date: M M Y Y
Direct Influence Date: M M D D Y Y
SWIR? Y N

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (If purchase, location of master meter)

MARYLAND AVE BERKELEY MANOR

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

Latitude: Deg. Min. Sec. 3 4 4 2 2 4 2
Longitude: Deg. Min. Sec. 0 7 7 2 0 4 3 7
How Determined: G (G=GPS, M=Map, S=Surveyed)
GPS Data: Q# or DOP # 9 2
No. of Sats. Locked on: 4

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N
Assessment Date: M M D D Y Y

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned
Entry Point Code

Entry Point Name

C=Ground/Permanent
D=Ground/non-permanent

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

100 ~~HP 607 MCB~~ HADNOT PT WTP

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance: San SWR line @ 50' (RV dump cleanout)

Surface water within 200'? (Y,N) If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance: OK

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: OK Type of freeze protection: elec heat

Well: Diameter: 8" Type: GRAVEL PACK Yield (gpm): 393 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth 50 ft. (If unknown, put 'UNK') Well depth: 310 Meter available? (Y,N)

Concrete slab adequate? (Y,N) If no, explain: Size: 12x12

Size of blow-off: 4" (v) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 200 HP: 15 Pump intake depth: 80 Auxiliary Power? (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 15"

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)

High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)

Is the water treated at this well? (Y,N) If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where? H-20 PLANT

If purchase, retreat? (Y,N) If yes, complete back of form.

① No well casing vent
② Sewer clean station s/s removed



DATE 7-25-00

PWSID 04-67-041

WELL # HP 607

WELL NAME ARMON POINT HP-20

BLDG. HP 607

CODE S

AVAILABILITY D

LOCATION MARYLAND AVENUE BERKLEY MANDR.

LATITUDE 34.70716

LONGITUDE 77.34622

WELL DIAMETER 8"

WELL DEPTH 210'

SCREEN INTERVAL _____

YIELD 289

STATIC LEVEL 30'

PUMPING LEVEL 82'

PUMP TYPE VERTICAL TURBINE

MOTOR HP 15


INTAKE DEPTH 105

DESIGN CAPACITY 200

ACTUAL GPM 289

SIZE OF CONCRETE SLAB 12X12

HEIGHT OF CASING 15"




WELL NUMBER 607		BY Stevens & Peterson			DATE 7-14-57	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90	35	48	13	70	100	28
		55	20	60	133	35
		45	30	50	192	45
		73	38	40	240	55
		28	43	30	278	05
		82	47	25	289	15

REMARKS

D/H 80 PST


MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



WELL NUMBER 607		BY Brown Steenson			DATE 7-14-94	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90	30	45	15	70	100	
		52	22	60	146	
		61	31	50	205	
		70	40	40	248	
		75	45	30	280	
		79	49	25	293	running * at

REMARKS Dead Head @ 86 PSI replaced shaft (1") by 4 column (5") tail piece & strainer - cleaned &assy old pump, ran 6.8 M @ above

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE




WELL NUMBER <i>607</i>		BY <i>Brown-Stevenson</i>			DATE <i>10-6-93</i>	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
<i>90'</i>	<i>30'</i>	<i>40</i>	<i>10</i>	<i>41</i>	<i>100</i>	<i>0900</i>
		<i>44</i>	<i>14</i>	<i>35</i>	<i>115</i>	<i>0915</i>
		<i>46</i>	<i>16</i>	<i>30</i>	<i>128</i>	<i>0930</i>
		<i>48</i>	<i>18</i>	<i>25</i>	<i>143</i>	<i>0945</i>
		<i>50</i>	<i>20</i>	<i>20</i>	<i>157</i>	<i>1000</i>

REMARKS *Dead Head 60*

*New Column
+ Shaft
Complete 7-11-94*

MANUFACTURER	TOTAL HEAD	SIZE



New Column
& Shaft
Complete

7-11-94


Handwritten text, possibly a list or notes, is visible on the paper. The text is extremely faint and illegible due to the low contrast and blurriness of the scan. Some faint characters and lines are visible, but they cannot be transcribed accurately.

WELL NUMBER 607.		BY Brown - Stevenson			DATE 10-6-93	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90'	30'	40	10	41	100	0900
		44	14	35	115	0915
		46	16	30	128	0930
		48	18	25	143	0945
		50	20	20	157	1000

REMARKS *Dead Head 60*

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE






WELL NUMBER 607		BY Thomas Seltman			DATE 10-17-28	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
90	30	46	16	73	108	10
	44	48	18	67	122	20
		54	24	60	151	30
		58	28	55	170	40
		63	33	50	195	50
		66	36	45	210	00
		69	39	40	224	10
		73	43	35	244	20
		75	45	30	259	30
	→	80	50	25	266	40

REMARKS


MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



Well 607

4-22-86

A-L	S-L	P-L	D-D	PSI	GPM	Time
						0830
105	27	38	11	74	120	15
		40	13	71	145	15
		42	15	68	160	15
		44	17	64	170	15
		47	20	60	190	15
		55	28	50	200	15
		60	33	40	220	15
		67	40	30	240	15
		72	45	20	260	15
		75	48	12	270	15



NORTH CAROLINA DEPARTMENT OF NATURAL AND ECONOMIC RESOURCES

OFFICE OF WATER AND AIR RESOURCES

GROUND WATER DIVISION

P. O. BOX 27687 - RALEIGH, N. C. 27611.

WELL RECORD

DRILLING CONTRACTOR: Carolina Well & Pump Co., Inc REG. NO. 126 WELL CONSTRUCTION PERMIT NO. _____

1. WELL LOCATION: (Show a sketch of the location on back of form)
 Nearest Town: _____ County: Onslow *OLD* *New*

Maryland Ave.
 (Road, Community or Subdivision and Lot No.) Quadrangle No. Well 612 *1007*

2. OWNER: Camp Lejeune

3. ADDRESS: _____

4. TOPOGRAPHY: draw, valley, slope, hilltop, flat

5. USE OF WELL: for Base DATE: 8-21-84

6. DOES THIS WELL REPLACE AN EXISTING WELL? yes

7. TOTAL DEPTH: 210 RIG TYPE OR METHOD: rotary

8. FORMATION SAMPLES COLLECTED: YES No. of Bags _____

9. CASING:

From	Depth	ft.	Inside Diam.	Wall thick. or weight /ft.	Type
0	50	ft.	18"	3/8	steel
0	115		8"	3/8	galv.
135	163		8"	3/8	galv.
175	190		8"	3/8	galv.

10. GROUT:
 From 0 to 50 ft. cement Method pumped

11. SCREEN:

From	Depth	ft.	Diam.	Type and Opening
115	135	ft.	8"	s.s. 20 slot
163	175		8"	s.s. 20 slot
190	200		8"	s.s. 20 slot

12. GRAVEL:

From	Depth	ft.	Size	Material
0	210	ft.		course sand

13. WATER ZONES(depth): as shown

14. STATIC WATER LEVEL: 24.3" ft. above top of casing.
 Casing is 1 ft. above land surface. below top of casing. ELEV. _____
 DATE MEASURED: 8-21-84

15. YIELD(gpm): 275 METHOD OF TESTING: pumped

16. PUMPING WATER LEVEL: 75.1" ft. after 24 hours at 275 gpm.

17. CHLORINATION: Type H.t.H. Amount 3 lbs

18. WATER QUALITY: _____ TEMPERATURE(°F) _____

19. PERMANENT PUMP:(Show a sketch of well head on back of form)

Date installed _____ Type _____ Make _____
 Capacity _____ (gpm) HP _____
 Intake Depth _____ Airline Depth 90'


20. HAVE YOU INFORMED THE WELL OWNER OF THE DEPARTMENTS REQUIREMENTS AND RECOMMENDATIONS? _____

21. REMARKS: _____

I do hereby certify that this well record is true and exact.

Ronald R. E. Miller
 SIGNATURE OF CONTRACTOR OR AGENT DATE _____

DRILLING LOG		
FROM	TO	FORMATION DESCRIPTION
1	8	Sandy clay
8	18	Yellow clay
18	44	Sand
44	60	Sand & clay
60	84	Clay
84	105	Shell rock, soft
105	143	Shell rock, hard
143	158	Clay
158	175	Shell rock, hard
175	186	Clay
186	200	Sand



CONTRACTOR'S SUBMITTAL TRANSMITTAL
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 162470-82-C-2511 TRANSMITTAL NO. Time (9) DATE 6-22-84

FROM CONTRACTOR Onslow Utilities Inc.
 TO ROICC

PROJECT TITLE AND LOCATION
Replace water wells 612 & 626
Camp Lejeune NC.
(Well No 612)

CONTRACTOR USE ONLY

*List only one specification division per form.


List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved ROICC Approval

REVIEWER USE ONLY

- **ACTION CODES**
 A-Approved
 D-Disapproved
 AN-Approved as noted
 RA-Receipt acknowledged.
 C-Comments
 R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
02734		DRILLER'S Log	6	A	CCS 405 7-10-84
"		Electric Log	6		
"		Water Analysis	6		
"		Recommendation AND DATA	6	✓	✓
		Submittal			



CONTRACTOR'S COMMENTS
Submittal for well # 612

COPY TO: FIELD
 DATE: 8-10-84

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

Ronald R. Ellen

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

TO

2 July 84

LANTDIV

Onslow UTILITIES

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS

APPROVED


COPIES TO:
 ROICC (2)
 LANTDIV (1)
 A-E (1)

DATE

SIGNATURE

12 July 84

[Signature]



ONSLow UTILITIES, INC.
General Contractors
Post Office Box 5498
Jacksonville, North Carolina 28540

June 25, 1984

Officer in Charge of Construction
Building 1005, Marine Corps Base
Camp LeJeune, N.C. 28542

Re: N62470-82-C-2541
Replace Water Wells 612 and 626
Camp LeJeune, N.C. 85 110
(Well No. 612)

607

Gentlemen:

We are enclosing six (6) copies of the Driller's Log, Electric Log, and Water Analysis for your review. The test well was drilled 202 feet deep. Water samples were taken at the 127 to 132, 165 to 170 and 193 to 198 levels.

We recommend a line of .20 slot screens set at the 115 to 135, 163 to 175, and 190 to 200 levels for a total of 42 VF of screens. The gravel pack recommended is a course sand. It is our best estimate that this well may yield 200-250 GPM.

Please review the data and advise if we are to proceed with developing a permanent well at this site.

Yours truly,

ONSLow UTILITIES, INC.

Ronald R. Ellen
Ronald R. Ellen, Pres.

RRE/ck
Enclosures

ATLANTIC DIVISION	
NAVAL FACILITIES ENGINEERING COMMAND	
NORFOLK, VIRGINIA 23511	
APPROVED <input checked="" type="checkbox"/>	_____
APPROVED AS NOTED	_____
DISAPPROVED	_____
SUBJECT TO THE REQUIREMENTS OF	
CONTRACT NO. 05-82-2541	
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE	
APPROVAL OF ANY DEVIATION FROM THE CON-	
TRACT REQUIREMENTS UNLESS THE CONTRAC-	
TOR CALLS ATTENTION TO AND SUPPORTS THE	
DEVIATION--THE CONTRACTOR SHALL BE	
RESPONSIBLE FOR PROVIDING PROPER	
PHYSICAL DIMENSIONS & WEIGHTS, COORDINA-	
TION OF TRADES, ETC., AS REQUIRED.	
REVIEWER CCS	DATE 10 JUL 1984
FOR OFFICER IN CHARGE OF CONSTRUCTION	




WELLS WEAVER WELLS AND PUMP COMPANY, INC.

Complete Well and Pump Service

P. O. BOX 1085

TELEPHONE 776-3415

SANFORD, NORTH CAROLINA 27330





N.W.W.A.
N.C.W.W.A.

Onslow Utilities, Inc.
General Contractors
P. O. Box 5498
Jacksonville, N. C. 28540

Contract N62470-82-C-2541
Job Well 612
Location Camp LeJeune, N.C.

0 - 1	top soil
1 - 8	sandy clay
8 - 18	yellow clay
18 - 44	sand
44 - 60	sand & clay
60 - 84	clay
84 - 105	shell rock soft
105 - 143	shell rock hard
143 - 158	clay
158 - 175	shell rock hard
175 - 186	clay
186 - 200	sand



WATER ANALYSIS LABORATORY
802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29512

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(R03) 479-4639

Well # 612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.

Date Analyzed: 5/10/84
Sample Number: 127-132

Analysis Results--Parts Per Million

<u>Determination</u>		<u>Determination</u>	
pH	<u>6.9</u>	Carbon Dioxide (CO ₂)	<u>5</u>
Iron (Fe)	<u>.05</u>	Total Acidity (CaCO ₃)	<u>8</u>
Nitrate (NO ₃)	<u>0.1</u>	Calcium Hardness (CaCO ₃)	<u>172</u>
Fluoride (F)	<u>.5</u>	Magnesium Hardness (CaCO ₃)	<u>22</u>
Manganese (Mn)	<u>Trace</u>	Carbonate Hardness (CaCO ₃)	<u>104</u>
Total Hardness (CaCO ₃)	<u>194</u>	Noncarbonate Hardness (CaCO ₃)	<u>0</u>
Chlorides (Cl)	<u>14</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>8.7</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>220</u>
Magnesium (Mg)	<u>5.3</u>	Total Alkalinity (CaCO ₃)	<u>220</u>
Calcium (Ca)	<u>69</u>	Total Dissolved Solids	<u>238</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°C)	<u>240</u>
Bicarbonate (HCO ₃)	<u>268</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not Objectionable</u>

SIGNED _____
LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE WATER," APHA, AWWA AND WPCF AND "METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES," WATER SUPPLY PAPER 1454 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



Wells Analysis, Goodbye Form

WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29312

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(803) 479-4639

612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.

Date Analyzed: 5/10/84
Sample Number: 165-170

Analysis Results--Parts Per Million

Determination

Determination

pH 6.9

Iron (Fe) .05

Nitrate (NO₃) 0.1

Fluoride (F) .5

Manganese (Mn) .05

Total Hardness (CaCO₃) 180

Chlorides (Cl) 11

Sulfate (SO₄) 77.3

Phosphate (PO₄) 0

Magnesium (Mg) 6.5

Calcium (Ca) 64.4

Carbonate (CO₃) 0

Bicarbonate (HCO₃) 195

Hydroxide (OH) 0

Carbon Dioxide (CO₂) 4

Total Acidity (CaCO₃) 6

Calcium Hardness (CaCO₃) 152

Magnesium Hardness (CaCO₃) 27

Carbonate Hardness (CaCO₃) 160

Noncarbonate Hardness (CaCO₃) 29

Alkalinity (Phenolphthalein) (CaCO₃) 0

Carbonate Alkalinity (CaCO₃) 0

Bicarbonate Alkalinity (CaCO₃) 160

Total Alkalinity (CaCO₃) 160

Total Dissolved Solids 196

Specific Conductance (micromhos at 25°C) 280


Appearance When Analyzed Clear

Odor When Analyzed Not Objectionable

SIGNED

LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: "STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE WATER," APHA, AWWA AND WPCF AND "METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES," WATER SUPPLY PAPER 1434 (1980), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29512

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(RQ3) 479-4639

612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.

Date Analyzed: 5/10/84
Sample Number: 193-198

Analysis Results--Parts Per Million

Determination

Determination


pH	<u>6.7</u>
Iron (Fe)	<u>.1</u>
Nitrate (NO ₃)	<u>Trace</u>
Fluoride (F)	<u>.7</u>
Manganese (Mn)	<u>.05</u>
Total Hardness (CaCO ₃)	<u>153</u>
Chlorides (Cl)	<u>17</u>
Sulfate (SO ₄)	<u>32.9</u>
Phosphate (PO ₄)	<u>0</u>
Magnesium (Mg)	<u>6.9</u>
Calcium (Ca)	<u>49.6</u>
Carbonate (CO ₃)	<u>0</u>
Bicarbonate (HCO ₃)	<u>153</u>
Hydroxide (OH)	<u>0</u>

Carbon Dioxide (CO ₂)	<u>10</u>
Total Acidity (CaCO ₃)	<u>13</u>
Calcium Hardness (CaCO ₃)	<u>124</u>
Magnesium Hardness (CaCO ₃)	<u>29</u>
Carbonate Hardness (CaCO ₃)	<u>125</u>
Noncarbonate Hardness (CaCO ₃)	<u>28</u>
Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Bicarbonate Alkalinity (CaCO ₃)	<u>125</u>
Total Alkalinity (CaCO ₃)	<u>125</u>
Total Dissolved Solids	<u>283</u>
Specific Conductance (micromhos at 25°C)	<u>410</u>
Appearance When Analyzed	<u>Clear</u>
Odor When Analyzed	<u>Not objectionable</u>

SIGNED _____

LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: 'STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE WATER,' APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1434 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



CONTRACTOR'S SUBMITTAL TRANSMITTAL
 5ND LANTDIV 4-4355/3 (Rev. 6/78)

file 60/100
/82

CONTRACT NO 82-B-254	TRANSMITTAL NO 16	DATE 8-28-84
PROJECT TITLE AND LOCATION REPLACE WATER WELLS 6.12+626 MCB, CLNC		

FROM CONTRACTOR
ONSLow UTILITIES, INC
 TO ATLANTIC DIVISION, NAVAL FAC
 ENGR CMD (NAVAL STATION, NORFOLK VA 23571)

CONTRACTOR USE ONLY		REVIEWER USE ONLY
*List only one specification division per form.		**ACTION CODES
List only one of the following categories on each transmittal form, and indicate which is being submitted		A-Approved
<input type="checkbox"/> Contractor Approved	<input checked="" type="checkbox"/> OICC Approval	D-Disapproved
		AN-Approved as noted
		RA-Receipt acknowledged.
		C-Comments
		R-Resubmit



ITEM NO	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. brochure number)	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
1	02734.3.1.6	PUMPING TEST	7 A	gms 9/10/84

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)
C.A. Mallette

DATE RECEIVED BY REVIEWER: **31 AUG 84**

FROM (Reviewer): **LANTDIV**

TO: **ONSLow UTILITIES/ROICC**

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.

REVIEWER'S COMMENTS


APPROVED

COPY TO: FIELD
DATE: 10-15-84

COPIES TO:
 ROICC (2)
 LANTDIV (1)
 A-E (1)

DATE: **11 SEP 84**

SIGNATURE: *J. Haste*



PUMPING TEST DATA

Carolina Well & Pump Co.

R. Patterson & W. Pickard

Well Owner: Camp Lejeune Address: _____
 Pumped Well No.: 612 Location: _____ County: Onslow
 Observation Well Locations: _____
 Airline Lengths: Pumped Well _____ Observation Wells _____
 Remarks: _____

Pumping Rate Measured With: AS Office Water Levels Measured With: E. Tape

PUMP WELL DATA

Date and Time	Elapsed Time Min.	Piezometer Tube Reading Inches	Pumping Rate GPM	Pump Discharge Pressure	Altitude Gauge Reading Feet	Feet to Water	Remarks
8-21-84							
1:00	0	15				24' 3"	
1:05	5	"				66' 9"	
1:10	10	"				67' 10"	
1:15	15	"				68' 6"	
1:20	20	"				69' 8"	
1:25	25	"				70'	
1:30	30	"				70' 3"	
1:35	35	"				70' 7"	
1:40	40	"				70' 7"	
1:45	45	"				70' 7"	
1:50	50	"				70' 9"	
1:55	55	"				71' 2"	
2:00	60	"				71' 1"	
2:05	65	"				71' 1 1/2"	
2:10	70	"				70' 10 1/2"	
2:15	75	"				71' 1"	
2:20	80	"				71' 2"	
2:25	85	"				71' 1"	
2:30	90	"				71' 2"	
2:35	95	"				71' 2"	
2:40	100	"				71' 1"	
2:45	105	"				71' 1"	
2:50	110	"				71' 2 1/2"	
2:55	115	"				71' 1"	
3:00	120	"				70' 10"	
4:00	180	"				72' 3"	
5:00	240	"				72' 3"	
6:00	300	"				72' 11"	
7:00	360	"				72' 8"	
8:00	420	"				73' 6"	
9:00	480	"				74' 3"	
10:00	540	"				74' 5"	
11:00	600	"				74' 6"	
12:00	660	"				74' 6"	
1:00	720	"				74' 5"	
2:00	780	"				74' 5"	
3:00	840	"				74' 5"	
4:00	900	"				74' 5"	
5:00	960	"				74' 8"	
6:00	1020	"				74' 11"	
7:00	1080	"				75' 2"	


ATLANTIC DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
NORFOLK, VIRGINIA 23511

APPROVED ✓
APPROVED AS NOTED
DISAPPROVED

SUBJECT TO THE REQUIREMENTS OF
CONTRACT NO. 05-82-2541
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE
APPROVAL OF ANY DEVIATION FROM THE CONTRACT
REQUIREMENTS UNLESS THE CONTRACT
FOR CALLS ATTENTION TO AND SUPPORTS THE
DEVIATION THE CONTRACTOR SHALL BE
RESPONSIBLE FOR PROVIDING PROPER
PHYSICAL DIMENSIONS & WEIGHTS
TION

Just

10 SEP 1984




PUMPING TEST DATA

By: Carolina Well & Pump Co. R. Patterson & W. Pickard
 Owner: Camp Lejeune Address: _____
 Pumped Well No: 612 Location: _____ County: Onslow
 Observation Well Locations: _____
 Airline Lengths: Pumped Well _____ Observation Wells _____
 Remarks: _____

Pumping Rate Measured With: 4x6 orifice Water Levels Measured With: E. Tape

PUMP WELL DATA

Date and Time	Elapsed Time Min.	Piezometer Tube Reading Inches	Pumping Rate GPM	Pump Discharge Pressure	Altitude Gauge Reading Feet	Feet to Water	Remarks
8:00	1140	"	"			75' 2"	
9:00	1200	"	"			75' 2"	
10:00	1260	"	"			75' 2 1/2"	
11:00	1320	"	"			75' 1"	
12:00	1380	"	"			75' 2"	
1:00	1440	"	"				
			Recovery				
1:05	5					32' 9"	
1:10	10					30' 7"	
1:15	15					29' 6"	
1:20	20					28' 10"	
1:25	25					28' 4"	
1:30	30					27' 11"	
1:35	35					27' 6"	
1:40	40					27' 3"	
1:45	45					27'	
1:50	50					26' 10"	
1:55	55					26' 8"	
2:00	60					26' 6"	



CONTRACTOR'S SUBMITTAL TRANSMITTAL
 LANTDIV NORFOLK 4-4355/3 (Rev. 11-80)

CONTRACT NO. 162470-82-C-2511 TRANSMITTAL NO. ONE (9) DATE 6-22-84

FROM CONTRACTOR Onslow Utilities Inc.
 TO ROICC

PROJECT TITLE AND LOCATION
Replace water wells 612 + 626
Camp Lejeune NC.
(Well No 612)


607

CONTRACTOR USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

Contractor Approved OICC Approval



REVIEWER USE ONLY

****ACTION CODES**
 A-Approved
 D-Disapproved
 AN-Approved as noted
 RA-Receipt acknowledged.
 C-Comments
 R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO.	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	COPIES	ACTION CODES	REVIEWER'S INITIALS CODE AND DATE
02734		Driller's Log	6	A	CCS 405 7-10-84
"		Electric Log	6		
"		Water Analysis	6		
"		Recommendation and Data	6	Y	Y
		Submittal			

CONTRACTOR'S COMMENTS
Submittal for well # 612

COPY TO: FIELD
 DATE: 8-10-84

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)
Ronald L. Ellis

DATE RECEIVED BY REVIEWER: 2 July 84 FROM (Reviewer): LANTDIV TO: Onslow Utilities

Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.

Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.


REVIEWER'S COMMENTS

APPROVED

COPIES TO:
 ROICC (2)
 LANTDIV (1)
 A-E (1)

DATE 12 July 84

SIGNATURE [Signature]



ONslow UTILITIES, INC.
General Contractors
Post Office Box 5498
Jacksonville, North Carolina 28540

June 25, 1984

Officer in Charge of Construction
Building 1005, Marine Corps Base
Camp LeJeune, N.C. 28542

Re: N62470-82-C-2541
Replace Water Wells 612 and 626
Camp LeJeune, N.C. 85 110
(Well No. 612)

607

Gentlemen:

We are enclosing six (6) copies of the Driller's Log, Electric Log, and Water Analysis for your review. The test well was drilled 202 feet deep. Water samples were taken at the 127 to 132, 165 to 170 and 193 to 198 levels.

We recommend a line of .20 slot screens set at the 115 to 135, 163 to 175, and 190 to 200 levels for a total of 42 VF of screens. The gravel pack recommended is a coarse sand. It is our best estimate that this well may yield 200-250 GPM.

Please review the data and advise if we are to proceed with developing a permanent well at this site.

Yours truly,

ONslow UTILITIES, INC.

Ronald R. Ellen
Ronald R. Ellen, Pres.

RRE/ck
Enclosures

ATLANTIC DIVISION NAVAL FACILITIES ENGINEERING COMMAND NORFOLK, VIRGINIA 23511	
APPROVED <input checked="" type="checkbox"/>	_____
APPROVED AS NOTED	_____
DISAPPROVED	_____
SUBJECT TO THE REQUIREMENTS OF CONTRACT NO. 05-82-2541	
APPROVAL OF A SUBMITTAL DOES NOT INCLUDE APPROVAL OF ANY DEVIATION FROM THE CON- TRACT REQUIREMENTS UNLESS THE CONTRAC- TOR CALLS ATTENTION TO AND SUPPORTS THE DEVIATION--THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROVIDING PROPER PHYSICAL DIMENSIONS & WEIGHTS, COORDINA- TION OF TRADES, ETC., AS REQUIRED.	
REVIEWER CCS	DATE 10 JUL 1984
FOR OFFICER IN CHARGE OF CONSTRUCTION	




CAROLINA WELL AND PUMP COMPANY, INC.

Complete Well and Pump Service

P. O. BOX 1085

TELEPHONE 776-3415

SANFORD, NORTH CAROLINA 27330




N.W.W.A.
N.C.W.W.A.

Onslow Utilities, Inc.
General Contractors
P. O. Box 5498
Jacksonville, N. C. 28540

Contract N62470-82-C-2541
Job Well 612
Location Camp LeJeune, N.C.

0 - 1	top soil
1 - 8	sandy clay
8 - 18	yellow clay
18 - 44	sand
44 - 60	sand & clay
60 - 84	clay
84 - 105	shell rock soft
105 - 143	shell rock hard
143 - 158	clay
158 - 175	shell rock hard
175 - 186	clay
186 - 200	sand



Water Analysis, Goodbye to...

WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29512

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(R03) 479-4639

Well # 612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.


Date Analyzed: 5/10/84
Sample Number: 127-132

Analysis Results--Parts Per Million

<u>Determination</u>		<u>Determination</u>	
pH	<u>6.9</u>	Carbon Dioxide (CO ₂)	<u>5</u>
Iron (Fe)	<u>.05</u>	Total Acidity (CaCO ₃)	<u>8</u>
Nitrate (NO ₃)	<u>0.1</u>	Calcium Hardness (CaCO ₃)	<u>172</u>
Fluoride (F)	<u>.5</u>	Magnesium Hardness (CaCO ₃)	<u>22</u>
Manganese (Mn)	<u>Trace</u>	Carbonate Hardness (CaCO ₃)	<u>104</u>
Total Hardness (CaCO ₃)	<u>104</u>	Noncarbonate Hardness (CaCO ₃)	<u>0</u>
Chlorides (Cl)	<u>14</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>3.7</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>220</u>
Magnesium (Mg)	<u>5.3</u>	Total Alkalinity (CaCO ₃)	<u>220</u>
Calcium (Ca)	<u>69</u>	Total Dissolved Solids	<u>238</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°)	<u>240</u>
Bicarbonate (HCO ₃)	<u>268</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not Objectionable</u>

SIGNED: _____
LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE-WATER; APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1454 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29812

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(R03) 479-4639

612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.

Date Analyzed: 5/10/84
Sample Number: 165-170

Analysis Results--Parts Per Million

Determination

Determination

pH 6.9

Iron (Fe) .05

Nitrate (NO₃) 0.1

Fluoride (F) .5

Manganese (Mn) .05

Total Hardness (CaCO₃) 180

Chlorides (Cl) 11

Sulfate (SO₄) 11.3

Phosphate (PO₄) 0

Magnesium (Mg) 6.5

Calcium (Ca) 64.4

Carbonate (CO₃) 0

Bicarbonate (HCO₃) 195

Hydroxide (OH) 0

Carbon Dioxide (CO₂) 4

Total Acidity (CaCO₃) 6

Calcium Hardness (CaCO₃) 162

Magnesium Hardness (CaCO₃) 27

Carbonate Hardness (CaCO₃) 160

Noncarbonate Hardness (CaCO₃) 29

Alkalinity (Phenolphthalein) (CaCO₃) 0

Carbonate Alkalinity (CaCO₃) 0

Bicarbonate Alkalinity (CaCO₃) 160

Total Alkalinity (CaCO₃) 160

Total Dissolved Solids 196

Specific Conductance (micromhos. at 25°) 280

Appearance When Analyzed Clear

Odor When Analyzed Not Objectionable

SIGNED

LABORATORY DIRECTOR



Page 11 of 11

Water Analysis Lab

WATER ANALYSIS LABORATORY

802 HAMLET HIGHWAY
BENNETTSVILLE, SOUTH CAROLINA
29512

CONSULTANTS FOR:
INDUSTRY
MUNICIPALITIES
HOME OWNERS
DEVELOPERS
IRRIGATION
OTHERS

(803) 479-4639

612

DATE: May 10, 1984

Report To: Carolina Well & Pump Co.
Sanford, N. C.


Date Analyzed: 5/10/84
Sample Number: 193-198

Analysis Results--Parts Per Million

<u>Determination</u>		<u>Determination</u>	
pH	<u>6.7</u>	Carbon Dioxide (CO ₂)	<u>10</u>
Iron (Fe)	<u>.1</u>	Total Acidity (CaCO ₃)	<u>13</u>
Nitrate (NO ₃)	<u>Trace</u>	Calcium Hardness (CaCO ₃)	<u>124</u>
Fluoride (F)	<u>.7</u>	Magnesium Hardness (CaCO ₃)	<u>29</u>
Manganese (Mn)	<u>.05</u>	Carbonate Hardness (CaCO ₃)	<u>125</u>
Total Hardness (CaCO ₃)	<u>153</u>	Noncarbonate Hardness (CaCO ₃)	<u>28</u>
Chlorides (Cl)	<u>17</u>	Alkalinity (Phenolphthalein) (CaCO ₃)	<u>0</u>
Sulfate (SO ₄)	<u>32.9</u>	Carbonate Alkalinity (CaCO ₃)	<u>0</u>
Phosphate (PO ₄)	<u>0</u>	Bicarbonate Alkalinity (CaCO ₃)	<u>125</u>
Magnesium (Mg)	<u>6.9</u>	Total Alkalinity (CaCO ₃)	<u>125</u>
Calcium (Ca)	<u>49.6</u>	Total Dissolved Solids	<u>283</u>
Carbonate (CO ₃)	<u>0</u>	Specific Conductance (micromhos at 25°)	<u>410</u>
Bicarbonate (HCO ₃)	<u>153</u>	Appearance When Analyzed	<u>Clear</u>
Hydroxide (OH)	<u>0</u>	Odor When Analyzed	<u>Not objectionable</u>


SIGNED _____
LABORATORY DIRECTOR

ANALYTICAL METHODS REFERENCES: 'STANDARD METHODS FOR THE EXAMINATION OF WATER AND WASTE-WATER,' APHA, AWWA AND WPCF AND 'METHODS FOR COLLECTION AND ANALYSIS OF WATER SAMPLES,' WATER SUPPLY PAPER 1434 (1960), U. S. GEOLOGICAL SURVEY, WASHINGTON, D. C.



HP 607

250 G.P.M. - DUAL DRIVE - 7 1/2 HP.
 250 " " actual D.D.-220




Solid
 Concrete
 at 132,
 4-5-82
 M

DTA well #8

D.T.A. WELL No. 8

Solid
Concrete
at 132,
4-5-82
M

250 G.P.M. - DUAL DRIVE - 7 1/2 H.P.
 250 " " actual. D.D.-220



DTA well #8

D.T.A. WELL No. 8



SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PWSID
0467041

Owner Assigned
source Code

608

Well Name (If purchase, name of system)

HAD NOT POINT 608

Code

G

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

M M Y Y

Source exempt—

SWTR?

Y
 N

Direct Influence Date

M M D D Y Y

Availability

P=Permanent
 E=Emergency
 S=Seasonal
 I=Interim
 O=Other

Location of well within the system (If purchase, location of master meter)

MICHAEL ROAD

T/B Abandoned

Latitude (N)

3 43 9 53

Longitude (W)

0 7 7 2 0 1 9

How Determined

G=GPS
 M=Map
 S=Surveyed

GPS Data

Q# or
 DOP#

No. of Sats. Locked on

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y
 N

Assessment Date

M M D D Y Y

ENTRY POINT INFORMATION

Use Code

C=C=Ground/Permanent
 D=D=Ground/non-permanent

Availability

P=P=Year-round
 E=E=Emergency
 S=S=Seasonal
 I=I=Interim
 O=O=Other

Owner Assigned
Entry Point Code

100

Entry Point Name

HP608

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? Y
 N If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance:

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: Type of freeze protection:

Well: Diameter: 8" Type: GRAVE PEEK Yield (gpm): 208 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth 61 ft. (If unknown, put 'UNK') Well depth: 132' Meter available? N (Y,N)

Concrete slab adequate? (Y,N) If no, explain: Size:

Size of blow-off: 3" (C) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 200 HP: REMOVED Pump intake depth: 132 Auxiliary Power? Y (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 30" /

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)

Is the water treated at this well? Y
 N If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where? HP-20 PLANT

If purchase, retreat? Y
 N If yes, complete back of form.

*Pump & Motor REMOVE
AUX ENGINE DOWN*



WELL NUMBER		BY			DATE	
608		Thomas / Brown / Ward			11-15-84	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
60'	27	35'	8	48	104	0840
		36	9	44	108	0900
		37	10	40	119	0910
		40	13	37	130	0920
		41	14	34	143	0930
		43	16	31	162	0940
		44	17	28	172	0950
		45	18	25	185	1000
		46	19	22	192	1010
		47	20	19	201	1020
REMARKS	left set at → 48		21	17	207	1030

Well Demo 10-95

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



WELL NUMBER 608		BY THOMAS / BROWN			DATE 3-21-84	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
60'	27'	33	6	50	108	1010
		35	8	45	122	1020
		36	9	42	133	1033
		37	10	38	146	1045
		39	12	35	162	1055
		40	13	30	178	1105
		41	14	25	197	1116
		43	16	20	210	1126
		44	17	16	226	1145


REMARKS

Pump set at 60' with 60' air line

test set at 16 PSI 226 GPM

pulled pump cleaned well acid cleaned
water jetted clean, added C-319
clean, chlorinated, installed pump


MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE
	7			



WELL NUMBER		BY			DATE	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
	30	35	5	21	100	1050
		36	6	14	108	1110
		38	8	10	115	1124

REMARKS

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



WELL #

LENGTH OF AIR LINE

STATIC LEVEL

PUMPING LEVEL

DRAW DOWN

DISCHARGE PRESSURE

CAP. PER FOOT OF DRAW DOWN

TOTAL CAP.

DATE

6-19-79

Well Pulled & Repaired THIS DATE IN SERVICE

Static 19'
Well Depth 132'
Air Line 63'

INSTALLED DIRECT READING GAUGE

REMARKS:

2-13-80

54'
58'
53'

19
15
20'
25'

154
199
146
75

INSTALLED GOULD - 7 STAGE 5-3-82
AIR LINE 60'

DEPTH OF WELL:
AIRLINE ELEVATION:
DATE
INSTALLED:

7/14/1917

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

1000

MAINTENANCE TROUBLE/SERVICE TICKET

608

NO. 125778

SHOP

83

BLDG.

~~127~~

DATE

9-12-79

EMERGENCY

JOB ORDER NO.

AAA-23, 3036-2383

- | | | |
|----------------------------------|------------------------------------|----------------------------------------------|
| <input type="checkbox"/> REPAIR | <input type="checkbox"/> COMMODE | <input type="checkbox"/> LIGHT/FIXTURE |
| <input type="checkbox"/> REPLACE | <input type="checkbox"/> URINAL | <input type="checkbox"/> SWITCH |
| <input type="checkbox"/> UNSTOP | <input type="checkbox"/> SINK | <input type="checkbox"/> OUTLET |
| <input type="checkbox"/> LEAKING | <input type="checkbox"/> DRAIN | <input type="checkbox"/> HEAT/AIR CONDITION |
| <input type="checkbox"/> RUNNING | <input type="checkbox"/> FAUCET | <input type="checkbox"/> DOOR/DOOR LOCK |
| <input type="checkbox"/> INSUFF. | <input type="checkbox"/> HOT WATER | <input type="checkbox"/> WINDOW/WINDOW GLASS |

FLOOR NO. B 1 2 3

HEAD NO. 1 2 3 4

SQUAD BAY 1 2 3 4

SIDE N E S W

ROOM NO. _____

OTHER

Check g.p.m. on
wells

#8 214 gal at 15 PSI
STATIC 42

PUMP LEVEL 55

FOR INFORMATION CALL

PHONE NO.

AUTHORIZED BY

JOB STARTED (DATE & TIME)

JOB COMPLETED (DATE & TIME)

TOTAL MAN HOURS USED

SIGNATURE (SHOP SUPERVISOR)

9/12/79
[Signature]

REMARKS



MAIL ROOM
 RECEPTION
 TELETYPE UNIT
 TELEPHONE ROOM
 RECORDS SECTION
 OFFICE
 MAIL ROOM
 RECEPTION
 TELETYPE UNIT
 TELEPHONE ROOM
 RECORDS SECTION
 OFFICE

Check P.P. No. 100
 10/10

FOR INFORMATION CALL PHONE NO. 1-800-XXX-XXXX

[Handwritten signature or initials]

WATER ANALYSIS

By N.H. Kellom

Date 3-24-42

Sample from Well No. 8 Rey area
40 hrs pumping

Total Solids 240 PPM Dissolved Solids 205 PPM

Suspended Solids 35 PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ 28 PPM

Total Alk. " " 150 " Ferrous Iron as Fe 0 "

Carbonates " " 0 " Total Iron as Fe 0.6 "

Bicarbonates " " 150 " Aluminum as Al. 2.8 "

Chlorides as Cl. 12 " Calcium as Ca. 60.9 "

Sulphates as SO₄ 20 " Magnesium as Mg. 6.2 "

Nitrites as NO₂ 0 " Sodium as Na. 1.3 "

Carbon Dioxide as CO₂ 0 "

pH 7.6 Soap Hardness as CaCO₃ 180 PPM

Odor slight Turbidity 30

REMARKS _____

WATER ANALYSIS

Sample from _____

Total Solids _____

Total Alkalinity _____

Total Hardness _____

Calcium as Ca _____

Magnesium as Mg _____

Total Chloride as Cl _____

Total Sulfate as SO4 _____

Total Iron as Fe _____

Aluminum as Al _____

DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE MC	2. TYPE Q	3. LATITUDE ° ' " N 34 39 52	4. LONGITUDE ° ' " W 77 20 20	5.
----------------------	--------------	------------------------------------	-------------------------------------	----

6. AGENCY STATION NO. 608	7. STATION NAME HP20-608
------------------------------	-----------------------------

8. DRAINAGE BASIN CODE No. Letter 06 N	9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONslow
----------------------------------------------	---------------------	------------------------	---------------------------

12. PERIOD OF RECORD Began 1942 Discontinued	Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption Exceeds 1 Year	13.	14.
----------------------------------------------------	-----------------------------------------------------------------------------------------------	-----	-----

15. SITE	<input type="checkbox"/> 101 Stream	<input type="checkbox"/> 102 Canal	<input type="checkbox"/> 103 Lake	<input type="checkbox"/> 104 Reservoir	<input type="checkbox"/> 105 Estuary	<input type="checkbox"/> 106 Spring	<input checked="" type="checkbox"/> 107 Well	<input type="checkbox"/> 110 Other
----------	-------------------------------------	------------------------------------	-----------------------------------	----------------------------------------	--------------------------------------	-------------------------------------	----------------------------------------------	------------------------------------

16. FREQUENCY OF MEASUREMENT	<input type="checkbox"/> 201 Continuous Recorder	<input type="checkbox"/> 202 Telemetered	<input type="checkbox"/> 203 Daily	<input type="checkbox"/> 204 Weekly	<input type="checkbox"/> 205 Monthly	<input type="checkbox"/> 206 Quarterly	<input type="checkbox"/> 207 Seasonal	<input type="checkbox"/> 208 Annual	<input type="checkbox"/> 209 Other Periodic	<input checked="" type="checkbox"/> 210 Occasional
------------------------------	--------------------------------------------------	------------------------------------------	------------------------------------	-------------------------------------	--------------------------------------	----------------------------------------	---------------------------------------	-------------------------------------	---------------------------------------------	----------------------------------------------------

17. TYPES OF DATA AVAILABLE	<i>Physical</i>	<i>Chemical</i>	<i>Organic</i>
<input type="checkbox"/> 311 Temperature	<input type="checkbox"/> 312 Specific Conductance	<input type="checkbox"/> 313 Turbidity	<input type="checkbox"/> 314 Color
<input type="checkbox"/> 315 Odor	<input type="checkbox"/> 316 Radioactivity	<input checked="" type="checkbox"/> 318 pH (lab)	<input type="checkbox"/> 319 Eh
<input type="checkbox"/> 320 Other	<input type="checkbox"/> 331 Dissolved solids	<input checked="" type="checkbox"/> 332 Chlorides Only	<input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds)
	<input type="checkbox"/> 334 Common ions	<input checked="" type="checkbox"/> 335 Hardness	<input type="checkbox"/> 336 Radiochemical
	<input type="checkbox"/> 337 Dissolved oxygen	<input type="checkbox"/> 338 Other Gases	<input type="checkbox"/> 339 Other
			<i>Biological</i>
			<input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.)
			<input type="checkbox"/> 352 Synthetic detergents
			<input type="checkbox"/> 353 Other
			<i>Sediment</i>
			<input type="checkbox"/> 361 Coliforms
			<input type="checkbox"/> 362 Other Micro-organisms
			<input type="checkbox"/> 363 BOD
			<input type="checkbox"/> 364 Other
			<input type="checkbox"/> 371 Concentration
			<input type="checkbox"/> 372 Particle size
			<input type="checkbox"/> 373 Other

18. SUPPLEMENTARY DATA FOR SITE	<input type="checkbox"/> 421 Surface Water Station	<input type="checkbox"/> 422 Ground Water Station	<input type="checkbox"/> 423 Water Stage or Level	<input checked="" type="checkbox"/> 424 Water discharge	<input type="checkbox"/> 425 Time of Travel	<input type="checkbox"/> 426 Drainage Area
---------------------------------	----------------------------------------------------	---------------------------------------------------	---------------------------------------------------	---------------------------------------------------------	---------------------------------------------	--------------------------------------------

19. STORAGE OF DATA	<input type="checkbox"/> 501 Periodic Report	<input type="checkbox"/> 502 Areal Report	<input checked="" type="checkbox"/> 503 Not Published	<input type="checkbox"/> 504 Data on Punchcard	<input type="checkbox"/> 505 Data on Magnetic Tape	<input type="checkbox"/> 506 Other
---------------------	----------------------------------------------	-------------------------------------------	-------------------------------------------------------	------------------------------------------------	----------------------------------------------------	------------------------------------

20. OFFICE AT WHICH DATA AVAILABLE	Office: BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION	Street No.: MARINE CORPS BASE	City Code:
	City, State, Zip: CAMP LEJEUNE, N. C. 28542		0735

21. OFFICE COMPLETING FORM	BASE MAINTENANCE DEPARTMENT	22. COMPILER'S NAME	F. E. TEW, JR.	23. DATE	Month: SEPT.	Year: 1966
----------------------------	-----------------------------	---------------------	----------------	----------	--------------	------------



Well 608


Static water level measured from
pump base 27 ft.

depth of well 126 ft.

air line 60'

3 stage Impeller unit

setting 76 ft to bottom of suction pipe



GAGE READING
 ↙ ↘

Date	Head.	Static	D.D.level	Feet of D.D.	G.P.M.		
1/6/59	New pump put in operation Layne. Pump Setting						Air Line
1/6/59	15 LB.	34 Ft.	9 Ft.	25 Ft	270		
"	18 "	"	11 "	23 "	242		
"	20 "	"	13 "	21 "	230	OPERATING HERE	
"	25 "	"	19 "	15 "	180		
11-23-66	35	29'	20'	9'	201	SE WELL TEST.	
8/3/69	P	29	20'	9	162		
		STATIC	PUMPING LEVEL				
9-4-69	19#	-4.3	-24.3	20'	162		

... ..
... ..
... ..

100	"	10	"	10	"	10	"
100	"	10	"	10	"	10	"
100	"	10	"	10	"	10	"
100	"	10	"	10	"	10	"

1

100

100

Date	Line Ft.	G.P.M.	D.D. El. Dage FT	Static El. Dage FT	Shut Off Head	D.D. Ft. New Pump
7-22-54	46	178	53	32		21
"	48	170	52	-		20
"	44	180	54	"		22
✓	40	192	55	"		23
"	34	201	59.5	operating Head. →		24.5 - Line -
"	39	195	56.5			25.5
"	-	-	60	32		28
In operation 2 weeks - very noisy - out off						
Put back in operation - 7-19-55. operation some quiet						
7-19-55	-	-	49	30ft.		19

Old pump discarded.
1-6-59.


as of 3/1/67 well 8 has a Logne pump
new Head Shaft - by Thomas 7-5-55

Air Line ?

64 ft. ?

figured 65 FT.

(64)



Well 608

3/2/77

DEPTH $\frac{114'}{8''}$ 114'

CASEING 8''

STATIC 23'8" MEASURED

AIRLINE 60'

PUMP LAYNE

SIZE 5''

SETTING 60' $\frac{1}{4}$ ''

TAIL 6" x 10'

BOWL ASSEMBLY

STAGE 3

SIZE 8

TYPE PIRHC

SERIAL 65263



HARTSFIELD WATER COMPANY, INC.
 Kinston, N. C.
 Phone JA 3-6007

FINAL TEST RECORD

WELL NO. 8


WELL FOR Tarawa Terrace

DESIRED FLOW 100

ADDRESS Camp Lejeune, N. C.

TEST 100

DATE	TIME	G.P.M.	DRAWDOWN	PUMPING LEVEL	REMARKS
11/1/61	7:00	100			Static level 7 $\frac{1}{2}$ ' from G.L.
	8:00	100	19' 6"	27'	
	9:00	100	20' 6"	28	
	10:00	100	20' 6"	28	
	11:00	100	20' 6"	28	
	12:00	100	22' 6"	28 29	
	1:00	100	21' 6"	29	
	2:00	100	21' 6"	29	
	3:00	100	21' 6"	29	
	4:00	100	21' 6"	29	
	5:00	100	21' 6"	29	
	6:00	100	21' 6"	29	
	7:00	150		38	
	8:00	150	30' 6"	38	
	9:00	150	30' 6"	38	
	10:00	150	30' 6"	38	
	11:00	175	37' 6"	45	
	12:00	175	37' 6"	45	
	1:00	175	37' 6"	45	
	2:00	175	37' 6"	45	
	3:00	195	44' 6"	52	
	4:00	195	44' 6"	52	
	5:00	195	45' 6"	53	
	6:00	195	45' 6"	53	
	7:00	195	45' 6"	53	



W E L L D A T A

Well No. 8

SPECIFICATIONS

Pump Base Elevation	31.7
Ground Elevation	29.7
Static Elevation	9.7
Maximum allowed Drawdown	-17
Total Discharge	250 G.P.M.
Total Head	73 Feet

TEST

300 G.P.M.	Pressure	Drawdown	-28.3	
250 G.P.M. 13 $\frac{1}{2}$	Pressure	Drawdown	-19.0	4.25
240 G.P.M. 15 $\frac{1}{2}$	Pressure	Drawdown	-18.3	5.0
230 G.P.M.	Pressure	Drawdown	-17.0	
210 G.P.M. 18 $\frac{1}{2}$	Pressure	Drawdown	-15.9	6.25
190 G.P.M. 21 $\frac{1}{2}$	Pressure	Drawdown	-11.9	

Recovers to elevation 4.0

Air line 61'

APR 1948

MEMORANDUM

TO : SAC, [illegible]

FROM : [illegible]

1. [illegible]

2. [illegible]

3. [illegible]

4. [illegible]

5. [illegible]

6. [illegible]

7. [illegible]

8. [illegible]

9. [illegible]

10. [illegible]

Very truly yours,

[illegible signature]

[illegible title]

[illegible address]

[illegible phone number]

[illegible teletype number]

[illegible distribution list]

Marine Barracks
New River, N. C.
April 13, 1942

Wells: Permanent Water Supply, Regimental Area
By Layne Atlantic Company
Report on Well No. 8

Locations: 500 ft. South of the intersection of cypress St. and Pine St.
in industrial area as shown on M.B. drawing No. 521.

Date Drilled: March, 1942

Drilling Equipment: Rotary rig, bits, and other equipment.

Status: Ground elevation 29.7

A 17½" hole drilled to 21 feet. This was reamed to 23" in diameter. 20 feet of 18" I.D. Steel casing, was set and the annular space around this was filled with cement grout. A 17½" hole was drilled to a total depth of 170 feet.

Log of Formations:	0 to 1'5"	Black top soil
	1'5" to 20'	Fine yellow sand
	20' to 37'	Hard rock
	37' to 57'	Streaks of soft rock and sand
	57' to 64'	Hard rock
	64' to 84'	Medium hard rock
	84' to 85'	Hard rock (rough drilling)
	85' to 93'	Soft rock and sand
	93' to 108'	Hard rock
	108' to 117'	Soft rock and sand
	117' to 126'	Soft rock with fine sand
	126' to 161'	Fine sand
	161' to 166'	Hard rock
	166' to 170'	Fine gray sand

Remarks: Due to the presence of fine sand, it was necessary to construct a gravel wall well.

Gravel Wall Construction: 111'6" of 8" steel pipe and 50' of silician bronze shutter screen was lowered into the well and the annular space was pumped full of a special ¼" cape gravel.

1942
1941
1940

Department of Agriculture

Washington, D.C.

For information of the Department of Agriculture, the following information is being furnished:

1942

1941

The following information is being furnished for the information of the Department of Agriculture:

Item	1942	1941
Wheat	1,200,000	1,100,000
Barley	500,000	450,000
Oats	800,000	750,000
Rye	100,000	100,000
Triticale	200,000	200,000
Other	100,000	100,000
Total	2,800,000	2,600,000

This information is being furnished for the information of the Department of Agriculture.

The following information is being furnished for the information of the Department of Agriculture:

Log of screen	0' to 61'6"	8" Blank pipe
setting:	61'6" to 81'6"	8" Bronze screen
	81'6" to 91'6"	8" Blank pipe
	91'6" to 101'6"	8" Bronze screen
	101'6" to 121'6"	8" Blank pipe
	121'6" to 131'6"	8" Bronze screen
	131'6" to 151'6"	8" Blank pipe
	151'6" to 161'6"	8" Bronze screen

The bottom of the screen was filled with a cement plug and then capped with a steel plate.

Static water level: 20 feet below surface

Pumping: Well was pumped for forty-two hours to clear off fine sand. Showed a constant flow of 205 gallons per minute with a 22 foot drawdown. This was approximately 9.3 gallons per foot drawdown.

See separate report for chemical analysis.

Report will be made of pump installations.

N. H. Kellam
Asst. Chem. Engineer

IN THE COURT OF THE DISTRICT OF COLUMBIA
IN AND FOR THE DISTRICT OF COLUMBIA
IN RE: THE ESTATE OF JOHN W. ...
...
...

The undersigned, being duly sworn, depose and say that the foregoing is a true and correct copy of the original as the same appears in the files of the ...

Subscribed and sworn to before me this ... day of ... 19...

Notary Public for the District of Columbia
My commission expires on ...

Witness my hand and the seal of my office this ... day of ... 19...

W. J. ...
Notary Public

3 lines

13 lost




H.P. Well 608

3 turned
13 lost

H.P. Well 608

609 was replaced by 585

200 G.P.M. - SINGLE DRIVE - 7 1/2 H.P.
200 " " " actual. D.D. - 197



150
53.3
7.5

883
50
175
25
30
35

609 was replaced 585
By powder 585

1150
53.3
7.5

883
10th
50
55
125
200

883

650
175
25
20
35

~~1214~~



609 was replaced by 585

150
53.3

96.7


200 G.P.M. - SINGLE DRIVE - 7 1/2 H.P.

200 " " " actual. D.D. - 19.7

Pump Fndn.

EL. 31.30

EL. 29.30





Sent To Wiggins 3-20-97

REQUISITION DATA - MAINTENANCE

MCBCL 11014/2 REV 01-93

DATE

2-24-97

STOCK NUMBER

PART NUMBER

MANUFACTURER

U/I

U/P

QTY

PRI

6CHC-4

GOULD

EA

5571

1

07

FIP: M67001 - 23 - 83 - - - - -

DESCRIPTION:

4 STAGE VERTICAL PUMP, HEAD 200 FT
250 GPM, 20 HP 3600 RPM 3 PH 230/460
VOLTS 4 EACH COLUMN AT 70 FT

JUSTIFICATION:

REPLACE WIRE PUMP 609
WORN OUT IN SERVICE

TICKET NUMBER:

SUGGESTED SOURCE:


COMPANY NAME TENCARVA MACH CO POC

ADDRESS PO BOX 3407 TEL 910-799-8800

CITY, STATE, & ZIP WILMINGTON NC 28406-0407

SIGNATURE

Sty J Miller



REQUISITION DATA - MAINTENANCE

MCBCL 11014/2 REV 01-93

DATE

2-24-57

STOCK NUMBER

PART NUMBER

6 CHC-4

MANUFACTURER

GOULD

U/I

EA

IMP

5571

QTY

1

PRI

07

FIP: M67001 - 23 - 83 - - - - -

DESCRIPTION:

4 STAGE VERTICAL PUMP, HEAD 200 FT
 250 GPM, 20 HP 3600 RPM 3 PH 230/460
 VOLTS 4 INCH COLUMN AT 70 FT

JUSTIFICATION:

REPLACE WELL PUMP 609
 WORN OUT IN SERVICE

TICKET NUMBER:

SUGGESTED SOURCE:

COMPANY NAME TENCARUA MACH. CO

POC

ADDRESS PO BOX 3407

TEL

910-799-8800

CITY, STATE, & ZIP WILMINGTON NC 28406-0407

SIGNATURE

Sty J Miller

[Faint handwritten text]

[Faint handwritten text]

[Faint handwritten text]

[Faint handwritten text]

[Faint handwritten text]

[Faint handwritten text]

MAT WIGGEL

Tencarva Machinery Co.

FAX Transmission

From: SCOTT HUDSON
To: STANLEY MILLER
Company: CAMP LEJEUNE

Date: February 19, 1997
Time: 4:09 PM
FAX #: 910-451-3544

Message: WELL HOUSE 609

Mr. Miller,


I am pleased to offer the following for the subject pump:

Rating: 250 GPM @ 200 Ft

1-Goulds 6CHC 4 stage vertical turbine pump, setting at 70 feet, 4 inch column, cone strainer, driven by a 20 HP 3600 RPM 3/60/230/460 volt WP1 VHS motor with non-reverse ratcheting.....**\$5571.00**

Terms-net 30 days or credit card
freight allowed
shipment 5 to 6 weeks

Thank you and please call with questions.



VOICE: 910 799 8800 FAX: 910 799 8801

P.O. Box 3407, 108 N. Kerr Ave, Suite K-3, Wilmington, N.C. 28406-0407

TO: [Illegible]

VOICE: 810 188 8900 FAX: 810 188 8901

[Handwritten signature]

Thank you and please call with orders

24 hours a day
7 days a week
1-800-555-1234

and motor with non-reverse starting

CHC's products are available in all states
except those where prohibited by law

© 1983 CHC

CHC's products are available in all states

CHC

Message: WELL HOUSE 803

Company: CAMPTON
TO: STANLEY WILSON
From: SCOTT HUDSON

FAX #: 810-188-8901
Date: 03/18/83
Time: 11:52

TXNY 20 0815

TO: [Illegible]

SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 5 9 5

PW/SID
0467041

Owner Assigned
Source Code

609

Well Name (If purchase, name of system)

HADNOT POINT 609

Code

G

G=Ground
W=Purchase/G
Y=O w/direct influence
Z=W w/direct influence

If Purchase, seller ID#

Source Begin Date

M M Y Y
M M Y Y

Source exempt—
SWTR?

Y
 N

Direct Influence Date

M M D D Y Y

Availability

P

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

Location of well within the system (If purchase, location of master meter)

SNEADS PERRY ROAD

Latitude (N)

343926

Longitude (W)

0771854

How Determined

G=GPS
 M=Map
 S=Surveyed

GPS Data

Q# or
 DOP #

No. of Sats. Locked on

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y
 N

Assessment Date

M M D D Y Y

ENTRY POINT INFORMATION

Use Code

C

C=Ground/Permanent
D=Ground/non-permanent

Availability

P

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

Owner Assigned
Entry Point Code

100

Entry Point Name

HADNOT PT WTP

Location:

Well Site: Owned or controlled? Y (Y,N) Control Area (100' radius)? N (Y,N) If no, explain: _____

Sources of pollution/distance: 50' to Road

Surface water within 200'? Y N If yes, actual distance feet If yes, bact. samples collected? _____ (Y,N)

Adequate slope? Y (Y,N) Flooding? N (Y,N) Maintenance: OK

Well House: Free of stored materials? Y (Y,N) Properly drained? Y (Y,N) Locked? Y (Y,N)

Condition of house: OK Type of freeze protection: NONE

Well: Diameter: 8" Type: GRAVE PACK Yield (gpm): 162 Properly sealed? Y (Y,N)

Properly vented? _____ (Y,N) Casing depth ft. (If unknown, put 'UNK') Well depth: 145' Meter available? N (Y,N)

Concrete slab adequate? _____ (Y,N) If no, explain: _____ Size: _____

Size of blow-off: 3" (C) Sample tap: Before treatment? Y (Y,N) After treatment? _____ (Y,N)

Pumps: Capacity: GPM: 140 HP: 2.5 Pump intake depth: 145 Auxiliary Power? N (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 16"

Storage at well site: Elev: Hydro: Ground:

If hydroautomatic, air volume control? _____ (Y,N) Safety valves? _____ (Y,N) Coded? _____ (Y,N)


High service pumps: 1. _____ gpm _____ hp 2. _____ gpm _____ hp 3. _____ gpm _____ hp Auxiliary Power? _____ (Y,N)

Is the water treated at this well? Y N If yes, complete back of form.

If other wells are treated here, which ones? _____ If treated elsewhere, where? HP-20 PLANT

If purchase, retreat? Y N If yes, complete back of form.

1 NO meter
2 NO vent




WELL NUMBER 609		BY <i>Stevens & Peterson</i>			DATE 8-24-97	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
20	18	60	42	90	183	45

REMARKS

D/H 100+

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



WELL NUMBER <i>609</i>		BY <i>BROWN-STEVENS</i>			DATE <i>10-5-94</i>	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
<i>70</i>	<i>20</i>	<i>60</i>	<i>40</i>	<i>50</i>	<i>162</i>	

REMARKS


D-H 80


MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE


6" - 4- ~~2-11~~ 12'

4" - 5-8'

2- 8' of 6"








WELL
609


DATE	LENGTH OF AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAW DOWN	DISCHARGE PRESSURE	CAP. PER FOOT OF DRAW DOWN	TOTAL CAP.
10-8-81	60'	30'	50	20	40	3 1/2"	
			56	26	37	100	
			58	28	34	119	
			60	30	31	133	

REMARKS:

Left net at 37 PSI

TYPE OF
CONE
MATERIAL
USED:







WELL NUMBER <i>609</i>		BY <i>Thomas / Brown</i>			DATE <i>10-25-84</i>	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME <i>1030</i>
<i>60</i>	<i>16</i>	<i>38</i>	<i>22</i>	<i>20</i>	<i>105</i>	<i>1040</i>
		<i>39</i>	<i>23</i>	<i>17</i>	<i>108</i>	<i>1056</i>
		<i>42</i>	<i>26</i>	<i>14</i>	<i>111</i>	<i>1106</i>
		<i>44</i>	<i>28</i>	<i>10</i>	<i>119</i>	<i>1116</i>
		<i>46</i>	<i>30</i>	<i>7</i>	<i>122</i>	<i>1126</i>

REMARKS *left set at 10 PSI 119 GPM*

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE





WELL #609

LENGTH
OF
AIR LINE

STATIC
LEVEL

PUMPING
LEVEL

DRAW
DOWN

DISCHARGE
PRESSURE

CAP. PER
FOOT OF
DRAW DOWN

TOTAL
CAP.

DATE

1-11-79

23'

25

104

20'

20

115

19'

15

119

17'

10

122

2-13-80

60'

47'

14

90

48'

10

95



46'

18

80



REMARKS:

DEPTH OF
WELL:
AIRLINE
ELEVATION: +
DATE
INSTALLED:



DATE - 4-26-63

WELL #	STATIC	PUMPING LEVEL GAGE.	DD -	DISCHARGE PRESS	GPM	AIR LINE GIFT
9	47 FT	4 FT			212	NEW WAYNE - INSTALLED 4-25-63
		5 1/2 FT			203	BY HENDERSON
		7 FT			195'	
		9 FT			187	
9			18 1/2	14 1/2		3/22/66
						as of 3/1/67 Logno pump in well 9
12/12/66	36.5		48'	21	190	
3/13/68	45		40	0	30	PULLED AND CLEANED.
8/11/69	44	11	33	12	133	SE WELL TEST
	STATIC	Pump Level				
9-4-69	+12'	-21'	33'	12	133	11-25-69 - PULLED + CLEANED



187 143
3124
P...


#18
32

Well # 9

52 FT.

Date	Line Ft.	G.P.M.	D.D. El.	Static El.	Shut Off head	D.D. Ft.	
11-10-52	54	?	-8	+17	115	25	OLD PUMP
9-16-53	-	-	-13	+18	-	31	
5-28-54	71	151	43?	22			NEW PUMP.
"	55	170	50?	22			
"	60	170	50?	22			
6-4-54	50	177	55	22		33	105
6-4-54	60	156	50	22		28	110
<p>16'6" to water level from base 149' just Deep before pumped.</p>							
	M.O. ALK	@ CHLORIDES	IRON	HARDNESS	PH. ALK.		
1-13-55	99	9	0.4	96	0		

Air Line 60 FT. LOWER EL. - 26



WELL #

609

LENGTH OF AIR LINE

STATIC LEVEL

PUMPING LEVEL

DRAW DOWN

DISCHARGE PRESSURE

CAP. PER FOOT OF DRAW DOWN

TOTAL CAP.

DATE

9, 15, 81


60

29'

REMARKS:

Pump not pumping

DEPTH OF WELL:
AIR LINE ELEVATION:
DATE INSTALLED:



PHYSICAL CHEMICAL ANALYSIS OF WATER

SAMPLE NO.

FROM: (Station or unit)

Well 9 Bldg 609

DATE

8-8-57

TO: (Name and location of laboratory)

SAMPLE FROM (Location of sampling point)

COLLECTED BY

Withrow

DATE

8-8-57

HOUR

SOURCE (Designate ground, surface, raw, treated)

Raw

REASON FOR EXAMINATION

EXAMINATION REQUESTED BY

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

I. FIELD ANALYSIS			III. ROUTINE LABORATORY ANALYSIS		
1. pH	TEMPERATURE		(CHECK ONE)		
	°F	°C	REQUESTED	NOT REQUESTED	
ITEM	PPM		1. COLOR		
2. CARBON DIOXIDE (CO ₂)			2. TURBIDITY		
3. DISSOLVED OXYGEN (O ₂)			3. ALKALINITY (CaCO ₃)		
4. HYDROGEN SULFIDE (H ₂ S)			P	MO	
5. CHLORINE DEMAND (Cl ₂)			0	88	
FIELD ANALYSIS BY			4. TOTAL HARDNESS (CaCO ₃)		
			92		
DATE OF ANALYSIS			5. NON-CARBONATE HARDNESS (CaCO ₃) (By Computation)		
II. SPECIAL LABORATORY ANALYSES			6. CARBONATE HARDNESS (CaCO ₃) (By Computation)		
Check (X) individual items to be included in the Special Analyses. Request determination only of those substances suspected of being present in significant amounts.			7. TOTAL DISSOLVED SOLIDS		
(X)	ITEM	PPM	8. SPECIFIC CONDUCTANCE (Micromhos)		
	1. As		ITEM		
	2. Se		PPM		
	3. Pb		9. CALCIUM (Ca)	34.4	
	4. B		10. MAGNESIUM (Mg)	1.2	
	5. Cu		11. SODIUM (Na) AND POTASSIUM (K)		
	6. Zn		12. HYDROXIDE (OH) ⁻	0.0	
	7. Cr (Hexavalent)		13. BICARBONATE (HCO ₃) ⁻	88.0	
	8. PO		14. CARBONATE (CO ₃) ⁻	0.0	
	9. Cd		15. SULFATE (SO ₄)	8.0	
	10. CN		16. CHLORIDE (Cl)	8.0	
	11. Phenolic Compounds (PPB)		17. NITRATE (NO ₃)		
	12. Others (Specify)		18. IRON (Fe) TOTAL	0.5	
	13.		19. MAGANESE (Mn)		
	14.		20. SILICA (SiO ₂)		
	15.		21. FLUORIDE (F)		
	16.		*State whether determined or computed from P and MO alkalinity.		

REMARKS (Such as unusual appearance, taste, odor, etc.)

LABORATORY ANALYSIS BY

Justice

DATE OF ANALYSIS



8-8-57

No.	Date	Location	Remarks
1	10/1/50
2	10/2/50
3	10/3/50
4	10/4/50
5	10/5/50
6	10/6/50
7	10/7/50
8	10/8/50
9	10/9/50
10	10/10/50
11	10/11/50
12	10/12/50
13	10/13/50
14	10/14/50
15	10/15/50
16	10/16/50
17	10/17/50
18	10/18/50
19	10/19/50
20	10/20/50
21	10/21/50
22	10/22/50
23	10/23/50
24	10/24/50
25	10/25/50
26	10/26/50
27	10/27/50
28	10/28/50
29	10/29/50
30	10/30/50
31	10/31/50

U.S. DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE MC	2. TYPE Q	3. LATITUDE ° ' " N 34 39 22	4. LONGITUDE ° ' " W 77 18 53	5.
6. AGENCY STATION NO. 609		7. STATION NAME HP20-609		
8. DRAINAGE BASIN CODE No. Letter 06 N		9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONSLOW
12. PERIOD OF RECORD Began Discontinued 1912		Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption Exceeds 1 Year		13. ONSLOW
15. SITE				
<input type="checkbox"/> 101 Stream <input type="checkbox"/> 102 Canal		<input type="checkbox"/> 103 Lake <input type="checkbox"/> 104 Reservoir <input type="checkbox"/> 105 Estuary		<input type="checkbox"/> 106 Spring <input checked="" type="checkbox"/> 107 Well <input type="checkbox"/> 110 Other
16. FREQUENCY OF MEASUREMENT				
<input type="checkbox"/> 201 Continuous Recorder <input type="checkbox"/> 202 Telemetered		<input type="checkbox"/> 203 Daily <input type="checkbox"/> 204 Weekly <input type="checkbox"/> 205 Monthly <input type="checkbox"/> 206 Quarterly		<input type="checkbox"/> 207 Seasonal <input type="checkbox"/> 208 Annual <input type="checkbox"/> 209 Other Periodic <input checked="" type="checkbox"/> 210 Occasional
17. TYPES OF DATA AVAILABLE				
Physical		Chemical		Organic
<input type="checkbox"/> 311 Temperature <input type="checkbox"/> 312 Specific Conductance <input type="checkbox"/> 313 Turbidity <input type="checkbox"/> 314 Color <input type="checkbox"/> 315 Odor <input type="checkbox"/> 316 Radioactivity <input type="checkbox"/> 317 pH (field) <input checked="" type="checkbox"/> 318 pH (lab) <input type="checkbox"/> 319 Eh <input type="checkbox"/> 320 Other		<input type="checkbox"/> 331 Dissolved solids <input checked="" type="checkbox"/> 332 Chlorides Only <input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds) <input type="checkbox"/> 334 Common ions <input checked="" type="checkbox"/> 335 Hardness <input type="checkbox"/> 336 Radiochemical <input type="checkbox"/> 337 Dissolved oxygen <input type="checkbox"/> 338 Other Gases <input type="checkbox"/> 339 Other		<input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.) <input type="checkbox"/> 352 Synthetic detergents <input type="checkbox"/> 353 Other
				Biologic
				<input type="checkbox"/> 361 Coliforms <input type="checkbox"/> 362 Other Micro-organisms <input type="checkbox"/> 363 BOD <input type="checkbox"/> 364 Other
				Sediment
				<input type="checkbox"/> 371 Concentration <input type="checkbox"/> 372 Particle size <input type="checkbox"/> 373 Other
18. SUPPLEMENTARY DATA FOR SITE				
<input type="checkbox"/> 421 Surface Water Station <input type="checkbox"/> 422 Ground Water Station		<input type="checkbox"/> 423 Water Stage or Level <input checked="" type="checkbox"/> 424 Water discharge		<input type="checkbox"/> 425 Time of Travel <input type="checkbox"/> 426 Drainage Area
19. STORAGE OF DATA				
<input type="checkbox"/> 501 Periodic Report <input type="checkbox"/> 502 Areal Report		<input checked="" type="checkbox"/> 503 Not Published <input type="checkbox"/> 504 Data on Punched Card		<input type="checkbox"/> 505 Data on Magnetic Tape <input type="checkbox"/> 506 Other
20. OFFICE AT WHICH DATA AVAILABLE				
Office BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION				
Street No. MARINE CORPS BASE				City Code
City, State, Zip CAMP LEJEUNE, N. C. 28512				0735
21. OFFICE COMPLETING FORM				
BASE MAINTENANCE DEPARTMENT				23. DATE
22. COMPILER'S NAME F. E. [unclear] JR.				Month Year SEPT. 66



cc

187

187

187

WATER ANALYSIS

By N.H. Kellam

Date 3-27-42

Sample from Supply Well Per AFCC
at Well Site No. 9

Total Solids _____ PPM Dissolved Solids _____ PPM

Suspended Solids _____ PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ _____ PPM

Total Alk. " " 54 " Ferrous Iron as Fe _____ "

Carbonates " " 0 " Total Iron as Fe _____ "

Bicarbonates " " 50 " Aluminum as Al. _____ "

Chlorides as Cl. 10 " Calcium as Ca. _____ "

Sulphates as SO₄ _____ " Magnesium as Mg. _____ "

Nitrites as NO₂ _____ " Sodium as Na. _____ "

Carbon Dioxide as CO₂ 5 "

pH 7.6 Soap Hardness as CaCO₃ _____ PPM

Odor slight Turbidity _____

REMARKS _____

ANALYSIS

No.	Description	Quantity	Value
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

WATER ANALYSIS

By N. H. Kellam

Date 3-21-42

Sample from Supply Well
at Well site No. 9

Total Solids _____ PPM Dissolved Solids _____ PPM

Suspended Solids _____ PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ _____ PPM

Total Alk. " " 106 " Ferrous Iron as Fe _____ "

Carbonates " " 0 " Total Iron as Fe _____ "

Bicarbonates " " 106 " Aluminum as Al. _____ "

Chlorides as Cl. 8 " Calcium as Ca. _____ "

Sulphates as SO₄ _____ " Magnesium as Mg. _____ "

Nitrites as NO₂ _____ " Sodium as Na. _____ "

Carbon Dioxide as CO₂ 0 "

pH 7.8 Soap Hardness as CaCO₃ _____ PPM

Odor Slight Turbidity 15

REMARKS _____

MEMORANDUM

TO : [Illegible]

FROM : [Illegible]

SUBJECT : [Illegible]

[Illegible text follows, appearing to be a list or series of points, but is too faint to transcribe accurately.]

Marine Barracks
New River, N. C.
April 14, 1942

Wells: Permanent Water Supply
By Layne Atlantic Company
Report on Well No. 9

Locations: On the west side of road to Hurst Beach 2500' south east
of well No. 6 as shown on M.B. Drawing No. 521.

**Date
Drilled:** April, 1942

**Drilling
Equipment:** Rotary rig, bits, and other equipment.

Status: Ground elevation 29.3

A 17 $\frac{1}{2}$ " hole drilled to a depth of 32'. This was reamed to 23"
in diameter to a depth of 31'. 30' of 18" I.D. steel casing
was set and the annular space was filled with cement grout.
A 17 $\frac{1}{2}$ " hole was then drilled to a total depth of 156 feet.

Log of Formations:	0' to 18'	Brown sand
	18' to 32'	White clay with little sand
	32' to 46'	Fine sand
	46' to 50'	Medium hard rock and sand
	50' to 66'	Soft rock and sand
	66' to 72'	Hard rock
	72' to 94'	Medium hard rock and sand
	94' to 105'	Soft rock and sand
	105' to 116'	Fine sand and shells
	116' to 151'	Very fine sand
	151' to 156'	Very hard rock

Remarks: Well finished at 150', due to the fine sand in the hole, it
was necessary to construct a gravel wall well.

**Gravel Wall
Construction:** 105 feet of 8" steel pipe and 45 feet of silician bronze shutter
screen was placed in the well and the annular space was pumped full
of a special $\frac{1}{4}$ " cape may gravel.

Sheet 2

Log of Screen	0' to 65'	8" Blank pipe
Setting:	65' to 80'	8" Bronze screen
	80' to 100'	8" Blank pipe
	100' to 110'	8" Bronze screen
	110' to 130'	8" Blank pipe
	130' to 150'	8" Bronze screen

The bottom of the screen was closed with a cement plug. The pipe was of threaded joints and the screen was welded.

Static Level: 11'6" below surface

Pumping: Well pumps 165 gallons per minute with a 28'6" drawdown. This is approximately 6 gallons per foot of drawdown. Well was pumped for 48 hours to clear off sand and mud.

Report will be made later of pump installation.

See separate report for chemical analysis.

N. H. Kellam
Asst. Chemical Engineer

BY THIS DEED	1911	1911
TO THE SAID	1911	1911
TO THE SAID	1911	1911
TO THE SAID	1911	1911
TO THE SAID	1911	1911
TO THE SAID	1911	1911
TO THE SAID	1911	1911

The portion of the ...
 This is a ...
 The ...

...
 ...
 ...
 ...
 ...

...
 ...
 ...
 ...
 ...

...
 ...
 ...
 ...

W E L L D A T A

Well No. 9

SPECIFICATIONS

Pump Base Elevation	31.3
Ground Elevation	29.3
Static Elevation	12.7
Maximum allowed Drawdown	-17
Total Discharge	200 G.P.M.
Total Head	85 Feet

TEST

206 G.P.M.	20# Pressure	Drawdown	- 19.5
185 G.P.M.	24# Pressure	Drawdown	- 16.1
165 G.P.M.	28# Pressure	Drawdown	- 14.4
145 G.P.M.	32# Pressure	Drawdown	- 6.5
135 G.P.M.	36# Pressure	Drawdown	- 2.5

Air line 62.5'

STATE OF TEXAS

County of _____

EXHIBIT


1. _____
2. _____
3. _____
4. _____
5. _____
6. _____
7. _____
8. _____
9. _____
10. _____

11. _____
12. _____
13. _____
14. _____
15. _____
16. _____
17. _____
18. _____
19. _____
20. _____

21. _____
22. _____
23. _____
24. _____
25. _____

H.P. Well 609

250 G.P.M. - DUAL DRIVE - 7 1/2 H.P.
260 actual. D.D.-11.6



DEPTH 178'

190'

610
12-18-92
TCE 37

D.T.A. WELL No. 10


610
12-18-92
TCE 37




610

12-18-92
TCE 37

250 G.P.M. - DUAL DRIVE - 7 1/2 H.P.
 260 actual. D.D.-11.6



DEPTH. 178'



SOURCE INFORMATION GROUND WATER

Date Form Completed

M M D D Y Y
0 1 2 4 9 5

PWSID
0467041

Owner Assigned
source Code

Well Name (If purchase, name of system)

010 HADNOT POINT 610

Code

G=Ground
W=Purchase/G
Y=G w/direct influence
Z=W w/direct influence

G

If Purchase, seller ID#

Source Begin Date

Source exempt—
SWTR?

Direct Influence Date

Availability

Source Begin Date: M M Y Y
SWTR? Y N

P=Permanent
E=Emergency
S=Seasonal
I=Interim
O=Other

T/A ABANDONED

Location of well within the system (If purchase, location of master meter)

HOLCOMB BLVD

Latitude (N)

Longitude (W)

How Determined

GPS Data

No. of Sats. Locked on

3 4 4 1 1 2

0 7 7 1 9 5 4

G=GPS
M=Map
S=Surveyed

Q# or
DOP #

(If purchase, use seller's primary source lat/long)

Vulnerable (VOCs) Y N
Assessment Date: M M D D Y Y

ENTRY POINT INFORMATION

Use Code

Availability

Owner Assigned
Entry Point Code

Entry Point Name

C=Ground/Permanent
D=Ground/non-permanent

P=Year-round
E=Emergency
S=Seasonal
I=Interim
O=Other

100 HP610

Location:

Well Site: Owned or controlled? (Y,N) Control Area (100' radius)? (Y,N) If no, explain:

Sources of pollution/distance:

Surface water within 200'? Y N If yes, actual distance feet If yes, bact. samples collected? (Y,N)

Adequate slope? (Y,N) Flooding? (Y,N) Maintenance:

Well House: Free of stored materials? (Y,N) Properly drained? (Y,N) Locked? (Y,N)

Condition of house: Type of freeze protection:

Well: Diameter: 8" Type: GRAVEL PACK Yield (gpm): 214 Properly sealed? (Y,N)

Properly vented? (Y,N) Casing depth 60 ft. (If unknown, put 'UNK') Well depth: 60' Meter available? N (Y,N)

Concrete slab adequate? (Y,N) If no, explain: Size:

Size of blow-off: 3" (V) Sample tap: Before treatment? (Y,N) After treatment? (Y,N)

Pumps: Capacity: GPM: 200 HP: 10 Pump intake depth: 190 Auxiliary Power? N (Y,N)

Type pump: VERTICAL TURBINE Height above floor (pump/casing): 26.5'

Storage at well site: Elev: Hydro: Ground:


If hydroautomatic, air volume control? (Y,N) Safety valves? (Y,N) Coded? (Y,N)


High service pumps: 1. gpm hp 2. gpm hp 3. gpm hp Auxiliary Power? (Y,N)

Is the water treated at this well? Y N If yes, complete back of form.

If other wells are treated here, which ones? If treated elsewhere, where? HP-20 PLANT

If purchase, retreat? Y N If yes, complete back of form.





WELL NUMBER 610		BY <i>Sardinas</i>			DATE 9-20-88	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
70'	30'	32'	2'	40	104	13:15
		33'	3'	35	125	13:30
		34'	4'	30	146	13:45
		42'	12'	25	164	14:00
		44'	14'	20	185	14:15
		46'	16'	15	195	14:30
		47'	17'	10	210	14:45
		48'	18'	5	222	15:00
						15:15

AH 62 psi

REMARKS

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE




WELL NUMBER 610		BY Thomas Brown			DATE 9-10-85	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
70'	30	32	2	38	100	15
		33	3	35	120	15
		34	4	32	130	15
		35	5	29	140	15
		36	6	25	150	15
		40	10	20	145	15
		46	14	10	200	15

REMARKS

used direct reading gauge
 need new gauge on air line

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



2-27-85

610 well House

Air Line 70 Feet

Top Screen 61' TO 73'

88' TO 109'

129' TO 141'

Re-Screened By EAST COAST CO.




WELL NUMBER 610		BY THOMAS - BROWN			DATE 3-29-85	
AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAIN DOWN	DISCHARGE PRESSURE	GPM	START TIME
70	25	35	10	40	105	1315
		37	12	37	120	1330
		40	15	33	135	1345
		41	16	30	150	1400
		43	18	25	165	1415
		45	20	21	175	1430
		45	20	18	185	1445
		46	21	14	195	1500
				10	205	1515

REMARKS

left test at 14 PST 195 GPM

MANUFACTURER	STAGE	S.N.	TOTAL HEAD	SIZE



Well 610 June 4, 1981

air line
50'

static	pumping level	drawdown	pressure	GPMS
21'	36'	15'	21	111
	40'	19'	18	128
	43'	22	15	140
	46'	24'	12	151


Set on
18 LBS
pressure

installed ashcroft liquid
pressure gauge

Well HP 610

T.V. inspection 10-27-82

showed worn screens
with possible collapsed lower
screen
screen




Well HP 610

T.V. inspection

10-27-82

showed worn screens
with possible collapsed lower
screen
screen



Well 610 June 4, 1981

air line
50'

static
21'

pumping level
36'

drawdown
15'

pressure
21

GPMS
111

Set on
18 LBS
pressure

40'

19'

18

128

43'

22

15

140

installed ashcroft liquid
pressure gauge

46'

24'

12

151



Well #.10

Date	Line Ft.	G.P.M.	D.D. El. FT	Static El. FT	Shut Off head FT	D.D. Ft.
6-4-53	45.5	185	AIR LINE BAD. UNABLE TO TAKE.		76	— OLD PUMP
"	40	200	Stage FT	—	—	"
9-9-53	62	180	-22.7	-1.3	92	21.4 NEW PUMP
"	46	225	-24.7	—	—	23.4 "
"	57	200	-23.7	—	—	22.4 "
9-14-53	76	?	-16.7	—	—	15.4 "
1-28-54	78	?	10	27		17 FT.
"	62	?	5	27		22
8/13/58	New Pump Installed					
11/1/66	AIRLINE 50'	199	1	37'	36'	SE WELL TEST
8/11/69	50'	130		37	35	SE WELL TEST.
9-4-69		130	-14.7	+17.3		32.0'

as of 3/1/67 well 10 has a Pomona Pump on Logans Bend
 19 FT. FROM PUMP BASE TO WATER BY MEASURE 9-10-53.

AIR LINE EL. LOWER END - 26.7

Air Line 46' NEW LINE. 9-10-53.

OLD LINE 60 FT.

Handwritten text at the top of the page, possibly a title or header.

Handwritten text in the middle section of the page.

Handwritten text in the lower middle section of the page.

Handwritten text at the bottom of the page, possibly a footer or concluding remarks.

CONSOLIDATED PUMP & EQUIPMENT, INC.

DISTRIBUTORS AND MANUFACTURER REPRESENTATIVES • WATER & WASTE WATER TREATMENT
POST OFFICE BOX 3188 • ROCK HILL, SOUTH CAROLINA 29731 • 803/328-1891

October 6, 1983

Contractor:

East Coast Const. Co.

Project:

Repair Water Wells
Bldgs 610, M628
Camp Lejeune, N. C.

Material Submitted:

Bldg 610

- 1 - Crane Deming Model XH6 9 Stage Vertical Turbine Pump, 10 HP, 1800 RPM, 240 Volt, 3 Phase, Combination Right Angle Gear Drive. COS 200 GPM @ 117' TDH

Bldg M628

- 1 - Crane Deming Model M6 9 Stage Vertical Turbine Pump, 7.5 HP, 1800 RPM, 208 Volt, 3 Phase.

OFFICE OF THE
OFFICER IN CHARGE OF CONSTRUCTION
CAMP LEJEUNE, NORTH CAROLINA

APPROVED

SUBJECT TO CONTRACT REQUIREMENTS

CONTRACT M62470-83-C-5842

DATE 10/19/83

R. E. CARLSON
CDR, CEC, USN
Officer in Charge
of Construction



DEPT. OF THE
OFFICE IN CHARGE
OF THE
RECORDS AND COMMUNICATIONS
SECTION

Bldg. 610

1 - Crane Deming Model XH6 Vertical Turbine Pump.

10 HP 1800 RPM, 240 Volt, 3 Phase US Motor, VHS, WP1

Model SD54-10 Discharge Head with Packing type seal, 6" companion flange discharge.

160' - 5" pump column with 1" drive shaft, water lubricated bearings, galvanized column.

10' - 5" suction pipe, galvanized.

5" bronze suction strainer.

3/4" steel foundation plate, 17" square.

Conditions of Service: 200 GPM @ 117' TDH


83% Eff. at design point, 7.12 BHP




SIZE XH6 SINGLE STAGE PERFORMANCE 1770 R.P.M.

EFFICIENCY CHANGE:		DIMENSIONS		FIG. 4700	FIG. 4750
3 STAGE DEDUCT	POINTS	BOWL DIAMETER		5 3/4	5 3/4
2 STAGE DEDUCT	0 POINTS	IMPELLER SHAFT DIA.			
1 STAGE DEDUCT	2 POINTS	LENGTH FIRST STAGE		17 1/8	20 1/8
ENAMELED BOWLS	4 POINTS	ADDITIONAL STAGE		6 1/2	6 1/2
		THRUST FACTOR		3.9	3.9


SUCTION - I.D. PIPE SIZE 4" SIZE COLUMN ADAPTER 4" " OR 5" SEMI-ENC. IMPELLER
 FOR OVER 40 STAGES CHECK BOWL LIMITATION ENGINEERING SECTION NO. 22957





INSTALLATION PLAN TYPE SD54 DISCHARGE HEAD

10 HP, 1800 RPM, VHS, 240 VOLT, 3 PH, 60 HZ.
 NRC, OTHER 215 TP




* COMBINATION RIGHT ANGLE GEAR DRIVE BETWEEN DISCHARGE HEAD AND MOTOR

DIMENSIONS ARE APPROXIMATE USE ONLY WHEN CERTIFIED

CUSTOMER	East Coast Construction Co.	ITEM NO.	B1dg. 610	GPM.	200
LOCATION	Camp Lejuene, N. C.	QUOTE NO.		T.D.H.	117'
	SPEC NO.	PUMP NO.	XH6	R.P.M.	1800
FOR APPROVAL	X	DATE	9/28/83	B.H.P.	10
	CERTIFIED				




DIMENSIONS OF TYPE SD DISCHARGE HEADS



HEAD SIZE	SYMBOL	A	B	C	D	E	F	G	H	J	K	M	N	P	Q	R	S	BF	AJ	AK	BD	T
SD34-10	34027									5 5/8	6											1 3/4
SD44-10	34028	14	12 3/8	2	5/8	6	7 1/2	0	15 1/2	5 5/8	6	9	4	5/8	7 1/2	19 1/8	12 3/4	7/16	9 1/8	8 1/4	10	1 3/4
SD54-10	34029									6 1/2	7											1 5/8
SD66-12	33715	17	14 1/2	2	7/8	6 1/2	9	3 3/4	15 1/2	9 7/8	10	11	6	3/4	9 1/2	23	15	7/16	9 1/8	8 1/4	12	
SD88-12	33716	17	14 1/2	2 1/8	7/8	7 3/4	9	4 1/4	16 1/2	12 3/4	13 1/4	13 1/2	8	3/4	11 3/4	23	15	7/16	9 1/8	8 1/4	12	
SD88-16 1/2	33717	20	17 1/16	2 1/8	7/8	7 3/4	10 1/2	4 1/4	16 1/2	12 3/4	13 1/4	13 1/2	8	3/4	11 3/4	27 3/8	18	11/16	14 3/4	13 1/2	16 1/2	


DEMING VERTICAL TURBINE PUMPS

Parts List No. 57G - Fig. 4700G Pumps With Stuffing Box



Item No.	Name of Part
1.	Vertical Hollowshaft Motor
2.	Discharge Head
3.	Stuffing Box Relief Assembly
4.	Grease Cup (To St. Box Bearing)
5.	Stuffing Box Packing
6.	Lantern Rings
7.	Stuffing Box Bearing
8.	Stuffing Box
9.	Shaft Coupling
10.	Bearing Retaining Cup
11.	Rivets
12.	Column Bearing
13.	Bearing Housing
14.	Intermediate Shaft
15.	Bottom Shaft
16.	Impeller Shaft Coupling
17.	Impeller Shaft
18.	Column Adapter
19.	Bowl Gaskets
20.	Bowl Bearing
21.	Snap Ring
22.	Cover Plate
23.	Intermediate Bowl
24.	Suction Bowl Cover Plate
25.	Suction Bowl Snap Ring
26.	Suction Bowl Bearing
27.	Wire Mesh Strainer
28.	Strainer Clamping Ring
29.	Motor Shaft
30.	Motor Shaft Coupling
31.	Stuffing Box Shaft
32.	Stuffing Box Gland (Split)
33.	Grease Cup (To Upper Lantern Ring)
34.	Stuffing Box Gasket
35.	Pipe Plug
36.	Discharge Flange
37.	Discharge Flange Gasket
38.	Top Column Flange Gasket
39.	Top Column Flange
40.	By-Pass Nipple With Orifice
41.	Top Column
42.	Column Coupling
43.	Intermediate Column
44.	Bottom Column
45.	Top Bowl
46.	Impeller Nut
47.	Impeller Sleeve
48.	Impeller
49.	Suction Bowl

NOTE - Specify pump serial number when ordering parts. This number will be found on the nameplate attached to the discharge head.



Vertical Motors

Section 504

Page 1

3 PHASE 60 CYCLES
230,460,575 VOLTS
40°C. AMBIENT-C.RISE WP-1

HOLLOSHAFT & SOLIDSHAFT
MOTORS
OPERATING CHARACTERISTICS

ENGINEERING DATA



HP	RPM		% EFFICIENCY			% POWER FACTOR			CURRENT IN AMPHERES 460 VOLTS		TORQUE AT FULL VOLTAGE			NEMA CODE
	NO LOAD	FULL LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	3/4 LOAD	1/2 LOAD	FULL LOAD	LOCKED (STARTING)	FULL LOAD TORQUE AT FULL LOAD SPEED (LB.FT.)	LOCKED	PULL OUT	
												(STARTING)	(BREAKDOWN)	
											PERCENT OF FULL LOAD			
2	900	860	75.0	74.5	70.0	68.0	60.0	47.5	3.9	18.0	12.2	130	210	J
	1800	1720	80.0	79.5	75.5	81.0	72.5	59.5	4.4	32.0	9.2	215	250	K
3	1200	1155	78.5	78.0	75.0	69.0	61.0	49.0	5.4	23.0	13.6	155	230	G
	900	860	78.5	79.0	75.5	67.5	59.0	46.0	5.8	30.5	18.3	130	205	K
5	3600	3480	81.0	82.0	80.5	86.0	80.5	69.5	6.9	45.0	7.5	150	215	H
	1800	1725	81.5	82.0	79.5	84.0	76.5	63.5	7.0	47.0	15.2	185	225	J
5	1200	1160	81.0	81.0	78.0	71.0	62.5	50.0	8.5	40.0	22.6	150	215	G
	900	875	80.5	80.0	77.0	72.0	64.0	51.0	8.2	44.0	30.0	130	205	H
7-1/2	3600	3460	84.0	85.0	84.0	88.0	84.0	75.5	9.8	63.0	11.4	140	200	H
	1800	1740	83.5	84.0	82.5	84.0	80.0	71.5	10.4	63.5	22.6	175	215	H
7-1/2	1200	1170	83.0	83.5	81.0	80.5	74.0	61.5	10.5	63.0	33.7	150	205	H
	900	875	80.5	80.5	77.5	71.5	63.0	50.5	12.5	63.0	45.0	125	200	K
10	3600	3500	83.5	84.0	83.0	87.0	84.0	76.5	13.4	79.0	15.0	135	200	H
	1800	1740	86.5	87.0	85.5	81.0	75.0	64.0	13.3	82.0	30.2	165	200	H
10	1200	1165	82.5	82.5	80.0	78.5	70.0	57.0	14.0	80.0	45.1	150	200	H
	900	875	86.0	86.5	84.5	72.0	65.0	53.0	15.5	81.0	60.0	125	200	H
15	3600	3485	85.0	86.5	86.0	88.5	87.0	82.0	19.5	112.0	22.6	130	200	G
	1800	1765	85.5	86.5	85.0	81.0	73.5	61.5	20.5	112.0	44.5	160	200	G
15	1200	1160	87.5	89.0	85.0	85.0	82.0	74.5	19.4	115.0	68.0	140	200	G
	900	870	86.0	87.5	86.5	75.5	69.5	58.5	22.5	118.0	90.6	125	200	G
20	3600	3515	85.5	87.0	87.0	89.0	87.5	82.5	25.4	145.0	29.9	130	200	G
	1800	1765	88.0	89.0	89.0	85.0	82.5	75.0	26.0	143.0	59.5	150	200	G
20	1200	1160	88.0	89.5	89.0	85.0	81.5	74.0	25.8	145.0	90.5	135	200	G
	900	880	85.0	86.5	86.0	74.5	69.0	57.0	30.5	140.0	120.0	125	200	G
25	3600	3510	89.0	90.0	89.0	88.5	87.0	81.0	30.4	172.0	37.4	130	200	F
	1800	1755	88.5	90.0	89.5	83.0	78.5	68.5	32.5	180.0	74.8	150	200	G
25	1200	1180	85.5	87.0	86.5	84.0	79.0	68.0	33.5	193.0	111.5	135	200	G
	900	880	86.0	88.0	87.5	77.0	72.0	61.0	36.5	175.0	150.0	125	200	G
30	3600	3510	89.5	90.5	89.5	87.5	85.0	78.0	37.0	218.0	44.9	130	200	G
	1800	1755	89.0	90.0	89.5	80.5	75.0	63.5	40.0	217.0	89.8	150	200	G
30	1200	1175	86.5	88.5	89.5	86.0	84.0	78.0	38.5	215.0	134.0	135	200	G
	900	880	88.0	89.5	89.5	75.0	70.0	59.5	43.5	205.0	179.0	125	200	G
40	3600	3515	90.0	91.0	90.0	86.5	83.0	75.0	48.5	310.0	59.8	125	200	G
	1800	1770	88.0	89.5	89.0	86.0	82.0	73.0	51.0	292.5	119.0	140	200	G
40	1200	1175	87.5	89.5	90.0	84.5	81.0	72.0	52.0	292.0	179.0	135	200	G
	900	875	88.0	90.0	90.0	76.0	71.5	61.0	57.5	280.0	240.0	125	200	F
50	3600	3540	88.0	89.5	89.0	87.0	84.5	78.0	63.0	350.0	74.2	120	200	G
	1800	1765	89.0	90.5	90.5	84.5	81.0	72.0	64.0	339.5	150.0	140	200	G
50	1200	1170	88.0	90.5	91.0	85.0	83.0	76.5	64.0	370.0	224.5	135	200	G
	900	875	88.5	90.0	90.0	80.0	76.0	67.0	68.0	325.0	300.0	125	200	G
60	3600	3540	89.5	91.0	91.0	89.0	89.0	86.0	72.5	410.0	89.0	120	200	G
	1800	1770	90.0	91.0	91.0	86.0	83.0	75.0	75.0	454.5	178.0	140	200	G
60	1200	1175	88.5	90.0	89.5	85.5	82.0	72.5	76.0	460.0	268.0	135	200	G
	900	875	89.0	90.5	90.5	80.5	77.0	68.0	80.5	410.0	360.0	125	200	G

See Page 2 for higher horsepowers and notes.


CUSTOMER NAME
CUST. ORD. NO.
U.S. ORD. NO.
MARK:
QTY. HP FRAME PHASE
HERTZ R.P.M. VOLTS



WPI-TYPE AU FRAMES 182 THRU 256TPA	HIGH THRUST VERTICAL HOLLOSHAFT NEMA P BASE	DIMENSIONS
FEATURES:		



Conduit opening may be located in steps of 90°. Standard as shown with conduit down.



ALL DIMENSIONS ARE IN INCHES


FRAME	P*	T	AA	AB	AC	AF	AG	AJ DIA.	AK -.003	BB	BD	BE	BF TAP SIZE	BV	CD	XC	XG	UNIMOUNT BRKT. P/N	
182TP		12-7/8	1-1/2	1	6-5/16	5-3/8	2-5/8	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
184TP		12-7/8	1-1/2	1	6-5/16	5-3/8	2-5/8	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
213TP		12-7/8	1-1/2	1	7-9/16	6-7/16	3-5/16	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
215TP		12-7/8	1-1/2	1	7-9/16	6-7/16	3-5/16	21-1/4	9-1/8	8-1/4	3/16	10	3/4	7/16	8	17-9/16	3-11/32	1-1/16	682186
254TP	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	10	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347107	
256TP	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	10	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347107	
254TPH	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	12	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347109	
256TPH	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	9-1/8	8-1/4	1/4	12	15/16	7/16	11-7/16	23-7/16	3-3/8	1-1/4	347109	
254TPA	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	11-7/16	23-7/16	3-3/8	1-1/4	347111	
256TPA	14	—	1-1/4	8-15/16	7-3/4	3-19/32	26-13/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	11-7/16	23-7/16	3-3/8	1-1/4	347111	
284TP	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	10	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347107	
286TP	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	10	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347107	
284TPA	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	12	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347109	
286TPA	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	9-1/8	8-1/4	1/4	12	15/16	7/16	12-1/4	24-13/16	3-3/8	1-1/4	347109	
284TPH	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	12-1/4	24-13/16	3-3/8	1-1/4	347111	
286TPH	14	—	1-1/2	9-3/16	7-5/8	4-7/16	28-3/16	14-3/4	13-1/2	1/4	16-1/2	15/16	11/16	12-1/4	24-13/16	3-3/8	1-1/4	347111	

All rough casting dimensions may vary by 1/4" due to casting variations.

TOLERANCES: "AK" Dimension: +.003, Face Runout: .004 F.I.R.
Permissible Eccentricity of Mounting Rabbet: .004 F.I.R.

* Largest Motor Diameter

All tapped holes are Unified National Course, right hand thread.



Effective: MAY 18, 1980
Supersedes: FEBRUARY 3, 1980

If properly endorsed this print is correct for frame & assembly positions indicated.
By _____ Date _____


PRINTED IN U.S.A.

amarillo

MARMON

RIGHT
ANGLE
GEAR
DRIVES



CATALOG NUMBER 30 • MARCH 1971



AMARILLO GEAR COMPANY - P.O. BOX 1789 - 2401 SUNDOWN LANE - A/C 806 622-1273, TWX 910-898-4128 - AMARILLO, TEXAS 79105

COMBINATION DRIVE

In response to the need for utmost reliability, a combination drive may be specified. This drive is normally installed with an electric motor top-mounted for constant service. In the event of power failure or motor failure the drive is simply converted for engine or turbine operation by lowering the integral sliding clutch into drive position. No additional pins or bolts are required for this conversion. These combination drives may be furnished with either solid or hollow shafts. Consult combination drive operation manual for installation instructions.



Combination Clutch — Sub-Assembly
Clutch Shown Disengaged

TABLE OF DIMENSIONS — COMBINATION DRIVE
TABLE 7

Model	D	N	Horizontal Shaft U			AJ	AK	BB	BD	BE	BF	XA	XB	XC	XL	XM	XN	XO	XQ	XR	XS	XT	XAJ	XAK	XBD	XBF	BX Bore Maximum
			Nominal	Actual	Keyway																						
C20	6 1/2	2 3/4	1 1/4	1.249	3/8 x 3/32	9 1/4	8.250	7/8	10	3/8	7/8	10 1/4			3/32	12 1/2	12 1/2	5 1/2	5 1/4	1/2	1 1/2	7/16					1"
C40A	8 1/2	4 3/4	1 1/2	1.499	3/8 x 7/16	9 1/4	8.250	1/4	12	7/16	7/8	15 1/2			3/32	16 1/2	16	6 1/2	7	3/8	2	3/8					1 1/4
C40B	8 1/2	4 3/4	1 1/2	1.499	3/8 x 7/16	14 3/4	13.500	1/4	16 1/2	7/16	1 1/8	15 1/2			3/32	16 1/2	16	6 1/2	7	3/8	2	3/8					1 1/4
C60	11 1/2	4 3/4	1 1/2	1.499	3/8 x 7/16	14 3/4	13.500	1/4	16 1/2	3/4	1 1/8	16 1/4			3/32	20 1/4	18	7 1/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C80	11 1/2	4 3/4	1 1/2	1.874	3/8 x 7/16	14 3/4	13.500	1/4	16 1/2	3/4	1 1/8	16 1/4			3/32	20 1/4	18	7 1/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C100	11 1/2	4 3/4	1 1/2	1.874	3/8 x 7/16	14 3/4	13.500	1/4	16 1/2	3/4	1 1/8	16 1/4			3/32	20 1/4	18	7 1/16	7 3/4	3/4	2 1/4	3/4					1 1/2
C125	11 1/2	4 3/4	2 1/16	2.436	3/8 x 7/16	14 3/4	13.500	1/4	16 1/2	3/4	1 1/8	18 1/2			3/32	21 1/8	18	7 1/2	9	3/4	2 1/4	3/4					1 11/16
C150	13 1/2	5 1/4	2 1/16	2.436	3/8 x 7/16	18 1/4	13.500	1/4	20	1 1/8	20 1/4	14 3/4	3/8-11-NC	3/32	25 1/8	20	9	10	3/4	2 3/4	3/4						2"
C200	13 1/2	5 1/4	2 1/16	2.436	3/8 x 7/16	18 1/4	13.500	1/4	20	1 1/8	20 1/4	14 3/4	3/8-11-NC	3/32	25 1/8	20	9	10	7/8	2 3/4	3/4						2
C275	16	6	2 1/16	2.936	3/4 x 3/8	23	13.500	1/4	24 1/2	1 1/8	1 1/8	125 1/2	14 3/4	3/8-11-NC	3/32	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1					2 7/16
C375	16	6	2 1/16	2.936	3/4 x 3/8	23	13.500	1/4	24 1/2	1 1/8	1 1/8	125 1/2	14 3/4	3/8-11-NC	3/32	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1					2 7/16
C450	16	6	3 3/4	3.749	3/4 x 7/16	23	13.500	1/4	24 1/2	1 1/8	1 1/8	125 1/2	14 3/4	3/8-11-NC	3/32	32 1/2	27	12	11 1/2	1 1/8	3 1/2	1					2 7/16
C600	18	6	3 3/4	3.749	3/4 x 7/16	23	13.500	1/4	24 1/2	1 1/8	1 1/8	126 1/2	14 3/4	3/8-11-NC	3/32	34 1/2	27	12 1/4	11 1/2	1 1/8	3 1/2	1 1/4					2 7/16
C750	21	8	4	3.998	1 x 1/2	28 1/2	22.000	1/4	30 1/2	1 1/4	1 3/16	36 1/2	26	3/4-10-NC	7/16	42	30	16 1/4	15	1 7/16	4	1 1/4					2 7/16
C1000G	21	8	4	3.998	1 x 1/2	28 1/2	22.000	1/4	30 1/2	1 1/4	1 3/16	36 1/2	26	3/4-10-NC	7/16	42	30	16 1/4	15	1 7/16	4	1 1/4					2 7/16

* Model C20, ratio 1:3, maximum clutch bore 7/8"; Model C150, ratio 1:3, maximum 1 1/16". Consult factory for maximum clutch bore for Fig. 2 and Fig. 3 rotation. Model C20, 1:3 ratio, not available with Fig. 2 or Fig. 3 rotation.

** Horizontal shaft dimensions shown for Model 450 apply to ratios in Table 4 only. Consult factory for dimensions of all others.

† "XA" dimensions shown apply to ratios in Table 4 only. Consult factory for dimensions of all others.


Please see pages 12, 13 and 14 for all information on Models 1000A, 1200, 1500 and 1800.

TABLE 3

NOTE: Drives that are rated at 1760 RPM vertical speed ARE NOT LIMITED to 1760 RPM. See Table 1.

MODEL	Vertical Shaft RPM	H.P. Rating	DOWNTHRUST CAPACITY IN POUNDS													
			HOLLOW SHAFT						SOLID SHAFT						COMB.	
			Type SL		Type S		Type SH		Type SSL		Type SS		Type SSH		Type C	
			Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
20	1160	15	0	978	797	2358	797	3680	0	978	0	2358			0	2358
	1460	18	0	901	760	2173	760	3392	0	901	0	2173			0	2173
	1760	20	0	850	700	2050	700	3200	0	850	0	2050			0	2050
	3460	30	0	680	534	1640	534	2560	0	680	0	1640			0	1640
40	1160	30	0	1495	1138	3565	1138	5520	0	1495	0	3565			0	3565
	1460	35	0	1378	1055	3286	1055	5088	0	1378	0	3286			0	3286
	1760	40	0	1300	1000	3100	1000	4800	0	1300	0	3100			0	3100
60	960	39	0	2074	1490	5002	1490	7320	0	2074	0	5002			0	5002
	1160	45	0	1955	1422	4715	1422	6900	0	1955	0	4715			0	4715
	1460	53	0	1802	1331	4346	1331	6360	0	1802	0	4346			0	4346
	1760	60	0	1700	1250	4100	1250	6000	0	1700	0	4100			0	4100
80	960	52	0	3904	2085	6954	2085	11224	0	3904	0	6954			0	6954
	1160	60	0	3680	1991	6555	1991	10580	0	3680	0	6555			0	6555
	1460	70	0	3392	1846	6042	1846	9752	0	3392	0	6042			0	6042
	1760	80	0	3200	1750	5700	1750	9200	0	3200	0	5700			0	5700
100	960	66	0	3904	2101	7198	2101	11224	0	3904	0	7198			0	7198
	1160	75	0	3680	1991	6785	1991	10580	0	3680	0	6785			0	6785
	1460	88	0	3392	1856	6254	1856	9752	0	3392	0	6254			0	6254
	1760	100	0	3200	1750	5900	1750	9200	0	3200	0	5900			0	5900
125	720	68	0	5535	3135	7965	3135	12420	0	5535	0	7965			0	7965
	960	83	0	5002	2722	7198	2722	11224	0	5002	0	7198			0	7198
	1160	94	0	4715	2560	6781	2560	10580	0	4715	0	6781			0	6781
	1460	110	0	4346	2387	6254	2387	9752	0	4346	0	6254			0	6254
150	720	80	0	6750	3520	9180	3520	14243	0	6750	0	9180	0	14243	0	9180
	960	98	0	6100	3234	8296	3234	12871	0	6100	0	8296	0	12871	0	8296
	1160	112	0	5750	3059	7820	3059	12133	0	5750	0	7820	0	12133	0	7820
	1460	132	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
200	720	107	0	6750	3531	9180	3531	14243	0	6750	0	9180	0	14243	0	9180
	960	131	0	6100	3242	8296	3242	12871	0	6100	0	8296	0	12871	0	8296
	1160	150	0	5750	3072	7820	3072	12133	0	5750	0	7820	0	12133	0	7820
	1460	176	0	5300	2864	7208	2864	11183	0	5300	0	7208	0	11183	0	7208
275	720	147	0	8100	3920	13973	3920	25650	0	8100	0	13973	3920	25650		
	960	180	0	7320	3600	12627	3600	23180	0	7320	0	12627	3600	23180		
	1160	206	0	6900	3410	11903	3410	21850	0	6900	0	11903	3410	21850		
	1460	241	0	6360	3169	10971	3169	20140	0	6360	0	10971	3169	20140		
375	720	201	0	8100	4586	25650	4586	33750	0	8100	0	15008	4871	27550		
	960	246	0	7320	4209	23180	4209	30500	0	7320	0	13973	4586	25650		
	1160	281	0	6900	3979	21850	3979	28750	0	6900	0	12627	4209	23180		
	1460	329	0	6360	3702	20140	3702	26500	0	6360	0	11903	3979	21850		
450	580	207	0	8700	5583	27550	5583	36250	0	8700	0	15008	5583	27550		
	720	241	0	8100	5236	25650	5236	33750	0	8100	0	13973	5236	25650		
	960	295	0	7320	4807	23180	4807	30500	0	7320	0	12627	4807	23180		
	1160	337	0	6900	4545	21850	4545	28750	0	6900	0	11903	4545	21850		
600	580	275	0	11600	6259	36250	6259	44645	0	11600	0	15008	6259	36250		
	720	321	0	10800	5885	33750	5885	41841	0	10800	0	13973	5885	33750		
	870	367	0	10080	5568	31500	5568	39532	0	10080	0	13041	5568	31500		
	960	393	0	9760	5404	30500	5404	38382	0	9760	0	12627	5404	30500		
750	580	344	0	11310	6959	36250	6959	44645	0	11310	0	15008	6259	36250		
	720	401	0	10530	6535	33750	6535	41841	0	10530	0	13973	5885	33750		
	870	458	0	9828	6177	31500	6177	39532	0	9828	0	13041	5568	31500		
	960	491	0	9516	6001	30500	6001	38382	0	9516	0	12627	5404	30500		
1000G	580	460	0	11310	9306	36250	9306	46738	0	11310						
	720	535	0	10530	8719	33750	8719	43802	0	10530						
	870	611	0	9828	8241	31500	8241	41385	0	9828						
	960	654	0	9516	7994	30500	7994	40181	0	9516	CONSULT FACTORY			CONSULT FACTORY		
1760	1160	747	0	8970	7556	28750	7556	37963	0	8920						
	1460	877	0	8268	7048	26500	7048	35432	0	8268						
	1760	1000	0	7800	6667	25000	6667	33500	0	7800						

Please see pages 12, 13 and 14 for all information on Models 1000A, 1200, 1500 and 1800.



CONTRACTOR'S SUBMITTAL TRANSMITTAL

5ND LANTDIV 4-355/3 (Rev. 6/76)

Copy to Prod Com 02

[Handwritten signature]

FROM CONTRACTOR

East Coast Construction Co. Inc.

TO

Officer in Charge of Construction

CONTRACT NO. *83-C-5842* TRANSMITTAL NO. *5* DATE *2/2/84*

PROJECT TITLE AND LOCATION
Repair Water Wells Bldgs 610 & M-628
MCR CAMP LEJEUNE NC.
Well No 610

CONTRACTOR USE ONLY

*List only one specification division per form.

List only one of the following categories on each transmittal form, and indicate which is being submitted

- Contractor Approved OICC Approval Deviation/Substitution For OICC Approval

REVIEWER USE ONLY

**ACTION CODES

- A-Approved
- D-Disapproved
- AN-Approved as noted
- RA-Receipt acknowledged.
- C-Comments
- R-Resubmit

ITEM NO.	PROJ. SPEC. SECT. & PARA. and/or PROJ. DWG. NO. *	ITEM IDENTIFICATION (Type, size, model no., Mfg. name, dwg. or brochure number)	NO. OF COPIES	ACTION CODES **	REVIEWER'S INITIALS CODE AND DATE
<i>1</i>	<i>15201-3.5</i>	<i>24 hour Pumping Test</i> <i>Well No 610 Holcomb Blvd</i>	<i>6</i>		

CONTRACTOR'S COMMENTS

COPY OF TRANSMITTAL AND SUBMITTALS TO ROICC

CONTRACTOR REPRESENTATIVE (Signature)

Ronald L. Miller

DATE RECEIVED BY REVIEWER

FROM (Reviewer)

- Submittals are returned with action indicated. Approval of an item does not include approval of any deviation from the contract requirements unless the contractor calls attention to and supports the deviation.
- Submittals are forwarded to LANTDIV with A-E recommendations indicated in REVIEWER USE ONLY Section and in comments below on ONE COPY of the transmittal form.


REVIEWER'S COMMENTS

RECEIVED
 ROICC/JANICA
 FEB 21 PM '84

RECEIVED

MAR 1 1984

COPIES TO: ROICC (2) LANTDIV (1) A-E (1)	DATE	SIGNATURE <i>East Coast Construction Co., Inc.</i>
---------------------------------------------------	------	-------------------------------------------------------




PUMPING TEST DATA


Test conducted by: Carolina Well & Pump Co. R. Thomas - R. Patterson
 Well Owner: U. S. Marine Corp. Address: _____
 Pumped Well No.: 610 Location: Holcomb County: Onslow
 Observation Well Locations: _____
 Airline Lengths: Pumped Well _____ Observation Wells _____
 Remarks: _____

Pumping rate measured with: 4 x 6 orifice Water levels measured with: electric tape

Pump Well Data

Date and Time	Elapsed Time Min.	Piezometer Tube Reading Inches	Pumping Rate GPM	Pump Discharge Pressure	Altitude Gauge Reading Feet	Feet to Water	Remarks
1/24/84							
9:30 AM		15	250			17' 11"	
9:35	5 min.	"	"			18' 2"	
9:40	10	"	"			18' 5"	
9:45	15	"	"			18' 7"	
9:50	20	"	"			18' 9"	
9:55	25	"	"			18' 11"	
10:00	30	"	"			19' 5"	
10:05	35	"	"			22' 8"	
10:10	40	"	"			24' 10"	
10:15	45	"	"			24' 10"	
10:20	50	"	"			25' 0"	
10:25	55	"	"			25' 4"	
10:30	60	"	"			25' 4"	
10:35	65	"	"			25' 4"	
10:40	70	"	"			25' 4"	
10:45	75	"	"			25' 4"	
10:50	80	"	"			25' 4"	
10:55	85	"	"			25' 7"	
11:00	90	"	"			25' 7"	
11:05	95	"	"			25' 7"	
11:10	100	"	"			25' 7"	
11:15	105	"	"			25' 7"	
11:20	110	"	"			25' 7"	
11:25	115	"	"			25' 7"	
11:30	120	"	"			25' 7"	
11:45	135	"	"			25' 7"	
12:00	150	"	"			25' 9"	
12:15	165	"	"			25' 9"	
12:30	180	"	"			26' 3"	
1:30	240	"	"			26' 3"	
2:30	300	"	"			26' 3"	
3:30	360	"	"			26' 3"	
4:30	420	"	"			26' 10"	
5:30	480	"	"			26' 10"	
6:30	540	"	"			26' 10"	
7:30	600	"	"			26' 10"	
8:30	660	"	"			27' 10"	
9:30	720	"	"			27' 10"	
10:30	780	"	"			27' 10"	
11:30	840	"	"			27' 10"	
12:30	900	"	"			27' 10"	
1:30	960	"	"			27' 10"	
2:30	1020	"	"			27' 10"	
3:30	1080	"	"			27' 10"	





PHYSICAL / CHEMICAL ANALYSIS OF WATER

SAMPLE NO.

FROM: (Station or unit)

Well 10 Bldg 610 HP

DATE

8-12-57

TO: (Name and location of laboratory)

SAMPLE FROM (Location of sampling point)

COLLECTED BY

Shackelford

DATE

8-17-57

HOUR

SOURCE (Designate ground, surface, raw, treated)

Raw

REASON FOR EXAMINATION

EXAMINATION REQUESTED BY

NOTE: All results reported in parts per million unless otherwise noted except for pH, temperature, and specific conductance. One liter of potable water is assumed to weigh one kilogram.

I. FIELD ANALYSIS			III. ROUTINE LABORATORY ANALYSIS		
1. pH	TEMPERATURE		(CHECK ONE)		
	°F	°C	REQUESTED	NOT REQUESTED	
ITEM	PPM		1. COLOR		
2. CARBON DIOXIDE (CO ₂)					
3. DISSOLVED OXYGEN (O ₂)					
4. HYDROGEN SULFIDE (H ₂ S)					
5. CHLORINE DEMAND (Cl ₂)					
FIELD ANALYSIS BY			P	MO	
			<i>0</i>	<i>127</i>	
DATE OF ANALYSIS			4. TOTAL HARDNESS (CaCO ₃)		
			<i>126</i>		
II. SPECIAL LABORATORY ANALYSES			5. NON-CARBONATE HARDNESS (CaCO ₃) (By Computation)		
Check (X) individual items to be included in the Special Analyses. Request determination only of those substances suspected of being present in significant amounts.			6. CARBONATE HARDNESS (CaCO ₃) (By Computation)		
			7. TOTAL DISSOLVED SOLIDS		
(X)	ITEM	PPM	ITEM		
	1. As		9. CALCIUM (Ca) <i>48.0</i> 10. MAGNESIUM (Mg) <i>1.2</i> 11. SODIUM (Na) AND POTASSIUM (K) 12. HYDROXIDE (OH) 13. BICARBONATE (HCO ₃) <i>CaCO₃</i> 14. CARBONATE (CO ₃) <i>CaCO₃</i> 15. SULFATE (SO ₄) 16. CHLORIDE (Cl) <i>8.0</i> 17. NITRATE (NO ₃) 18. IRON (Fe) TOTAL <i>1.5</i> 19. MAGANESE (Mn) 20. SILICA (SiO ₂) 21. FLUORIDE (F)		
	2. Se				
	3. Pb				
	4. B				
	5. Cu				
	6. Zn				
	7. Cr (Hexavalent)				
	8. PO				
	9. Cd				
	10. CN				
	11. Phenolic Compounds (PPB)				
	12. Others (Specify)				
	13.				
	14.				
	15.				
	16.				

*State whether determined or computed from P and MO alkalinity.

REMARKS (Such as unusual appearance, taste, odor, etc.)

LABORATORY ANALYSIS BY

DATE OF ANALYSIS



REGIONAL CHEMICAL ANALYSIS REPORT

Form 100-10

LABORATORY NO. 100-10-100

DATE 10-10-10

TIME 10:10

THIS REPORT IS VALID IN ALL STATES EXCEPT WHERE SHOWN OTHERWISE

TEST NO. 100-10-100

100-10-100

LABORATORY NO. 100-10-100

DATE 10-10-10

REGIONAL CHEMICAL ANALYSIS REPORT

THIS REPORT IS VALID IN ALL STATES EXCEPT WHERE SHOWN OTHERWISE

TEST NO. 100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

100-10-100

DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE M61	2. TYPE Q	3. LATITUDE ° ' " N 34 41 13	4. LONGITUDE ° ' " W 77 19 53	5.
------------------------------	---------------------	-------------------------------------------	--------------------------------------------	----

6. AGENCY STATION NO. 610	7. STATION NAME HP20-610
-------------------------------------	------------------------------------

8. DRAINAGE BASIN CODE No. Letter 106 N	9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONslow
------------------------------------------------------	----------------------------	-------------------------------	----------------------------------

12. PERIOD OF RECORD Began Discontinued 1942	Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption Exceeds 1 Year	13.	14.
-----------------------------------------------------------	-----------------------------------------------------------------------------------------------	-----	-----

15. SITE	<input type="checkbox"/> 101 Stream	<input type="checkbox"/> 103 Lake	<input type="checkbox"/> 106 Spring
	<input type="checkbox"/> 102 Canal	<input type="checkbox"/> 104 Reservoir	<input checked="" type="checkbox"/> 107 Well
		<input type="checkbox"/> 105 Estuary	<input type="checkbox"/> 110 Other

16. FREQUENCY OF MEASUREMENT	<input type="checkbox"/> 201 Continuous Recorder	<input type="checkbox"/> 203 Daily	<input type="checkbox"/> 207 Seasonal
	<input type="checkbox"/> 202 Telemetered	<input type="checkbox"/> 204 Weekly	<input type="checkbox"/> 208 Annual
		<input type="checkbox"/> 205 Monthly	<input type="checkbox"/> 209 Other Periodic
		<input type="checkbox"/> 206 Quarterly	<input checked="" type="checkbox"/> 210 Occasional

17. TYPES OF DATA AVAILABLE	<i>Physical</i>	<i>Chemical</i>	<i>Organic</i>
	<input type="checkbox"/> 311 Temperature	<input type="checkbox"/> 331 Dissolved solids	<input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.)
	<input type="checkbox"/> 312 Specific Conductance	<input checked="" type="checkbox"/> 332 Chlorides Only	<input type="checkbox"/> 352 Synthetic detergents
	<input type="checkbox"/> 313 Turbidity	<input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds)	<input type="checkbox"/> 353 Other
	<input type="checkbox"/> 314 Color		<i>Biologic</i>
	<input type="checkbox"/> 315 Odor	<input type="checkbox"/> 334 Common ions	<input type="checkbox"/> 361 Coliforms
	<input type="checkbox"/> 316 Radioactivity	<input checked="" type="checkbox"/> 335 Hardness	<input type="checkbox"/> 362 Other Micro-organisms
	<input type="checkbox"/> 317 pH (field)	<input type="checkbox"/> 336 Radiochemical	<input type="checkbox"/> 363 BOD
	<input checked="" type="checkbox"/> 318 pH (lab)	<input type="checkbox"/> 337 Dissolved oxygen	<input type="checkbox"/> 364 Other
	<input type="checkbox"/> 319 Eh	<input type="checkbox"/> 338 Other Gases	<i>Sediment</i>
	<input type="checkbox"/> 320 Other	<input type="checkbox"/> 339 Other	<input type="checkbox"/> 371 Concentration
			<input type="checkbox"/> 372 Particle size
			<input type="checkbox"/> 373 Other

18. SUPPLEMENTARY DATA FOR SITE	<input type="checkbox"/> 421 Surface Water Station	<input type="checkbox"/> 423 Water Stage or Level	<input type="checkbox"/> 425 Time of Travel
	<input type="checkbox"/> 422 Ground Water Station	<input checked="" type="checkbox"/> 424 Water discharge	<input type="checkbox"/> 426 Drainage Area

19. STORAGE OF DATA	<input type="checkbox"/> 501 Periodic Report	<input checked="" type="checkbox"/> 503 Not Published	<input type="checkbox"/> 505 Data on Magnetic Tape
	<input type="checkbox"/> 502 Areal Report	<input type="checkbox"/> 504 Data on Punchcard	<input type="checkbox"/> 506 Other

20. OFFICE AT WHICH DATA AVAILABLE	Office BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION
	Street No. MARINE CORPS BASE
	City, State, Zip CAMP LEJEUNE, N. C. 28542
	City Code 0735

21. OFFICE COMPLETING FORM	BASE MAINTENANCE DEPARTMENT
----------------------------	------------------------------------

22. COMPILER'S NAME	F. E. TEW, JR.	23. DATE	Month SEPT Year 1966
---------------------	-----------------------	----------	------------------------------------



Marine Barricks
New River, N. C.
April 20, 1942

WELLS-PERMANENT WATER SUPPLY-REGIMENTAL AREA
By Layne Atlantic Company

Report on Well No. 10

Location: West side of main access Road, 3000' South of Wallace Creek Bridge. As shown on M. B. Drwg. No. 521.

Date Drilled: April 1942

Status: A 23" hole cased with 18" I. D. steel casing to a depth of 30' below surface. The annular space around this was filled with cement grout. A 17½" hole drilled to a total depth of 198'.

Log of formation:

0 to 30'	White Sand
30' to 33'	Blue Clay
33' to 47'	Sand and clay (tight)
47' to 94'	Sand and Blue Clay with Shells
94' to 161'	Rock hard and soft layers
161' to 169'	Rock, Sand and Shells
169' to 171'	Hard Rock
171' to 198'	Rock, Sand and Shells

Remarks: Because of the presence of Sand in the Rock formation it was necessary to construct a gravel wall well.

**Gravel Wall
Constructions:** An 8" steel pipe with sections of Silicon Bronze Shatter screen was lowered into the 17½" hole to a dept of 190'. The annular space around this was filled with a special ¼" Cap May gravel.

Log of screen Setting:

0 to 60'	8" Steel pipe
60' to 70'	8" Bronze screen
70' to 90'	8" Steel pipe
90' to 110'	8" Bronze screen
110' to 130'	8" Steel pipe
130' to 140'	8" Bronze screen
140' to 180'	8" Steel pipe
180' to 190'	8" Bronze screen

The bottom of the screen was filled with a cement plug. The steel pipe was of threaded joints and the screen was welded.

Static Level: 16' below surface.

Pumping: After 25 hours pumping well gave a constant flow of 250 gallons per minute with a 24 foot draw down from static level. Pumps 390' gallons per minute with a draw down of 40' from static level.

April 20, 1931

WELL-REPAIRMENT WATER SUPPLY-INDUSTRIAL AREA

By James A. Smith

Record on Well No. 10

West side of Main Street, North 3000' South of Well No. 10
Creek bridge, as shown on N. 24' map, N. 21'.

Location

Date Drilled:

2 1/2" hole cased with 1 1/2" I. P. steel casing to a depth of 30'. Below surface, the water space around this was filled with cement grout. A 1 1/2" hole drilled to a depth of 100'.

Depth

Log of formation

10' to 15'	Rock, sand and shells
15' to 20'	Hard rock
20' to 25'	Black sand and shells
25' to 30'	Black hard and soft layers
30' to 35'	Sand and blue clay with shells
35' to 40'	Hard and clay (light)
40' to 45'	Blue clay
45' to 50'	White sand

In view of the presence of sand in the well formation it was necessary to construct a gravel well.

Remarks

Gravel Well

An 8" steel pipe with sections of Milliam Brown Gravel screen was lowered into the 1 1/2" hole to a depth of 100'. The water space around this was filled with a special 3/4" gravel.

Construction

Log of screen settings

100'	8" Brown screen
110'	8" Steel pipe
120'	8" Brown screen
130'	8" Steel pipe
140'	8" Brown screen
150'	8" Steel pipe
160'	8" Brown screen
170'	8" Steel pipe
180'	8" Brown screen
190'	8" Steel pipe
200'	8" Brown screen

The bottom of the screen was filled with a cement plug. The steel pipe was of standard joints and the screen was welded.

Static level

10' below surface.

Remarks

After 22 hours running well gave a constant flow of 250 gallons per minute with a 24' foot draw down from static level. Pressure 100' from surface 10' from static level.

WATER ANALYSIS

By N. H. Kellam

Date April 10 42

Sample from Supply Well at Well site No. 10

Reg area

Total Solids _____ PPM Dissolved Solids _____ PPM

Suspended Solids _____ PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ _____ PPM

Total Alk. " " 130 " Ferrous Iron as Fe _____ "

Carbonates " " 0 " Total Iron as Fe _____ "

Bicarbonates " " 130 " Aluminum as Al. _____ "

Chlorides as Cl. 25 " Calcium as Ca. _____ "

Sulphates as SO₄ _____ " Magnesium as Mg. _____ "

Nitrites as NO₂ _____ " Sodium as Na. _____ "

Carbon Dioxide as CO₂ _____ "

pH 6.8 Soap Hardness as CaCO₃ _____ PPM

Odor Slight Turbidity _____

REMARKS _____

JF

[Faint, illegible text, possibly bleed-through from the reverse side of the page. The text is mirrored and difficult to decipher.]

W E L L D A T A

Well No. 10

SPECIFICATIONS

Pump Base Elevation	46.0	30.3
Ground Elevation	44.0	28.3
Static Elevation	12.3	
Maximum allowed Drawdown	-11.7	
Total Discharge	250 G.P.M.	
Total Head	81 Feet	

TEST

305 G.P.M.	10#	Pressure	Drawdown	-14.2
290 G.P.M.	12.5#	Pressure	Drawdown	-13.2
275 G.P.M.	15#	Pressure	Drawdown	-11.4
250 G.P.M.	19#	Pressure	Drawdown	-7.2
200 G.P.M.	29#	Pressure	Drawdown	-2.6
188 G.P.M.	30#	Pressure	Drawdown	-1.5

Recovers to elevation \downarrow 10 in three (3) minutes.

This well should be discharged out side for 30 minutes before pumping into line, and should not be pumped over 200 G.P.M. as it will pump sand.

Air line 61.5'

W E L L D A T A

Well No. 10

INVESTIGATIONS

48.0	Top Base Elevation
44.0	Ground Elevation
19.8	Static Elevation
-11.7	Maximum Allowed Drawdown
300 p.p.m.	Total Chloride
81 feet	Total Lead

		<u>TEST</u>		
-1.8	Drawdown	10'	Pressure	305 p.p.m.
-1.8	Drawdown	12.5'	Pressure	300 p.p.m.
-1.4	Drawdown	13'	Pressure	275 p.p.m.
-7.2	Drawdown	15'	Pressure	350 p.p.m.
-8.0	Drawdown	20'	Pressure	300 p.p.m.
-1.8	Drawdown	30'	Pressure	185 p.p.m.

Recovers to elevation + 10 in three (3) minutes.

This well should be abandoned out side for 30 mi. before pumping into line, and should not be pumped over 300 p.p.m. as it will pump sand.

W E L L D A T A

Well No. 10

SPECIFICATIONS


Pump Base Elevation	46.0
Ground Elevation	44.0
Static Elevation	12.8
Maximum allowed Drawdown	-11.7
Total Discharge	250 G.P.M.
Total Head	81 Feet

TEST

305 G.P.M.	10#	Pressure	Drawdown	-14.2
290 G.P.M.	12.5#	Pressure	Drawdown	-13.2
275 G.P.M.	15#	Pressure	Drawdown	-11.4
250 G.P.M.	19#	Pressure	Drawdown	- 7.2
200 G.P.M.	29#	Pressure	D_sawdown	- 2.6
188 G.P.M.	30#	Pressure	Drawdown	- 1.5

Recovers to elevation + 10 in three (3) minutes.

This well should be discharged out side for 30 minutes before pumping into line, and should not be pumped over 200 G.P.M. as it will pump sand.




250 G.P.M. - SINGLE DRIVE - I.C.H.P.

253 " " actual. D.D. - 8.35

260 " " " D.D. - 8.90

Pump Endn.

EL. 33.0
EL. 31.0



Armco Iron Screen Used In This Well





Power Source
for Living

HAYES & LUNSFORD ELECTRICAL CONTR'S INC.
P.O. BOX 754, ASHEVILLE, NC 28802

THIS SUBMITTAL AND/OR TECHNICAL DATA
REFERS TO SECTION 16.216 PARAGRAPH 1.4
OF THE SPECIFICATIONS

Prepared for:

Hayes & Lunsford

Post Office Box 754

Asheville, NC 28802

Project: Building 610

Building BB 221

Building LCH 4007



Prepared by:

Owsley & Sons, Inc.

Drawer L

Fort Mill, SC 29715

OWSLEY & SONS INCORPORATED


FORT MILL, S.C.
803 548-3636

GREENSBORO, N.C.
919/668-2454

WILMINGTON, N.C.
919/763-4666

RICHMOND, VA.
804/275-2603





SUMMARY OF ACCEPTANCE REQUIREMENTS

BLDG 610, BB221, LCH4007


Contract N62470-85-B6441

ENGINE GENERATOR

- 16216-1.4.1 Provide anchor bolt details for setting on foundation.
- 16216-1.4.2 Provide certified vibration stress reports for each diesel engine and prototype test reports for the generator.
- 16216-2.1.1 Generator set for Bldg LC 4007 required to supply 40 kW output. (Quotation form states 30 kW but Mfgr states 44 kW). Discrepancy is noted but generator with 44 kW is satisfactory.
- 16216-2.3.2.3 Provide voltage adjusting rheostat.

MUFFLER

- 16216-2.12 The muffler finish shall be zinc coated or phosphated and prime painted unless enclosed in the housing.



QUOTE # 197-96

DATE: November 18, 1986

PROJECT: Building 610

1 Model 40DL6 ONAN Housed, Water Cooled, Diesel
Engine Driven Generator Rated 30 KW Continuous Standby at 120/240
VOLTS, 37.5 KVA, 3 PHASE, 4 WIRE, 60 HERTZ, per spec sheet A-869
attached with the following modifications & accessories:

FUEL SYSTEM

Diesel

Flexible fuel lines
Day tank 25 gallons
with electric fuel pump and accessories:
weather proof
Fuel tank 275 gallons
aboveground
steel double wall
with internal fitting kit to include:
fill cap, vent
Levelometer/Fuel Gauge

COOLING SYSTEM

Unit mounted radiator
3 gallons Anti-freeze
Engine block heater 120 V.A.C. 1 phase.

CONTROLS, INSTRUMENTS AND SAFETIES

Voltmeter-Ammeter Phase selector with
OFF position, frequency meter, running time meter.
Governor: Electrical
Main line circuit breaker 3 pole, 100 amps
mounted on generator
Individual fault lamps for:
Low oil pressure shutdown
High engine temperature
Overspeed shutdown
Overcrank cutout
Switch not in automatic
Prealarm for low oil pressure, and high engine temperature.
Remote annunciator panel
Alarm howler
Oil pressure gauge, water temperature gauge
battery charge ammeter.

ENCLOSURES AND EXHAUST COMPONENTS

Muffler grade: residential
Weather protective enclosure: Steel
Exhaust system: mounted on generator enclosure
Raincap

<input type="checkbox"/>	ACCEPTED	<input type="checkbox"/>	NOT ACCEPTED
<input checked="" type="checkbox"/>	ACCEPTED AS CORRECTED	(SEE SUMMARY)	
<input type="checkbox"/>	REVISE AND RESUBMIT		

Checking is for compliance with the information given in the plans and/or specifications and for conformance with the design concept of the project only. Contractor is responsible for dimensions to be verified and correlated at the job and for the coordination of the work of all trades and subject to all Contract requirements.

BY MD DATE 12/1/86
ALLEN & HOSHALL, INC.

STATE WAS RECEIVED
 RECEIVED VS. COMPLETED
 RECEIVED NOT RECEIVED

TRANSFER SWITCH AND ACCESSORIES

1 ONAN Automatic transfer switch model

OTBCD 100-*U/3401

*5D Building 610 & Building LCH4007

*4 Building BB221

rated 120/240 / 120/208 volts, 120 amp, 3 phase, 3 pole.
with the following characteristics and options
per spec sheet: A-878.

Undervoltage sensing

Under/Over frequency sensing

Time delay engine start

Time delay engine stop

Time delay on transfer

Time delay on retransfer

Simulated power failure switch

Lamps to indicate: load connection

Auxiliary contacts:

normal side

emergency side

Nema class 4 enclosure

Neutral bar

Manual transfer operator handle

MISCELLANEOUS MATERIALS AND TESTING

Starting battery: 12 VDC

Lead Acid

Battery: rack

SCR battery float charger 10 amp.

12 quarts engine lubrication oil

Vibration isolators

Standard between Eng/Gen & skid base


Operators manuals

1 Year Warranty

Initial startup and checkout not to exceed 4 hours.

Load bank test of 8 hours.

WE OFFER NO BID ON THE FOLLOWING: extended wiring or piping
(fuel or exhaust cooling)
exhaust insulation





Drawer L
Fort Mill, S.C. 29715
803/548-3636

P.O. Box 34508
Richmond, VA. 23234
804/275-2603

P.O. Box 8627
Greensboro, N.C. 27419
919/668-2454

P.O. Box 1058
Wilmington, N.C. 28402
919/763-4666

QUOTE # 197-96

DATE: November 18, 1986

PROJECT: Building BB221

1 Model 40DL6 ONAN Housed, Water Cooled, Diesel
Engine Driven Generator Rated 30 KW Continuous Standby at 120/208.
VOLTS, 37.5 KVA, 3 PHASE, 4 WIRE, 60 HERTZ, per spec sheet A-869
attached with the following modifications & accessories:

FUEL SYSTEM

Diesel

- Flexible fuel lines
- Day tank 25 gallons
with electric fuel pump and accessories:
weather proof
- Fuel tank 275 gallons
aboveground
steel double wall
with internal fitting kit to include:
fill cap, vent
Levelometer/Fuel Gauge

COOLING SYSTEM

- Unit mounted radiator
- 3 gallons Anti-freeze
- Engine block heater 120 V.A.C. 1 phase.

CONTROLS, INSTRUMENTS AND SAFETIES

- Voltmeter-Ammeter Phase selector with
OFF position, frequency meter, running time meter.
- Governor: Electrical
- Main line circuit breaker 3 pole, 100 amps
mounted on generator
- Individual fault lamps for:
Low oil pressure shutdown
High engine temperature
Overspeed shutdown
Overcrank cutout
- Switch not in automatic
- Prealarm for low oil pressure, and high engine temperature.
- Remote annunciator panel
- Alarm howler
- Oil pressure gauge, water temperature gauge
battery charge ammeter.

ENCLOSURES AND EXHAUST COMPONENTS

- Muffler grade: residential
- Weather protective enclosure: Steel
- Exhaust system: mounted on generator enclosure
- Raincap

<input type="checkbox"/>	ACCEPTED	<input type="checkbox"/>	NOT ACCEPTED
<input checked="" type="checkbox"/>	ACCEPTED AS CORRECTED	(SEE SUMMARY)	
Checking is for compliance with the information given in the plans and/or specifications and for conformance with the design concept of the project only. Contractor is responsible for dimensions to be verified and correlated at the job and for the coordination of the work of all trades and subject to all Contract requirements.			
BY <u>MD</u>		DATE <u>12/1/86</u>	
ALLEN & HOSHALL, INC.			

VICTIM'S RIGHTS
SECTION

PLEASE PRINT NAME AND ADDRESS OF VICTIM
NAME: _____ ADDRESS: _____
CITY: _____ STATE: _____ ZIP: _____

MAKE YOUR REPORT
 RECEIVED & COLLECTED
 RECEIVED NOT RECEIVED

TRANSFER SWITCH AND ACCESSORIES

1 ONAN Automatic transfer switch model

OTBCD 100-*U/3401

*5D Building 610 & Building LCH4007

*4 Building BB221

rated 120/240 / 120/208 volts, 120 amp, 3 phase, 3 pole.
with the following characteristics and options
per spec sheet: A-878.

Undervoltage sensing

Under/Over frequency sensing

Time delay engine start

Time delay engine stop

Time delay on transfer

Time delay on retransfer

Simulated power failure switch

Lamps to indicate: load connection

Auxiliary contacts:

normal side

emergency side

Nema class 4 enclosure

Neutral bar

Manual transfer operator handle

MISCELLANEOUS MATERIALS AND TESTING

Starting battery: 12 VDC

Lead Acid

Battery: rack

SCR battery float charger 10 amp.

12 quarts engine lubrication oil

Vibration isolators

Standard between Eng/Gen & skid base


Operators manuals

1 Year Warranty

Initial startup and checkout not to exceed 4 hours.

Load bank test of 8 hours.

WE OFFER NO BID ON THE FOLLOWING: extended wiring or piping
(fuel or exhaust cooling)
exhaust insulation



QUOTE # 197-96
PROJECT: Building ECH 4007
1 Model 40DL6 ONAN Housed, ⁴⁰Water Cooled, Diesel
Engine Driven Generator Rated 30 KW, Continuous Standby at 120/240
VOLTS, 37.5 KVA, 3 PHASE, 4 WIRE, 60 HERTZ, per spec sheet A-869
attached with the following modifications & accessories:

FUEL SYSTEM

Diesel
Flexible fuel lines
Day tank 25 gallons
with electric fuel pump and accessories:
weather proof
Fuel tank 275 gallons
aboveground
steel double wall
with internal fitting kit to include:
fill cap, vent
Levelometer/Fuel Gauge

COOLING SYSTEM

Unit mounted radiator
3 gallons Anti-freeze
Engine block heater 120 V.A.C. 1 phase.

CONTROLS, INSTRUMENTS AND SAFETIES

Voltmeter-Ammeter Phase selector with
OFF position, frequency meter, running time meter.
Governor: Electrical
Main line circuit breaker 3 pole, 100 amps
mounted on generator
Individual fault lamps for:
Low oil pressure shutdown
High engine temperature
Overspeed shutdown
Overcrank cutout
Switch not in automatic
Prealarm for low oil pressure, and high engine temperature.
Remote annunciator panel
Alarm howler
Oil pressure gauge, water temperature gauge
battery charge ammeter.

ENCLOSURES AND EXHAUST COMPONENTS

Muffler grade: residential
Weather protective enclosure: Steel
Exhaust system: mounted on generator enclosure
Raincap

<input type="checkbox"/> ACCEPTED	<input type="checkbox"/> NOT ACCEPTED
<input checked="" type="checkbox"/> ACCEPTED AS CORRECTED	
<input type="checkbox"/> REVISE AND RESUBMIT	
Checking is for compliance with the information given in the plans and/or specifications and for conformance with the design concept of the project only. Contractor is responsible for dimensions to be verified and correlated on the job and for the coordination of the work of all trades and subject to all Contract requirements.	
BY <u>MD</u>	DATE _____
ALLEN & HOSHALL, INC.	

VITAMIN B HUSBAND 1910
MA 1910

RECEIVED BY THE DIRECTOR OF THE BUREAU OF THE CENSUS
WASHINGTON, D. C. 20540
MAY 19 1910

RECEIVED BY THE DIRECTOR OF THE BUREAU OF THE CENSUS
 RECEIVED BY THE DIRECTOR OF THE BUREAU OF THE CENSUS
 RECEIVED BY THE DIRECTOR OF THE BUREAU OF THE CENSUS

1910

1910

TRANSFER SWITCH AND ACCESSORIES

1 ONAN Automatic transfer switch model

OTBCD 100-*U/3401

*5D Building 610 & Building LCH4007

*4 Building BB221

rated 120/240 / 120/208 volts, 120 amp, 3 phase, 3 pole.
with the following characteristics and options

per spec sheet: A-878.

Undervoltage sensing

Under/Over frequency sensing

Time delay engine start

Time delay engine stop

Time delay on transfer

Time delay on retransfer

Simulated power failure switch

Lamps to indicate: load connection

Auxiliary contacts:

normal side

emergency side

Nema class 4 enclosure

Neutral bar

Manual transfer operator handle

MISCELLANEOUS MATERIALS AND TESTING

Starting battery: 12 VDC

Lead Acid

Battery: rack

SCR battery float charger 10 amp.

12 quarts engine lubrication oil

Vibration isolators

Standard between Eng/Gen & skid base


Operators manuals

1 Year Warranty

Initial startup and checkout not to exceed 4 hours.


Load bank test of 8 hours.

WE OFFER NO BID ON THE FOLLOWING: extended wiring or piping
(fuel or exhaust cooling)
exhaust insulation




Onan

40 DL6T GenSet Diesel



Standby Power
Prime Power

Shown With Options



- **Prototype Test Supported (PTS)** to ensure reliability
- **Revolving Field, Brushless Alternators** 12-lead, broad range (reconnectable models)
- **Torque-Matched** voltage excitation system provides superior motor starting
- **Onan-Built L Series** Turbocharged diesel engine
- **50 or 60 hertz** models available
- Complete line of **Factory Options and Accessories**
- Backed by a **Worldwide Sales & Service** network

GenSet Performance

One step load acceptance: 100% of nameplate kW rating. Meets requirements of NFPA 110 paragraph 5-13, 2.6

Voltage recovery after acceptance of 100% of rated load in one step: **2 sec**

Voltage regulation under varying loads from 0 to 100% load $\pm 3\%$ max.

Random voltage variation: Will not exceed $\pm 1\%$ of its mean value for constant loads from no load to full load.

Frequency regulation under varying loads from 0 to 100% load: **5% max**

Random frequency variation: Will not exceed $\pm 0.5\%$ of its mean value for constant loads from no load to full load

- **Electromagnetic Interference Attenuation** meets requirements of most industrial and commercial applications.
- **Total Harmonic Content** of the AC waveform is less than 5%
- **Telephone Influence Factor (TIF)** less than 40 per NEMA MG1-22.43.
- **Alternator Temperature Rise** at rated load is within NEMA MG1-22.40, BS 4999 part 32, and IEC 34-1.
- **Waveform Deviation Factor**, less than 0.06 line-to-line, reduces risk of overheating and of interference with sensitive communication equipment

Continuous Standby Rating: The unit will operate at the stated rating for the duration of normal utility power interruptions.

Engine Detail

Model: Onan L634T

Design: Metric diesel

Cylinders: 6, in-line

Cycle: 4

Bore: 3.50-in (89 mm)

Stroke: 3.62-in (92 mm)

Piston Displacement: 210-in³ (3,434 cm³)

Compression Ratio: 21.5 to 1

Radiator Cooling:

Coolant capacity—18.5-qt (17.5 L) Rated at 50°C ambient against an external restriction of 0.5-in (12.7 mm) H₂O

Aspiration: Turbocharged

Main Bearings: 7

Lube Oil Capacity: 12-qt (11.4 L)

Fuel System:

Fuel filter

Mechanical fuel transfer pump,

fuel lift 6-ft (1.83 m)

Automatic electric fuel shutoff

Distributor injection pump with integral

mechanical governor

Starting System: Remote, 12-volt, 2-wire, negative ground

Cylinder Block: 1-piece, cast iron

Valves: Overhead

Alternator Detail

Design: Onan revolving field, 4-pole, brushless, drip proof construction

Stator: Skewed for minimal field heating and voltage harmonics

Twice impregnated with high temperature polyester varnish

Rotor: Dynamically balanced and directly coupled to engine with a flexible drive disc.

Windings vacuum impregnated with 100% solid epoxy resin for improved cooling and environmental protection

Amortisseur (damper) windings minimize voltage deviation or unbalance

Exciter: Brushless, with 8-pole stator and 3-phase rotor

Rectifiers encapsulated for environmental protection

Field circuit breaker (manual reset)

Voltage Regulator: Solid state and temperature compensated, with silicon controlled rectifiers and phase controlled sensing circuit

Insulation: Class F per NEMA MG1-1.65 and BS 2757 definition

Insulating varnish conforms to MIL-I-24092, Grade CB, Class 155°C

Bearing: Double sealed, prelubricated ball bearing

Cooling: Direct drive centrifugal blower

Control Detail

DC Engine Controls

Run-Stop-Remote switch

Remote start-stop terminals

Lighted oil pressure gauge

Lighted coolant temperature gauge

Lighted battery charge rate ammeter

Running time meter

Preheat switch (glow plugs)

Control circuit breaker, 7-amp

Remote circuit breaker, 7-amp

Two-Light GenSet Monitoring System

Run light (green)

Fault light (red) with alarm contact (manual reset) indicates engine shutdown for:


- Overcrank
- Overspeed
- High coolant temperature
- Low oil pressure

Unit Mounted Console with Panel Lighting


500-2057

- A1 AIR DUCT FLANGE
- BI BATTERY
- C1 CONTROL BOX
- C2 CIRCUIT BREAKER (OPTIONAL)
- C3 ELECTRICAL CONNECTION AREA
- D1 OIL DRAIN
- E1 EXHAUST, 3" NPT
- E2 EXHAUST, 2-1/2" NPT (MALE)
- F1 - FUEL IN 1/4" NPT (FEMALE)
- F2 - FUEL OUT
- HI - HOUSING (OPTIONAL)
- K1 - 1/2" KO (4 PLACES)
- M1 - MOUNTING HOLES (.625 Ø, 4 PLACES)

REV. NO.	LET	REVISION	DATE	BY	CHK	APP
21569	-	RELEASED FOR PROD				
22038	A	1.50 WAS TO SKID BASE	30	JR	DD	JP 4-25-83
22038	B	F1 WAS 3" O.D.	40	JR	DD	JP 4-22-83
25577	C	1 RMV 54.56, MOVED DIM TO 38.20	50	DR	DK	RP 1-9-85



NOTES:
 1. DRY WEIGHT: 1470 LBS. (666.8 KG)
 2. DIMENSIONS ARE IN INCHES. FOR METRIC CONVERSION, MULTIPLY DIM. BY 25.4 FOR MILLIMETERS.



TOLERANCES UNLESS OTHERWISE SPECIFIED	FINISH	PROJ.	SCALE	ITEM	QUANTITY	DESCRIPTION OR MATERIAL
FRACTIONS: .0005, .001, .002, .005, .010, .015, .030, .060, .125, .250, .500, 1.000, 2.000, 5.000, 10.000	AS SHOWN	THIRD ANGLE	3/64	40 DL6T		Onan Corporation Minneapolis Minnesota OUTLINE - ENG/GEN 500-2057

CAUTION: For construction details, all models, obtain installation outline from the factory.

Approximate net weight: 1470-lb (667 kg)

Operating Data 40 DL6T

Hertz	Engine Power Min. bhp (kW)	Piston Speed fpm (mm/s)	Radiator Cooling Air-cfm (m³/min)	Max. Heat Rejection (Engine to coolant) Btu/min (MJ/min)	Coolant Pumpage gpm (L/min)	Combustion Requirement Air-cfm (m³/min)	Generator Cooling Air-cfm (m³/min)	Heat Radiated to Room (Engine and Generator) Btu/min (MJ/min)	Average Fuel Consumption				Motor Starting		
									#2 Diesel, gph at load	1/4	2/4	3/4	4/4	Three-Phase kW	kVA
60 (1800 r/min)	65 (48.5)	1086 (5517)	5480 (155)	2900 (3.05)	41 (155)	140 (4.0)	240 (6.8)	1100 (1.16)	1.0 (3.8)	1.6 (6.0)	2.3 (8.7)	3.1 (11.6)	3.9 (14.9)	44	150
50 (1500 r/min)	53 (39.5)	905 (4597)	3100 (88)	2490 (2.62)	34 (129)	100 (2.9)	200 (5.6)		0.7 (2.8)	1.2 (4.7)	1.8 (6.8)	2.5 (9.3)	3.2 (12.1)		

Model Selection

60-Hz
1800 r/min

- 40 DL6T-15R**
3-phase, Reconnectable, Broad Range
120/208V 139A 127/220V 131A
139/240 120 120/240 120
240/416 69 254/440 66
277/480 60
Rated 40.0 kW Continuous Standby, 50.0 kVA at 0.8 PF
- 40 DL6T-7R**
3-phase, 4-wire
220/380V 76A
Rated 40.0 kW Continuous Standby, 50.0 kVA at 0.8 PF

- 40 DL6T-9XR**
3-phase, 4-wire
347/600V 48A
Rated 40.0 kW Continuous Standby, 50.0 kVA at 0.8 PF

- 40 DL6T-6DR**
240/480V 60A
Rated 40.0 kW Continuous Standby, 50.0 kVA at 0.8 PF

50-Hz
1500 r/min

- 32 DL6T-515R**
3-phase, Reconnectable, Broad Range
110/190V 122A
115/200 116
120/208 111
127/220 105
110/220 105
115/230V 101A
120/240 96
220/380 61
230/400 58
240/416 56
254/440 53
Rated 32 kW Continuous Standby, 40 kVA at 0.8 PF



CSA Certified
 Ratings and performance data apply to altitudes up to 300 ft (91.4 m), standard cooling, 77°F (25°C) ambient, and No. 2 diesel fuel. Single-phase power can be taken in capacities up to 2/3 of the rated 3-phase kVA. Broad range alternators have 12 leads brought out for user reconnect. Continuous rating per BS 5514 and DIN 6270 is 36.4 kW for the 40 DL6T (60 Hz) and 29.1 kW for the 32 DL6T (50 Hz).

Standard Equipment

- Turbocharged Diesel Engine
- AC Alternator
- Skid Support Chassis with Three-Point Mounting and Vibration Isolators between Engine-Generator and Skid
- Mounted Control Console to face rear or accessory side
- Battery Rack
- Flexible Fuel Lines
- Heavy Duty Air Cleaner
- Oil Drain Valve with Hose Extension
- Fork Lift Sockets
- Radiator with Air Discharge Duct Adapter Flange
- Battery Charging Alternator
- Glow Plugs

Options and Accessories

Control System

- Nine-light generator set monitoring system** (complete package only)

Solid state engine monitor with individual lights and common external alarm contact indicating each of the following conditions:

- Run (green light)
- Overcrank Shutdown (red light)
- Overspeed Shutdown (red light)
- High Coolant Temperature Shutdown (red light)
- Low Oil Pressure Shutdown (red light)
- Pre-warning for High Coolant Temperature (yellow light)
- Pre-warning for Low Oil Pressure (yellow light)
- Low Coolant Temperature (red light— indicates inoperative coolant heater)
- Switch OFF (flashing red light - indicates genset is not in automatic start mode)

Monitoring System includes Lamp Test Switch and Reset Switch for tripped condition lamps

- Additional meters and controls** (complete package only)
- AC Ammeter (dual range, indicates current each phase)
 - Voltmeter
 - Voltmeter-Ammeter Phase Selector with an OFF position
 - Frequency Meter
 - Console Mounted Voltage Adjusting Rheostat

Fuel System

- Day tank fuel reservoir

Starting

- Battery
 Engine coolant heater

Housing

- Weatherprotective housing
 Weatherprotective housing with factory mounted critical silencer

AC Output

- Line circuit breaker
 Switching regulator

Onan Design Integrity



This seal certifies that the **design integrity** of Onan Electric Generating Sets has been verified by comprehensive prototype testing. Prototypes are subjected to rigorous tests with typical and atypical loads and transients well above rated performance.

Prototype Testing Typically Includes:

- Reserve Capacity, Overload and Recovery • Failure Mode
- Multiple Consecutive Short Circuits • Endurance, Resonance and Fatigue • Environmental Extremes • Alternator Temperature Rise by Multiple Embedded Temperature Sensors • Component

- Variance Analysis • Simulation of Actual In-Service Load Circuit Disturbances • Protective System Safety Margin

(Prototype tested units are never sold as new equipment.)

Production units earn the PTS seal only after individual testing at rated load and *power factor* in addition to demonstrating acceptable performance relative to criteria established by the Prototype Test Program.

Onan Builds Complete Power Systems of precisely matched components including all transfer switches, controls and monitors to assure smooth, continuous operation. Expertise and engineering services available from Onan will provide guidance in selecting the most reliable emergency electric power protection for your investment.

Parts and Service are available worldwide for all of Onan's generating sets, more than 1,000 models ranging from 1.75 kW to 4000 kW.

Manufacturers Limited Warranty to original users is one year. See your Onan distributor for information or complete documents on available **Manufacturers Two-Year and Five-Year Warranties.**

See Your Onan Distributor:

Onan Corporation

1400 73rd Avenue N.E.
Minneapolis, MN 55432

Telephone
612 574-5000

Telex 29 0476 (U.S.)
Telex 29 0856 (outside U.S.)



TWX 910 576-2833
Cable ONAN

500-2057

C

- A1 AIR DUCT FLANGE
- B1 BATTERY
- C1 CONTROL BOX
- C2 CIRCUIT BREAKER (OPTIONAL)
- C3 ELECTRICAL CONNECTION AREA
- D1 OIL DRAIN
- E1 EXHAUST, 3" NPT
- E2 EXHAUST, 2-1/2" NPT (MALE)


- F1 - FUEL IN 1/4" NPT (FEMALE)
- F2 - FUEL OUT
- HI - HOUSING (OPTIONAL)
- K1 - 1/2" KO (4 PLACES)
- M1 - MOUNTING HOLES (.625 Ø, 4 PLACES)





ER NO.	LET	REVISION	ZONE	DR	ENG	CHK	DATE
21569	-	RELEASED FOR PROD					
22038	A	30 WAS TO SKID BASE	3C	JR	DG	JP	4-25-83
22038	B	WAS 3" O.D.	4D	JR	DG	JP	4-25-83
25677	C	MOV 34.56, MOVED DIM TO 38.20	3C	DH	JR	JSP	1-8-85

NOTES:
 1. DRY WEIGHT: 1470 LBS. (666.8 KG)
 2. DIMENSIONS ARE IN INCHES. FOR METRIC CONVERSION, MULTIPLY DIM. BY 25.4 FOR MILLIMETERS.

TOLERANCES UNLESS OTHERWISE SPECIFIED		NEXT ASSY	SEPIA FROM	ITEM	BULK PART NO.	DWG SIZE	QTY.	DESCRIPTION OR MATERIAL
MM	INCH	500-2025 C	DR	J. PICT				Onan Corporation Minneapolis Minnesota
.1 ±	.XX ±	Third Angle Projection	CR	JP				
.X ±	.XXX ±		ENGR	DG				
NOTES		The proprietary design information on this print is owned by Onan Corporation. Conveyance of this right is not extended to others.	SAMP REL	DG				OUTLINE - ENG / GEN
ANGLES ±		SCALE 3/64	PROD REL	DG				
					40 DL6T			500-2057




START-RUN ALARM FOR CUSTOMER USE CONTACT RATING: 10 AMP, 28 VDC/120 VAC




TBI-10 } TO AC
TBI-9 } DIAGRAM

BOTTOM OF CONTROL BOX




CUSTOMER CONNECTIONS

TACHOMETER INSTALLATION



- NOTES:
1. OPTIONS ARE SHOWN CONNECTED IN DASHED LINES
 2. UNLESS OTHERWISE NOTED, ALL COMPONENTS ARE SHOWN IN DE-ENERGIZE POSITION
 3. INSTALL S11 & S12 WITH ACTUATOR PROTRUSION UP
 4. WHEN USING 2 FLANGED SPADE CONNECTORS ON THE SAME SCREW TERMINAL, INSTALL THE LOWER CONN WITH FLANGES TOWARD TERMINAL BLOCK & UPPER CONN WITH FLANGES AWAY FROM TERMINAL BLOCK
 5. STD METERING INCLUDES 3 DC GAUGES & 1 TIME METER, DOES NOT INCLUDE ANY AC METERING
 6. OPTIONAL METERING INCLUDES ONE ADDITIONAL GAUGE (M5) EITHER OIL TEMP OR TACH
 7. SOLDER LEAD TO ANODE OF ALTERNATOR RECTIFYING DIODE LOCATED BETWEEN THE REGULATOR AND THE GROUND TERMINAL FOR TACH INPUT
 8. TEST ROOM TACH CALIBRATION. START SET AND ADJUST FREQUENCY TO 60 Hz (50Hz) THEN TURN CALIBRATION POT ON THE REAR OF THE TACH UNTIL THE TACH READS 1800 (1500) RPM OR 3600 (3000) RPM
 9. CUT LEADS OF TACH LAMP AS REQUIRED THEN TERMINATE WITH A #10 RING CONNECTOR (ONAN No 332-0147)




ENG PARTS LIST (REF)				
REF DES	PART NO	QTY	DESCRIPTION	
B1		1	STARTER & SOLENOID	
BT1		1	BATTERY - 12V	
E1		1	SENDER-OIL PRESSURE	
E2		1	SENDER-WATER TEMP	
E3		1	SENDER-OIL TEMP (-02,-04)	
G1		1	ALTERNATOR	
HR1,2,3,4		4	GLOW PLUG (DL4,DL6)	
HR5,6		2	GLOW PLUG (DL6)	
K1		1	SOLENOID (LEAD - STARTER)	
K2		1	SOLENOID - HEATER	
K3		1	SOLENOID - FUEL	
S1		1	SWITCH - HET	
S3		1	SWITCH - LOP	
S6		1	SWITCH - OVERSPEED	
S7		1	SWITCH - LWL	
TB26		1	BRACKET ASSY - TERMINAL	
CONTROL PARTS LIST				
A11	300-2510	D	1	ENG MONITOR
CB1	320-1110	C	1	CIRCUIT BREAKER (REMOTE,7A)
CB2	320-1110	C	1	CIRCUIT BREAKER (CONTROL,7A)
DS1	322-0238	P	1	LIGHT-IND (RUN)
DS2	322-0128	A	1	LIGHT-IND (FAULT)
	322-0241	-	7	BEZEL ASSY
DS10-12	322-0308	P	3	LAMP-PILOT
	322-0210	P	3	SOCKET-BAYONET
K11	307-1061	B	1	RELAY-STARTER PILOT
	323-0765	A	1	SOCKET-RELAY
	307-1157	P	1	SPRING-RELAY HOLDDOWN
K12	307-1058	B	1	RELAY-RUN (-03,-04,-06)
	323-0804	A	1	SOCKET-RELAY (K12-X03-04-06)
M1	302-1402	B	1	AMMETER-CHARGE
M2	193-0320	B	1	GAUGE-OIL PRESSURE
M3	193-0319	B	1	GAUGE-WATER TEMP
M4	302-0885	B	1	METER-RUN TIME
S10	308-0531	P	1	SWITCH (SPDT)
S12	308-0532	P	1	SWITCH (SPDT)
S11	308-0533	P	1	SWITCH (SPST)
M5	193-0330	B	1	GAUGE-OIL TEMP (-02,-04)
M5	302-1715	B	1	TACHOMETER (-03,-06)
W10	336-6388	A	1	LEAD (M3-3,M5-3) (-05,-06)
W11	336-6389	A	1	LEAD (M2-1,M5-1)(-02,-04,-05,-06)
	338-143-01	C	1	WIRE HARNESS-DC (METER)
	338-1644	C	1	WIRE HARNESS-DC (SWITCH)
	338-1646	B	1	WIRE HARNESS-DC (2 LITE)
	307-6230	D	1	CONTROL BOX ASSY
	517-0132	P	1	PLUG-HOLE
	337-8049	A	1	STEER-BAND
	508-844	P	1	BRONNET
DS13	322-0004	P	1	LAMP-PILOT (-01,-04,-05,-06)
	322-0210	P	1	SOCKET-BAYONET

* WHEN USED


REV	DESCRIPTION	DATE
1	25670 G 1 SEE ER	12-20-84
2	S11 WAS 308-0532	10-5-84
3	S12 WAS 308-0533	10-5-84
4	E 1 REVERSED M1 CONNECTIONS	12-5-84
5	D 3 ADD 402-0527/301-8955	10-18-84
6	D 2 SEE SHEET 2	10-18-84
7	D 1 SEE SHEET 2	10-18-84
8	C 1 ADD-07 B-08	11-18-84
9	B SEE ER (SHEET 142)	11-5-82
10	A ADDED S7 WHEN USED	10-14-82
11	SUPSD DWG SAME NO DATED 2-12-72 W/CHNG	

Onan DIVISION OF ONAN CORPORATION
 Minneapolis, Minnesota
 DATE: 9-18-82 BY: JC
 CONTROL - GEN SET DC (2 LITE)
 (WIRING DIAGRAM)
 612-5914 612-6020 SH1 OF 2





Onan



SCR Battery Float Chargers

**Fully Automatic
Constant Voltage
Current Limiting
Equalize Charge Timer**

12-Volt, 10-Amp

24-Volt, 6-Amp

12-volt, 2-amp, 50 or 60-hertz input

Construction Details

Cabinet: The sturdy, compact sheet steel cabinet is a hinged two-piece (cover and chassis) enclosure, equipped with rubber feet for table mounting and brackets for wall mounting. The louvered top and expanded-metal-mesh bottom provide good convection cooling.

Cabinet Cover: one-piece—includes the sides, louvered top and a front panel that holds the DC VOLTMETER (3% accuracy); DC AMMETER (5% accuracy); ON-OFF SWITCH—opens and closes the AC and DC circuits simultaneously; FUSE—protects the power transformer and the full-wave silicon bridge rectifier against excessive overloads; EQUALIZE-CHARGE TIMER—manually set for equalize charge, up to 12 hours, automatically switches back to float voltage.

Cabinet Chassis: one-piece (bottom and back) holds the Current Limiting POWER TRANSFORMER—factory wired for 120-volt, 60-hertz input and taps for 208- and 240-volt input, user reconnect; FULL-WAVE SILICON BRIDGE RECTIFIER—converts the AC input to a pulsing DC charging Output SURGE-SUPPRESSOR—non-polarized rectifier prevents transient voltage surge damage to SCR and Silicon Bridge Rectifier; VOLTAGE REGULATOR—an All Electronic Package that controls the battery voltage by firing the SCR when the battery voltage is above the charger's minimum operating voltage and below the preset voltage. The regulator turns-on the SCR only as often as is necessary to maintain the preset voltage; SCR—blocks the DC circuit in both directions when not being fired (turned-on) by the voltage regulator; TERMINAL BLOCK—plainly marked, provides convenient connection for the user supplied input and output leads.

Performance

Onan, Fully Automatic, Battery Float Chargers—with SCR (silicon controlled rectifier) are constant voltage, current limiting chargers. Designed for float charging Lead-Acid or Nickel-Cadmium starting batteries, these transistorized units, complete with built-in Equalize Charge Timer, are an ideal package for stationary or portable starting battery charging service.

Stationary Service: As stationary chargers, the permanently connected battery continuously floats at a constant voltage. As the battery approaches full-charge preset voltage, the charging current automatically tapers to zero amperes or to the steady-state load on the battery. ONAN automatic float chargers keep starting batteries fully charged—NO gassing, NO overcharging.

Portable and Equalize-Charge Service: For faster charging in Portable Service or to Equalize-Charge the floating, lead-acid battery, manually set the equalize-charge timer for any time period up to 12 hours (most lead-acid battery manufacturers recommended 24 hours of equalize charging every month). Setting the Timer raises the charger's output voltage and maintains the higher charging voltage for the time selected. At the end of the timed interval, the Timer automatically switches back to float voltage. For faster battery charging, parallel two or more chargers.



CSA Certified

Self-Protecting: Inherently self-protected against shorted or reversed battery connections and overload currents.

Battery Float Charger—Fully Automatic


Constant Voltage—Current Limiting—Solid State

PERFORMANCE and PHYSICAL CHARACTERISTICS	Model 305-0347	Model 305-0346
OUTPUT: Nominal Voltage	12 V	24 V
Adjustable Float Voltage	12.8 V to 14.5 V	25.6 V to 29 V
Adjustable Equalize-Voltage	Float V to 14.5 V	Float V to 29.0 V
Recommended Float Voltage (Lead-Acid Batteries)	13.2 V	26.4 V
Recommended Float Voltage (Nickel-Cadmium Batteries)	14.0 V (10 cell)	28.0 V (20 cell)
Recommended Equalize Voltage (Lead-Acid Batteries)	14.4 V	28.8 V
Voltage Regulation with $\pm 5\%$, 60-hertz frequency and $\pm 10\%$, line voltage	$\pm 2\%$	$\pm 2\%$
Ampere-Maximum and Taper (Minimum)	10-amp to 0-amp	6-amp to 0-amp
Equalize Charger Time (Manually Set)	0- to 12-hr	0- to 12-hr
INPUT: Voltage, 60-hertz (Optional Adder 480-v input)	120, 208, 240 V	120, 208, 240 V
Approximate Net Weights:	23-lb (10.4 kg)	27-lb (12.2 kg)
Approximate Dimensions: Height x Width x Depth - inches (mm)	8 x 10 x 8 (203 x 254 x 203)	8 x 10 x 8 (203 x 254 x 203)
Ambient Temperature operation: from	-40F to 140F (-40C to 60C)	-40F to 140F (-40C to 60C)

PERFORMANCE and PHYSICAL CHARACTERISTICS	MODEL 305-0513*
OUTPUT: Nominal Voltage (Battery cables, 6-ft (1.8 m) with insulated clips furnished)	12 V
Adjustable Float Voltage	12.6 to 15.0 V
Recommended Float Voltage (Lead-Acid Batteries)	13.3 V
Recommended Float Voltage (Nickel-Cadmium Batteries, 10 cell)	14.0 to 14.5 V
Voltage Regulation with $\pm 5\%$, line frequency and $\pm 10\%$, line voltage	$\pm 2\%$
Ampere-Maximum and Taper (Minimum)	2-amp to 0-amp
INPUT: Voltage, 50- or 60-hertz (molded, 3-wire, cord assembly furnished)	120 V*
Approximate Net Weight:	9-lb (4.1 kg)
Approximate Dimensions: Height x Width x Depth—inches (mm)	6.06 x 8.68 x 5.5 (154 x 220 x 140)
Ambient Temperature operation: from	-40F to 140F (-40 C to 60 C)

* Available also for 220-volt operation (Model 305-0598).

Rectifier Battery Chargers



ONAN Model 305-0325, Battery Charger, 12-volt

ONAN Model 305-0224, Battery Charger, 24-volt

These battery chargers charge batteries from a 120-volt, 50 or 60-hertz input line. They charge at a high rate of 2 amperes or switch to an adjustable, low trickle charge rate of 0.100 to 0.500-amperes. The meter reads the low trickle charge rate, only. The pilot light indicates the high charge rate.



ONAN Model 305-0175, 12-volt Trickle Charger

This 12-volt Trickle Charger operates from a 120-volt, 50 or 60-hertz input line. Leave permanently connected to battery. The charge rate is approximately 0.050 to 0.300 amperes. Milliammeter and rheostat are included.

See Your Onan Distributor:

Onan Corporation


1400 73rd Avenue N.E.
Minneapolis, MN 55432

Telephone
612 574-5000

Telex 29 0476 (U.S.)
Telex 29 0856 (outside U.S.)

TWX 910 576-2833
Cable ONAN

ER	LET	REVISION	JOB#	DR	ENG	CR	DATE
9250	-	RLSE FOR PROD					
9262	A	ADDED ITEM 14 821-0016	2B	JR	CM	JP	5-18-82
9262	B	ADDED ITEM 15 870-0257	2B	JR	CM	K	5-18-82
9270	C	DELETED ITEM 2 (333-0204)	A2	JRP	CM	J	6-21-82
9270	D	ITEM 1 WAS 533-0203	A2	JRP	CM	J	6-21-82
9270	E	REVISED TABULATION	A4	JRP	CM	J	6-21-82
20748	F	DELETED ITEM 13 (502-0613)	B2	JR	CM	JP	10-8-82
21062	F	ADDED ITEM 13, 503-1225	2B	JSP	DG	JR	11-11-82
21062	G	ITEM 5: ADDED DASH N° -05,-06	2A	JSP	DG	JR	11-11-82
21062	H	ITEM 5: ADDED DASH N° -01,-02,-03,-04	4A	JSP	DG	JR	11-11-82
21062	J	ADDED -05 TO TAB	4A	JSP	DG	JR	11-11-82
21062	K	ADDED -06 TO TAB	4A	JSP	DG	JR	11-11-82
21294	L	SEE ER	-	JSP	DG	J	12-17-82
22038	H	ADD ITEM 5 (130-0755)	2A	JR	DG	JP	5-2-83
22038	B	ADDED ITEM 14 (821-0016)	2B	JR	DL	JP	5-2-83
22038	A	ADDED ITEM 15 (870-0257)	2B	JR	DG	JP	5-2-83
24002	M	ITEM 13 WAS (6.5")	2B	DH	DG	JR	2-29-84



DASH NO.	MODEL	ITEM 1	HTR. RATING
-01	4 CYL	333-0203	850 W 120 V 1Ø
-02	6 CYL	333-0204	1500 W 120 V 1Ø
-03	4 CYL	333-0201	1000 W 230 V 1Ø
-04	6 CYL	333-0202	1500 W 230 V 1Ø

ITEM	QTY	DESCRIPTION OR MATERIAL
16	1	ELBOW - STREET (90° - 3/8)
15	1	WASHER - LK H (5/16 - 18)
14	1	SCREW - LK H (5/16 - 18 X 3/4)
13	1	HOSE, FLEX (8')
12	1	ELBOW - STREET (45° X 1/4)
11	1	NIPPLE - HALF (3/8 X 1-1/2)
10	1	HOSE (42.0")
9	1	HOSE (50")
8	4	CLAMP - HOSE
7		
6	1	REDUCER (3/4 X 3/8)
5	1	BPACKET - WATER HEATER MTG
4	1	SCREW - HHC (M8 X 1.25 X 20)
3	1	WASHER - LK (M8)
2		
1	1	HEATER - ENGINE

TOLERANCES UNLESS OTHERWISE SPECIFIED		HEAT ASSY
MM	INCH	1/16 TO 1/8
± .2	± .01	
± .1	± .005	
± .15	± .002	

Third Angle Projection

The proprietary design information on this print is owned by Onan Corporation. Copying or use of this right is not extended to others.

SCALE 1/4

179-2206 C

SEP 1980

INITIAL DATE

DR JPR 3-12-82

ENR BWH 3-23-82

ENGR C MELTON 3-27-82

SCALE PART NO. QTY. DESCRIPTION OR MATERIAL

SEC PUB MS

OC PO

H

3-29-82

L/C 4,6 (CYL)

179-2206

WORD SIZE C

Onan Onan Corporation
Minneapolis Minnesota

INSTL - COOLANT HTR

179-2206 C



MICROFILMED

625-1027

(D)

KV	VOLTAGE & PH	DASH NO.	BREAKER NO.	AMP	LEAD ASSY (QTY)
25-30	120/240V, 1 PH	-01	320P344	175	226A892 (2)
	120/208V, 3 PH	-02	320P412	100	226A891 (3)
	120/240V, 3 PH	-03	320P411	90	↓
	220/380V, 3 PH	-04	320P384	60	
	277/480V, 3 PH	-05	320P413	50	
	347/600V, 3 PH	-06	320P415	40	
200/346V, 3 PH	-19	320P384	60		
35-45	120/240V, 1 PH	-07	320P359	225	
	120/208V, 3 PH	-08	320P346	150	226A892 (3)
	120/240V, 3 PH	-08	320P346	150	226A892 (3)
	220/380V, 3 PH	-09	320P379	90	226A891 (3)
	277/480V, 3 PH	-10	320P414	70	↓
	347/600V, 3 PH	-11	320P418	60	
200/346V, 3 PH	-20	320P379	90		
50	120/208V, 3 PH	-12	320P347	175	
	120/240V, 3 PH	-08	320P346	150	226A892 (3)
	220/380V, 3 PH	-13	320P380	100	226A891 (3)
	277/480V, 3 PH	-09	320P379	90	226A891 (3)
	347/600V, 3 PH	-11	320P418	60	226A891 (3)
	200/346V, 3 PH	-21	320P380	100	226A891 (3)
55	120/208V, 3 PH	-14	320P348	200	226A892 (3)
	120/240V, 3 PH	-12	320P347	175	226A892 (3)
	220/380V, 3 PH	-13	320P380	100	226A891 (3)
	277/480V, 3 PH	-09	320P379	90	226A891 (3)
	347/600V, 3 PH	-15	320P417	70	226A891 (3)
	200/346V, 3 PH	-22	320P419	125	226A892 (3)
60	120/208V, 3 PH	-16	320P349	225	226A892 (3)
	120/240V, 3 PH	-14	320P348	200	226A892 (3)
	220/380V, 3 PH	-17	320P419	125	226A892 (3)
	277/480V, 3 PH	-09	320P379	90	226A891 (3)
	347/600V, 3 PH	-15	320P417	70	226A891 (3)
	200/346V, 3 PH	-23	320P419	125	226A892 (3)
65	120/208V, 3 PH	-16	320P349	225	226A892 (3)
	120/240V, 3 PH	-14	320P348	200	226A892 (3)
	220/380V, 3 PH	-17	320P419	125	226A892 (3)
	277/480V, 3 PH	-13	320P380	100	226A891 (3)
	347/600V, 3 PH	-18	320P418	90	226A891 (3)
	200/346V, 3 PH	-24	320P425	150	226A893 (3)

NOTES: 1. THIS LINE BREAKER MOUNTS INSIDE OF STANDARD OUTPUT BOX.


PARTS LIST

REF. DES.	PART NO.	QTY	DESCRIPTION
	301B3192	1	COVER-JUNCTION BOX
	301B3197	1	BRACKET-CXT BRKR MTG
	800-3	2	SCREW-HHC 1/4-20 1/2 LG
	850-40	2	WASHER-LK
	817-84	4	SCREW-RHM 8-32 3-5/8 LG
	850-25	4	WASHER-LK
	800-28	5	SCREW-HHC 5/16-18 1 LG
	526-22	10	WASHER-FLAT
	850-45	5	WASHER-LK
	862-15	5	NUT-HEX
	898-869	4"	SLEEVING-INSULATION
	898-867	4"	SLEEVING-INSULATION
	898-865	4"	SLEEVING-INSULATION
	898-863	4"	SLEEVING-INSULATION
	98A2304	1	SILKSCREEN-CXT BRKR (WARNING)

(A)

(B)

(C)



625-1027



D	ADDED -19 THRU-24	7-17-79
C	COMPLETED TAB	10-8-71
B	ADDED 98A2304	11-19-70
A	A SLEEVING WAS 6" OF 867	6-29-70
REV.	REVISION	DATE
DIVISION OF STUDEBAKER CORPORATION Minneapolis, Minnesota		
DATE	1-30-70	BY CIP
NAME	WIRING DIAGRAM CIRCUIT BREAKER	
DWG. NO.	625-1027	



305-0347


B

ER	III	DIVISION	DATE	DE	ENG	CAR	PA
0471		PRCD RELEASE					
1039	A	ADDED ITFMS 7 THRU 10	2-0	JC			2-11
2807	B	AI WAS 305-0344	2-0	MRD			5-13




NOTES:

- ITEMS 1, 2 & 3 SHIPPED LOOSE
- DO NOT TIGHTEN AGAINST SHEET METAL, LOCKNUTS AGAINST EACH OTHER
- WIRE PER 625-0602(C)
- PARTS LIST FROM 625-0602(C)



SECTION A-A
SCALE 1/1


(4) HOLES FOR .25 MOUNTING SCREWS



(A)
(B)

ITEM	PART NO.	QTY.	DESCRIPTION OR MATERIAL
IO	854-0014	- 1	WASHER-IT 1/4
9	871-0016	- 2	NUT-BRASS (1/4-20)
8	856-0006	- 2	WASHER-EIT (1/4)
7	810-0153	- 1	SCREW-RHDM (1/4-20 X 1)
AI	305-0345	B 1	REGULATOR ASSY
	332-0886	A 1	STRIP-MARKER
CR1	305-0348	B 1	RECTIFIER-BRIDGE
CR2	305-0349	A 1	RECTIFIER-SURGE SUPPRESSOR
CR3	305-0385	A 1	SCR ASSY
FI	321-0127	- 1	FUSE - 15 AMP
	321-0104	P 1	HOLDER-FUSE
M1	302-0561	P 1	AMMETER-DC 0-10 AMP
M2	302-0562	P 1	VOLTMETER-DC 0-20V
SI	308-0211	P (RER)	SWITCH, ON-OFF
S2	308-0213	A 1	SWITCH (EQUALIZE CHARGE TIMER 0-1)
TI	315-0175	C 1	TRANSFORMER-POWER
TBI	332-0537	A (REF)	TERMINAL BOARD
	99-1169	A 1	PLATE-FUSE
	98-2060	A 1	SILKSCREEN-LEADS
WI	338-0641	D 1	WIRING HARNESS
W2	336-2134	A 1	LEAD ASSY
W3	336-2135	A 1	LEAD ASSY
	332-1179	A 2	SPACER-FIBER
	870-0129	- 2	NUT-NYLON
6	301-2457	D 1	CHASSIS
5	301-2459	C 1	COVER ASSY
4	99-0949	A 1	NAMEPLATE
3	301-2456	A 4	BRACKET-MTG(SEE NOTE 1)
2	402-0331	P 4	RUBBER FOOT (SEE NOTE 1)
1	508-0071	P 2	GROMMET (SEE NOTE 1)

TOLERANCES UNLESS OTHERWISE SPECIFIED		TEXT ASSY	305-0347	305-0347	SEPA	ITEM	PART NO.	QTY.	DESCRIPTION OR MATERIAL
mm	INCH	305-0346 B	305-0347	DR RK	8-20-79				A DIVISION OF OMAN CORPORATION
.1 ±	.003	Third Angle Projection		ENGR CIP	7-21-77				Minneapolis, Minnesota
.1X ±	.0005			ENGR [Signature]	7/21/79				CHARGER-BATTERY (12V)
HOLES				ENGR [Signature]	7/21/79				305-0347
+ 0.15		+ .006							
- 0.05		- .002							
ANGLES ±		SCALE 1/4							





Remote Alarm Annunciator

Audible & Visual Alarm for Engine-Generator Malfunction

For Use with "DV" and "L" Series GenSets ONLY

Series ANN 12 or 24-volt Negative (ground) Signal
Series ANP 12 or 24-volt Positive Signal

300-2751
300-2752

Code Requirements for Alarm Annunciators

National Fire Protection Association (NFPA) standards for Essential Electrical Systems for Health Care Facilities and Emergency and Standby Electric Power Systems, as well as the National Electric Code (NEC) require that alternate electric power sources such as emergency generator sets be equipped with both audible and visual signal devices to monitor and warn of malfunction or alarm conditions. These codes further specify that the signal device be battery powered and installed outside the standby generating room in a location readily observable by operating personnel at regular work stations. These regulations are also included in other codes and specifications.

CAUTION: Do NOT run annunciator control wiring through power cable conduit or raceway.

Special Features

- Alarm Silence button on annunciator resets circuit for any subsequent fault condition whether or not initial fault has been cleared
- Inputs for either 12 or 24-volt DC
- Contacts for common remote alarm
- Voltage Normal light on battery monitor
- Stainless steel front panel; desk-top or wall-mounting
- Knockouts for wire installation from top
- Solid state with LED lamps for high reliability and low power consumption
- Lamp test switch
- Replaces and is interchangeable with all previous Onan annunciators for piston-driven equipment

Annunciators and Associated GenSet Series

ANP 12-volt Onan 300-2752*

DL4	DL6B
DL6	DL6TB
DL6T	ES
DL4B	

ANN 24-Volt Onan 300-2751*

TechStar (Gas) DV (All)

*Optional adapter ring for flush wall mount available, Onan 301-3091

Signal Level Requirements

Positive: At least 9 volts DC but not more than 30 volts DC.

Negative: Less than 1 volt DC.

Battery Voltage

Functional Range of audible and visual alarms: 6 volts to 50 volts.

Low Battery Voltage Setting: 11 volts for 12-volt systems; 22 volts for 24-volt systems.

High Battery Voltage Setting: 15 volts for 12-volt systems; 30 volts for 24-volt systems.

Temperature Range

Operating: 0°C (32°F) to 70°C (158°F)

Storage: -55°C (-67°F) to 100°C (212°F)


Power Requirement

Maximum Consumption: 5 Watts

Standby Consumption: 1/4 Watt


Stability

Voltage Sensor Drift: ±2% maximum



Approx. Weight
3.75 lb (1.75 kg)

Dimensions in ()
are mm



Annunciator Lamps*

Lamp Legend	Generator Set Condition Indicated	Light	Audible Alarm
High Battery Voltage	Battery charger malfunction	Red	No
Low Battery Voltage	Battery voltage below low voltage setting	Red	No
Normal Battery Voltage	Battery voltage ok	Green	No
Generator Running	Generator has output voltage	Green	No
Normal Utility Power	Utility power supplying the load	Green	No
EPS Supplying Load	Genset supplying the load	Green	No
Pre-Low Oil Pressure	Oil pressure approaching preset minimum	Yellow	Yes
Low Oil Pressure	Genset has shut down due to low oil pressure	Red	Yes
Pre-High Coolant Temp	Temperature of cooling medium approaching preset maximum	Yellow	Yes
High Coolant Temp	Genset has shut down due to high coolant temp	Red	Yes
Low Engine Temp	Engine heater has malfunctioned	Red	Yes
Overspeed	Engine has shut down due to overspeed	Red	Yes
Overcrank	Cranking fails to start engine within 45-75 sec	Red	Yes
Not in Auto	Switch on control not in AUTO position; Genset will not start automatically	Flashing Red	Yes
Low Bat Electrolyte	Low battery electrolyte level	Red	No
Low Fuel	Fuel level below preset minimum	Red	Yes
Fault	Customer preselected condition	Red	Yes

See Your Onan Distributor:

OWSLEY & SONS, INC.
DRAWER L
I-77 & S. C. EXIT 72
FORT MILL, S. C. 29715
PHONE (803) 548-3636

Onan Corporation


1400 73rd Avenue N.E.
Minneapolis, MN 55432

Telephone
612 574-5000




Telex 29 0476 (U.S.)
Telex 29 0856 (outside U.S.)

TWX 910 576-2833
Cable ONAN

VIEW A-A



SCHEMATIC DIAGRAM



VIEW B-B

CADD SYSTEM DWG

TOLERANCES UNLESS OTHERWISE SPECIFIED	SIM TO	NEXT ASSY
M/M	INCH	THIRD ANGLE PROJECTION
X .X	.XX	
.XX	.XX	
.XX	.XX	
MACHINED HOLES		
+0.15	-.006	
-0.05	-.002	
ANGLES	SCALE 1 TO 1	

ER NO.	LTR NO.	REVISION	ZONE	DR	CHKR	APPROVED	DATE
21,325	-	SAMPLE RELEASE	-	MM	LN	SH	12-30-82
21,442	-	PRODUCTION RELEASE, NO CHANGE	-	MM	LN	SH	1-21-83
22,577	A	UPDATE FRONT VIEW OF PCB PER ER	-	MM	LN	SLS	9-6-83
22,473	B	REV REF DES OF IC'S ON SILK ANG SCHEMATIC	-	MM	LN	SLS	9-6-83
23,058	C	UPDATE SCH PCB PER ER CHANGE	-	LN	MM	SH	12-13-83
24,148	D	1 CAL PROCEDURE R4 WAS R3	2-C	MD	MM	SH	4-9-84
		2 CAL PROCEDURE R6 WAS R5	2-C	MD	MM	SH	4-9-84

CALIBRATION PROCEDURE

- WITH 30 VDC INPUT AT PINS 1-3, ADJUST R2 UNTIL LED DS17 SWITCHES ON FROM OFF.
- WITH 22VDC INPUT AT PIN 1-3, ADJUST R4 UNTIL LED DS16 SWITCHES ON FROM OFF.
- WITH 11VDC INPUT AT PINS 2-3, ADJUST R6 UNTIL LED DS16 SWITCHES FROM OFF TO ON. CHECK THE OVERVOLTAGE SETTING DS17, IT SHOULD BE 15.1 VDC AT PINS 2-3.

TEST PROCEDURE

- APPLY 12 VDC TO PIN 2.
- APPLY 12 VDC SEQUENTIALLY TO PINS 4 THROUGH 17 (RETAINING INPUTS).
- RESET AFTER EACH ALARM. (GREEN LEDS AND LOW BATTERY ELECT EXCLUDED).
- VERIFY LAMP TEST (ALL LEDS).

SPECIFICATIONS


- GENERAL
 - POWER SUPPLY VOLTAGE
 - VDC PIN 1 24V ± 6V
 - VDC PIN 2 12V ± 3V
 - HIGH VOLTAGE 30V ± 2V; 15V ± 1
 - LOW VOLTAGE 22V ± 2V; 11 ± 1
 - MAX POWER CONSUMPTION 5 WATTS AT 30V IN STAND-BY POWER CONSUMPTION 400 MWATTS AT 12V 1 WATT AT 24V
 - OPERATION TEMPERATURE RANGE 0° C TO 50° C
 - STORAGE TEMPERATURE RANGE -55° C TO 100° C
 - VOLTAGE SENSOR DRIFT ± 2%
 - SOUND LEVEL 68-80 DB

ITEM	QTY	PART NO.	DESCRIPTION OR MATERIAL
15			
14			
13			
12	226-0845	A 2	LEAD (TB21-23,24 ITEM #7)
11	518-0440	P 1	RING-LOCKING
10	812-0059	- 6	SCREW RHM #6-32 X 1/4 LG
9	870-0221	- 2	NUT-HEX HD W/ET (8-32)
8	812-0028	- 4	SCREW-RHM 1#4-40 X 5/16 LG
7	333-0133	A 1	SIGNAL-AUDIBLE
6	630-1198	B 1	WD-INTERCONNECTION (POS ANNI)
5	301-7620	B 1	BRACKET-PC BOARD MTG
4	300-2603	D 1	PCB ASSY-STD ANN P.L.
3	98-4876	B 1	SILKSCREEN (ALARM ANNUNCIATOR)
2	301-7619	C 1	PANEL-ANNUNCIATOR
1	301-3090	C 1	CONTROL BOX

Onon CORPORATION
MILWAUKEE, WISCONSIN

ANNUNCIATOR ASSY-PL

300-2752



1. Name HORN, VIBRATING

2. Mfrd. by EDWARDS CO. INC.
Address NORWALK, CONN.

3. Manufacturer's No.:

Mfr. standard no. 343A
which describes it fully. It is a standard commercial item.

Mfr. style no. _____
which is an incomplete description. Also necessary to specify _____

4. Government Spec: The part described

is not required to meet a Gov't Spec.

must meet Gov't Specs as follows:

5. Or Equal

Only the brand detailed above is acceptable.

An equal in another brand is acceptable.

6. Same as Onan No. _____ except _____

7. After Receipt by Onan:


Used as is

Modified becomes Onan No. _____

8. First Used on Model _____

9. Data Furnished by T. AASEN

Ref.-V.A. FOR TEST, VA ± 20%
12 VOLT, DC, (SPECIAL)
V.A., AMPS DC OHMS (REF)
62 DECIBELS AT 10 FT. GRAY.
MOUNTS ON SURFACE OF ELECTRICAL BOX




WT. - 1-1/4 LB.

REDRAWN W/CHGS-OLD DWG		dated	10-25-62
LET	REVISION	ENG CKR	DATE

DR <u>MLK</u>	SC <u>OP</u>		DIVISION OF ONAN CORPORATION Minneapolis, Minnesota
CKR <u>CP</u>			
ENGR <u>TO AASEN</u>		HORN, VIBRATING	
DATE <u>4-19-73</u>			

MODEL	DWG NO.	333 - 0011	DWG SIZE P
-------	---------	------------	---------------


		6-X(2)				X	X	SAMP REL
PUR.	TP	COST	RELAY	QC	PO			PROD REL
								TO AASEN





Protective Housings

For GenSets 20 thru 500 kW, Radiator Cooled



Mufflers not included with housings


Weather Protective Housing encloses the electric generating set, yet allows *ample airflow*. Factory-installed enclosure of heavy gauge, reinforced sheet steel, attaches to the generator set's standard mounting base and radiator cowling. *Easy access* to engine-generator provided by removable panels on each side. Rear hinged door opens to permit access to the instrument panel.

Protective Housing Selection

For GenSet-			Housing Overall Dimensions		
Series	Fuel	Figure	Shown in inches, metric in parentheses (mm)		
			Length	Width	Height
ES	Gasoline	A	58 (1473)	26 (660)	39.5 (1003)
DL4	Diesel	B	68.5 (1740)	28.5 (724)	41.5 (1054)
DL6	Diesel	B	75 (1905)	28.5 (724)	41.5 (1054)
DL6T	Diesel	B	75 (1905)	28.5 (724)	41.5 (1054)
SK	Gasoline	C	72.5 (1841)	29.3 (743)	51.3 (1302)
EK,EM	Gasoline	D	78 (1981)	33 (838)	45.6 (1157)
EN	Gasoline	D	85 (2159)	40.8 (1035)	52.5 (1334)
ENT	Natural Gas	D	93 (2362)	40.8 (1035)	52.5 (1334)
WA	Natural Gas	E	102 (2591)	40 (1016)	57 (1448)
DFP,DFM	Diesel	E	114 (2896)	44 (1118)	70 (1778)
DFS,DFN	Diesel	E	120 (3048)	55 (1397)	70 (1778)
DVA,DVB	Diesel	F	90 (2286)	33 (838)	59 (1497)
DVC,DVD,DVE	Diesel	H	106 (2692)	35 (889)	59 (1497)
DVF,DVG	Diesel	I	126 (3200)	44 (1118)	75 (1905)
DVH,DVJ	Diesel	J	138 (3505)	50 (1270)	75 (1905)
DVK,DVL	Diesel	K	162 (4115)	60 (1524)	91 (2311)
SJB	Gas/N. Gas/LPG	G	70.3 (1785)	31.5 (800)	47.6 (1210)
SKB	Gas/N. Gas/LPG	G	84.2 (2139)	31.5 (800)	47.6 (1210)
DL4B	Diesel	G	78.3 (1990)	31.5 (800)	47.6 (1210)
DL6B	Diesel	G	88.2 (2240)	36.8 (934)	55.2 (1402)
DL6TB	Diesel	G	92.7 (2354)	36.8 (934)	55.2 (1402)

Weatherproof Shelters

For Radiator Cooled GenSets



Weatherproof Outdoor Shelters completely enclose the factory-installed, electric generating set to give year 'round protection against adverse weather and environmental conditions. Housings also discourage tampering and act as a barrier to rodents, etc.

Ruggedly constructed of welded and bolted, reinforced sheet steel in both 16-gauge and 14-gauge thicknesses. The floor plate is 14-gauge steel. All metal parts are prime-coated and finish-painted. Each housing has *shuttered air openings* on front and sides, with mesh screens covering side shutters.

Four 22-volt AC motors on Modification 96 and 97 and six on Modification 98 open the shutters to permit air to enter when gensets operate. *Motors are spring-loaded to close shutters when gensets stop.*

Hinged, double doors on each side give *easy access* to the genset, and a rear door allows access to the control panel. All door handles are key-lock type. Skid and floor design includes a removable panel below the engine oil pan. All shelters come *ready for job-installation*. Exhaust silencer, mounting hardware, vibration isolators, battery racks, etc., are optional and must be ordered separately.

Weatherproof Shelter Selection

For GenSet

Capacity	Fuel	Modification	Length	Width	Height	Weight
20-70 kW	Gasoline	F96	150 (3810)	64 (1626)	79 (2007)	1400 (636)
75 kW	Natural Gas					
85 kW	Gasoline					
300-100 kW	Diesel					
115 & 175 kW	Natural Gas	F97	150 (3810)	64 (1626)	79 (2007)	1400 (636)
125-250 kW	Diesel	F98	180 (4572)	84 (2134)	97 (2464)	1600 (726)
300-350 kW	Diesel	F121	180 (4572)	86 (2184)	97 (2464)	1800 (816)
400-500 kW	Diesel					

Shelter Overall Dimensions and Approximate Weights

Shown in inches, metric in parentheses (mm); weight-lb (kg)

See Your Onan Distributor:

Onan Corporation

1400 73rd Avenue N.E.
Minneapolis, MN 55432

Telephone
612 574-5000


Telex 29 0476 (U.S.)
Telex 29 0856 (outside U.S.)

TWX 910 576-2833
Cable ONAN

SIMPLX[®]

Packaged Day Tank Systems


Engineering Submittal




MODEL	CAPACITY (GALLONS)	DIMENSIONS (INCHES)		
		W	H	D
SFT3	3	36	22.25	12.25
SFT5	5	36	22.25	12.25
SFT7/10	7	36	22.25	12.25
SFT10A	10	24	23	12
SFT10S	10	24	24.5	5
SFT20S	20	24	24.5	8
SFT25A	25	24	34	12
SFT50A	50	24	43	18
SFT75A	75	24	56	18
SFT100A	100	24	56	24
SFT150A	150	27	59	36.25
SFT275A	275	27	58	66

Standard Day Tank


Standard Day Tank consists of: heavy gauge steel tank, epoxy coated inside, rust-proofed and finished painted outside (tank in Brewster Green, lift-off top cover in customer colors); 1" NPT threaded pipe connections for vent, overflow, engine suction and two 1" NPT threaded pipe connections for engine fuel return: one located above max fuel level, one located at same head pressure level as engine suction; tank drain; 2 gpm bronze gear pump connected to 1/3HP, 120V AC motor; 1 HP float switch with adjustment to maintain large reserve; control panel with "Press-to-Test" button, fuel level gauge and space for control options; complete wiring and plumbing.




Control panel with standard press-to-test; gauge. Optional status lights; switch.




Each day tank supplied standard with complete inside epoxy coating. Standard upflow baffle (lower left) directs return fuel up and away from settled sediment.




Overize motors, bronze gear pumps





Heavy-duty float switches



Standard lift-off top cover



Standard pipe connections



SFT275A standard dual connections

SIMPLEX

PACKAGED DAY TANK SYSTEMS FOR DIESEL AND FUEL OIL

CUSTOMER P.O. NO. REFERENCE EQUIPMENT

Option	Description
010	Auxiliary hand pump, piston type, 1 GPM capacity.
015	Auxiliary hand pump, piston type, 20 gallons per 100 strokes.
020	Manual fuel fill cap, 2" diameter.
030	6" square, gasketed inspection port in top of tank.
040	Wall-mounting brackets (available for 10 and 25 gallon units only).
050	Pipe stand adapter to raise tank above floor (pipe legs to be supplied by others).
060	Fuel strainer (shipped loose—mounts in Day Tank intake line).
063	Vent cap. Shipped loose for installation at outdoor vent termination. 1" NPT.
065	Drain hand valve in lieu of threaded plug in bottom of tank.
067	Manual quick-drain.
068	Emergency quick drain.
070	Check valve on pump intake to prevent loss of pump prime. For 2 GPM pump.
075	As above, for use with Option 400, 7 GPM pump.
080	Solenoid valve on pump intake to prevent loss of pump prime or tank flooding. For AC systems.
083	Solenoid valve, as above, for DC systems.
087	Manual fuel cut-off valve on day tank fuel inlet for gravity fed day tanks.
090	Foot valve to prevent loss of pump prime, 1" NPT (shipped loose).
093	High temperature fuel return.
095	Pressure relief valve.
110	Relocation of standard motor-pump to remote pumping unit.
120	Extra 1" NPT pipe connections on tank.
130	Oversize pipe connections, 1 1/4 to 2 1/2 NPT.
140	Special paint finishes.
150	Extra-heavy tank construction.
160	Stainless steel tank construction.
170	Tanks built and tested to withstand 50 PSI.
180	Weatherproof Modification.
185	2 or 3 complete day tanks mounted on common base, interconnected with isolation valves to provide system redundancy.
190	Rupture basin.
191	Addition to Option 190: Float switch in rupture basin to sense day tank rupture and stop pump motor.
192	Addition to Option 191: Adds wiring and terminal block on day tank to provide remote signal of day tank rupture.
193	Addition to Option 190: Adds plumbing and hand valve to permit draining of rupture basin through manual quick-drain installed on day tank.
194	Addition to Option 190: In event of tank rupture, provides automatic gravity draining of rupture basin back to main tank.
198	Earthquake zone version of day tank.
261	"On-Off" Day Tank system circuit breaker with short circuit trips. Mounted on day tank.
262	Thermal overload protection built into pump motor.
270	Power available green pilot light connected to line side of float switch.
280	"Pump Run-Off-Automatic" operation mode selector switch (includes 270 and 340).
295	Remote low fuel level alarm dry signal contacts.
297	Remote high fuel level alarm dry signal contacts.
299	Auxiliary relay for use with option 295 or 297 above.
305	Low fuel level alarm light (red) on day tank control panel.
307	High fuel level alarm light (red) on day tank control panel.
311	Local/remote low fuel level alarm.
312	Local/remote high fuel level alarm.
325	High fuel level emergency pump-stop switch.
329	Low fuel level red light to indicate low fuel in the remote main storage tank.
333	Critical low fuel level alarm—engine shut down.
334	Alarm horn installed on day tank.
338	Explosion-proof float switch in lieu of NEMA1 float switch for high/low level options.
340	"Pump Running" amber light.
350	Duplex pump controller system-Provides motor-pump backup system.

Mechanical Options


Control Devices and Alarms


360	Second standard motor-pump assembly: 1/3HP, 120V AC, 2GPM motor-pump complete with second float switch mounted and wired.
370	Explosion proof main float switch for motor-pump control in lieu of standard float switch.
380	Float valve for use in gravity fed systems.
390	Reversal of float switch and motor-pump to pump out on fuel level rise.
200	Sight glass (flexible plastic) with hand valve at lower end and guard.
210	Sight glass (glass) with 2 hand valves and guard.
220	Remote reading electric fuel level gauge for day tank.
230	Gauge to read fuel level of remote main storage tank (details required).
400	7 GPM highlight pump in lieu of 2 GPM basic unit pump. Requires a 1/2HP motor.
410	10 GPM highlight pump in lieu of 2 GPM basic unit pump. Requires a 3/4HP motor.
415	17GPM highlight pump in lieu of 2 GPM basic unit pump. Requires a 1HP motor.
510	Transformer, 480/120V AC, single phase, 60 Hz for use with standard & optional 1/3HP motors.
511	Transformer, 480/120V AC, single-phase, 60HZ, for use with optional 1/2HP motors.
605	1/3HP, 230V AC, single phase, 60 Hz motor.
610	1/3HP, 480V AC, single phase, 60 Hz motor c/w motor starter and control transformer.
615	1/3HP, 110V AC, single phase, 50 Hz motor.
616	1/3HP, 220V AC, single phase, 50 Hz motor.
620	1/3HP, 230V AC, 3 phase, 60 Hz motor.
625	1/3HP, 460V AC, 3 phase, 60 Hz motor c/w motor starter and control transformer.
630	1/3HP, 12V DC motor.
635	1/3HP, 24-28V DC motor.
638	1/3HP, 24-28V DC explosion-proof motor. Option 110 Required.
640	1/3HP, 32-36V DC motor.
645	1/3HP, 115V AC, single phase, 60 Hz motor, totally enclosed, fan cooled. #110 Req'd.
650	1/3HP, 230V AC, 3 phase, 60 Hz motor, totally enclosed, fan cooled. #110 Req'd.
655	1/3HP, 460V AC, 3 phase, 60 Hz motor, totally enclosed, fan cooled c/w motor starter and control transformer.
660	1/3HP, 115V AC, single phase, 60 Hz explosion-proof motor.
700	1/2HP, 115V AC, single phase, 60 Hz motor.
705	1/2HP, 230V AC, single phase, 60 Hz motor.
710	1/2HP, 480V AC, single phase, 60 Hz motor, c/w motor starter and control transformer.
715	1/2HP, 110V AC, single phase, 50 Hz motor.
716	1/2HP, 220V AC, single phase, 50 Hz motor.
720	1/2HP, 230V AC, 3 phase, 60 Hz motor.
725	1/2HP, 460V AC, 3 phase, 60 Hz motor c/w motor starter and control transformer.
730	1/2HP, 12V DC motor.
735	1/2HP, 24-28V DC motor.
738	1/2HP, 24-28V DC explosion proof motor.
740	1/2HP, 32-36V DC motor.
745	1/2HP, 115V AC, single phase, 60 Hz motor, totally enclosed, fan cooled.
750	1/2HP, 230V AC, 3 phase, 60 Hz motor, totally enclosed, fan cooled.
755	1/2HP, 460V AC, 3 phase, 60 Hz motor, totally enclosed, fan cooled, c/w motor starter and control transformer.
760	1/2HP, 120V AC, single phase, 60 Hz explosion-proof motor.
768	Single-phase magnetic motor starter with heater coil and control transformer.
770	3-phase magnetic motor starter with 3 heater coils and control transformer.

Gauges & Sight Glasses


Pumps and Motors

SIMPLEX INC
 SPRINGFIELD, ILLINOIS 62702
 PH217-525-6995 217-528-3130 (24hr.) Option List 8A 14022C
 TELEX 406-415 Printed in USA





Onan



OT II

Automatic Transfer Switches

With Power Sentry® Control

40 through 1000 amperes
50/60 hertz

Two or three pole
UL listed (Standard 1008)
CSA Certified
Various NEMA cabinets or
open construction

Wall Mounting NEMA 1
Enclosure With Options

Free Standing NEMA 1 Enclosure

The critical link between your load and the emergency power source is the Onan OT II automatic transfer switch. The transfer switch and an engine-generator make up a basic emergency power system to furnish power for your load when the normal power source is unsatisfactory.

Important Features Built Into OT II Transfer Switches With Power Sentry Control

- **High withstand rating**
- **Electronic control** with all-phase monitoring and four normally required time delays
- **Linear induction motor** operator
- **Programmed transition capability** for transfer of high inductive loads
- **Plug connector interface** with control simplifies maintenance and addition of features
- **Permanently mounted handles** for manual operation under load

Transfer Switch

Advanced Transfer Switch Design:

Bi-directional linear induction motors power all Onan OT II transfer switches. These motors provide virtually friction-free, constant force, straight-line switch action, with no gears or cams to break or wear.

Transfer Action:

Break-before-make action prevents the application of power to the load from both sources at the same time. A simple, mechanical interlocking beam ensures this action.

Mechanically Held Contacts:

Whether the switch is in the "Normal" or "Emergency" position, the contacts are mechanically held in that position.

Main Contacts:

Long-life, high pressure, silver cadmium oxide contacts resist burning and pitting.

Arc Interruption:

Multiple leaf arc chutes cool the gases and quench the arcs. Covers prevent interphase flashover.

Neutral:

Neutral bar with lugs is standard on OT II transfer switches supplied with cabinet.

Auxiliary Contacts:

An auxiliary switch on each side, operated by the transfer switch, is provided to operate peripheral equipment. These single-pole, double-throw switches, rated 10-amp, are wired to an easy access terminal block.

Current Rating:

All OT II transfer switches will carry their full rated current continuously.

Voltage Rating:

Power contacts are rated up to and including 600 VAC. The auxiliary contacts and linear induction motor are rated up to and including 480 VAC.

Manual Operators:

Insulated handles operate quick-make, quick-break spring over-center mechanism to allow manual transfer of rated current without disconnecting either source.

Withstand and Closing Ratings (Amperes) of Onan OT II Transfer Switches, per UL Standard 1008:

Transfer Switch Continuous Ampere Ratings	40,70,100	150,260	400, 600	800,1000
480-Volt Rating				
Circuit Breaker Protected				
Available RMS Symmetrical Fault Current, Amp	14,000	30,000	65,000	65,000
Protective Device Continuous Rating (max), Amp	125	400	1,200	2,000
600-Volt Rating				
Circuit Breaker Protected				
Available RMS Symmetrical Fault Current, Amp	5,000	10,000	14,000	25,000
Protective Device Continuous Rating (max), Amp	125	400	1,200	2,000
Fuse Protected				
Available Symmetrical Fault Current, Amp	200,000	200,000	200,000	200,000
Protective Device Continuous Rating (max), Amp	200	600	1,200	2,000
Fuse Class	J,RK1,RK5	J,RK1,RK5	L	L

Voltage

		Voltage Code	
		60-Hz	50-Hz
120	1-phase, 2-wire	1	51
120/240	1-phase, 3-wire	3	53
120/208	3-phase, 4-wire	4	54
277/480	3-phase, 4-wire	4X	54X
120/240	3-phase, 4-wire	5D	55D
220/380	3-phase, 4-wire	7	57
240/416	3-phase, 4-wire	7X	57X
127/220	3-phase, 4-wire	8	58
347/600	3-phase, 4-wire	9X	

Power Sentry® Electronic Control

Adjustable Undervoltage Sensors With Dropout Time Delay

These undervoltage sensors simultaneously monitor all phases of both normal and emergency sources.

Close Differential Adjustment Range

Pickup		Dropout		Time Delay
Min.	Max.	Min.	Max.	
85% ± 2.5% of nominal voltage	100% of nominal voltage	74% ± 3% of pickup setting	98% ± 0.3% of pickup setting	0.5 ± 0.25 seconds (fixed)

Adjustable range solid state voltage sensors let customer adjust for specific application needs. Protection can be field adjusted for brownout conditions to protect sensitive equipment, or adjusted to protect conventional equipment against gross voltage variations.

Start Contacts

Form-C (dry contacts, one normally open and one normally closed), for two-wire engine control, wired to an easy access terminal block.

Control Mode Status Indicators

Adjustable Solid State Time Delays

Time Delays enhance system performance and versatility.

Delay	Adjustment	Factory Setting
Start	0 to 6-sec	2-sec
Transfer	0 to 120-sec	2-sec
Retransfer	0 to 30-min	15-min
Stop	0 to 8-min	5-min

Start — Prevents nuisance genset starts in the event of momentary power system variation or loss.

Transfer — Allows genset to stabilize before application of load; prevents needless power interruption if normal source variation or loss is momentary.

Retransfer — Prevents needless power interruption if return of normal source is momentary; allows staggered retransfer of loads in multiple transfer switch systems.

Stop — Maintains availability of genset for immediate reconnection in the event that the normal source fails shortly after retransfer; allows gradual genset cool-down by running unloaded.

Enclosure

The transfer switch and Power Sentry control units are mounted in a single-door enclosure.

- Meters and indicator lamps readable from front of closed cabinet
- The key locking NEMA 1 cabinet utilizes 14-gauge welded steel construction
- Includes Normal/Emergency transfer switch position indicator lamps

- Includes key operated Test/Normal/Retransfer switch for system test and maintenance, and return to normal control, without opening the cabinet. Retransfer position provides immediate retransfer to normal, bypassing time delay.
- 40 through 100 amp switch cabinets wall mounting. Larger units free standing.
- Wiring space complies with 1984 NEC Table 373-6 (b)


Terminal Lug Capacity

For Copper or Aluminum Conductors unless otherwise indicated (Lugs not supplied on rear-connect models)

Switch Amp Rating	Number of Conductors	Size Range of Conductors	Switch Amp Rating	Number of Conductors	Size Range of Conductors
40	1	#0 AWG to #14 AWG	400	1	#6 AWG to 250 MCM
70	1	#0 AWG to #14 AWG		1	#2/0 AWG to 600 MCM
100	1	#0 AWG to #14 AWG	600	2	250 MCM to 350 MCM (copper)
150	1	#6 AWG to 350 MCM		2	350 MCM to 500 MCM (aluminum)
260	1	#4 AWG to 500 MCM	800	4	#4 AWG to 600 MCM
			1000	4	#4 AWG to 600 MCM


CAUTION: Do not run control wiring through power cable conduit or raceway.

Approximate Physical Dimensions




NEMA 1 Cabinet and Transfer Switch

Switch Amp Rating	Height (H)	Width (W)	Depth W/Door —		Weight (Switch & Cabinet)
			Closed (D)	Open (D _o)	
40	30.5 in (775mm)	23.0 in (584mm)	15.1 (384 mm)	32.75 in (832mm)	140 lb (64kg)
70					
100					
150	63.0 in (1600mm)	30.0 in (762mm)	21.6 (549mm)	45.5 (1156 mm)	480 lb (218kg)
260					
400	63.0 (1600 mm)	30.0 in (762mm)	21.6 (549 mm)	45.5 (1156 mm)	550 lb (249kg)
600					
800	84.0 in (2134mm)	36.0 in (914mm)	22.6 in (574mm)	51.7 in (1313mm)	650 lb (294kg)
1000					



Transfer Switch

Switch Amp Rating	Height		Width (W)	Depth		Weight
	Front Connect (H _f)	Rear Connect (H _r)		Front Connect (D _f)	Rear Connect (D _r)	
40	18.75 in (476mm)	18.75 in (476mm)	13.0 in (330mm)	7.9 in (200mm)	9.4 in (238mm)	24.5 lb (11.1kg)
70						
100						
150	32.4 (823 mm)	29.5 in (749mm)	16.25 in (413mm)	13.1 (333 mm)	13.6 in (345mm)	50 lb (23kg)
260						
400	26.6 (676 mm)	26.8 (681 mm)	16.3 (414 mm)	13.6 (345 mm)	14.8 (376 mm)	76 lb (34.4 kg)
600						
800	41.0 in (1041mm)	37.0 in (940mm)	18.0 in (457mm)	15.8 in (401mm)	15.2 in (386mm)	130 lb (60kg)
1000						



Power Sentry® Electronic Control

Approximate Weight
24-lb (11 kg)

Power Sentry Control unit for enclosed or open construction OT transfer switches.

Options and Accessories

Overvoltage and Frequency Sensing

- Control Package** - Overvoltage Sensors and Frequency Sensors

Adjustable Overvoltage Sensors with Dropout Time Delay (all phases, both sides)

Close Differential Adjustment Range

Pickup	Min.	Max.	Dropout	Time Delay	
				Min.	Max.
100% of nominal voltage	130% of nominal voltage	±5%	5% ± 1% of nominal voltage above pickup setting (fixed)	0.5-sec	2.2-min ±0.6-min

Adjustable Frequency Sensors with Dropout Time Delay (both sides)

Frequency Bandwidth Adjustment Range

Pickup	Min.	Max.	Dropout	Time Delay	
				Min.	Max.
±4% of nominal frequency	±4%	±20%	5% of nominal wider than pickup frequency bandwidth	0.1-sec	15 sec

Meters

- Voltmeter** — 3.5 in. (89 mm), 2% accuracy.
- Ammeter** — 3.5 in. (89 mm), 2% accuracy.
- Frequency Meter** — 3.5 in. (89 mm), pointer type.
- Running Time Meter** records genset cumulative operating hours.

GenSet Exercise

- Exerciser Clock** sets the day, time, and duration of the genset exercise period; includes With/Without Load selector switch.

Special Feature

- Programmed Transition** extends the transition or disconnect period beyond the normal 6-cycle time to allow residual voltages generated by heavy inductive loads to decay to a safe level. Available for either factory or field installation.

- Manual push to retransfer**

Battery Float Chargers (includes charge rate ammeter)

- 2-amp, 12 volt** **2-amp, 24-volt**
- 6-amp, 24-volt** **10-amp, 12-volt**

Two-To-Three-Wire Converter (includes overcrank lamp)

- With diesel preheat time delay**
- Without diesel preheat time delay**

Cabinet

- NEMA 4** — Raintight
- NEMA 3R** — Dustproof and rainproof
- Open Construction** (no cabinet) model, for installation in customer's enclosure. Includes automatic transfer switch and all cabinet mountable devices and associated wiring — shipped loose.

Relay Control

- Electromechanical Relay Control**, as an option to the Power Sentry electronic control, is an economical, reliable control for the automatic transfer switch functions where sophisticated controls are not required. Three control packages are offered:
 - Single-phase, non-adjustable line-loss relay provides automatic standby set starting in response to normal source failure, and shutdown on return of normal power.
 - All-phase, non-adjustable line-loss relay, plus time delays —
 - **Start**, adjustable 0.5 to 5.0 seconds.
 - **Retransfer**, adjustable 3.0 to 30 minutes.
 - All-phase, line-loss relay and time delays start and retransfer, as above, plus time delays —
 - **Stop**, 5 minutes, non-adjustable.
 - **Transfer**, 0.5 seconds, non-adjustable.

Ordering Note: Place the code (numbers or letters adjacent to boxes checked as selected features) in the model number block below. Additional options or accessories do not affect the model number.

OT	B	C	D	100 - 4	u	/ 34	01
----	---	---	---	---------	---	------	----

Series	Pole	Basic Application	Enclosure	Continuous Ampere Rating	Voltage 60-Hz 50-Hz	Agency Certification	Control Group	Meter Group
<input checked="" type="checkbox"/> OT Automatic Transfer Switch	<input type="checkbox"/> A 2-pole <input checked="" type="checkbox"/> B 3-pole	<input checked="" type="checkbox"/> C GenSet Standby to Utility	<input type="checkbox"/> A General Purpose (NEMA 1) <input type="checkbox"/> B Dustproof & Rainproof (NEMA 3R) <input type="checkbox"/> C Open Construction <input checked="" type="checkbox"/> D Watertight (NEMA 4)	<input type="checkbox"/> 40 <input type="checkbox"/> 70 <input checked="" type="checkbox"/> 100 <input type="checkbox"/> 150 <input type="checkbox"/> 260 <input type="checkbox"/> 400 <input type="checkbox"/> 600 <input type="checkbox"/> 800 <input type="checkbox"/> 1000	<input type="checkbox"/> 1 <input type="checkbox"/> 51 120-volt 1-phase, 2-wire <input type="checkbox"/> 3 <input type="checkbox"/> 53 120/240 volt 1-phase, 3-wire <input checked="" type="checkbox"/> 4 <input type="checkbox"/> 54 120-208-volt 3-phase, 4-wire <input type="checkbox"/> 4X <input type="checkbox"/> 54X 277/480-volt 3-phase, 4-wire <input checked="" type="checkbox"/> 5D <input type="checkbox"/> 55D 120/240-volt 3-phase, 4-wire <input type="checkbox"/> 7 <input type="checkbox"/> 57 220/380-volt 3-phase, 4-wire <input type="checkbox"/> 7X <input type="checkbox"/> 57X 240/416-volt 3-phase, 4-wire <input type="checkbox"/> 8 <input type="checkbox"/> 58 127/220-volt 3-phase, 4-wire <input type="checkbox"/> 9X 347/600-volt 3-phase, 4-wire	<input checked="" type="checkbox"/> U Underwriters' Laboratories, Inc. <input type="checkbox"/> C Canadian Standards Association <input type="checkbox"/> N None	Power Sentry Electronic Control <input type="checkbox"/> 31 Normal side sensing: Undervoltage (all lines) Emergency side sensing: Undervoltage (all lines) <input type="checkbox"/> 32 Normal side sensing: Undervoltage (all lines) Emergency side sensing: Undervoltage (all lines) Under/Over Frequency <input type="checkbox"/> 33 Normal side sensing: Undervoltage (all lines) Emergency side sensing: Undervoltage (all lines) Overvoltage (all lines) Under/Over Frequency <input checked="" type="checkbox"/> 34 Normal side sensing: Undervoltage (all lines) Overvoltage (all lines) Under/Over Frequency Emergency side sensing: Undervoltage (all lines) Overvoltage (all lines) Under/Over Frequency Electromechanical Relay Control <input type="checkbox"/> 56 Line Loss Relay <input type="checkbox"/> 57 Line Loss Relay Time Delay Start Time Delay Retransfer <input type="checkbox"/> 58 Line Loss Relay Time Delay Start Time Delay Transfer Time Delay Retransfer Time Delay Stop	<input checked="" type="checkbox"/> 01 None <input type="checkbox"/> 02 AC Voltmeter <input type="checkbox"/> 03 AC Voltmeter AC Ammeter(s) Running Time Meter Frequency Meter <input type="checkbox"/> 04 Running Time Meter <input type="checkbox"/> 05 Running Time Meter Frequency Meter <input type="checkbox"/> 06 AC Voltmeter AC Ammeter(s) Frequency Meter <input type="checkbox"/> 11 AC Ammeter(s)

See Your Onan Distributor:


Onan Corporation





1400 73rd Avenue N.E.
Minneapolis, MN 55432

Telephone
612 574-5000

Telex 29 0476 (U.S.)
Telex 29 0856 (outside U.S.)

TWX 910 576-2833
Cable ONAN





REV	DATE	BY	CHKD	DESCRIPTION
4306				PROD RELEASE
5198				REVISED PER ER
7009				REVISED CONNECTION NO
8693				ADDED RESISTOR
8693				REVISED CONNECTION
8693				ADD NOTE
9527				ADDED S18 VOLTAGE CODE

11. TO ADD PARALLELING SWITCHBOARD TRANSFER SWITCH INHIBIT CIRCUIT, REMOVE JUMPER BETWEEN TBI-5 & 6

(E) TRANSFER SWITCH SHOWN IS 40-100 AMP SIZE. ON THE 150-1000 AMP SWITCH THE LOAD IS LOCATED BELOW THE NORMAL CONNECTIONS ON THE SWITCH. THE NEUTRAL BAR ON THE 150-1000 AMP SWITCH IS MOUNTED ON THE BACK OF THE CABINET.

ITEM	DESCRIPTION
R1	RESISTOR-LAMP
A1	CONTROL ASSY
A2	CONVERTER-2 TO 3 WIRE (K10, K11, K12 TBI)(S13)(S14)
A3	BATTERY CHARGER
C1	CAPACITOR (TRANSFER SW)
CB1	CIRCUIT BREAKER (TRANSFER SWITCH TRANSFORMER-CURRENT)
CT1,2,3	LAMP-NORM L
DS1	LAMP-EMERGENCY
DS2	LAMP-OVERCRANK (PART OF S14)
DS3	LAMP-OVERCRANK (TIMING)
J1-J5	RECEPTACLES
K1, K2	RELAY-INTERPOSING (DUAL COIL)
K9	RELAY-PROGRAM TRANSITION
K10	RELAY-START DISCONNECT
K11	RELAY-OVERCRANK (TIMING)
K12	RELAY-PREHEAT (TIMING)
M1	LINEAR MOTOR
M2	EXERCISER CLOCK
M3	VOLTMETER-AC
M13	AMMETER-AC
M14	METER-FREQUENCY
M15	METER-TIME TOTALIZING
P1-P5	PLUGS
S1	SWITCH-DISCONNECT
S2,3,5,6,7	SWITCHES-CONTROL (TRANSFER SW)
S4	CONTACT-AUXILIARY (NORMAL SIDE)
S8	CONTACT-AUXILIARY (EMERGENCY SIDE)
S12	SWITCH-SELECTOR (STOP, AUTO, HAND CRANK)
S13	SWITCH-SELECTOR (STOP, AUTO, HAND CRANK)
S14	SWITCH-RESET (OVERCRANK)
S15	SWITCH-SELECTOR (VOLT & AMMETER)
S16	SWITCH-SELECTOR (W/ & W/O LOAD)
TBI	TERMINAL BLOCK (CUSTOMER CONN)
TB2	TERMINAL BLOCK (INTERCONNECTION)
TB10	TERMINAL BLOCK (CUSTOMER CONN)
TS1	TRANSFER SWITCH

NOTES

1. THERE ARE OPTIONS SHOWN THAT ARE NOT ON EVERY TRANSFER SWITCH. SEE LABEL INSIDE TRANSFER SWITCH CABINET FOR SPECIFIC OPTIONS INSTALLED.

OPTIONS

- A BATTERY CHARGER (A3)
- B PROGRAM TRANSITION (K9)
- C EXERCISER CLOCK (M2)
- D 2 TO 3 WIRE CONVERTER (A2)(S13)(S14)
- E METERS (M12)(M13)(M14)(M15)
- F DIESEL PREHEAT (K12)

2. ALL COMPONENTS ARE SHOWN IN THE DE-ENERGIZED POSITION UNLESS OTHERWISE STATED.

3. TRANSFER SWITCH IS MECHANICALLY HELD BOTH SIDES AND ELECTRICALLY OPERATED WITH MANUAL OPERATORS. TRANSFER SWITCH IS SHOWN CONNECTED TO THE NORMAL SOURCE.

4. NO NC DESIGNATES NORMALLY OPEN, M.C. DESIGNATES NORMALLY CLOSED, M.O. DESIGNATES NORMALLY OPENED.

5. DISCONNECT SWITCH: FOR MANUAL OPERATION OF TRANSFER SWITCH, THROW SWITCH TO "OFF". CAUTION: RETURN TRANSFER SWITCH TO ORIGINAL POSITION BEFORE SWITCHING TO "ON". SWITCH MUST BE LEFT IN "ON" POSITION EXCEPT FOR MANUAL OPERATION OF TRANSFER SWITCH.

6. SHOWN WIRED FOR 480V OR 600V OPERATION. DASH LINE INDICATES CONNECTION FOR 208V OR 240V OPERATION. UNLESS OTHERWISE NOTED ALL COMPONENTS ARE SHOWN IN THE DE-ENERGIZED POSITION.

7. TRANSFER SWITCH WITHOUT PROGRAM TRANSITION WILL HAVE A BYPASS PLUG IN J2.

8. LIGHT

9. RELAY COIL TO ON PICKUP

10. RELAY COIL TO ON DROPOUT


11. VOLTAGE CODE: 4, 5A, 5D, 5S, 4X, 54X, S18 3 POLE TRANSFER SWITCH

TOLERANCES UNLESS OTHERWISE SPECIFIED	UNIT	DESCRIPTION OF MATERIAL
±.001	INCH	626-1047
±.005	INCH	12-5-80
±.010	INCH	12-7-80
±.015	INCH	2-2-82
±.020	INCH	
±.030	INCH	
±.040	INCH	
±.050	INCH	
±.060	INCH	
±.070	INCH	
±.080	INCH	
±.090	INCH	
±.100	INCH	
±.120	INCH	
±.150	INCH	
±.200	INCH	
±.250	INCH	
±.300	INCH	
±.375	INCH	
±.500	INCH	
±.625	INCH	
±.750	INCH	
±.875	INCH	
±1.000	INCH	
±1.250	INCH	
±1.500	INCH	
±1.750	INCH	
±2.000	INCH	
±2.500	INCH	
±3.000	INCH	
±3.750	INCH	
±4.500	INCH	
±5.000	INCH	
±5.500	INCH	
±6.000	INCH	
±6.500	INCH	
±7.000	INCH	
±7.500	INCH	
±8.000	INCH	
±8.500	INCH	
±9.000	INCH	
±9.500	INCH	
±10.000	INCH	
±12.500	INCH	
±15.000	INCH	
±17.500	INCH	
±20.000	INCH	
±25.000	INCH	
±30.000	INCH	
±37.500	INCH	
±45.000	INCH	
±50.000	INCH	
±56.250	INCH	
±62.500	INCH	
±68.750	INCH	
±75.000	INCH	
±81.250	INCH	
±87.500	INCH	
±93.750	INCH	
±100.000	INCH	
±125.000	INCH	
±150.000	INCH	
±175.000	INCH	
±200.000	INCH	
±250.000	INCH	
±300.000	INCH	
±375.000	INCH	
±450.000	INCH	
±525.000	INCH	
±600.000	INCH	
±675.000	INCH	
±750.000	INCH	
±825.000	INCH	
±900.000	INCH	
±975.000	INCH	
±1000.000	INCH	
±1250.000	INCH	
±1500.000	INCH	
±1750.000	INCH	
±2000.000	INCH	
±2500.000	INCH	
±3000.000	INCH	
±3750.000	INCH	
±4500.000	INCH	
±5250.000	INCH	
±6000.000	INCH	
±6750.000	INCH	
±7500.000	INCH	
±8250.000	INCH	
±9000.000	INCH	
±9750.000	INCH	
±10000.000	INCH	


2 4 X









CUSTOMER CONNECTIONS



NOTES:

1. THERE ARE OPTIONS SHOWN THAT ARE NOT ON EVERY TRANSFER SWITCH. SEE LABEL INSIDE TRANSFER SWITCH CABINET FOR SPECIFIC OPTIONS INSTALLED.
 OPTIONS
 a. BATTERY CHARGER (A3)
 b. PROGRAM TRANSITION (K9)
 c. EXERCISER CLOCK (M2)(S16)
 d. CONVERTER-2 TO 3 WIRE (A2)(S13)(S14)
 e. DIESEL PREHEAT (K12)
2. WHEN ADDING EXERCISER CLOCK:
 A. REMOVE JUMPER BETWEEN TBI-8 AND TBI-9.
 B. TO A TWO WIRE START REMOVE WIRE MARKED S16-8, S13-1.
 C. TO A THREE WIRE START REMOVE JUMPER BETWEEN S16-8 AND S16-4 (NOT SHOWN) REMOVE WIRE BETWEEN S13-1 AND TBI-4 (NOT SHOWN)
3. REMOVE JUMPER BETWEEN TBI-2 & TBI-3 WHEN ADDING 2 TO 3 WIRE CONVERTER DISCARD PLUGS 517-0150 AND INSTALL S13 AND S14.
4. REMOVE JUMPER BETWEEN TBIO-5 & TBIO-6 WHEN ADDING PRE-HEAT
5. FOR 208 V WIRE MARKED K9-L1, P2-7 IS CONNECTED TO K9-L3
 FOR 240 V WIRE MARKED K9-L2, P2-3 IS CONNECTED TO K9-L3.
6. TO ADD AREA PROTECT EQUIPMENT OR REMOTE TEST TRANSFER SWITCH, REMOVE JUMPER AND CONNECT BETWEEN TERMINALS 7 & 8.
7. PROGRAM TRANSITION NOTE:
 TRANSFER SWITCH WITHOUT PROGRAM TRANSITION WILL HAVE A BYPASS PLUG IN J2
8. ~~TI TRANSFORMER ASSY (STRDN) ARE MOUNTED IN A1 CONTROL ASSY~~
9. TO ADD PARALLELING SWITCHBOARD TRANSFER SWITCH INHIBIT CIRCUIT, REMOVE JUMPER BETWEEN TBI-5 & 6
10. WIRES FROM P3-8 TO S12-4 AND FROM P3-9 TO S12-3 ARE INSTALLED IN TRANSFER SWITCHES DATED BETWEEN DEC 1984 AND MAY 1985. THESE WIRES SHOULD BE REMOVED IF A 300-3036 TIMING MODULE IS INSTALLED IN THE (A1) CONTROL ASSEMBLY.




	40 AMP	70 AMP	100 AMP
208V, 240V 50, 60Hz	-01	-02	-03

3 POLE NO METERS OI
 VOLTAGE CODE: 4, 5D, 54, 55D

THIS DOCUMENT SUBJECT TO FOLLOWING STANDARDS/CODES <input checked="" type="checkbox"/> UL <input checked="" type="checkbox"/> CSA <input type="checkbox"/> IEC <input type="checkbox"/> BS		TOLERANCES UNLESS OTHERWISE SPECIFIED DIM INCH ±.005 DIM MM ±.15 HOLES ±.006 ANGLES ±.5°		NEXT ASSY TITRE ANGLE PROJECTION THE PROPRIETARY DESIGN INFORMATION ON THIS DRAWING IS OWNED BY ONSAN CORPORATION. CONSTRUCTION OF THIS DRAWING IS NOT EXTENDED TO OTHERS.		626-1042 9-23-80 CIP 10-6-80 10-7-80 10-7-80		ITEM BULK PART NO. - DWG SIZE QTY DESCRIPTION OR MATERIAL A DIVISION OF ONSAN CORPORATION Minneapolis, Minnesota WIRING DIAGRAM-OT OT40-100 Spec E 626-1042	
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	------------------------------------------------------------------------------------------------------	--	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	--------------------------------------------------------------------	--	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

ER	LET	REVISION	ZONE	DR	ENC	CAR	DATE
3864		PROD RELEASE					
4146	A	REVISED NOTE 2C	5B	CIP			11-10-80
4146	B	REVISED S16-4 & S16-9, REM NOTE 2C	4D	CIP			11-10-80
4146	C	ADDED 406-0089 QTY 1	2C	CIP			11-10-80
4146	D	REMOVED 308-0566	2B	CIP			11-10-80
4146	E	ADDED 308-0579 & 308-0580	2C	CIP			11-10-80
6162	F	REVISED PER ER	4C	CIP			4-27-81
8345	G	DS1 WAS 322-0249, DS2 WAS 322-0248	2B	CIP			12-4-81
8345	H	ADDED RI 350-1205 QTY 2	2B	CIP			12-4-81
8345	J	ADDED 322-0316 QTY 2	2B	CIP			12-4-81
22,423	K	ITEM A1 WAS 300-2107	1C	RU			9-26-83
22,423	L	DELETED NOTE B / TI 301-0493		RU			9-26-83
22,423	M	ADDED RELATED WIRING TO A1, S12, TBI, TSI		RU			9-26-83
25,220	N	ADDED P3-8 & P3-9		TF			10-8-84
26324	P	ADD NOTE #10	1-C	TF			10-26-84
			5A	AH			5-9-85

(E)	308-0580	C	1	CONTACT BLOCK (N.C.)
(C)	308-0579	C	1	CONTACT BLOCK (N.O.)
(K)	406-0089	P	1	CATCH
(N2)	323-1226	A	1	PLUG-BYPASS
(A1)	300-2774	D	1	CONTROL ASSY
(A2)	(REF)	-	1	CONVERTER-2 TO 3WIRE
(A3)	(REF)	-	1	BATTERY CHARGER
	99-1269	A	1	NAMEPLATE-LOAD XFR
	98-5387	B	1	LABEL-DANGER
	98-5380	A	1	TAG-CAUTION
(REF)	508-0231	P	3	BUMPER
(L)	316-0493	C	2	TRANSFORMER ASSY (STRDN)
(DS1)	322-0318	P	1	LAMP-HOUSING (WHITE)
(DS2)	322-0317	P	1	LAMP-HOUSING (YELLOW)
	322-0316	A	2	LAMP-NEON
(K9)	(REF)	-	1	PROGRAM TRANSITION
(M2)	(REF)	-	1	EXERCISER CLOCK
(H)	350-1205	A	2	RESISTOR ASSY
(S12)	308-0577	C	1	SWITCH-PUSH/ROTARY
(S13)	PART OF A2	-	1	SWITCH-SELECTOR (STOP, REMOTE, HAND CRANK)
(S14)	PART OF A2	-	1	SWITCH-RESET (OVERCRANK)
(S16)	PART OF M2	-	1	SWITCH-SELECTOR (W/WO LOAD)
	332-0052	P	2	CLIP-WIRE
	332-2420	P	4	MOUNT-CABLE TIE
(TS1)	306-2204	D	1	TRANSFER SW ASSY (-01)
	306-2222	D	1	TRANSFER SW ASSY (-02)
	306-2240	D	1	TRANSFER SW ASSY (-03)
	517-0150	A	2	PLUG-HOLE
	98-4339	B	1	LABEL-OPTIONS
	338-1436	D	1	WIRING HARNESS-CABINET
	301-6086	D	1	CONTROL BOX
	301-6087	D	1	MOUNTING PLATE
	332-1469	A	1	MARKER STRIP (USE ON TB2)
	332-2425	A	1	MARKER STRIP (USE ON TBI)
	301-6154	D	1	DOOR ASSY-CONT BOX
	406-0522	P	1	HANDLE



626-1059

A

ER	LEI	REVISION	DR	ENC	CHK	DATE
3952		PROD RELEASE				
20,425	A	ITEM 1 WAS 300-2111QTY 1	CIP	CIP		8-12-82
20,125	B	REM ITEM 2 (300-2113)QTY 1	CIP	CIP		8-12-82
20,425	C	REV NOTE 1, REM NOTE 2	CIP	CIP		8-12-82
20,425	D	WAS GROUP 14	CIP	CIP		8-12-82
21,319	E	P/N WAS 300-2548	RD	Y		12-22-82
23357	F	1 ADD -01 TO ITEM 1	JTM	JF		1-14-85
		2 ADD -02, 50 HZ	JTM	JF		1-14-85


NOTES:


- INSTALL ITEM 1 INTO SLOT J1 & J3 LOCATED IN CONTROL ASSY (A1) C

TABULATION		
CONTROL-SENSOR PART NO.	ITEM 1 PART NO.	HZ
626-1057-01	300-2373-01	60
626-1057-02	300-2373-02	50

TOLERANCES UNLESS OTHERWISE SPECIFIED		FEAT ASSY	SEPIA DIMS	ITEM	QUANTITY	PART NO	DWG SIZE	QTY	DESCRIPTION OR MATERIAL
mm	INCH	VIA TO	INITIAL	DATE					A DIVISION OF OMAN CORPORATION Minneapolis Minnesota
± .015	± .006	Third Angle Projection	CIP	10-7-80					CONTROL-SENSOR
± .005	± .002	(1:1)	CIP	10-9-80					
ANGLES °	SCALE	The proprietor's design is intended to be used by Oman Corporation. Licensees of this right is not extended to others.	JTM	10-9-80					GROUP 34 D
									626-1059

E B A







MANUFACTURER'S LIMITED WARRANTY

Onan extends to the original purchaser of goods for use, the following warranty covering goods manufactured or supplied by Onan and used within the United States, subject to the qualifications indicated.

THERE IS NO OTHER EXPRESS WARRANTY.

IMPLIED WARRANTIES INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED TO PERIODS OF WARRANTY SET FORTH BELOW AND TO THE EXTENT PERMITTED BY LAW, ANY AND ALL IMPLIED WARRANTIES ARE EXCLUDED.

IN NO EVENT IS ONAN LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES.

Note: Some states do not allow limitations on how long an implied warranty lasts, so the above limitations may not apply in every instance.

- (1) Onan warrants to original purchaser for the periods set forth below that goods manufactured or supplied by it will be free from defects in workmanship and material, provided such goods are installed, operated, and maintained in accordance with Onan's written instructions, and further provided, that installation inspection and initial start-up on commercial-industrial generator set or power system installations are conducted by an Onan Authorized Distributor or its designated service representative.

PRODUCT APPLICATION

- Goods used in personal, family and household applications.
- Goods designed for and used in Recreational Vehicles.
- Goods used in commercial-industrial applications.
- Commercial-industrial stationary generator sets.
- Industrial Floodlighter generator sets.
- Rental or demonstrator units.
- Commercial-industrial, standby power systems, and residential standby systems which are installed in the U.S. (must include Onan supplied generator sets, automatic transfer switch, exerciser and running time meter).
- Power take-off (PTO) Alternators. (Direct drive only)
- Repair or replacement parts

PERIOD OF WARRANTY

- One (1) year from date of purchase.
- Two (2) years from date of purchase.
- One (1) year from date of purchase.
- One (1) year from date of initial start-up.
- Two (2) years or 2000 hours, whichever occurs first from date of purchase.
- One (1) year from date of first rental or demonstration.
- Five (5) years or 1500 hours, whichever occurs first from date of initial start-up. Labor allowance for the first two (2) years or 1500 hours, whichever occurs first from the date of initial start-up. See your Onan distributor for the additional details.
- Five (5) years from date of purchase. Labor allowance for the first two (2) years.
- Ninety (90) days from date of purchase, excludes labor.

- Must be registered within thirty (30) days of initial start-up on Form No. 23-065, to be provided and completed by seller.

- (2) Onan's sole liability and Purchaser's sole remedy for a failure of goods under this warranty and for any and all other claims arising out of the purchase and use of the goods, including negligence on the part of the manufacturer, shall be limited to the repair of the product by the repair or replacement, at Onan's option, of parts that do not conform to this warranty, provided that the product or parts are returned to Onan's factory at 1400 73rd Avenue NE, Minneapolis, Minnesota 55432, or to an Onan Authorized Distributor or its designated service representative, transportation prepaid.

Except as indicated below, this warranty does not include travel time, mileage, or labor for removal of Onan product from its application and reinstallation.

a) Removal and Reinstallation

Onan will pay the following stated labor at straight time only for warranty work requiring removal and reinstallation of Onan Products in the following applications, provided, such warranty labor is performed by an Onan Authorized Distributor or its designated service representative:

- i. On-Highway Recreational and Commercial Vehicle Applications - Up to a maximum of two (2) hours.
- ii. Marine Product installations - Up to a maximum of four (4) hours for all single and two cylinder engine powered Marine Generator Sets Installed below-deck.
—Up to eight (8) hours for all four and six cylinder engine powered Marine Generator Sets installed below-deck.

b) Travel Time and Mileage

- i. Marine Generator Set Installations - Onan will for twelve (12) months after date of purchase, pay travel time up to two and one half (2.5) hours and mileage cost up to one hundred (100) miles on generator sets with a kilowatt (kW) rating of fifteen (15) or less, and up to six and one half (6.5) hours and mileage cost up to two hundred fifty (250) miles on generator sets with a kilowatt (kW) rating above fifteen (15) for related warranty repairs, provided, such travel and repairs are performed by an Onan Authorized Distributor or its designated service representative.
- ii. Industrial Floodlighter Generator Sets - Onan will for twelve (12) months after date of purchase, pay travel time up to two and one half (2.5) hours and mileage cost up to one hundred (100) miles for related warranty repairs, provided, such travel and repairs are performed by an Onan Authorized Distributor or its designated service representative.
- iii. Commercial-Industrial Standby Generator Set, System Installations, and Residential Standby Systems - Provided the generator set or system is permanently wired in a stationary installation, Onan will for twelve (12) months after initial start-up, pay travel time up to two and one half (2.5) hours and mileage cost up to one hundred (100) miles on generator sets with kilowatt (kW) rating of seventeen and one half (17.5) or less, and up to six and one half (6.5) hours and mileage cost up to two hundred fifty (250) miles on generator sets with a kilowatt (kW) rating above seventeen and one half (17.5) and for transfer switches used with industrial standby generator set and system installations, for warranty repairs performed by an Onan Authorized Distributor or its designated service representative.

(3) All claims must be brought to the attention of Onan or an Authorized Distributor or its designated service representative within thirty (30) days after discovery that goods or parts fail to meet this warranty.

(4) THIS WARRANTY SHALL NOT APPLY TO:

- a) Cost of maintenance, adjustments, installation and start-up.
- b) Failures due to normal wear, accident, misuse, abuse, negligence or improper installation, or lack of reasonable and necessary maintenance.
- c) Products which are altered or modified in manner not authorized by manufacturer in writing.
- d) Failure of goods caused by defects in the system or application in which the goods are installed.
- e) Telephone, telegraph, teletype or other communication expenses.
- f) Living and travel expenses of persons performing service, except as specifically included in Section 2.
- g) Rental equipment used while warranty repairs are being performed.
- h) Overtime labor requested by purchaser.
- i) Optional engine coolant heaters after the first year.
- j) Starting batteries.


No person is authorized to give any other warranties or to assume any other liabilities on Onan's behalf, unless made or assumed in writing by an officer of Onan, and no person is authorized to give any warranties or assume any other liability on behalf of Seller unless made or assumed in writing by Seller.


(5) This warranty gives the user specific legal rights, and the user may also have other rights which vary from state to state.


CERTIFICATE FOR PTS LINE OF PROTOTYPE TEST SUPPORTED GENERATOR SETS

Electrical Products Division of Onan Corporation, certifies that Onan products bearing the Prototype Test Supported seal have benefitted from a development history which includes an extensive prototype testing program. A Prototype Test Supported production model has been built to documentation developed through comprehensive research, design, and design verification. Design verification is based on tests of preproduction prototype models built expressly for test purposes and not sold as new equipment. To be certified as a Prototype Test Supported model, an Onan generator set must have satisfied these prerequisites:

1. **Design Purpose.** The PTS certified generator must be designed specifically for application in standby or emergency power systems which, because of their critical nature, require high reliability and rapid response.
2. **Prototype Test Program.** The fitness of the PTS certified generator set for standby service must have been proven by tests on separate, representative, preproduction prototype models. The prototype test program is designed to:
 - a. Assure that the prime mover and generator have reserve capacity beyond design limits so that surges and transitory overloads are not likely to damage the generator set or render it inoperable.
 - b. Determine the sensitivity of generator set performance to variance in components and to the varying effects of time, temperature, and usage as a basis for establishing critical production tolerances.
 - c. Investigate and identify failure modes to minimize the risk of any single component failure or human error leading to cascading, catastrophic consequences.
 - d. Determine that electrical components are free of internal hot spots that would result in premature failure of the generator set.
 - e. Establish short circuit capability. The generator set must survive, without damage, ten short circuits, each of thirty seconds duration, applied across all phases while the generator set is operating at rated voltage, amperage, power factor, and speed. When the short circuits are cleared, the generator must build up voltage and perform normally without manual intervention of any kind such as resetting breakers or other tripping devices. After the tests, inspection must not uncover electrical or mechanical damage to any system component.
 - f. Demonstrate the capability of the generator set, its vital controls, and accessories to function reliably and compatibly when in-service demands are made by disturbances commonly occurring in actual load circuits, such as surges caused by motor starting, elevator operation, rectifiers, SCR controllers, X-ray equipment, and reactive discharges.
 - g. Discover by endurance testing that there are no resonance conditions in the generator set, or its accessories, that will cause premature fatigue failures of components on production units.
 - h. Prove a margin of safety, in actual trials, between the generator set and its protective system so that the generator set is not weakened or damaged before the protective system would shut it down.
 - i. Verify that production generator sets will perform to specifications under all extremes of environment expected in actual service.
3. **Documentation and Software.** The PTS certified generator set must be documented in a single drawing package and all components identified with Onan part numbers. Software in support of the product-specification sheets, operator's manuals, parts lists, service manuals, and installation procedure—must be available and on record for future reference.
4. **Quality Assurance.** Engineering drawings, specifications, and test requirements for a PTS certified generator set must be classified by components and assembly quality characteristics. A component and in-process inspection and test plan must be developed and maintained to assure product conformance to the documentation requirements. The quality assurance inspection and test plan, along with supporting documents and records, must be available for customer review.
5. **Production Model Testing.** PTS certified generator sets must have passed tests that demonstrate conformance to specification at all rated conditions including startup, full load pick-up, and voltage regulation at full rated load and power factor as well as temperature stability tests. Data from selected non-destructive tests must confirm that the PTS certified generator set would function comparably with the preproduction prototype under more extreme conditions likely to occur in actual service.







W E L L D A T A

Well No. 11

SPECIFICATIONS


Pump Base Elevation	33.0
Ground Elevation	31.0
Static Elevation	+ 6.0
Maximum allowed Drawdown	-11.0
Total Discharge	250 G.P.M.
Total Head	91 Feet

TEST

200 G.P.M.	34# Pressure	Drawdown	+1.5
220 G.P.M.	30# Pressure	Drawdown	+0.4
250 G.P.M.	26# Pressure	Drawdown	-1.2
290 G.P.M.	18# Pressure	Drawdown	-3.5

Recovers to elevation + 12.6 in three (3) minutes.

This Well pumps sand and should not be pumped over 200 G.P.M.
(should have pipe installed to pump out side)



Marine Barracks
New River, N. C.
June 27, 1942

Wells: Permanent Water Supply, Regimental Area
By Layne Atlantic Company
Report on Well No. 11, this area.

Location: 4850' west of station 355 + 57 on Main Access
Road as shown on N.B. Drawing No. 577.

Date Drilled: June, 1942

**Drilling
Equipment:** Rotary rig and bits.


Status: A 23" hole drilled to a depth of 20 feet, 20' of 18"
steel casing set and the annular space filled with
cement grout to surface level. A 17½" hole drilled
to a total depth of 168'.

**Log of
Formations:**

0 to 1'	Sandy top soil.
1' to 33'	Light yellow clay and sand mixed
33' to 35'	White clay
35' to 40'	Blue clay
40' to 45'	White sand with little clay
45' to 58'	White sand packed hard
58' to 86'	Fine blue sand
86' to 112'	Hard rock
112' to 121'	Hard rock with sand pockets
121' to 162'	Hard rock with fine sand in layers
162' to 168'	Fine blue sand and clay mixed.

Remarks: Well finished at 161'. Due to the presence of fine
sand in the rock formation it was necessary to
construct a gravel wall well.

**Gravel Wall
Construction:** 61' of 8" steel pipe with sections of armo iron screen
was placed in the well and the annular space around this
was pumped full of 1/4" washed gravel.



Continued -

Page 2

Log of Screen	0 to 61'	8" steel pipe
Setting:	61' to 71'	8" Screen
	71' to 91'	8" steel pipe
	91' to 101'	8" screen
	101' to 121'	8" steel pipe
	121' to 136'	8" screen
	136' to 156'	8" steel pipe
	156' to 161'	8" screen

There was 40' of screen placed in the well.
The bottom of the screen was filled with a
cement plug.

Static Level: 15.5' below surface.

Air line: 60' of 1/4" pipe welded to steel casing.

Pumping: Well was cleaned with air lift and flow was
measured with 12" weir. Well pumps 220 gallons
per minute with a 24.5' draw down below static.
Recovers to 9.5' below static in three minutes.

See separate report for chemical analysis.

N. H. Kellam
Asst. Chemical Engineer



The first part of the document
 discusses the general principles
 of the system and its
 objectives. It also outlines
 the scope of the project and
 the roles of the various
 participants.

The second part of the document
 describes the methodology used
 in the study. This includes
 a detailed account of the
 data collection process and
 the analysis techniques used
 to interpret the results.

The third part of the document
 presents the findings of the
 study. This section includes
 a summary of the key results
 and a discussion of their
 implications for the field.

The fourth part of the document
 discusses the conclusions of the
 study and offers suggestions
 for future research. This
 section also includes a list
 of references and an appendix
 containing additional data.

The fifth part of the document
 provides a final summary of
 the project and its findings.
 This section also includes a
 list of acknowledgments and
 a list of authors.

WATER ANALYSIS

By N. H. Kellan

Date 6/29/42

Sample from Well No. 11 Reg Area

Total Solids 244 PPM Dissolved Solids 214 PPM

Suspended Solids 30 PPM Volatile Solids _____ PPM

Phenol. Alk. as CaCO₃ 0 PPM Silica as SiO₂ 28 PPM

Total Alk. " " 190 " Ferrous Iron as Fe 0 "

Carbonates " " 0 " Total Iron as Fe 1.0 "

Bicarbonates " " 190 " Aluminum as Al. 4.8 "

Chlorides as Cl. 15 " Calcium as Ca. 64.9 "

Sulphates as SO₄ 16 " Magnesium as Mg. 9.0 "

Nitrites as NO₂ Trace " Sodium as Na. 7.2 "

Carbon Dioxide as CO₂ (1) 0 "

pH 7.6 Soap Hardness as CaCO₃ 210 PPM

Odor slight Turbidity 10

REMARKS (1) Pumped With air lift

146 054
25 67

Date

Sample from

_____	_____	_____	_____
_____	_____	_____	_____

_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

_____	_____	_____	_____
_____	_____	_____	_____

U.S. DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
OFFICE OF WATER DATA COORDINATION
INVENTORY OF HYDROLOGIC DATA STATIONS
QUALITY OF WATER

APPROVED.
Budget Bureau No. 42-R1485
Approval Expires June 30, 1968

1. AGENCY CODE MC	2. TYPE Q	3. LATITUDE ° ' " N 34 42 11	4. LONGITUDE ° ' " W 77 21 6	5.
----------------------	--------------	------------------------------------	------------------------------------	----

6. AGENCY STATION NO. 611	7. STATION NAME HP20-611
------------------------------	-----------------------------

8. DRAINAGE BASIN CODE No. Letter 06 N	9. STATE CODE 32	10. COUNTY CODE 133	11. COUNTY NAME ONslow
----------------------------------------------	---------------------	------------------------	---------------------------

12. PERIOD OF RECORD Began 1942	Discontinued	Y <input type="checkbox"/> Continuous <input type="checkbox"/> Interruption Exceeds 1 Year	13.	14.
------------------------------------	--------------	--------------------------------------------------------------------------------------------------	-----	-----

15. SITE	<input type="checkbox"/> 101 Stream	<input type="checkbox"/> 102 Canal	<input type="checkbox"/> 103 Lake	<input type="checkbox"/> 104 Reservoir	<input type="checkbox"/> 105 Estuary	<input type="checkbox"/> 106 Spring	<input checked="" type="checkbox"/> 107 Well	<input checked="" type="checkbox"/> 110 Other
----------	-------------------------------------	------------------------------------	-----------------------------------	----------------------------------------	--------------------------------------	-------------------------------------	----------------------------------------------	-----------------------------------------------

16. FREQUENCY OF MEASUREMENT	<input type="checkbox"/> 201 Continuous Recorder	<input type="checkbox"/> 202 Telemetered	<input type="checkbox"/> 203 Daily	<input type="checkbox"/> 204 Weekly	<input type="checkbox"/> 205 Monthly	<input type="checkbox"/> 206 Quarterly	<input type="checkbox"/> 207 Seasonal	<input type="checkbox"/> 208 Annual	<input type="checkbox"/> 209 Other Periodic	<input checked="" type="checkbox"/> 210 Occasional
------------------------------	--------------------------------------------------	------------------------------------------	------------------------------------	-------------------------------------	--------------------------------------	----------------------------------------	---------------------------------------	-------------------------------------	---------------------------------------------	----------------------------------------------------

17. TYPES OF DATA AVAILABLE	<i>Physical</i>	<i>Chemical</i>	<i>Organic</i>
	<input type="checkbox"/> 311 Temperature	<input type="checkbox"/> 331 Dissolved solids	<input type="checkbox"/> 351 Pesticides (insecticides, herbicides, etc.)
	<input type="checkbox"/> 312 Specific Conductance	<input checked="" type="checkbox"/> 332 Chlorides Only	<input type="checkbox"/> 352 Synthetic detergents
	<input type="checkbox"/> 313 Turbidity	<input type="checkbox"/> 333 Nutrients (Nitrogen and phosphorus compounds)	<input type="checkbox"/> 353 Other
	<input type="checkbox"/> 314 Color	<input type="checkbox"/> 334 Common ions	<i>Biologic</i>
	<input type="checkbox"/> 315 Odor	<input checked="" type="checkbox"/> 335 Hardness	<input type="checkbox"/> 361 Coliforms
	<input type="checkbox"/> 316 Radioactivity	<input type="checkbox"/> 336 Radiochemical	<input type="checkbox"/> 362 Other Micro-organisms
	<input type="checkbox"/> 317 pH (field)	<input type="checkbox"/> 337 Dissolved oxygen	<input type="checkbox"/> 363 BOD
	<input checked="" type="checkbox"/> 318 pH (lab)	<input type="checkbox"/> 338 Other Gases	<input type="checkbox"/> 364 Other
	<input type="checkbox"/> 319 Eh	<input type="checkbox"/> 339 Other	<i>Sediment</i>
	<input type="checkbox"/> 320 Other		<input type="checkbox"/> 371 Concentration
			<input type="checkbox"/> 372 Particle size
			<input type="checkbox"/> 373 Other

18. SUPPLEMENTARY DATA FOR SITE	<input type="checkbox"/> 421 Surface Water Station	<input type="checkbox"/> 422 Ground Water Station	<input type="checkbox"/> 423 Water Stage or Level	<input checked="" type="checkbox"/> 424 Water discharge	<input type="checkbox"/> 425 Time of Travel	<input type="checkbox"/> 426 Drainage Area
---------------------------------	----------------------------------------------------	---------------------------------------------------	---------------------------------------------------	---------------------------------------------------------	---------------------------------------------	--------------------------------------------

19. STORAGE OF DATA	<input type="checkbox"/> 501 Periodic Report	<input type="checkbox"/> 502 Areal Report	<input checked="" type="checkbox"/> 503 Not Published	<input type="checkbox"/> 504 Data on Punchcard	<input type="checkbox"/> 505 Data on Magnetic Tape	<input type="checkbox"/> 506 Other
---------------------	----------------------------------------------	-------------------------------------------	-------------------------------------------------------	------------------------------------------------	----------------------------------------------------	------------------------------------


20. OFFICE AT WHICH DATA AVAILABLE	Office <u>BASE MAINTENANCE DEPARTMENT, UTILITIES DIVISION</u>
Street No. <u>MARINE CORPS BASE</u>	City Code
City, State, Zip <u>CAMP LEJUNE, N. C. 28542</u>	<u>0735</u>

21. OFFICE COMPLETING FORM	<u>BASE MAINTENANCE DEPARTMENT</u>
----------------------------	------------------------------------

22. COMPILER'S NAME	<u>F. E. TEN, JR.</u>	23. DATE	Month	Year
			<u>SEPT.</u>	<u>1966</u>



OM



LOG OF FORMATION WELL #11 REG 270

- 0 To 1' Sandy Top Soil
- 1' To 33' Light yellow clay and sand mixed
- 33' To 35' White clay
- 35' To 40' Blue clay
- 40' To 45' White sand with little clay
- 45' To 58' White sand packed tight
- 58' To 86' fine Blue sand
- 86' To 112' Hard Rock
- 112' To 121' " " With sand mixed
- 121' To 162' hard Rock and salt and pepper sand in layers
- 162' To 168' fine Blue sand and Blue clay mixed

Well finished at 161'-0" deep

C.C. MY MONTROE
MY KELLAM

W. H. D. D.

F. R. G. A. A.,

WELL #
611

DATE	LENGTH OF AIR LINE	STATIC LEVEL	PUMPING LEVEL	DRAW DOWN	DISCHARGE PRESSURE	CAP. PER FOOT OF DRAW DOWN	G.P.M. TOTAL CAP.
1-10-79	60'	22' ?	12'	10'	24 LBS		235

REMARKS:

ALT. GAUGE
SET PUMP PRESSURE THIS DATE 24 LBS
WELL JUST CUT OFF. STATIC MAY BE HIGHER
TOP SCREEN 60'

DEPTH OF WELL:
AIRLINE ELEVATION: +
DATE INSTALLED:



[Faint, illegible handwriting covering the majority of the page, likely bleed-through from the reverse side.]

Well # 11

Date Line Ft. G.P.M. D.D. El. Static El. Shut Off head D.D. Ft.

Date	Line Ft.	G.P.M.	D.D. El.	Static El.	Shut Off head	D.D. Ft.
4-15-54						
5-5-54	79	280	43	28 FT	-	15
"	68	260	46	-	-	18
5-25-54	64	?	47	28	-	19
6-8-54	62		47	28	-	19
6-4-54			50	28		22
7-28-54	56		50	28		22
4-18-55	65		44	31		13
3/6/58	New pump installed					
12/17/66	162		50'			SF WELL TEST.
8/13/69	224			28'		
9-4-69	244		-9'	+11'		20'

as of 3/1/67 Well 11 has a Layne pump
 NEW PUMP INSTALLED. 5-5-54

STATIC HD. LINE - 56

measured 146' - 4-26-54
 FILLED - 15 FT.

25 FT. - PUMP BASE TO WATER LEVEL - 4-15-54 - (BLOWN OUT WITH AIR - TO 154 FT)

Air Line 50'

Handwritten scribbles and marks at the bottom left of the page, including a checkmark and illegible characters.

W E L L D A T A

Well No. 11

SPECIFICATIONS

Pump Base Elevation	33.0
Ground Elevation	31.0
Static Elevation	+ 6.0
Maximum allowed Drawdown	-11.0
Total Discharge	250 G.P.M.
Total Head	91 Feet

TEST

200 G.P.M.	34#	Pressure	Drawdown	+1.5
220 G.P.M.	30#	Pressure	Drawdown	+0.4
250 G.P.M.	26#	Pressure	Drawdown	-1.2
290 G.P.M.	18#	Pressure	Drawdown	-3.5

Recovers to elevation + ²13.6 in three (3) minutes.

This Well pumps sand and should not be pumped over 200 G.P.M.
(should have pipe installed to pump out side)

Air line 63'

Elev D.D. Gauge 23.5'

WELL LOG

Well No. 11

DESCRIPTION

0.0	Top of hole
1.0	Ground level
4.0	Top of sand
11.0	Top of shale
23.0	Top of limestone
24.0	Bottom of hole

TEST

Drawdown 4.0	Flow rate 100 G.P.M.
Drawdown 4.5	Flow rate 200 G.P.M.
Drawdown 5.0	Flow rate 300 G.P.M.
Drawdown 5.5	Flow rate 400 G.P.M.

Reservoir correlation is 100% in all cases.

This well was drilled and tested for gas and oil.

(Special tests were made to determine gas content.)

H.P. Well 611