

DATE OF INSPECTION
 19 AUG 1987

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER
 CAMP. LEJEUNE, N. C.

2. TO
 NAVFACENCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRE 19 AUG 1989

15. BOILER INSPECTOR
 Thomas L. Lenoir
 NAVY OR NATIONAL BOARD NO.

3. MANUFACTURER
 INGERSOLL RAND

4. PROPERTY NO. PV-202
 5. MFG. SERIAL NO. 30T 575843
 6. MFG. MODEL NO. N.B. 63477D

7. BUILDING NO. A.S.-116
 8. YEAR BUILT 1985
 9. CAPACITY 33 CU. FT. VOL.

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED 200 psi OPERATING 120 psi TEST 200 AIR. psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE
 NAVFAC 239

17. BOILER USE
 AIR RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂

20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 EATON

22. NUMBER AND SIZE
 1-1/4"

23. PSI SETTING
 200

24. CONDITION
 SAT.

STEAM PRESSURE GAUGE

25. MANUFACTURER
 U.S.G.

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS
 START AND MAINTAIN P, M. LOG.

INSTALL COVER OVER AIR-COMP, TO KEEP OUT OF WEATHER

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 Timothy Jewell 8/27/87
 BY DIRECTION





