

JOB ORDER NO	DATE COMPLETED signed	COST	DESCRIPTION
023-02967-82	1/10/63		Remove damaged concrete ramps and repour
4103	10-3-74	2208	Rpl 6 fuel loading nozzles + hoses
3436	1-18-74	589	Rpl liquid ladles (4) with hose
4391	11-22-74	499	Rpl gasoline dispensing pumps
4318	1-4-74		Gas spill
2683	1-12-73	406	Provide 1 box + fill with sand
2466	7-11-72	880	Pump out all gasoline + kerosene fuel stg tanks underground
3755	7-27-72	5492	Rpl gasoline dispensing pumps
3920	7-21-71	314	Raze old shed + construct new shed + paint
3634	5-6-71	669	Rpl underground elec service
1078	10-19-71	507	Remove old septic tank + distribution box
3873	9-30-70	5656	Rpl broken places in concrete apron
3836	9-24-70	317	Rpl caps on 4 underground tanks
1044	9-25-70	235	Install double throw switch
31096	9-11-68	596	Rps + paint exterior trim
05N-169	11-22-67	873	Pave entrance road to gas pumps
559-101	10-28-66	1020	Rpl damages to gas pumps
5008	5-2-75	0/E	Remove dirt cover from fuel tanks
2602	1-7-75	0/E	Clean up oil spill
4358	1-7-75	1357	Replace 8 fuel dispensing pumps
1320	9-30-76	1591	Install a fuel + water separator catch basin
3518	11/12/74	1149	Rpl gasoline dispensing pump
3505	4/3/75	9470	Rpl of dispensing pump
4723	8/2/77	162	Route wires through existing 100 Amp double throw switch
Contract # 79-2624	Fy 80	71972	Ext. Paint

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
2631	10-21-77	1850	Install traffic control devices
<sup>cont'd</sup> 79-2623	6-23-80 F480	4610	Ext. paint Replace roof
3418	3-9-79	2829	Remove & repl (2) 4 post gasoline venting systems
4770	2-1-80	493	Addendum to 504770
4031	8-8-80	189	Replace master meter
3824	8-8-80	553	Replace nozzle on truck loading pump
3139	1-2-81	1543	Install new gas dispenser
4029	6-17-80	840	Calibrate gas level indicator units
2536	3-20-79	1661	Install outlets
3968	3-15-83	1021	RPI DETERIORATED FLOOD LIGHTING
3925	3-14-83	1269	RPR WINDOW, DOORS, PAINT INT/EXT
1349	7-21-83	1711	RUN DRAIN LINE FROM KEROSENE FILLSTATION
4979	8-17-83	2363	RPI GAS REFUELING PUMP
1107	7-23-85	1020	INSTALL Shower & Eye Wash - COMBINATION SAFETY STATION
2113	6-8-84	400	RPA ALARM SYSTEM
✓ 3175	3-2-84	2256	Replace VALVE PIT <sup>AD</sup> ADMENT
3671	Comp	593	Pump OUT WATER FROM Fuel Tanks (1002) 2-22-84
4484	6-25-85	303	Rpl Gasoline & Diesel Refueling parts
5277	7-30-85	4029	RPA on underground Potable Water Line
3175	3-2-84	1776	Replace Valve Pit
3137	12-14-90	21	Turn on Steam Heat

JOB ORDER NO	DATE COMPLETED signed	COST	DESCRIPTION
4348	11-20-74	1200	CONTRACT - RPR & CALIBRATE 4 FUEL METERS
3285	9-18-73	1278	RPL FUEL LINE
4718	3-2-73	225	Rpr & calibrate 2 flow thru meter
3164	1-18-73	552	Rpl 1 petroleum meter in pump room
4741	3-6-73	157	Rpr catch basin
3344	6-30-69	361	Carpenter work & paint ext trim
1116	11-12-70	1031	Modifications to pipe lines
3845	9-15-69	2748	Rpr petroleum pumping & metering equip
1247	7-23-76	559	Install Check valves on 3 fuel lines
5357	76	300	Repair & calibration 7 inline gas meters
4878	2-28-75	53	Repair gas fuel line
1238	3/22/76	803	Over unleaded gas line
5754	8/30/76	196	Rpl deck boards hard rail
Contract # 79-2624	Fy 80	\$1992	Ext. Paint
" 79-2623	Fy 80	\$4611	Replace roofs
4770	Comp	2213	Exposure, inspect & Rpr & or replace underprod valve
4346	Comp	294	Install filter on fuel dispensing pipe
3891	8-4-81	894	Rpl. 2" fuel hoses at fuel farm
2092	3-27-81	1218	Clean up oil spill
2062	2-13-81	544	" " " "
3085	3-12-82	5939	Replace Bulk fuel nozzles & seats at fuel farm
3434	7-27-83	9095	Replace Bulk Fuel Loading Assemblies
1024	3-26-82	411	Remove end section of concrete walk & curb
3681	4-16-82	503	Repr. Gas line
3456	3-18-83	1336	Replace Rotary Positive Displacement Line Meter w/ Register cannot be calibrated

