

JOB ORDER NO <i>Contract No.</i>	DATE COMPLETED signed	COST	DESCRIPTION
497-61	2-14-61		Inst heavy guage wire over 3 windows (C 6/23/61)
603-61	3/13/61		Relocate presses and tumblers (C 5/25/61)
42-62	7/3/61		Fabricate and inst brine tank, replace wooden steam pit w/metal (C 8/24/61)
109-62	7/7/61		Overhaul return lines (C 7/28/61)
022-07171-620413	7/11/61		Enlarge area of Receiving Dept (C 10/24/61)
07267	5/7/62		Inst doors in call office in lieu of windows (C 6/15/62)
023-03061-82	2/18/63		Renovate
023-03092-82	3/1/63		Renovate
NA4-99049-22	2/26/64	2948.38	Enlarge door opening
CONTRACT	5/22/67	6,666.00	Additional Electric Power
<i>Nk 2470-70-8-1464</i>	<i>8/4/70 - Completed</i>		<i>Paint interior</i>
<i>2603</i>	<i>5-22-74</i>	<i>198</i>	<i>Rpl 3 coils in dryer</i>
<i>2429</i>	<i>7-1-74</i>	<i>233</i>	<i>Rpl 3 coils in dryer</i>
<i>4848</i>	<i>6-5-74</i>	<i>247</i>	<i>Insulate new piping & valves</i>
<i>3951</i>	<i>9-6-74</i>	<i>503</i>	<i>Clean & adjust & lubricate all fans & louvers in monitor system</i>
<i>4222</i>	<i>11-16-73</i>	<i>1577</i>	<i>Rpl valves, traps & strainers</i>
<i>4173</i>	<i>11-1-73</i>	<i>177</i>	<i>Rpl traps on 25-unit heaters</i>
<i>3868</i>	<i>8-4-73</i>	<i>332</i>	<i>Repair lint collector</i>
<i>4982</i>	<i>4-18-73</i>	<i>279</i>	<i>Rpl window lock</i>
<i>4351</i>	<i>4-26-77</i>	<i>617</i>	<i>Rpl to steam pit deck</i>
<i>3850</i>	<i>8-7-73</i>	<i>1,005</i>	<i>Rpl water heating system</i>
<i>5051</i>	<i>3-24-72</i>	<i>446</i>	<i>Rpl 120 L.F. pipe insulation & erect guard rail</i>
<i>2517</i>	<i>11-30-72</i>	<i>105</i>	<i>Hook up 4 fans mounted on ceiling</i>
<i>2709</i>	<i>2-20-73</i>	<i>116</i>	<i>Tab & install</i>
<i>Cont. # 79-2624</i>	<i>Fy 80</i>	<i>1972</i>	<i>Int. paint</i>

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
2708	2-20-73	164	Modify assembly rail
2650	11-29-72	372	Lab & install plexiglass guards 2 ea
2639	11-21-72	160	Lab 6 metal guards
2608	10-25-72	169	Lab & install 2 pressure damp boxes
2597	10-12-72	162	Hook up 4 per laundry equip
3774	7-28-72		Rpr high velocity steam unit
3827	8-4-72	361	Rpr gutters
3855	8-16-72	491	Cover bare steam & return lines to equipment
3938	9-5-72	1449	Rpl heavy steam flow leater
3907	8-29-72	771	Clean adjust & lubricate all fans and louvers in monitor sys.
4086	10-12-72	716	Reroute return line from unit leaters
4544	1-30-73	350	Rpr steam coils on tumblers
4291	12-14-72	1601	Rpl 2 main pressure reducing valves
3227	3-16-73	899	Paint leads & lounges
3939	8-27-73	861	Clean, lubricate fans in monitor
2474	7-13-72	125	Lab 2 garment boxes
2473	7-13-72	247	Lab & install dispensers on washing machine
2452	7-6-72	359	Lab & install canopy
4985	3-9-72	283	Rpr steam leak at steam coil
4984	3-9-72	374	Rpl 2 thermostatic valves on Velocity steam unit
4780	3-3-72	686	Rpl 2 defective steam unit leaters
4659	2-9-72	660	Rpl 2 steam leaters & rpr steam leak
4596	1-27-72	274	Rpr mattress cleaning unit
4147	9-13-71	807	Rpr concrete floor
3586	3-22-71	890	Rpr elec conduit, wiring & panels

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
2642	3-9-72	2383	Inst 3 exh fans + 37 on walls
2604	11-26-71	347	Mount + hook up 2 soap circulating pumps
2547	7-26-71	964	Lab + install 1 mattress cleaner + sterilizer
0050	10-6-71	488	Construct + paint 2 cabinets
0050	9-20-71	173	Fabricate 5 metal clothes hangers
5327	6-27-75	416	Repair elect dist lines inside bldg
3291	11/11/77	694	clean, adjust + lubricate all pans
4740	2-20-76	0/E.	Repairs to Condensate Return System
4105	11-7-75	585	clean, adjust + lubricate all fans + blowers
2669	3-5-76	304	make elect repairs to equipment
1248	4-23-76	375	Install block wall and new deck
4455	11/4/75	1719	make necessary repairs to piping system
4910	2/17/74	1059	Repairs to pipe insulation
5594	7/20/74	718	Rpt (1) valves + 1 line strainer
5217	4/29/76	831	Repair electric circuit to A. Comp
1013	10/21/74	435	extend air line to flat ironers
1046	10/20/74	495	installation of shower facility
2444	10-7-77	560	Install factory mod. for finger guard/duffer roll safety switch
2488	12-2-77	894	Test/repair 10 steam coils
2686	8-15-77	473	Replace 3 steam coils in 400 lb dryer
4378	5-3-77	557	Replace double metal doors/hardware
4351	4-26-77	617	Repairs to steam pit deck
2531	1-5-77	502	Lab (5) skids for laundry
4272	6-16-78	486	Modfy 3 stands on air compressor and paint
1169	3-23-79	1103	Alter structure of Bldg for new ironing machine
5097	12-29-78	640	Rm/Rpl low line controller for air/gas system

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
2153	12-19-80	366	Fab + Install safety guards
2114	7-18-80	403	make repairs to 8 washing machines pulley guards
3734	3-6-81	724	Rpr. tube bundle in Hot water tank
3189	12-4-81	1632	Rpl. fiberglass insulation insulation,
5150	10-9-81	1990	Rpl Asbestos "
3871	7-24-81	286	Rpr. neck on hot water Htr.
3843	4-10-81	723	Rpl. steam coils
3104	12-17-82	1021	Repr steam coils
3435	1-14-83	544	Repr 4 large steam coils
2099	8-20-82	466	Repl. exhaust lines on 3 Unions
F265	7-5-83	980	Clean / Adjust All Fans
4961	8-16-83	2137	INT RPR
3688	10/17/83	6066	RMV / RPI Concrete SUPPORTS
4853	3-21-86	352	Modify Door Opening For Shop 63
1014	2-1-85	509	INSTALL SAFETY STATION IN BLDG 1500
1037	2-8-85	1001	RENOVATE Laundry - For CONTRACTOR TAKE OVER
1222	6-13-86	929	CONSTRUCT 11'6" x 65' cage - Pubent
2162	2-15-85	357	Remove 10' Floor - Search From BLDG 14-21 INSTALL IN Bldg 1500
7863	4-5-85	671	June steam & water main line supplying
4186	Comp	3,386	Relocate three inch condenser line ⁶⁻¹⁴⁻⁸⁴ from 5' steam PIT
4748	12-7-84	596	Rpl steam unit heater at Bldg 1500
1222	5-13-86	929	Cons PARTITION w/ welded wire
4853	3-10-86	352	Modify Door opening
1064	8-25-89	5899+5899	Construct Alpha space
FN 13Q		16,541	Install Electric SVC 02-174758

