



2-1 1/2" PVC TYPE "EB" TO PEDESTAL MNTD. FIRE BOX. 1-1 1/2" TO CONTAIN 3 1/2 #12 FOR FIRE LIGHT 1-1 1/2" TO CONTAIN 5 1/2 #12 FOR F.A.

NOTES: 1. ALL CONDUIT 1/2" UNLESS NOTED OTHERWISE
 2. END-OF-LINE DEVICES FOR BELL CIRCUITS 1 1/2 AND INITIATING CIRCUIT ARE LOCATED IN THE WIRE TROUGH.

FIRE ALARM SYSTEM

- WIRE NUMBERS
- PULLSTATIONS- 1-2
 - BELL CIRCUIT #1- 3-4
 - BELL CIRCUIT #2- 03-04
 - TROUBLE BELL- 5
 - ALARM TEST SWITCH- 6
 - HIGH RATE OF CHARGE LAMP- 7
 - +24VDC- 8
 - 24VDC- 9

BEQ-CAMP LEJEUNE N62470-75-C-5393	
AS BUILT DRAWING	REVISIONS
	0-1
ELECTRONIC SOUND & EQUIPMENT CO., INC.	
DATE	DRAWING NUMBER
12-28-78	5393-1

