

DATE OF INSPECTION

21 FEB 1984

TYPE OF INSPECTION

A INTERNAL & EXTERNAL

B INTERNAL & EXTERNAL WITH PRESSURE TEST

C OPERATIONAL

1 FROM
 BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.

2 TO
 NAVFACENGCOM
 NORFOLK, VA.

14. CERTIFICATE ISSUED YES NO

15. BOILER INSPECTOR

Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.

NAVFAC 239

16. REASON FOR NOT ISSUING CERTIFICATE

DRY LAY UP

BOILER DATA

3. MANUFACTURER

KEWANEE

4. PROPERTY NO.

23

5. MFG. SERIAL NO.

B 7610

6. MFG. MODEL NO.

W.B. 14620

7. BUILDING NO.

803

8. YEAR BUILT

1953

9. CAPACITY

10. FUEL (Check)

COAL OIL GAS

11. PRESSURE

DESIGNED

OPERATING

TEST

100

psi

psi

psi

12. FEED WATER TREATMENT

SATISFACTORY

UNSATISFACTORY

13. TYPE

WATER TUBE

FIRE TUBE

C. I.

17. BOILER USE

GAS PLANT

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION

% CO₂

% EXCESS O₂

20. FLUE GAS TEMPERATURE

AFTER BOILER

°F

AFTER HEAT TRAP

°F

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER

22. NUMBER AND SIZE

23. PSI SETTING

24. CONDITION

STEAM PRESSURE GAUGE

25. MANUFACTURER

26. CORRECTIONS

WATER LEG CONSTANT

psi

OTHER

psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

Boiler front right side - door missing

OIL FIRESIDE REPLACE GASKETS & DRYING AGENT - SEAL BOILER

32. ATTACHMENT(S) (Check)

COPY OF INSPECTOR'S REPORT

SPECIAL COMMENTS

33. SIGNATURE

F. E. Cone

BY DIRECTION

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
 27 DEC. 1978

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
 BASE MAINT. OFFICER CAMP LEJEUNE N.C.

2. TO
 NAUFACENG-COM NORFOLK, VA. 23511

14. CERTIFICATE ISSUED YES NO

15. BOILER INSPECTOR
 Jesse L. Sellen
 NAVY OR NATIONAL BOARD NO.

NAUFAC 225

16. REASON FOR NOT ISSUING CERTIFICATE
 DRY LAY UP

BOILER DATA

3. MANUFACTURER
 KEWANEE

4. PROPERTY NO. 23
 5. MFG. SERIAL NO. B7610
 6. MFG. MODEL NO. NB-14620

7. BUILDING NO. 803
 8. YEAR BUILT
 9. CAPACITY

10. FUEL (Check)
 COAL OIL GAS
 11. PRESSURE
 DESIGNED 100 psi OPERATING psi TEST psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY
 13. TYPE
 WATER TUBE FIRE TUBE C. I.

17. BOILER USE
 GAS PLANT
 18. COMBUSTION CONTROL (Mfg. Name)
 19. COMBUSTION
 % CO₂ % EXCESS O₂
 20. FLUE GAS TEMPERATURE
 AFTER BOILER °F : AFTER HEAT TRAP °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER
 22. NUMBER AND SIZE
 23. PSI SETTING
 24. CONDITION

STEAM PRESSURE GAUGE

25. MANUFACTURER
 26. CORRECTIONS
 WATER LEG CONSTANT psi; OTHER psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS
 OIL FIRE SIDE - REPLACE GASKETS & DRYING AGENT.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 R.W. Sellen
 BY DIRECTION

