

DATE OF INSPECTION
 21 FEB. 1985

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1 FROM BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.
 2 TO NAVFACENCOM
 NORFOLK, VA

14. CERTIFICATE ISSUED YES NO
 EXPIRES 21 FEB. 1987
 15. BOILER INSPECTOR
 Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.

BOILER DATA

3. MANUFACTURER
 BRUNNER ENG. & MFG. CO.

4. PROPERTY NO PU-20	5. MFG. SERIAL NO.	6. MFG. MODEL NO. N.B. 3802C
7. BUILDING NO BB-9	8. YEAR BUILT 1981	9. CAPACITY 18 cu. ft. volume
10. FUEL (Check) <input type="checkbox"/> COAL <input type="checkbox"/> OIL <input type="checkbox"/> GAS	11. PRESSURE DESIGNED OPERATING TEST 200 psi 125 psi 170 AIR. psi	
12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY	13. TYPE <input type="checkbox"/> WATER TUBE <input type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.	

NAVFAC 239
 16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
 AIR-RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂

20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F ; AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER KUMKLE	22. NUMBER AND SIZE 1-1/4"	23. PSI SETTING 150	24. CONDITION GOOD
----------------------------	-------------------------------	------------------------	-----------------------

STEAM PRESSURE GAUGE

25. MANUFACTURER
U.S. GAGE

26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS
 1. START & MAINTAIN P.M. LOG.
 2. INSTALL NEW SAFETY VALVE, MFG. KUMKLE SIZE 1/4 SET @ 150 PSE.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
 J. H. Sells BY DIRECTION

DATE OF INSPECTION
 22 Sept. 1982

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM **BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.**
 2. TO **NAVFACENGCOM
 NORFOLK, VA.**

14. CERTIFICATE ISSUED YES NO
 EXPIRES 22 Sept. 1984
 15. BOILER INSPECTOR
Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.
 NAUFAC 239

BOILER DATA

3. MANUFACTURER
BRUNNER ENG. & MFG. CO.
 4. PROPERTY NO. **PV-20** 5. MFG. SERIAL NO. 6. MFG. MODEL NO. **NB 3802C**
 7. BUILDING NO. **BB-9** 8. YEAR BUILT **1981** 9. CAPACITY **18 CU. FT. VOLUME**
 10. FUEL (Check)
 COAL OIL GAS
 11. PRESSURE
 DESIGNED **200** psi OPERATING **125** psi TEST **300** psi
 12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY
 13. TYPE
 WATER TUBE FIRE TUBE C. I.

16. REASON FOR NOT ISSUING CERTIFICATE

17. BOILER USE
AIR-RECEIVER
 19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)

 20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

SAFETY DEVICES
 SAFETY VALVES

21. MANUFACTURER **KUNKLE** 22. NUMBER AND SIZE **1-1/4"** 23. PSI SETTING **175** 24. CONDITION **GOOD**

STEAM PRESSURE GAUGE

25. MANUFACTURER **U.S. GAGE** 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi
 27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

START & MAINTAIN PM LOG-

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
R.M. Wilson
 BY DIRECTION

