

DATE OF INSPECTION  
 18 FEB. 1986

TYPE OF INSPECTION  
 A  INTERNAL & EXTERNAL B  INTERNAL & EXTERNAL WITH PRESSURE TEST C  OPERATIONAL

1. FROM  
 COMMANDING GENERAL  
 MCB, CAMP LEJEUNE, NC

2. TO  
 NAVFACENCOM  
 FOLK, VA

14. CERTIFICATE ISSUED  YES  NO  
 EXPIRES 18 FEB. 1988

15. BOILER INSPECTOR  
 Thomas L. Lanier  
 NAVY OR NATIONAL BOARD NO.  
 NAVFAC 239

16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER  
 CURTIS

4. PROPERTY NO. PU-51	5. MFG. SERIAL NO. 194137	6. MFG. MODEL NO. NB. 157888
7. BUILDING NO. 1502	8. YEAR BUILT 1972	9. CAPACITY 16 CU. FT. VOL.
10. FUEL (Check) <input type="checkbox"/> COAL <input type="checkbox"/> OIL <input type="checkbox"/> GAS	11. PRESSURE DESIGNED 200 psi    OPERATING 150 psi    TEST 300 psi	
12. FEED WATER TREATMENT <input type="checkbox"/> SATISFACTORY <input type="checkbox"/> UNSATISFACTORY	13. TYPE <input type="checkbox"/> WATER TUBE <input type="checkbox"/> FIRE TUBE <input type="checkbox"/> C. I.	

17. BOILER USE  
 AIR-RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION  
 % CO<sub>2</sub>    % EXCESS O<sub>2</sub>

20. FLUE GAS TEMPERATURE  
 AFTER BOILER \_\_\_\_\_ °F ; AFTER HEAT TRAP \_\_\_\_\_ °F

SAFETY DEVICES  
 SAFETY VALVES

21. MANUFACTURER KINGSTON	22. NUMBER AND SIZE 1-3/8	23. PSI SETTING 200	24. CONDITION GOOD
------------------------------	------------------------------	------------------------	-----------------------

25. MANUFACTURER  
ASHCROFT

26. CORRECTIONS  
 WATER LEG CONSTANT \_\_\_\_\_ psi; OTHER \_\_\_\_\_ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		
31. INSPECTOR'S COMMENTS		

CLEAN & PAINT COMPRESSOR TANK.

32. ATTACHMENTS (Check)  
 COPY OF INSPECTOR'S REPORT     SPECIAL COMMENTS

33. SIGNATURE  
 [Signature] BY DIRECTION



**INSPECTION REPORT-BOILERS**  
 NAVFAC 9-11014/41 (3/67)  
 Supersedes NAVDOCKS 2544  
 S/N 0105-LF-004-0000

DATE OF INSPECTION  
 14 AUG 1979

TYPE OF INSPECTION  
 A  INTERNAL & EXTERNAL B  INTERNAL & EXTERNAL WITH PRESSURE TEST C  OPERATIONAL

1. FROM  
 BASE MAINT. OFFICER  
 CAMP. LEJEUNE, N. C.

2. TO  
 NAVFACENGCOM  
 NORFOLK, VA

14. CERTIFICATE ISSUED  YES  NO  
 EXPIRES 14 AUG 1981

15. BOILER INSPECTOR  
 Jesse L. Sellers  
 NAVY OR NATIONAL BOARD NO.  
 NAUFAC 225

16. REASON FOR NOT ISSUING CERTIFICATE

**BOILER DATA**

3. MANUFACTURER  
 CURTIS

4. PROPERTY NO. PV-51	5. MFG. SERIAL NO. 194137	6. MFG. MODEL NO. NB-157888
7. BUILDING NO. 1502	8. YEAR BUILT 1972	9. CAPACITY 16 CU. FT. VOLUME

10. FUEL (Check)  
 COAL  OIL  GAS

11. PRESSURE  
 DESIGNED 200 psi OPERATING 160 psi TEST 200 AIR psi

12. FEED WATER TREATMENT  
 SATISFACTORY  UNSATISFACTORY

13. TYPE  
 WATER TUBE  FIRE TUBE  C. I.

17. BOILER USE  
 AIR RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION  
 \_\_\_\_\_ % CO<sub>2</sub> \_\_\_\_\_ % EXCESS O<sub>2</sub>

20. FLUE GAS TEMPERATURE  
 AFTER BOILER \_\_\_\_\_ °F : AFTER HEAT TRAP \_\_\_\_\_ °F

**SAFETY DEVICES**  
**SAFETY VALVES**

21. MANUFACTURER KINGSTON	22. NUMBER AND SIZE 1-3/8"	23. PSI SETTING 200	24. CONDITION GOOD
------------------------------	-------------------------------	------------------------	-----------------------

25. MANUFACTURER  
U.S. GAGE

26. CORRECTIONS  
 WATER LEG CONSTANT \_\_\_\_\_ psi; OTHER \_\_\_\_\_ psi

27. REASON IF NOT TESTED

**FIRING EQUIPMENT**

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

START & MAINTAIN PM LOG -

ATTACHMENTS (Check)  
 COPY OF INSPECTOR'S REPORT  SPECIAL COMMENTS

33. SIGNATURE  
 R.M. Sellers  
 BY DIRECTION



77-5785

BOILER INSPECTION CHECK LIST

LOCATION	BLDG NO.	BOILER NO.	DATE
MCBCL	400°	1502	5/14 AUG 79

BOILER MFG. CURTIS	OPERATING PRESS. 160	DESIGN PRESS. 200	CAP. 16 CFM
SERIAL NO. 194137	MODEL NO.	N.B. NO. 157888	

BURNER MFG.	FIRING RATE:		
STEAM GAGE NAME: <del>US GAGE</del> US GAGE	PRESS. 0-300	TEST NEW	
SV MFG. FC KINGSTON	CAP 118 CFM	NO. 1	SIZE 3/8"

NO. 1	SET 200	OPEN 198	CLOSE 120	
NO. 2	SET	OPEN	CLOSE	
NO. 3	SET	OPEN	CLOSE	
CO2%	02%	STACK TEMP	COMB. EFF.	PURGE TIME

NO. 1 FIREYE	C/O	A/L
NO. 2 FIREYE	C/O	A/L
HI-STEAM TEMP.	C/O	A/L
EXCESS STEAM TEMP.	C/O	A/L
HI OIL TEMP.	C/O	A/L
HI OIL PRESS.	C/O	A/L
LO OIL TEMP.	C/O	A/L
LO OIL PRESS.	C/O	A/L
LO ATOM AIR/STEAM	C/O	A/L
NO. 1 LW	C/O	A/L
NO. 2 LW	C/O	A/L
LO FURNACE DRAFT	C/O	A/L
LO FIRE START	C/O	A/L
TYPE OF FUEL	YEAR BUILT 1972	A/L
HEAT SURFACE	Boiler	WATER WALL

~~Hold For - DONE~~  
~~Need GAGE~~

Removed plug from  
AUTO DRAIN (DONE)

REMARKS:

① ~~REPLACE BROKEN PRESS. GAGE 0-300 1/4" - 3"~~ **DONE**

② CK - AUTO DRAIN VALVE

24" X 66"

**EXPIRES 14 AUG 80**

