

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/87)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
10 MAR. 1986

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM
**COMMANDING GENERAL
 MCB, CAMP LEJEUNE, NC**

2. TO
**NAVFACENGCOM
 NORFOLK, VA**

14. CERTIFICATE ISSUED YES NO
EXPIRES 10 MAR. 1988

15. BOILER INSPECTOR
Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.
NAVFAC 239

16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER
KARGARD

4. PROPERTY NO. **PV-95** 5. MFG. SERIAL NO. **235472** 6. MFG. MODEL NO. **NB. 32838**

7. BUILDING NO. **AS-122** 8. YEAR BUILT **1985** 9. CAPACITY **11 CU.-FT. VOL.**

10. FUEL (Check)
 COAL OIL GAS

11. PRESSURE
 DESIGNED **200** psi OPERATING **125** psi TEST **300** psi

12. FEED WATER TREATMENT
 SATISFACTORY UNSATISFACTORY

13. TYPE
 WATER TUBE FIRE TUBE C. I.

NAVFAC COPY

17. BOILER USE
AIR-RECEIVER

19. COMBUSTION
 _____ % CO₂ _____ % EXCESS O₂

18. COMBUSTION CONTROL (Mfg. Name)

20. FLUE GAS TEMPERATURE
 AFTER BOILER _____ °F : AFTER HEAT TRAP _____ °F

**SAFETY DEVICES
 SAFETY VALVES**

21. MANUFACTURER **C. D. I.** 22. NUMBER AND SIZE **1-1/4"** 23. PSI SETTING **200** 24. CONDITION **SAT.**

STEAM PRESSURE GAUGE

25. MANUFACTURER **U. S. GAGE** 26. CORRECTIONS
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

NEW AIR-COMPRESSOR WILL REMAIN SAME PROPERTY NO. AS OLD UNIT

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
W. M. Rice
 BY DIRECTION

