

INSPECTION REPORT-BOILERS
 NAVFAC 9-11014/41 (3/67)
 Supersedes NAVDOCKS 2544
 S/N 0105-LF-004-0000

DATE OF INSPECTION
15 JUNE 1983

TYPE OF INSPECTION
 A INTERNAL & EXTERNAL B INTERNAL & EXTERNAL WITH PRESSURE TEST C OPERATIONAL

1. FROM **BASE MAINT. OFFICER
 CAMP LEJEUNE, N. C.**
 2. TO **NAVFACENGCOM
 NORFOLK, VA.**

14. CERTIFICATE ISSUED YES NO
 EXPIRES **15 JUNE 1985**
 15. BOILER INSPECTOR

Thomas L. Lanier
 NAVY OR NATIONAL BOARD NO.
NAVFAC 239

16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER **WAYNE**

4. PROPERTY NO. **PV-106** 5. MFG. SERIAL NO. 6. MFG. MODEL NO. **N.B.**

7. BUILDING NO. **AS 515** 8. YEAR BUILT **1962** 9. CAPACITY **136688**

10. FUEL (Check) 11. PRESSURE
 COAL OIL GAS
 DESIGNED **200** psi OPERATING **125** psi TEST **300** psi

12. FEED WATER TREATMENT SATISFACTORY UNSATISFACTORY 13. TYPE
 WATER TUBE FIRE TUBE C. I.

9. CAPACITY **18 CU. FT. VOL.**

17. BOILER USE **AIR-RECEIVER** 18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION % CO₂ % EXCESS O₂ 20. FLUE GAS TEMPERATURE
 AFTER BOILER °F : AFTER HEAT TRAP °F

SAFETY DEVICES

21. MANUFACTURER **C. D. I.** SAFETY VALVES

22. NUMBER AND SIZE **1 1/4"** 23. PSI SETTING **165** 24. CONDITION **GOOD**

25. MANUFACTURER **U.S. GAGE** STEAM PRESSURE GAUGE

26. CORRECTIONS 27. REASON IF NOT TESTED
 WATER LEG CONSTANT _____ psi; OTHER _____ psi

ITEM	FIRING EQUIPMENT	
	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS
 ① START & MAINTAIN P. M. LOG
 ② CLEAN AIR-COMPRESSOR & TANK
 ③ INSTALLED NEW PRESSURE GAGE.

32. ATTACHMENT(S) (Check)
 COPY OF INSPECTOR'S REPORT SPECIAL COMMENTS

33. SIGNATURE
R.M. Keller
 BY DIRECTION

