

DATE OF INSPECTION

9 APR-1985

TYPE OF INSPECTION

A

INTERNAL & EXTERNAL

B

INTERNAL & EXTERNAL WITH PRESSURE TEST

C

OPERATIONAL

1. FROM **BASE MAINT. OFFICER  
CAMP LEJEUNE, N. C.**

2. TO **NAVFACENGCOM  
NORFOLK, VA**

14.

CERTIFICATE ISSUED  YES  NO

EXPIRES 9 APR. 1987

15. BOILER INSPECTOR

*Thomas L. Lanier*  
 NAVY OR NATIONAL BOARD NO.

NAVFAC 239

16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER

WESTERN

4. PROPERTY NO.

PV-147

5. MFG. SERIAL NO.

6. MFG. MODEL NO.

NB. 22249

7. BUILDING NO.

BB-177

8. YEAR BUILT

1959

9. CAPACITY

10 CU FT VOLUME

10. FUEL (Check)

COAL  OIL  GAS

11. PRESSURE

DESIGNED

200

psi

OPERATING

180

psi

TEST

200

psi

AIR

12. FEED WATER TREATMENT

SATISFACTORY  UNSATISFACTORY

13. TYPE

WATER TUBE

FIRE TUBE

C. I.

17. BOILER USE

AIR-RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION

% CO<sub>2</sub>

% EXCESS O<sub>2</sub>

AFTER BOILER

°F

AFTER HEAT TRAP

°F

SAFETY DEVICES

SAFETY VALVES

21. MANUFACTURER

KINGSTON

22. NUMBER AND SIZE

1-3/8

23. PSI SETTING

200

24. CONDITION

GOOD.

STEAM PRESSURE GAUGE

25. MANUFACTURER

ASHCROFT

26. CORRECTIONS

WATER LEG CONSTANT

psi

OTHER

psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

31. INSPECTOR'S COMMENTS

START & MAINTAIN P.M. LOG-

REPLACED PRESSURE GAUGE - 0-300 PSI

32. ATTACHMENT(S) (Check)

COPY OF INSPECTOR'S REPORT

SPECIAL COMMENTS

33. SIGNATURE

*J. L. Seller* BY DIRECTION



DATE OF INSPECTION  
 22 Sept. 1982

TYPE OF INSPECTION  
 A  INTERNAL & EXTERNAL B  INTERNAL & EXTERNAL WITH PRESSURE TEST C  OPERATIONAL

1. FROM  
 BASE MAINT. OFFICER  
 CAMP LEJEUNE, N. C.

2. TO  
 NAVFACENGCOM  
 NORFOLK, VA

14. CERTIFICATE ISSUED  YES  NO  
 EXPIRES 22 Sept. 1984

15. BOILER INSPECTOR  
 Thomas L. Loria  
 NAVY OR NATIONAL BOARD NO.

NAVFAC 239  
 16. REASON FOR NOT ISSUING CERTIFICATE

BOILER DATA

3. MANUFACTURER

4. PROPERTY NO. 5. MFG. SERIAL NO. 6. MFG. MODEL NO.

7. BUILDING NO. 8. YEAR BUILT 9. CAPACITY

10. FUEL (Check) 11. PRESSURE

DESIGNED OPERATING TEST  
 COAL  OIL  GAS 200 psi 180 psi 300 psi

12. FEED WATER TREATMENT 13. TYPE

SATISFACTORY  UNSATISFACTORY  WATER TUBE  FIRE TUBE  C. I.

17. BOILER USE  
 AIR RECEIVER

18. COMBUSTION CONTROL (Mfg. Name)

19. COMBUSTION  
 % CO<sub>2</sub> % EXCESS O<sub>2</sub>

20. FLUE GAS TEMPERATURE  
 AFTER BOILER °F ; AFTER HEAT TRAP °F

SAFETY DEVICES  
 SAFETY VALVES

21. MANUFACTURER 22. NUMBER AND SIZE 23. PSI SETTING 24. CONDITION  
 KINGSTON 1-3/8" 200 NEW

25. MANUFACTURER 26. CORRECTIONS

U.S. GAGE WATER LEG CONSTANT psi; OTHER psi

27. REASON IF NOT TESTED

FIRING EQUIPMENT

ITEM	IN SERVICE	ALTERNATE
28. MANUFACTURER		
29. TYPE		
30. FUEL GRADE		

28. MANUFACTURER

29. TYPE

30. FUEL GRADE

31. INSPECTOR'S COMMENTS

① REPLACED PRESSURE GAUGE 0-300 PSI.  
 ② REPLACED SAFETY VALVE

32. ATTACHMENT(S) (Check)  
 COPY OF INSPECTOR'S REPORT  SPECIAL COMMENTS

33. SIGNATURE  
 Carl [Signature]  
 BY DIRECTION

