

T-6241/2

6240
NREAD
3 Nov 87

From: Commanding General, Marine Corps Base, Camp Lejeune
To: Distribution List

Subj: WASTE OIL MANAGEMENT

Encl: (1) Inventory of Contents of Central Waste Oil Storage
Tanks as of 28 Oct 87

1. The enclosure is provided for your information and use as a
waste oil management tool.

2. Point of contact is Mr. Tom Barbee, extension 2083.

JULIAN I. WOOTEN
By direction

Copy to:
DRMO
BMO
FAC

Blind copy to:
EC&ML



1944
MAY 11

Dear Mr. [Name],

I have your letter of May 10, 1944, regarding the [Subject].

The information you provided is being reviewed.

I will contact you again once a decision has been reached.

Sincerely,
[Signature]



INVENTORY OF CONTENTS OF CENTRAL WASTE OIL STORAGE TANKS
AS OF 28 OCT 1987 *

STORAGE LOCATION	QUANTITY ON HAND, IN GALLONS		
	WASTE OIL	HAZARDOUS WASTE OIL	SLUDGE
S-781 (Bldg. 45)			5,750 *
AS-419		22,202	
AS-420		19,697	
AS-421		13,776	
STT-61		18,783	
STT-62		19,898	
STT-63	3,670		
STT-64		18,025	
STT-65		15,758	
STT-66 **	14,223		
S-888	7,257		
S-889		14,279	
S-890	16,313		
S-891		23,010	
TOTALS	41,463	165,428	5,750

* Based on measurements and calculations by Mr. Tom Barber and Mr. Manuel Martin, NREAD. Work sheet is attached. Formula from BASIC TRADE MATHEMATICS.

** Tank currently being used for storage of current pickups from generation sites.



14

2

STORAGE LOCATION	DATA FROM PLANS OR TANKS				MEASUREMENTS BY MARTIN AND BARBEE 28 OCT 1987				COMPUTED GALLONS INSIDE	INCHES SLUDGE IN TANK	COMPUTED GALLONS OF SLUDGE	COMPUTED CAPACITY OF TANK GALLONS
	CIRCUMFERENCE FT-INCHES	DIAMETER FT-IN	HEIGHT OR LENGTH FT-IN	CAPACITY IN GALLONS	CIRCUMFERENCE FT-IN	DIAMETER FT-IN	HEIGHT OR LENGTH FT-IN	DEPTH OF LIQUID IN TANK FT-IN (IN)				
S-781	120'-0"	38'-0"	29'-3"	(248,113 MAX CALCULATED) 200,000 (STATED ON PLAN)	120'-4"	38'-3"	29'-3"	0'-8"	5,750	8	5,750	252,119
AS 419	} PLANS NOT SEEN				47'-5"	15'-3"	18'-0"	16'-3"	22,202	0	0	24,593
AS 420					47'-5"	15'-3"	18'-0"	14'-5"	19,697	0	0	24,593
AS 421					47'-5"	15'-3"	18'-0"	10'-1"	13,776	0	0	24,593
STT-61	} PLANS NOT SEEN			(PLAQUE ON TANK) 30,000	28'-4"	9-0	63-0	(65)	18,783	0	0	29,979
STT-62				30,000	28'-4"	9-0	63-0	(68.5)	19,898	0	0	29,979
STT-63				30,000	28'-4"	9-0	63-0	(19.5)	3,670	0	0	29,979
STT-64				30,000	28'-4"	9-0	63-0	(63)	18,025	0	0	29,979
STT-65				30,000	28'-4"	9-0	63-0	(56)	15,758	0	0	29,979
STT-66				30,000	28'-4"	9-0	63-0	(52)	14,223	0	0	29,979
S-888	-	8- $\frac{1}{2}$	50-1 $\frac{1}{4}$	17,585	25-3	8- $\frac{1}{2}$	47-4	(39)	7,257	0	0	17,975
S-889	-	8- $\frac{1}{2}$	50-1 $\frac{1}{4}$	17,585	25-3	8- $\frac{1}{2}$	47-4	(68)	14,279	0	0	17,975
S-890	-	8- $\frac{1}{2}$	50-1 $\frac{1}{4}$	17,585	25-3	8- $\frac{1}{2}$	47-4	(78)	16,313	0	0	17,975
S-891	-	9- $\frac{1}{2}$	64-8	30,000	28-9 $\frac{1}{2}$	9-2	60-4	(75.5)	23,010	$\frac{1}{4}$	-	29,783

