

BLDG NO

INT. PAINT SQ FT

EXT. PAINT SQ FT

ROOF SQ FT

CONDEN. LINES LIN FT

FACILITY HISTORY RECORD

MCBCL 11011/3

CRD-611A

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3114		4085	INSTALL WATER Meter vic of #32
3125	1-16-87	1765	Rpl Det. Drawline to Grease Trap (Amendmt)
1289	7-3-87	15,571	Const. 6" potable water main
4034	5-17-85	692	Loc, inspect, mark, repack + raise valves boxes on all potable water distribution main valves + fire hydrant valves
1017	10-22-84	1620	REPL VALVE BOXES AT WASH TRACKS
1026	11-8-84	2849	INSTALL POTABLE WATER LINE & YARD HYDRANT
2602	6-24-85	4086	LOCATE, INSPECT, MARK, REPACK & RAISE VALVE BOXES
3213	6-12-85	363	INSTALL WATER METER
3290	10-22-84	1078	REPL 6-INCH Left Hand Underground WTR MAIN
4450	3-22-85	3777	REPL (4) EIGHT INCH COUNTERCLOCKWISE OPENING U/G WTR MAINS
4572	4-23-85	1213	REPR BURSTED WATER MAIN
5263	2-11-85	690	REPR UNDERGROUND POTABLE WATER MAIN
5276	9-17-85	2874	REPL & FINISH CONCRETE SLAB AROUND GAS PUMPS
5277	7-16-85	2374	REPR UNDERGROUND POTABLE WATER LINE
5290	9-12-85	1785	R/12 12" UNDERGROUND WATER VALVE
5299	8-12-85	1688	REPR 10" UNDERGROUND RAW WATER LINE
5595	8-23-85	1484	REPAIR POTABLE WATER MAIN LINE NEAR BLDG
6080	8-21-85	3028	REPL (4) DEFECTIVE FIRE HYDRANT GATE VALVES
6089	9-4-85	1356	REPR (6") CAST IRON POTABLE WTR MAIN
3265	5-8-87	408	Rps Broken 12" water main under Holcomb Bldg.
3289	6-26-87	1006	Rplc. 2 yrd Hydrants in Parking Lot near Bldg AS4106
3902	1-16-87	4319	Rplc. Defected & deteriorated gate valves on underground potable water distr. sys. Cmp Geiger in vicinity Bld. TC1025, 1045, 1050 & 1063.

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3285	5-11-84	1981	Replace water line on golf course
4304	8-17-84	1460	Replace disconnected lateral water line
4404	7-27-84	185	Repair 6" water main 45° blow pipe to fire hydrant
4909	2-10-84	3999	Repair damage line on Campbell at MCAS
5235	2-3-84	1253	Repair 6" incl cast iron water main
5251	4-16-84	1782	Repair (2) 8" water main + (1) 2" water main
5708	6-8-84	1620	Repair 8" water main vicinity LCH 436
5720	6-15-84	749	Repair 3" water main valve
5717	6-8-84	597	Repair burst water main
5716	8-8-84	503	Repair (3) slip incl water main valve
5708	8-24-84	1620	Repair 8" water main vicinity LCH 436
5736	8-31-84	1012	Repair 6" water main vicinity KTP 1200
2059	Compl	1065	Change lock on New Well Houses 10-31-84
3160	Compl	612	Rpr Broken Water Line 10-19-84
3536	Compl	1654	Rpr/Rplc Damaged Raw Water Main on Saw Mill 11-28-84
3885	8-26-83	5123	Loc, Inspect, Mark & Repack Main Water Distrib Lines
4713	Compl	652	Rplc 3" Underground Water Line 8-21-84
5236	2-3-84	417	Rpr 6" Underground Cast Iron Water Main
5247	3-8-85	3881	Rpr burst underground pot water main under concrete parking lot
3070	3-1-85	1653	Rplc pilings & level 10" Potable water main located across
5274	5-17-85	793	fr canal in vic Bldg 612
5274	5-17-85	793	Rpr 8" underground water main break HP 219
5261	4-5-85	2027	Rpr 6" underground pot water main + 1/2" lateral water line TC 848
5252	1-25-85	607	Rpr 8" ductile iron potable water main vic Bldg 914
5250	3-15-85	980	Rpr 6" underground cast iron pot water main TT 982 vic
5248	2-15-85	564	Rpr underground water main vic A-8
5211	4-5-85	195	Rpr/Rplc 8" + 10" gate valves w/ valve boxes on underground water main
4139	1-2-85	261	Rplc approx 60' of 1" PVC pipe + 1 yard hydrant SPT-32

BLDG NO

INT. PAINT SQ FT

EXT. PAINT SQ FT

ROOF SQ FT

CONDEN. LINES LIN FT

FACILITY HISTORY RECORD

MCBCL 11011/3

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3883	3-10-83	4986	inspect/Repair Main valves
3882	3-10-83	2736	inspect/Repair Main valves
3881	3-10-83	5167	inspect/Repair Main valves
3884	3-10-83	7034	inspect/Repair Main valves
3892	3-10-83	3360	inspect/Repair Main valves
5234	12-30-83	1715	Repair cast iron water main
5232	12-30-83	971	Repair cast iron water main
3659	1-24-83	843	Repair underground water main
4386	5-3-83	1053	Repair cast iron water main
4421	5-6-83	909	Repair leaking water main
4600	6-27-83	1209	Repair Bursted cast iron water main
3658	1-24-83	648	Repair Bursted cast iron water main
3657	1-24-83	794	Repair Bursted cast iron water main
4529	7-26-83	9705	Locate water lines
4916	8-8-83	564	Repair underground water leak
5221	12-8-83	1148	Replace underground water main
3355	1-13-82	8236	Replace water lines
3931	6-1-82	6779	inspect/Repair Main valves
3752	4-23-82	3752	Relocate Fire Hydrant
3467	2-22-82	334	Damage Report/Fire Hydrant
4297	8-30-82	1002	Repair water main
3753	4-23-82	646	Repair leaking water main
3138	10-25-82	1009	Repair flange joint on water main
5213	12-2-83	1146	Repair a Bursted cast iron underground main
3071	12-7-84	1265	Replace deteriorated water lines
3186	10-12-84	586	Repair water lines

BLDG NO

INT. PAINT SQ FT

EXT. PAINT SQ FT

ROOF SQ FT

INDEN. LINES LIN FT

FACILITY HISTORY RECORD

MCBCL 11011/3

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3579	2-6-81	740	RPR WATER MAIN
3532	2-6-81	794	RPR 8" WATER LINE
3541	2-6-81	1604	RPL BROKEN FIRE HYDRANT
3578	2-27-81	1741	RPR (2) WATER MAIN LEAKS
3626	Comp	388	Cut + Number 83 hydrant tags
3661	1-21-82	3057	INSPECT, LUBE & RPR FIRE HYDRANTS
3658	1-27-82	1547	LUBE, INSPECT + RPR FIRE HYDRANTS
3580	2-6-81	660	RPR WATER MAIN
4041	5-14-81	480	MATERIALS FOR MAINT. OF WATER DIST.
3728	3-27-81	1258	RPR 8" WATER MAIN
3531	2-6-81	921	" " " LINE
3800	4-3-81	868	RPR BROKEN WATER MAIN
4177	7-24-81	1031	RPL WATER LINE
2096	6-26-81	768	CLEAN OUT WATER TREATMENT SETTLING POND NEAR AS-110
3858	7-25-81	2083	Locate, PM, water Dist. Main valves
3720	9-25-81	809	LUBE, INSPECT & RPR FIRE HYDRANTS
3659	6-12-81	266	" " " " "
3662	11-6-81	2180	" " " " "
3657	1-27-82	1412	" " " " "
3660	1-27-82	1166	" " " " "
4275	Comp	1240	RPR 15' Frost protection valves and construct dry well
3089	10-7-82		INVESTIGATE & RPR leaks in water Dist. system Courthouse Bay
3089	10-7-82	3979	Repair in-operative valves
3233	11-12-82	3333 2905	Replace existing cast iron water main pipe
3496	12-30-82	2385	Repair Broken water line
3886	3-10-83	5223	Repair necessary water lines/valves

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
4468	3-21-83	252	Procure clamps for MMLU 80
3380	1-5-81	1292	MMLU-88
3337	12-12-80	2158	Rpl 8" water main, expose & backfill
3291	11-7-80	792	Rpl water main break 8"
3426	9-24-81	359	Procure MMLU-88 stock for water dist.
4778	9-18-80	105	Amend to 4778 for additional hrs for shop 72
4402	8-8-80	650	Removed Rpl. thermal overload units etc.
4752	8-15-80	1239	Rpl fire hydrant
4777	8-15-80	275	Rpl water line
4382	8-8-80	872	Rpl water main under rail road
3955	8-1-80	1645	MMLU-88
4201	5-30-80	802	Procure new stock material for water dist. system
3831	5-2-80	1443	Substrate inspect & rpl fire hydrant
3078	4-25-80	162	Amend to 3078 Rpl fire hydrant - delete -
3830	4-25-80	615	Substrate inspect & rpl fire hydrant
3812	4-29-80	578	Amend to 3812 Substrate inspect & rpl fire hydrant
4409	4-16-80	297	Amend to 4409 Rpl fire hydrant - delete -
3600	4-16-80	1284	Rpl broken fire hydrant
3578	2-15-80	696	Rpl leaking water main
3582	2-15-80	1211	Rpl 6" water main
4468	7-1-80	252	Procure clamps for MMLU 80
3577	2-15-80	1388	Rpl water main leak
3593	2-22-80	976	Rpl broken water main
3600	2-8-80	1284	Rpl broken fire hydrant & water line
3609	Camp	894	Rpl MMLU 80

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
3519	1-13-78	—	Repair water main break near T-43
3590	1-13-78	—	-do- -do- -do-do- -do- at KTP
3214	1-6-78	—	Repair water line under BK M-178
3793	1-13-78	—	Repair water main M-518
3758	1-5-78	—	Repair " " H.P. 326-1140
3968	2-1-78	—	Repair 2 water mains at P.P. 2810-2900
3760	1-6-78	—	Repair or replace 2" water main near old trailer
4020	2-8-78	—	park - 458 Repair water main at 1202
4098	2-22-78	—	Repair water main near Gldy 22
4268	3-22-78	—	Repair how water main
4532	4-17-78	—	" " " line under concrete deck
4622	4-25-78	—	" water main at BA101
5000	6-5-78	713	" " " near M-128
5138	6-26-78	1508	Repair 10" water main LCH.
5149	6-29-78	189	fab. paint & install ladder shield on ladder - water tank
5144	6-29-78	331	fab. paint & " " " " " " " "
5147	6-29-78	313	" " " " " " " " " "
5146	6-29-78	193	" " " " " " " " " "
5145	6-29-78	189	" " " " " " " " " "
5067	8-18-78	1101	Repair water main underground near traffic circle
5100	8-18-78	600	Repair broken water main near M518
5143	6-29-78	260	fab. paint, & install ladder shield on ladder on water tank
5142	6-29-78	730	" " " " " " " " " "
5240	6-27-78	884	Repair water main
5148	6-29-78	189	fab. paint & install ladder shield on ladder - water tank
1250	5-17-78	444	Construct track rack
8987	9-6-78	82	fill holes after shop 41
4759	8-4-78	543	Repair water line

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
022-07161-620613	7/6/61		Inst meter and chlorinator (C-9/20/61)
023-03607-82	7/9/6		Inst fluoridation equipment
023-02522-82	7/25/62		Renovate
NB4-04056-22	4/1/63	5393.95	Inst chemical pumps (C-5/8/64)
NB4-04964-22080G	1/15/64	632.48	Inst water meter (C-6/30/64)
NB4-04966-22080G	1/15/64	5.80	Inst Chemical pumps (
Contract	4/5/68	21,078.00	Replace Filter Controls
Contract	12/10/69		Exterior repairs & paint
AA923 3508 23XXT	11/7/69	8,431	Carpentry and masonry repairs, paint interior
AA923 30610	8/26/68	3,901	Replace roof , closed out work to be accomplished by contract
AA923 30940	11/12/68	1,092	Replace lime slurry pump
AA923 31295	12/13/68	1,544	Repair windows
AA923 31398	4/29/69	1,923	Replace (2) lime slurry pumps, water treatment plant.
AA923 30610	1/17/69	4,833	Replace roof, recaulk flashing and parapet wall cap, Bldg. 20 HP
AA923 3190 23XXT	10/3/69	1,787	Replace steam condensate return system to include traps and trap assemblies, replace steam generated water heater with electric heater
AA023 3521 2308T		2,157	Replace (2) "worn"out chemical pumps
AA023 3905 23XXT	10/17/69	518	Repair broken water main
AA023 4060 23XXT	12/24/69		Repair underground gas tank
AA123 3714 2308T		540	Replace metering pump
AA122 3812 2318T	12/31/70	484	Replace Johnson A-421 refrigerated after cooker and diger
AA123 3827 2308T	3/4/71	703	Repair centrifugal pump
AA123 4235 2308T	3/26/71	581	Repair chlorinators Bldg 20, water treatment plant
AA223 5010 23XXT	4/3/72		Repair water shed between the two reservoirs

BLDG NO

INT. PAINT SQ FT

EXT. PAINT SQ FT

ROOF SQ FT

CONDEN. LINES LIN FT

FACILITY HISTORY RECORD

MCBCL 11011/3

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
8988	9-6-78	127	Fix hole after Shop 41
3311	11-6-78	1827	Repair broken water main near Bldg 2
3422	11-20-78	610	Clear 20' right of way along water & sewer lines
3571	12-27-78	653	Repair water main break near M-513
3551	12-26-78	1009	" " " near M-113
8993	9-6-78		
3548	12-22-78	472	Repair water main near PT-4
80-C-2053	2-4-82	32,922 ⁰⁰	Rebuild water facility
3249	11-9-79	966	Repair broken water line
3247	11-21-79	1982	" " " main
3147	10-19-79	1139	" water main leak
3131	10-10-79	1046	Repair " "
4763	9-13-79	846	" " "
8262	6-26-79	542	" " line
4471	7-3-79	1274	" " leak
4036	3-23-79	456	" main water line
3813	2-21-79	618	" water main
3701	1-25-79	818	" " main
3600	1-9-79	1101	" " "

JOB ORDER NO	DATE COMPLETED <i>Signed</i>	COST	DESCRIPTION
AA6234541 23	11-24-75		Rpr water main
AA623434723	11-24-75		Rpr water main in Bry Scout area
AA623430123	9-25-75		Rpl fire hydrant near HP 226
AA523524623	5-6-75		Rpr water line at Bldg 50
AA523468023	1-22-75		Rpr water main break at BB-190
AA523444623	12-9-74		Rpr broken water main near Bldg 106
AA523441623	12-3-74	850	Perform P.M. to electronic equip
AA523336723	6-20-74		Rpr broken water main between Lot 140 & Helmont Blvd.
AA523329023	1-21-74	1354	Repairs to Water Mains
AA523039823	8-22-74	8963	Rpl cables feeding wellhouses
AA423447723	2-14-74		Rpr water main break near 423
AA423430123	12-18-73		Rpr water main break at 3110PP
AA423376023	7-25-73		Rpr 4" water main valve near bldg 1300
AA423350723	7-5-73	1043	Clear sight-of-way along water distribution lines
AA423348723	7-5-73	1700	P.M. electronic equip used with water sys
AA323490923	4-4-73	617	Rpl fire hydrant near 1808
AA323478523	3-12-73		Repair water main valve near bldg 1300
AA323467323	2-26-73		Repair water main break near 14020
AA3467223	2-26-73		Repair water main break near PT-4
AA323464023	2-21-73		Repair water main break near Wallace Creek Bridge
AA323432723	12-27-72		Repair water main break - Main Service Rd and K St
AA323388923	8-25-72		Rpr water main break
AA323362823	7-6-72	1500	P.M. electronic equipment

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
4823	2-13-76	O/E	Repair water main break between KTP + MP.
3471	12-31-76		" 8" raw water main near I.J
3529	12-10-76		" broken water main near 902
3655	12-24-76		" " " " near 4P.67
3699	12-24-76		" water main break near AS-710
3607	11-29-77	/	Rpr. water lines near TT-3385
4885	9-9-77	/	Rpr. 2 water main leaks - TT 3392 - TT 2259
4599	6-30-77	/	" water main near M 292
4403	5-9-77	/	" " lines at Knox Junior PK.
4188	4-1-77	/	" raw water line near M-131
3996	3-11-77	/	Rpr. water valves at West house #602
4052	3-6-77	/	" " main near TT-863
3898	2-7-77	/	" " " " B.# 20
3487	11-11-76	/	" " lines in 4 bldgs (1827-1828-) (574-576)
3868	1-31-77	/	" " main near 519
3826	2-18-77	/	" " " " 67
3841	1-24-77	/	" " " " at 1202
3846	1-25-77	/	" " " " 235
3904	2-18-77	/	" " " at Wallace Oak - at P.P.
3900	2-18-77	/	" " " near LCH 322
3752	2-4-77	/	" " " near AS 1174
3840	2-4-77	/	Rpr " " near T.C. 611
3857	2-4-77	/	" " " " 5-47
3863	2-4-77	/	" " " " 2206
3887	2-4-77	/	" forced sewer main near B.B-4
3789	1-28-77	/	Repair water main at TT 1321
3838	1-28-77	/	" " "
3655	Camp.	830	Repair water main - amendment

WATER DIST.

BLDG NO	INT. PAINT SQ FT	EXT. PAINT SQ FT	ROOF SQ FT	CONDEN. LINES LIN FT	FACILITY HISTORY RECORD MCBCL 11011/3
---------	------------------	------------------	------------	----------------------	--

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
HQ8CMAORA106	10/11/67	286	Repairs to water dist mains
HQ8CMORA112	2/20/68	226	Repairs to water main breaks water dist system
AA923 31606	2/7/69	470	Repair water main break near 2728
AA023 3234 23XX	12/19/69	1,614	Repair supports to water and sewer line across Wallace creek between HP&PP
AA023 4137 2319	6/30/70	3,226	Locate and repair underground water main valve boxes thru-out HP and PP areas mark locations on public work drawings to be completed by 6/30/70
AA023 4547 23XXT		502	Repair water main break near HP 1012
AA123 3581 2316		976	Procure annual service contract to perform preventive maint to electronic equipment used in connection with water system.
AA123 3610 23XX		9	Repair well pump
AA1 4018 2319	2/5/71	616	Repair water dist lines access Wallace creek
AA123 4133 23XX		108	Repair water main break
AA123 4144 23XX	1/29/71	392	Repair water main break near bldg 1707
AA123 4525 23XX	4/23/71		Repair 18" water main near bldg 20
AA123 4532 23XX	4/23/71	442	Repair water main break at A street and Main service road
AA223 3793 2304	6/30/72	976	Procure annual service contract to perform preventive maintenance to electronic equipment used in connection with water system
AA223 4203 23**	11/4/71		Repair broken water main S//W ,Bldg 1606
AA223 4529 23XX	1/7/72		Repair water main break at beach
AA223 4569 2321	2/11/72	1,447	Clear right of way over water and sewer lines in PP and CH areas
AA223 4648 2319	2/11/72	Rel13	Repair water main break near BB 54
AA223 4682 23XX			Repair water main break near LCH 323
AA223 4730 23XX	3/10/72	681	Repair water main break near K st and main service road
AA223 5043 23XX	4/14/72		Repair water main break near Bldg 37
AA223 5384 23XX	6/16/72	373	Repair water main break near HP 322

