

Dependent's School

BLDG NO TT-48	INT. PAINT SQ FT	EXT. PAINT SQ FT	ROOF SQ FT	CONDEN. LINES LIN FT	FACILITY HISTORY RECORD MCBCL 11011/3
------------------	------------------	------------------	------------	----------------------	--

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
205-62	9/15/61	1328.79	Miscellaneous repairs
<del>023-05481-82</del>	4/8/63	1013.	Renovate
NM-09688 22)	6/30/64	1651	Paint exterior
<del>NM5-145007-122)</del>			
JB7 819 101 120	8/26/67	18,839	Structural mechanical electrical and paint repairs. Fertilize lawn and playground area
JB7 819 101 127	10/7/66	114	Install two add. flood lights in front of TT school as per diagram
JB7 819 101 155		209	Misc. repairs to ceilings, screens, cabinets, doors and paint two doors.
AA923 ** 15111	12/27/68	1,494	Repair leak on heating line at TT #2 school replace oil fired water heater.
AA923 xx 15118	2/28/69	178	Repair roof leaks
AA923 ** 15133	2/10/69		Repair leaking hot water lines.
AA023 0306 23**T		774	Repair leak in hot water heating line serving radiator in room 21 includes excavating buried piping under concrete floor and at fitting underground
AA023 0318 23XXT	10/24/69	259	Replace condensing unit on walk in reefer
AA023 0332 23XXT	5/1/70		Replace one motorized valve in classroom
AA023 0335 2318T			CANCELED 6/4/70
AA123 0321 23**T		1,137	Furnish and install 48 venetian blinds in rooms 10, 11, 12 13, clinic, teachers lounge, principal and secretary's offices
AA123 0327 23XXT	9/11/70	124	Furnish and install exhaust fan in compressor room in rear of cafeteria
AA223 0348 2319T	11/12/71	535	Install additional radiators in rooms 14, 15, 16 at TT 48 wall hung fin type
AA223 0350 23XXt	11/19/71	385	Install two floor drains in boiler room
AA223 0391 23XXT	12/10/71	1,122	Correct drainage and raise sidewalk east end of wing 50. fill holes on playground and around playground equipment
AA223 0396 2320T	11/10/71	181	Repair blower in heating system at TT-48
AA223 4552 2317Tq	6/30/72	144	Replace instrument transformers feeding electric meter at school
AA223 5144 23XXT	5/12/72		Locate and repair broken underground hot water line

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
AA223 9210 2316T	3/1/72	756	Install six four tub 8' flues lights in auditoriums and (3) 115V recepts of lobby of administrative offices
AA223 9226 23**T	1/14/72	255	Repair broken masonry beam and broken brick at west end of wing 50
AA223 9229 2319T	1/7/72	198	Replace circulation pump
AA223 9241 23XXT	2/25/72	178	Cut post off, install L-shape plate, repair concrete beam at wing 50
AA223 9259 23XXT	5/12/72	2,111	Make and install (73) venetian blinds in wings 20, 30, and cafeteria
AA223 9279 2316T	6/23/72	8,666	Remove incandescant lights and install flourescent lights in wings 10, 20, 30, 40, and 50.
<del>1787</del>	<del>1-17-75</del>		
1787	1-17-74	252	Repair storm drain pipes on playground
1779	1-17-75	192	Remove & replace A/C compressor
1757	9-27-74	310	Open sink drain
1752	2-28-75	345	Plumbing repairs
1749	9-20-74	843	Construct concrete pad for dump master
1780	10-5-73	330	Install reupt.
1778	10-2-73	598	Repair leak in hot water dist. line
1743	1-18-74	11,064	Make 12 openings between classrooms
1805	2-9-73	313	Replace v belts and motor mounts
1763	11-15-72	2979	Replace oil fired water heaters
1757	12-8-72	420	Repair gutters
1752	9-15-72	711	Remove boiler #27
1786		96	Fabricate & furnish angles & strips

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
1788	12-16-74	255	Install (6) elect outlet
2566	9-19-75	855	Const (1) cover for organ
1741	11-28-75	499	Repair walk in cooler
1750	9-19-75	218	Install (2) 8' flo tubes
1954	11-7-75	9/E	Unstop 2 sinks
1781	9-8-76	373	Install (10) light fixtures under walkway <span style="float:right">canopy</span>
1786	8-27-76	96	Fabricate & furnish angles & steps
1728	1-12-79	366	Remove spitting 12" fan and install 24" fan thermostat & shutter in kitchen
1750	8-4-78	1064	Fabricate new cabinet, replace sink and trim paint cabinet 2-coat yellow
1724	4-29-78	1544	Install outside water fountain
1751	2-17-78	—	Clean up oil spill at TT-48
1722	1-6-78	2030	Remove old fixtures and install new unbreakable fixtures
1723	1-6-78	2773	Install flood lights in rear of Bld near Basketball courts
1759	3-21-78	710	Service motors & bearings on steam heating units in dining area
2421	10-3-78	239	Construct table for organ
1772	8-23-78	2416	Job. new desk, new w.c., extend suspended ceiling - etc.
1777	8-15-77	3177	Replace sink tops & sinks in wings 40 & 50. Replace cabinets
1779	8-28-78	409	Get opening in wall between Rooms 14 & 15 install door
1761	3-30-79	798	Install additional electric outlets thru-out
1771	Comp	280	M/C Repair to Cafeteria & to Cafe area
1768	9-7-79	119	Install new 115 volt duplex recep
1748	6-22-79	1348	Replace boiler water heater in cafe room
1746	4-13-79	386	Install load center panel & 230 volt & 30 amp
1743	2-16-79	301	Insulate 60' pipe in the at room
3344	Comp	1731	Install pulley chand a safety valve

JOB ORDER NO	DATE COMPLETED	COST	DESCRIPTION
1710	12-2-80	286	Install 20 AMP 208V A/C Recept.
1727	4-11-80	266	Disassemble & remove 80' antenna tower & hardware
1709	2-20-81	456	Connect existing exhaust fan in cafeteria
1719	7-10-81	1913	Install concrete blocks to fill opening in masonry walls
1720	Comp	990	Remove pine straw cones etc lawn & playground
1745	9-12-80	620	Cut opening in wall between rooms
1802	1-13-84	1072	Replace bursted heating
1816	3-2-84	7876	Replace fuel oil supply
1808	7-6-84	6144	clean school grounds
1819	7-6-84	3784	Replace six (6) inch sewer line from manhole Bldg 40
1830	9-7-84	647	Repair & Paint V Blinds
1832	11-30-84	973	cover surfaces skylight paint plaster from falling <sup>children</sup> off roof
5231	7-6-84	1888	Replace water valves near Boiler
1821	3-15-84	2587	Replace (6) Control Valves
1807	Cpl	1033	Turn on Heat Depend Schools
5213	Cpl	1146	Rpr bursted 3" cast iron underground water main
1848	8-15-85	2987	Install 100 AMP Single Phase Load Center
1840	6-7-85	3382	Rpr leaking water line outside rm 14
1836	9-4-85	1096	Clmp, clean, rpr # 28 boiler
1835	9-4-85	1096	" " " # 27 "
1834	10-31-85	1096	" " " # 26 "
1833	4-5-85	1096	" " " # 25 "
1813	2-22-85	148	Remove Dispose, Debris, Reseed grounds
1813	11-25-83	539	Rpr to redirect hot air fr old hallway heating unit back into hallway through block wall
1812	1-11-85	1640	Rpr underground air line going to fuel tank
1802	Comp	6138	lower Ceiling in cafeteria, extend duct work, etc
1801	5-26-89	3800	Remove suspended Ceiling, reinstall 12 ltr fixtures
1816	12/31/87	354	Remove existing wall in kitchen