


ABC FIRE EXT.
\$ 18.00

| | <u>HYDROSTATICALLY</u> | <u>TEST</u> |
|---------------------|------------------------|-------------|
| RECHARGE | 15 LB CO2 | 25.00 |
| ✓ | 5 LB CO2 | 16.00 |
| | WATER | 16.00 |


5 LB ABC - 35.00
10 LB. ABC - 55.00

RECHARGE 5 LB. 11.00
" 10 LB. 16.00



WORK DESCRIPTION

1. Purchase 20 each, 2 1/2 gallon water extinguisher Model 240 made by Amerex Corporation, NSN 4210-00-720-1815.
20 Each at \$29.08 = \$582.00
2. Purchase 20 each, 15 LB. CO2 extinguishers, NSN 4210-00-202-7858.
20 Each at \$91.98 = \$1,840.00
3. Purchase 6 each 5 LB. CO2 extinguishers, Model 322 by Amerex Corporation. NSN 4210-00-595-1777.
6 Each at \$52.03 = \$316.00
4. After all purchased extinguishers have been received, exchange the new extinguishers with each area as shown on attached sheet. Install new tag on extinguisher and mark the date new extinguisher was installed.
5. Fill out 1149 to have the extinguishers that were removed hydrostatic tested by GSA contractor as per attached specifications.
6. After that set has been hydrostatic tested, use them to replace the extinguishers in the next area. Note on tag.
7. Then do the same as before to have hydrostatic tested. Continue this same cycle until all extinguishers have been hydrostatic tested.



Elwood
ACTION TAKEN!
Your Copy

11000
13
05 Apr 94

From: Elwood Morris
To: LT Smith

Subj: HYDROSTATIC TESTING OF PORTABLE FIRE EXTINGUISHERS

Ref: (a) NFPA 10

Encl: (1) Page 10-14 of NFPA 10

1. In accordance with reference (a), all portable extinguishers are required to be hydrostatically tested every five years. Previous testing was completed in 1988 (see enclosure (1)).

2. I propose to purchase and install new A:B:C 5 lb. portable extinguishers (dry chemical) in lieu of having our existing extinguishers hydrostatic tested.

My justification for this proposal is as follows:

a. To hydrostatic test requires installing a temporary extinguisher at each location, sending the permanent extinguisher off for testing, then replacing the temporary extinguisher. We have 156 each water extinguisher, 88 each 15 lb CO², and 30 each 5 lb. CO². The estimated cost is:


| | | |
|---------------------------------|---|----------------|
| Water 156 @ \$16 | = | \$2,496 |
| 15 lb CO ² 88 @ \$25 | = | 2,200 |
| 5 lb CO ² 30 @ \$10 | = | 480 |
| | | <u>\$5,176</u> |
| 120 hrs. labor | = | \$2,417 |
| | | <u>\$7,593</u> |

Hydrostatic test has to be accomplished every five years.

b. To purchase and replace the existing extinguishers with 5 lb. A:B:C (dry chemical) will require replacing the existing, and changing the stickers on the cabinet to show that the extinguisher is for all fires.

The estimated cost is:

| | | |
|---------------------------------|---|--------------|
| New A:B:C 5 lb. 274 each @ \$18 | = | \$4,932 |
| Labor to install 68 hrs. | = | <u>1,370</u> |
| | | \$6,302 |
| New stickers | | <u>125</u> |
| | | \$6,427 |



3. Advantages of A:B:C over existing:

a. A:B:C have to be hydrostatic tested every 12 years (see enclosure (1)).

b. One size extinguisher covers all.

c. One extinguisher for all type of fires - will not have to think about which extinguisher to use during a fire situation.

d. Less expensive.

4. I talked to MCB Fire Inspector (Ms. Huffman) and she recommends this idea. According to her, the MCB is going to A:B:C.

5. Onslow Memorial Hospital has gone completely to 5 lb A:B:C.

6. Mr. John Kokinda (Safety Dept) agrees with this idea.

7. This cost is P1 money.

Elwood Morris

ELWOOD MORRIS




Table 5-2

Hydrostatic Test Interval for Extinguishers

| Extinguisher Type | Test Interval (Years) |
|--|-----------------------|
| Soda-Acid | Note 1 |
| Cartridge-Operated Water and/or Antifreeze | Note 1 |
| Stored Pressure Water, Loaded Stream, and/or Antifreeze | 5 |
| Wetting Agent | 5 |
| Foam | Note 1 |
| AFFF (Aqueous Film Forming Foam) | 5 |
| Dry Chemical with Stainless Steel Shells | 5 |
| Carbon Dioxide | 5 |
| Dry Chemical, Stored Pressure, with Mild Steel Shells, Braze Brass Shells, or Aluminum Shells | 12 |
| Halogenated Agents | 12 |
| Dry Powder, Cartridge- or Cylinder-Operated, with Mild Steel Shells | 12 |

NOTE 1: These extinguishers have had a 5-year hydrostatic test interval. When the next regular hydrostatic test date arrives, extinguishers of this type shall not be tested but removed from service.

NOTE 2: All types of extinguishers with copper or brass shells joined by soft solder are prohibited from hydrostatic testing. [See 5-1.3(f).]

NOTE 3: Stored pressure water extinguishers with fiberglass shells (pre-1976) are prohibited from hydrostatic testing due to manufacturer's recall.

5-3.2 Stored Pressure Types. All stored pressure extinguishers shall be hydrostatically tested at the factory test pressure not to exceed three times the normal operating pressure.

NOTE: Extinguishers that are required to be returned to the manufacturer for recharging shall be hydrostatically tested only by the manufacturer.

5-3.3 Cartridge-Operated Types. Cartridge- or cylinder-operated dry chemical and dry powder types of extinguishers shall be hydrostatically tested at their original factory test pressure as shown on the nameplate or shell.

5-3.4 Test Pressures for Hose Assemblies.

5-3.4.1 Carbon dioxide hose assemblies requiring a hydrostatic pressure test shall be tested at 1,250 psi (8619 kPa).

5-3.4.2 Dry chemical and dry powder hose assemblies requiring a hydrostatic pressure test shall be tested at 300 psi (2068 kPa) or at service pressure, whichever is higher.

5-4 Test Equipment.

5-4.1 General.

5-4.1.1 This standard only permits the hydrostatic testing of pressure vessels used as fire extinguishers.

WARNING: If air or gas is used as a sole medium for pressure testing, the failure of the extinguisher vessel will be violent and dangerous.

5-4.1.2 When extinguisher shells, cylinders, or cartridges fail a hydrostatic pressure test, they shall be destroyed by the owner or at his/her direction.

5-4.2 Test Equipment for Compressed Gas Types.

5-4.2.1 The equipment for testing cylinders and cartridges shall be of the water jacket type that meets the specifications of the pamphlet *Methods for Hydrostatic Testing of Compressed Gas Cylinders* (CGA C-1), published by the Compressed Gas Association.

5-4.2.2 Hose assemblies of carbon dioxide extinguishers that require a hydrostatic test shall be tested within a protective cage device.

5-4.3* Test Equipment for Noncompressed Gas Types.

5-4.3.1 The equipment for testing noncompressed gas types consists of the following:

(a) A hydrostatic test pump, hand or power operated, to be capable of producing not less than 150 percent of the test pressure. It is to include appropriate check valves and fittings.

(b) A flexible connection for attachment to the test pump. It shall be provided with necessary fittings to test through the extinguisher nozzle, test bonnet, or hose outlet, as is applicable.

(c) A protective cage or barrier for personnel protection, designed to provide visual observation of the extinguisher under test.

5-4.3.2 Drying equipment is required to dry all non-water types of extinguishers that have passed the hydrostatic test.

5-5 Testing Procedures.

5-5.1 Compressed Gas Types.

5-5.1.1 In addition to the visual examinations required prior to test as stated in 5-1.3, an internal examination shall be made prior to the hydrostatic test. The procedures for this internal examination shall be in accordance with the requirements of the *Standard for Visual Inspection of Compressed Gas Cylinders* (CGA C-6) and *Standard for Visual Inspection of High-Pressure Aluminum Compressed Gas Cylinders* (CGA C-6.1), published by the Compressed Gas Association.


5-5.1.2 The hydrostatic testing of compressed gas cylinders and cartridges shall be in accordance with the procedures specified in the pamphlet *Methods for Hydrostatic Testing of Compressed Gas Cylinders* (CGA C-1), published by the Compressed Gas Association.

5-5.2* Testing Procedures for Noncompressed Gas Types. The testing procedures for noncompressed gas cylinders and shells and hose assemblies are detailed in Appendix A of this standard.

5-5.3* Testing Procedures for Hose Assemblies. The testing procedures for hose assemblies requiring a hydrostatic test are detailed in Appendix A.

5-5.4 Recording of Tests.

5-5.4.1 Compressed Gas Types. For compressed gas cylinders and cartridges passing a hydrostatic test, the month, year, and the DOT identification number shall be stamped into the cylinder in accordance with the re-



ASHLAND, VIRGINIA 23005
804-798-3381

=====

HYDRAULIC DESIGN INFORMATION SHEET

=====

NAME NAVAL REGIONAL MEDICAL CENTER
 LOCATION BOILER ROOM (REVISION #1)
 BUILDING "E" LEVEL #1
 CONTRACTOR WORSHAM SPRINKLER CO. , INC.
 CALCULATED BY P. WAYNE HODNETT
 CONSTRUCTION: () COMBUSTIBLE (X) NON-COMBUSTIBLE
 OCCUPANCY

DATE 5-5-80
 SYSTEM NO. BOILER RM
 CONTRACT NO. 10006
 DRAWING NO.
 CEILING HEIGHT

S ! () NFPA 13 () LT. HAZ. ORD.HAZ.GP.() 1 () 2 () 3 () EX. HAZ.
 Y ! () NFPA 231 () NFPA 231C FIGURE CURVE
 S ! () OTHER
 T ! () SPECIFIC RULING MADE BY DATE

E !
 M ! AREA OF SPRINKLER OPERATION 3000 SYSTEM TYPE
 ! DENSITY-GAL/MIN/SQ.FT .2 (X) WET () DRY () DELUGE () PREACTION
 D ! AREA PER SPRINKLER 130 SPRINKLER OR NOZZLE
 E ! HOSE ALLOWANCE GPM-INSIDE 0 MAKE GEM MODEL F-950
 S ! HOSE ALLOWANCE GPM-OUTSIDE 0 SIZE 1/2 K-FACTOR 5.56
 I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING 286
 G !
 N !

=====

CALCULATION ! GPM REQUIRED 753.97 PSI REQUIRED 112.81 AT BASE OF RISER
 SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 0

=====

| | | | | |
|---------------------|---|---------------|---|-------------------|
| W ! WATER FLOW TEST | ! | PUMP DATA | ! | TANK OR RESERVOIR |
| A ! DATE & TIME | ! | RATED CAP 500 | ! | CAP. 0 |
| T ! STATIC PSI 0 | ! | AT PSI 85 | ! | ELEV. 0 |
| E ! RESIDUAL PSI 0 | ! | ELEV 11.77 | ! | |
| R ! GPM FLOWING 0 | ! | | ! | WELL |
| S ! ELEVATION | ! | | ! | PROOF FLOW GPM 0 |

U !
 P !
 P ! LOCATION : 750 GPM AVAILABLE AT PUMP DISCHARGE @ 115 PSI
 L ! SOURCE OF INFORMATION :
 Y !


=====

| | | | | |
|-----------------------------------|--|--------------|--|-------------|
| C ! COMMODITY | | CLASS | | LOCATION |
| D ! STORAGE HT. | | AREA | | AISLE WIDTH |
| M ! STORAGE METHOD: SOLID PILED % | | PALLETIZED % | | RACK % |

=====

M ! () SINGLE ROW () CONVENTIONAL PALLET () AUTOMATIC STORAGE () ENCAPSULATED
 ! R ! () DOUBLE ROW () SLAVE PALLET () SOLID SHELVING () NON-ENCAPSULATED
 S ! A ! () MULTIPLE ROW () OPEN
 T ! C !
 D ! K ! FLUE SPACING IN INCHES: CLEARANCE: STORAGE TO CEILING
 R ! ! LONGITUDINAL TRANSVERSE FT.
 A ! !
 G ! ! HORIZONTAL BARRIERS PROVIDED:
 E ! !

FIRE PROTECTION--BY COMPUTER DESIGN



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive
Kornersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING D LEVEL 1 (ZONE 101)

JOB INFORMATION

JOB NUMBER : 10006
JOB NAME : NAVAL REG. MED. CTR.
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 9
DATE 1-20-90

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|-----------|
| TOTAL AREA OF | | SPRINKLER MAKE | GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | F-950 |
| DENSITY | : 0.100 G.P.M. | SPRINKLER SIZE | 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | |
| RACK SPRINKLER | | RATING | 2 1/2 f |
| ALLOWANCE (G.P.M.): | : N/A | SYSTEM TYPE | WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 621.30 G.P.M. AT 111.33 P.S.I. AT PUMP DISCHARGE.
K-FACTOR USED = OVERHEAD 120
UNDERGROUND N/A

WATER SUPPLY

WATER FLOW TEST

PUMP DATA


TANK OR RESERVOIR

| | | | |
|-----------------|---|------------------------|-------------------|
| RATE | : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| LINE | : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) | : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | : | | |
| FLOW (GPM) | : | | |
| ELEVATION | : | | |

QC. OF TEST :
SOURCE OF INFO.:

NOTES

- 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.
- APPENDAGE CHECK AREA ATTACHED.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.

1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING E BASEMENT

JOB INFORMATION

JOB NUMBER : 10006
JOB NAME : NAVAL REG. MED. CTR.
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 5
DATE 2-5-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

TOTAL AREA OF SPRINKLER OPERATION : 3000 SQ. FT.
DENSITY : 0.200 G.P.M.
INSIDE HOSE STREAMS (G.P.M.) : N/A
OUTSIDE HOSE STREAMS (G.P.M.) : N/A
RACK SPRINKLER ALLOWANCE (G.P.M.) : N/A

SPRINKLER MAKE : GEM
SPRINKLER MODEL : F-950
SPRINKLER SIZE : 1/2 X 1/2
SPRINKLER K-FACTOR : 5.56
SPRINKLER TEMP. : 212
RATING : f
SYSTEM TYPE : DRY

CALCULATION SUMMARY

SYSTEM REQUIRES - 681.60 G.P.M. AT 101.21 P.S.I. AT PUMP DISCHARGE.
C-FACTOR USED = OVERHEAD 100
UNDERGROUND N/A

WATER SUPPLY

WATER FLOW TEST

PUMP DATA


TANK OR RESERVOIR

| | | | | |
|-----------------|-----------------|--------|-------------------|---|
| DATE : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): | : |
| TIME : | AT (PSI) : | 85.00 | ELEVATION : | : |
| STATIC (PSI) : | ELEVATION : | 11.77' | | |
| RESIDUAL (PSI): | | | | |
| FLOW (GPM) : | | | | |
| ELEVATION : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



 ** Hydraulic Summary Sheet By **
 ** Worsham Sprinkler Co., Inc. **
 ** 1355 South Park Drive **
 ** Kernersville, North Carolina 27284 **

GENERAL AREA DESCRIPTION

BUILDING E LEVEL 1 (ZONE 1E2)

***** **JOB INFORMATION** *****

JOB NUMBER : 10006 SHEET 1 OF 8
 JOB NAME : NAVAL REG. MED. CTR. DATE 1-31-80
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

***** **SYSTEM DESIGN** *****

STANDARDS USED : CONTRACT DOCUMENTS
 TOTAL AREA OF SPRINKLER OPERATION : 3000 SQ. FT. SPRINKLER MAKE : GEM
 DENSITY : 0.100 G.P.M. SPRINKLER MODEL : F-950
 INSIDE HOSE STREAMS (G.P.M.) : N/A SPRINKLER SIZE : 1/2 X 1/2
 OUTSIDE HOSE STREAMS (G.P.M.) : N/A SPRINKLER K-FACTOR : 5.56
 RACK SPRINKLER RATING : ~~1~~ 2 1/2 f
 ALLOWANCE (G.P.M.) : N/A SYSTEM TYPE : WET

***** **CALCULATION SUMMARY** *****


SYSTEM REQUIRES - 666.20 G.P.M. AT 88.47 P.S.I. AT PUMP DISCHARGE.
 K-FACTOR USED = OVERHEAD 120
 UNDERGROUND N/A

***** **WATER SUPPLY** *****

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|------------------|------------------------|-------------------|
| DATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | | |
| FLOW (GPM) : | | |
| ELEVATION : | | |
| LOC. OF TEST : | | |
| SOURCE OF INFO.: | | |

***** **NOTES** *****

- 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.
- DRY APPENDAGE DATA ATTACHED.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING F LEVEL 1 (GRID)

***** JOB INFORMATION *****

JOB NUMBER : 10006 SHEET 1 OF 12
JOB NAME : NAVAL REG. MED. CTR. DATE 1-29-80
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

***** SYSTEM DESIGN *****

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.250 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | |
| RACK SPRINKLER | | RATING | : 2 1/2 f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : WET |

***** CALCULATION SUMMARY *****

SYSTEM REQUIRES - 994.10 G.P.M. AT 80.91 P.S.I. AT PUMP DISCHARGE.
C-FACTOR USED = OVERHEAD 120
UNDERGROUND N/A

***** WATER SUPPLY *****


WATER FLOW TEST PUMP DATA TANK OR RESERVOIR

| | | | | | |
|----------------|---|-----------------|----------|-------------------|---|
| DATE | : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): | |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 11.77' | | |
| RESIDUAL (PSI) | : | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

***** NOTES *****

1. CHECK AREA ATTACHED.
2. DOCK APPENDAGE AREA ATTACHED.
3. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



ASHLAND, VIRGINIA 23005
804-798-3381

HYDRAULIC DESIGN INFORMATION SHEET

NAME NAVAL REGIONAL MEDICAL CENTER DATE 5-5-80
LOCATION STANDPIPE DESIGN AT RISER #1 (REMOTE RISER)(R-1)
BUILDING SYSTEM NO. RISER #1
CONTRACTOR WORSHAM SPRINKLER CO. , INC. CONTRACT NO. 10006
CALCULATED BY P. WAYNE HODNETT DRAWING NO.
CONSTRUCTION: ()COMBUSTIBLE (X)NON-COMBUSTIBLE CEILING HEIGHT
OCCUPANCY

S ! ()NFPA 13 ()LT. HAZ. ORD.HAZ.GP.()1()2()3()EX. HAZ.
Y ! ()NFPA 231 ()NFPA 231C FIGURE CURVE
S ! ()OTHER
T ! ()SPECIFIC RULING MADE BY DATE
E !
M ! AREA OF SPRINKLER OPERATION 0 SYSTEM TYPE
! DENSITY-GAL/MIN/SQ.FT 0 (X)WET()DRY()DELUGE()PREACTION
D ! AREA PER SPRINKLER 0 SPRINKLER OR NOZZLE
E ! HOSE ALLOWANCE GPM-INSIDE 500 MAKE MODEL
S ! HOSE ALLOWANCE GPM-OUTSIDE 0 SIZE K-FACTOR 0
I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING
G !
N !

CALCULATION ! GPM REQUIRED 500 PSI REQUIRED 0 AT BASE OF RISER
SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 0

W ! WATER FLOW TEST ! PUMP DATA ! TANK OR RESERVOIR
A ! DATE & TIME ! RATED CAP 500 ! CAP. 0
T ! STATIC PSI 0 ! AT PSI 85 ! ELEV. 0
E ! RESIDUAL PSI 0 ! ELEV 11.77 !
R ! GPM FLOWING 0 ! WELL
! ELEVATION ! PROOF FLOW GPM 0
S !
U !
P !


P ! LOCATION :750 GPM AVAILABLE AT PUMP DISCHARGE @ 115 PSI
L ! SOURCE OF INFORMATION :
Y !

! COMMODITY CLASS LOCATION
C ! STORAGE HT. AREA AISLE WIDTH
D ! STORAGE METHOD:SOLID PILED % PALLETIZED % RACK %
M !
M ! ()SINGLE ROW()CONVENTIONAL PALLET()AUTOMATIC STORAGE()ENCAPSULATED
! R ! ()DOUBLE ROW()SLAVE PALLET()SOLID SHELVING()NON-ENCAPSULATED
S ! A ! ()MULTIPLE ROW ()OPEN
T ! C !

O ! K ! FLUE SPACING IN INCHES: CLEARANCE:STORAGE TO CEILING
R ! ! LONGITUDINAL TRANSVERSE FT.
A ! !

G ! ! HORIZONTAL BARRIERS PROVIDED:
E ! !

FIRE PROTECTION--BY COMPUTER DESIGN



Hydraulic Summary Sheet By
 Worsham Sprinkler Co., Inc.
 1355 South Park Drive
 Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING A LEVEL #2 ZONE 2B SIMILAR

JOB INFORMATION

JOB NUMBER : 10006
 JOB NAME : NAVAL REG. MED. CTR.
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 15
 DATE 1-31-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-----------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MAKE | : GEM |
| DENSITY | : 0.100 G.P.M. | SPRINKLER MODEL | : F-950 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER SIZE | : 1/2 X 1/2 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| RACK SPRINKLER ALLOWANCE (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212 |
| | | RATING | : f |
| | | SYSTEM TYPE | : WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 636.50 G.P.M. AT 106.51 P.S.I. AT PUMP DISCHARGE.
 C-FACTOR USED = OVERHEAD 120
 UNDERGROUND N/A


WATER SUPPLY

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|-----------------|------------------------|-------------------|
| DATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | | |
| FLOW (GPM) | | |
| ELEVATION | | |

LOC. OF TEST :
 SOURCE OF INFO.:

NOTES

- 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive

Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING A (LEVEL 1), ZONES 1B1, 1C1, 1C2, & 1D2 ARE SIMILAR
FOR HYD CALC (E)

JOB INFORMATION

JOB NUMBER : 10006
JOB NAME : NAVAL REG. MED. CTR.
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 12
DATE 1-28-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-----------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MAKE | : GEM |
| DENSITY | : 0.100 G.P.M. | SPRINKLER MODEL | : F-950 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER SIZE | : 1/2 X 1/2 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| RACK SPRINKLER ALLOWANCE (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212 |
| | | RATING | : f |
| | | SYSTEM TYPE | : WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 564.80 G.P.M. AT 109.80 P.S.I. AT PUMP DISCHARGE.
K-FACTOR USED = OVERHEAD 120
UNDERGROUND N/A

WATER SUPPLY

WATER FLOW TEST

PUMP DATA

TANK OR RESERVOIR

| | | | | | |
|----------------|---|----------------|----------|------------------|---|
| DATE | : | RATED AT (GPM) | : 500.00 | CAPACITY (GALS.) | : |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 11.77' | | |
| RESIDUAL (PSI) | : | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.
2. SIMILAR GRIDS ON THIS LEVEL TO BE SIZED SIMILARLY.

ASHLAND, VIRGINIA 23005
 804-798-3381

=====

HYDRAULIC DESIGN INFORMATION SHEET

=====

NAME NAVAL REGIONAL MEDICAL CENTER
 LOCATION 0081
 BUILDING ZONE 2B1 BUILDING "B"
 CONTRACTOR WORSHAM SPRINKLER CO., INC.
 CALCULATED BY P. WAYNE HODNETT
 CONSTRUCTION: () COMBUSTIBLE (X) NON-COMBUSTIBLE
 OCCUPANCY

DATE 5-13-80
 SYSTEM NO. ZONE 2B1
 CONTRACT NO. 10006
 DRAWING NO. 10 OF 17
 CEILING HEIGHT

S ! () NFPA 13 () LT. HAZ. ORD. HAZ. GP. () 1 () 2 () 3 () EX. HAZ.
 Y ! () NFPA 231 () NFPA 231C FIGURE CURVE
 S ! () OTHER
 T ! () SPECIFIC RULING MADE BY DATE
 E !
 M ! AREA OF SPRINKLER OPERATION 3000 SYSTEM TYPE
 ! DENSITY-GAL/MIN/SQ.FT .1 () WET () DRY () DELUGE () PREACTION
 D ! AREA PER SPRINKLER 130 SPRINKLER OR NOZZLE
 E ! HOSE ALLOWANCE GPM-INSIDE 0 MAKE STAR MODEL FLUSH
 S ! HOSE ALLOWANCE GPM-OUTSIDE 0 SIZE 1/2 K-FACTOR 5.6
 I ! RACK SPRINKLER ALLOWANCE 0 TEMPERATURE RATING 212
 G !
 N !

=====

CALCULATION ! GPM REQUIRED 786.55 PSI REQUIRED 101.73 AT BASE OF RISER
 SUMMARY ! C FACTOR USED: OVERHEAD 120 UNDERGROUND 0

=====


| W ! WATER FLOW TEST ! | PUMP DATA ! | TANK OR RESERVOIR ! |
|-----------------------|-----------------|---------------------|
| A ! DATE & TIME ! | RATED CAP 500 ! | CAP. 0 ! |
| T ! STATIC PSI 0 ! | AT PSI 85 ! | ELEV. 0 ! |
| E ! RESIDUAL PSI 0 ! | ELEV 11.77 ! | |
| R ! GPM FLOWING 0 ! | | WELL |
| ! ELEVATION ! | | PROOF FLOW GPM 0 |

S !
 U !
 P !

P ! LOCATION : 750 GPM AVAILABLE AT PUMP DISCHARGE @ 115 PSI
 L ! SOURCE OF INFORMATION :
 Y !

=====

| ! COMMODITY | CLASS | LOCATION |
|---|--------------|-------------|
| C ! STORAGE HT. | AREA | aisle width |
| D ! STORAGE METHOD: SOLID PILED % | PALLETIZED % | RACK % |
| M ! | | |
| M ! () SINGLE ROW () CONVENTIONAL PALLET () AUTOMATIC STORAGE () ENCAPSULATED | | |
| R ! () DOUBLE ROW () SLAVE PALLET () SOLID SHELVING () NON-ENCAPSULATED | | |
| S ! A ! () MULTIPLE ROW () OPEN | | |
| T ! C ! | | |
| D ! K ! FLUE SPACING IN INCHES: CLEARANCE: STORAGE TO CEILING | | |
| R ! LONGITUDINAL TRANSVERSE | | FT. |
| A ! | | |
| G ! HORIZONTAL BARRIERS PROVIDED: | | |
| E ! | | |



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING C LEVEL 2 GRID

JOB INFORMATION

OB NUMBER : 10006 SHEET 1 OF 12
OB NAME : NAVAL REG. MED. CTR. DATE 2-4-80
OB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|------------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-750 |
| DENSITY | : 0.10 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212 |
| BACK SPRINKLER | | RATING | : f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 635.40 G.P.M. AT 111.66 P.S.I. AT PUMP DISCHARGE.
K-FACTOR USED = OVERHEAD 120
UNDERGROUND N/A

WATER SUPPLY


WATER FLOW TEST PUMP DATA TANK OR RESERVOIR

| | | | |
|-----------------|-----------------|--------|-------------------|
| DATE : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : | 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : | 11.77' | |
| RESIDUAL (PSI): | | | |
| FLOW (GPM) : | | | |
| ELEVATION : | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING C LEVEL 2 DRY AREA (PRE-ACTION)

JOB INFORMATION

OB NUMBER : 10006
OB NAME : NAVAL REG. MED. CTR.
OB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 10
DATE 2-4-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|---------------|--------------------|-------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : ENTIRE AREA | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.10 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212° |
| RACK SPRINKLER | | RATING | : 1 f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : DRY |

CALCULATION SUMMARY

SYSTEM REQUIRES - 486.80 G.P.M. AT 112.67 P.S.I. AT PUMP DISCHARGE.
D-FACTOR USED = OVERHEAD 100
UNDERGROUND N/A

WATER SUPPLY


WATER FLOW TEST PUMP DATA TANK OR RESERVOIR

| | | | | | |
|-----------------|---|-----------------|----------|-------------------|---|
| DATE | : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): | |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 11.77' | | |
| RESIDUAL (PSI): | | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.
1355 South Park Drive

Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING C LEVEL 2 ZONE ZC1

JOB INFORMATION

NUMBER : 10006
NAME : NAVAL REG. MED. CTR.
LOCATION : CAMP LEJEUNE - N.C.
AORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 10
DATE 2-4-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | | |
|-------------------------------|----------------|--------------------|---|------------------|
| PROTECTED AREA OF | | SPRINKLER MAKE | : | GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : | F-950 |
| DESIGN FLOW RATE | : 0.10 G.P.M. | SPRINKLER SIZE | : | 1/2 X 1/2 |
| MINIMUM HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : | 5.56 |
| MINIMUM HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : | 212 |
| MINIMUM K SPRINKLER | | RATING | : | 150 f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : | WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 628.50 G.P.M. AT 114.95 P.S.I. AT PUMP DISCHARGE.
ACTOR USED = OVERHEAD 120
UNDERGROUND N/A

WATER SUPPLY


WATER FLOW TEST PUMP DATA TANK OR RESERVOIR

| | | |
|--------------------------|------------------------|-------------------|
| DESIGN FLOW RATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| DESIGN PRESSURE : | AT (PSI) : 85.00 | ELEVATION : |
| TEST PRESSURE (PSI) : | ELEVATION : 11.77' | |
| DESIGN FLOW RATE (GPM) : | | |
| VARIATION : | | |

RESULTS OF TEST :
SOURCE OF INFO.:

NOTES

750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
 EORSON Sprinkler Co., Inc.
 1355 South Park Drive
 Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDING D LEVEL 2 ZONE 2D2 (ZONES 2D1 & 2D1A SIMILAR)

JOB INFORMATION

DB NUMBER : 10006
 DB NAME : NAVAL REG. MED. CTR.
 DB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 8
 DATE 2-4-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.100 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212° |
| ACK SPRINKLER | | RATING | : 1 |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 673.40 G.P.M. AT 114.60 P.S.I. AT PUMP DISCHARGE.
 -FACTOR USED = OVERHEAD 120
 UNDERGROUND N/A

WATER SUPPLY

WATER FLOW TEST

PUMP DATA


TANK OR RESERVOIR

| | | | |
|----------------|---|------------------------|-------------------|
| DATE | : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME | : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) | : | ELEVATION : 11.77' | |
| RESIDUAL (PSI) | : | | |
| FLOW (GPM) | : | | |
| ELEVATION | : | | |

LOC. OF TEST :
 SOURCE OF INFO.:

NOTES

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



 *
 * Hydraulic Summary Sheet By *
 * Worsham Sprinkler Co., Inc. *
 * 1355 South Park Drive *
 * Kernersville, North Carolina 27284 *
 *

 GENERAL AREA DESCRIPTION

BUILDING D LEVEL 2 DRY AREA (PRE-ACTION)

***** JOB INFORMATION *****

JOB NUMBER : 10006
 JOB NAME : NAVAL REG. MED. CTR.
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 4
 DATE 2-4-80

***** SYSTEM DESIGN *****

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|------------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : LARGER ROOM | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.100 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 4/2 |
| RACK SPRINKLER | | RATING | : 1 f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : DRY |

***** CALCULATION SUMMARY *****

SYSTEM REQUIRES - 244.00 G.P.M. AT 61.14 P.S.I. AT CONN. TO RISER.
 C-FACTOR USED = OVERHEAD 100
 UNDERGROUND N/A

***** WATER SUPPLY *****

WATER FLOW TEST


PUMP DATA

TANK OR RESERVOIR

| | | | | | |
|----------------|---|-----------------|----------|-------------------|---|
| DATE | : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): | |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 11.77' | | |
| RESIDUAL (PSI) | : | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
 SOURCE OF INFO.:

***** NOTES *****



 ** Hydraulic Summary Sheet By **
 ** Worsham Sprinkler Co., Inc. **
 ** 1355 South Park Drive **
 ** Kernersville, North Carolina 27284 **

GENERAL AREA DESCRIPTION

LEVEL 1 OF BUILDINGS G & H (ZONE 1G2)

***** JOB INFORMATION *****

JOB NUMBER : 10006
 JOB NAME : NAVAL REG. MED. CTR.
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 9
 DATE 1-23-80

***** SYSTEM DESIGN *****

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.100 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 212 |
| RACK SPRINKLER | | RATING | : f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : WET |

***** CALCULATION SUMMARY *****

SYSTEM REQUIRES - 585.60 G.P.M. AT 109.04 P.S.I. AT PUMP DISCHARGE.
 C-FACTOR USED = OVERHEAD 120
 UNDERGROUND N/A


***** WATER SUPPLY *****

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|-----------------|------------------------|-------------------|
| DATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | | |
| FLOW (GPM) : | | |
| ELEVATION : | | |

LOC. OF TEST :
 SOURCE OF INFO.:

***** NOTES *****

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.
2. OTHER SYSTEMS IN THESE BUILDINGS ON THIS FLOOR ARE SIZED SIMILAR



 * Hydraulic Summary Sheet By *
 * Worsham Sprinkler Co., Inc. *
 * 1355 South Park Drive *
 * Kernersville, North Carolina 27284 *

GENERAL AREA DESCRIPTION

SECOND LEVEL OF BUILDINGS G & H (TREE SYS.)

***** JOB INFORMATION *****

JOB NUMBER : 10006 SHEET 1 OF 9
 JOB NAME : NAVAL REG. MED. CTR. DATE 1-23-80
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

***** SYSTEM DESIGN *****

STANDARDS USED : CONTRACT DOCUMENTS
 TOTAL AREA OF :
 SPRINKLER OPERATION : 3000 SQ. FT. SPRINKLER MAKE : GEM
 DENSITY : 0.100 G.P.M. SPRINKLER MODEL : F-950
 INSIDE HOSE STREAMS (G.P.M.) : N/A SPRINKLER SIZE : 1/2 X 1/2
 OUTSIDE HOSE STREAMS (G.P.M.) : N/A SPRINKLER K-FACTOR : 5.56
 RACK SPRINKLER : SPRINKLER TEMP. :
 ALLOWANCE (G.P.M.) : N/A RATING : 2/2 f
 SYSTEM TYPE : WET

***** CALCULATION SUMMARY *****


SYSTEM REQUIRES - 618.20 G.P.M. AT 82.39 P.S.I. AT PUMP DISCHARGE.
 K-FACTOR USED = OVERHEAD 120
 UNDERGROUND N/A

***** WATER SUPPLY *****

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|------------------|------------------------|-------------------|
| DATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | | |
| FLOW (GPM) : | | |
| ELEVATION : | | |
| LOC. OF TEST : | | |
| SOURCE OF INFO.: | | |

***** NOTES *****

1. 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.

1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

DRY AREA OF THE 3RD. LEVEL OF BUILDING H

JOB INFORMATION

JOB NUMBER : 10006
JOB NAME : NAVAL REG. MED. CTR.
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 7
DATE 1-23-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|--------------------|
| TOTAL AREA OF | | SPRINKLER MAKE | : GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.100 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | : 2/2 |
| RACK SPRINKLER | | RATING | : 1/2 f |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : DRY |

CALCULATION SUMMARY

SYSTEM REQUIRES - 556.50 G.P.M. AT 84.78 P.S.I. AT REF. POINT ()
C-FACTOR USED = OVERHEAD 100
UNDERGROUND N/A

WATER SUPPLY

WATER FLOW TEST

PUMP DATA


TANK OR RESERVOIR

| | | | | | |
|-----------------|---|-----------------|----------|-------------------|---|
| DATE | : | RATED AT (GPM): | 500.00 | CAPACITY (GALS.): | : |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 11.77' | | |
| RESIDUAL (PSI): | : | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

1. SEE NOTE ON SHEET #7.



Hydraulic Summary Sheet By
 Worsham Sprinkler Co., Inc.
 1355 South Park Drive
 Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BUILDINGS G & H LEVEL #4 ZONES 3G1, 3G2 & 3H1 ARE SIMILAR

JOB INFORMATION

JOB NUMBER : 10006
 JOB NAME : NAVAL REGIONAL MEDICAL CENTER
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 11
 DATE 1-23-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS
 TOTAL AREA OF SPRINKLER OPERATION : 3000 SQ. FT.
 DENSITY : 0.100 G.P.M.
 INSIDE HOSE STREAMS (G.P.M.) : N/A
 OUTSIDE HOSE STREAMS (G.P.M.) : N/A
 RACK SPRINKLER ALLOWANCE (G.P.M.) : N/A

SPRINKLER MAKE : GEM
 SPRINKLER MODEL : F-950
 SPRINKLER SIZE : 1/2 X 1/2
 SPRINKLER K-FACTOR : 5.56
 SPRINKLER TEMP. : 212
 RATING : f
 SYSTEM TYPE : WET

CALCULATION SUMMARY

SYSTEM REQUIRES - 591.00 G.P.M. AT 104.30 P.S.I. AT pump discharge.
 C-FACTOR USED = OVERHEAD 120
 UNDERGROUND n/a


WATER SUPPLY

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|------------------|-------------------------|--------------------|
| DATE : | RATED AT (GPM) : 500.00 | CAPACITY (GALS.) : |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI) : | | |
| FLOW (GPM) : | | |
| ELEVATION : | | |

LOC. OF TEST :
 SOURCE OF INFO. :

NOTES

- 750.00 g.p.m. at 115.00 p.s.i. available at pump discharge.
- grids on levels 2 3 & 4 are all sized similar.



Hydraulic Summary Sheet By
 Worsham Sprinkler Co., Inc.
 1355 South Park Drive
 Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

BOILER ROOM

JOB INFORMATION

JOB NUMBER : 10006 SHEET 1 OF 6
 JOB NAME : NAVAL REG. MED. CTR. DATE 2-6-80
 JOB LOCATION : CAMP LEJEUNE - N.C.
 AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------------|--------------------|-------------|
| TOTAL AREA OF | | SPRINKLER MAKE | GEM |
| SPRINKLER OPERATION | : 3000 SQ. FT. | SPRINKLER MODEL | : F-950 |
| DENSITY | : 0.200 G.P.M. | SPRINKLER SIZE | : 1/2 X 1/2 |
| INSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER K-FACTOR | : 5.56 |
| OUTSIDE HOSE STREAMS (G.P.M.) | : N/A | SPRINKLER TEMP. | |
| RACK SPRINKLER | | RATING | : VARIES |
| ALLOWANCE (G.P.M.) | : N/A | SYSTEM TYPE | : DRY |

CALCULATION SUMMARY


SYSTEM REQUIRES - 718.70 G.P.M. AT 114.81 P.S.I. AT PUMP DISCHARGE.
 C-FACTOR USED = OVERHEAD 100
 UNDERGROUND N/A

WATER SUPPLY

| WATER FLOW TEST | PUMP DATA | TANK OR RESERVOIR |
|------------------|------------------------|-------------------|
| DATE : | RATED AT (GPM): 500.00 | CAPACITY (GALS.): |
| TIME : | AT (PSI) : 85.00 | ELEVATION : |
| STATIC (PSI) : | ELEVATION : 11.77' | |
| RESIDUAL (PSI): | | |
| FLOW (GPM) : | | |
| ELEVATION : | | |
| LOC. OF TEST : | | |
| SOURCE OF INFO.: | | |

NOTES

- 750.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.



Hydraulic Summary Sheet By
Worsham Sprinkler Co., Inc.

1355 South Park Drive
Kernersville, North Carolina 27284

GENERAL AREA DESCRIPTION

STANDPIPE DESIGN AT RISER #1 (REMOTE RISER)

ALL RISERS ARE SIMILAR

JOB INFORMATION

JOB NUMBER : 10006
JOB NAME : NAVAL REGIONAL MEDICAL CENTER
JOB LOCATION : CAMP LEJEUNE - N.C.
AUTHORITY HAVING JURISDICTION : U.S. GOVT.

SHEET 1 OF 4
DATE 1-2-80

SYSTEM DESIGN

STANDARDS USED : CONTRACT DOCUMENTS

| | | | |
|-------------------------------|----------|--------------------|-------|
| TOTAL AREA OF | : | SPRINKLER MAKE | : |
| SPRINKLER OPERATION | : | SPRINKLER MODEL | : |
| DENSITY | : | SPRINKLER SIZE | : |
| INSIDE HOSE STREAMS (G.P.M.) | : 500.00 | SPRINKLER K-FACTOR | : |
| OUTSIDE HOSE STREAMS (G.P.M.) | : | SPRINKLER TEMP. | : |
| RACK SPRINKLER | : | RATING | : |
| ALLOWANCE (G.P.M.) | : | SYSTEM TYPE | : WET |

CALCULATION SUMMARY

SYSTEM REQUIRES - 500.00 G.P.M. AT 113.89 P.S.I. AT PUMP DISCHARGE.
C-FACTOR USED = OVERHEAD 120
UNDERGROUND

WATER SUPPLY

WATER FLOW TEST

PUMP DATA

TANK OR RESERVOIR

| | | | | | |
|----------------|---|-----------------|-----------|-------------------|---|
| DATE | : | RATED AT (GPM): | 500 | CAPACITY (GALS.): | : |
| TIME | : | AT (PSI) | : 85.00 | ELEVATION | : |
| STATIC (PSI) | : | ELEVATION | : 111.77' | | |
| RESIDUAL (PSI) | : | | | | |
| FLOW (GPM) | : | | | | |
| ELEVATION | : | | | | |

LOC. OF TEST :
SOURCE OF INFO.:

NOTES

- 500.00 G.P.M. AT 115.00 P.S.I. AVAILABLE AT PUMP DISCHARGE.

