



NOTES:
 1. ON 3/12/84 25 WELLS WERE LISTED AS IN SERVICE AND 7 WELLS WERE LISTED "CONTRACT FOR REPLACEMENT". ALL ON THE RAW WATER WELL CONTROL BOARD AT THE HOLCOMB BOULEVARD WATER TREATMENT PLANT. THREE WELLS WERE LISTED AS "IN SERVICE" BUT ARE INCLUDED AS REPLACEMENT WELLS UNDER SPEC. 05-80-0349 (538,639, LCH 4008). TWO WELLS (610 AND 615) WERE LISTED AS OUT OF SERVICE, BUT NOT SCHEDULED FOR REPLACEMENT.

- LEGEND**
- WATER LINES, EXISTING AND FIELD VERIFIED
 - - - WATER LINES, FUTURE OR NOT FIELD VERIFIED
 - BACKWASH LINES, EXISTING AND FIELD VERIFIED
 - - - BACKWASH LINES, FUTURE OR NOT FIELD VERIFIED
 - CHEMICAL LINES, EXISTING AND FIELD VERIFIED
 - - - CHEMICAL LINES, FUTURE OR NOT FIELD VERIFIED
 - 7 PUMP NO. 7
 - 6 VALVE NO. 6
 - GATE VALVE
 - CHECK VALVE
 - PLUG VALVE
 - BUTTERFLY VALVE
 - GLOBE VALVE
 - BALL VALVE
 - ANGLE VALVE
 - EDUCTOR
 - SIDE OUT SEATED VALVE
 - REDUCER
 - MOTOR CONTROL VALVE
 - HYDRAULIC CONTROL VALVE
 - PNEUMATIC CONTROL VALVE
 - METER
 - RATE OF FLOW CONTROLLER
 - ALTITUDE VALVE
 - BACK PRESSURE CONTROL VALVE
 - SIGHT GLASS AIR GAP
 - P.S. PRESSURE GAGE
 - A.R. AIR RELEASE VALVE
 - DIRECTION OF FLOW

NO.	DESCRIPTION OF REVISION	DATE	INT.

DEPARTMENT OF THE NAVY
 MARINE CORPS BASE
 CAMP LEJEUNE, NORTH CAROLINA

WATER TREATMENT PLANT
 ONE - LINE DIAGRAM
 HADNOT POINT - BUILDING 20

EXISTING CONDITIONS

DATE 31 JULY 84	SCALE: NONE	SHEET 1 of 1
APPROVED / DATE		

