

MARINE CORPS AIR STATION - NEW RIVER OCTOBER 1980 - DECEMBER 1981

DATE	WATER TREATMENT PLANT					BLDG G-520 2 ND FLR MEN'S ROOM					BLDG 4025 BARRACKS REC ROOM					BLDG 710 O CLUB GALLY SINK					BLDG 2800 BOAT MARINA					MONTH	Ave	
	CHCL3	CHCL3/B	CHCL3/C	CHB3	THM	CHCL3	CHCL3/B	CHCL3/C	CHB3	THM	CHCL3	CHCL3/B	CHCL3/C	CHB3	THM	CHCL3	CHCL3/B	CHCL3/C	CHB3	THM	CHCL3	CHCL3/B	CHCL3/C	CHB3	THM			
Time 24 OCTOBER 80	1348 11.8					1530 25.0					1425 22.6					1448 16.3					1506 18.1					(0.11) 110.7	-	
NOVEMBER 80	No SAMPLE - LAB UNAWARE IT WAS A MONTHLY SAMPLING. LAW REQUIRES QUARTERLY																											
Time 19 DECEMBER 80	1435 25.9					1500 28.1					1310 35.9					1355 34.6					1420 52.9					(0.09) 88.1	(0.10) 99.4	
Time 25 JANUARY 81	1350 17.3					1545 33.1					1405 29.1					1425 22.8					1527 21.2					(0.12) 78.0	-	
Time 18 FEBRUARY 81	1349 20.7					1515 29.8					1406 39.5					1424 29.3					1500 30.8					(0.09) 89.4	-	
MARCH 81	No SAMPLE - SAMPLE BOTTLES DID NOT ARRIVE IN TIME																											
Time 22 APRIL 81	1345 14.0					1450 27.6					1350 20.4					1430 16.9					1400 24.6					(0.10) 120.5	-	
MAY 81	No SAMPLE - SAMPLE BOTTLES DID NOT ARRIVE IN TIME																											
Time 12 JUNE 81	1300-1500 6.8					20.8					107.6					9.7					23.9					(0.07) 73.3	(0.08) 84.7	
Time 23 JULY 81	1330-1410 3.5					10.0					13.4					4.1					5.0					(0.15) 153.5	-	
19 AUGUST 81	SEPTUM INVERTED - 42.5 33.3 40.7 37.9 154.4 SEPTUM INVERTED - 45.3 31.9 38.7 40.1 116 48.6 33.4 41.1 24.6 147.7																											
Time 21 SEPTEMBER 81	1345 20.9					1445 30.9					1400 26.3					1430 23.7					1415 25.1					(0.16) 163.5	(0.15) 154.1	
OCTOBER 81	No SAMPLE - SAMPLE BOTTLES DID NOT ARRIVE IN TIME																											
NOVEMBER 81	No SAMPLE - No SAMPLE BOTTLES SENT BECAUSE INSTRUMENT DOWN																											
DECEMBER 81	No SAMPLE - INSTRUMENT STILL DOWN																											
AVERAGE	15.1	15.7	21.8	17.1	69.8	29.5	29.1	45.3	26.7	128.7	24.4	28.0	38.2	31.6	122.0	22.5	24.3	33.7	23.0	103.6	27.8	29.6	49.2	31.2	137.7	(0.11) 123.2	CLW	

ANALYSIS BY: US ARMY EHA @ FT McPHERSON
RED SHADED BOXES CONTAIN VALUES EXCEEDING THE 0.1 mg/l (100 ug/l) LIMIT