

SUMMARY OF TRIHALOMETHANE ANALYSIS

<u>Sample #</u> & <u>System</u>	<u>June</u>	<u>Averages (Units mg/l, Limit=0.10 mg/l)</u>			<u>Compliance**</u>
		<u>April &amp; May</u>	<u>Running Average(2 Qtr<sup>+</sup>)</u>		
124-128 Tarawa Terrace	0.02	0.01	0.02	yes	
130-134 Montford Point	0.01	0.01	0.01	yes	
135-139 New River	0.10	0.09	0.10	yes	
140-144 Holcomb Blvd	0.03	0.04	0.04	yes	
145-149 Rifle Range	0.07	0.05	0.06	yes	
150-154 Courthouse Bay	0.05	0.05	0.05	yes	
155-159 Onslow Beach	0.07	0.05	0.06	yes	
160-164 Hadnot Point	0.02	0.04	0.03	yes	

\*-According to the Trihalomethane regulation date, the quarters run as follows: December-February, March-May, June-August, and September-November.

F

\*\* - Compliance is actually determined from the running annual(4 Qtr) average.

CLW

0000000563