

WATER SYSTEM: MARINE CORPS AIR STATION - NEW RIVER

JANUARY 1982 - MARCH 1983

0157

DATE	WATER TREATMENT PLANT AS-110					BLDG G-520 2ND FLR MEN'S ROOM					BLDG AS-4025 BARRACKS REC ROOM					BLDG 710 O'CLUB GALLY SINK					BLDG 2300 PORT MARINA					AVERAGE			
	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	THM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	THM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	THM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	THM	CHCl ₃	CHCl ₂ B	CHClB ₂	CHB ₃	THM	MG/1	MG/1	MG/1	
JANUARY 1982	NO SAMPLES																												
FEBRUARY	NO SAMPLES																												
MARCH	NO SAMPLES																												
20 APRIL 1982	1255					1345					1310					1325					1335								
28 MAY	1125					1110					1135					1155					1145								
25 JUNE	1005					0953					1020					1045					1035								
29 JULY	1110					1209					1122					1145					1135								
17 AUGUST	0953					1040					1205					1235					1225								
21 SEPTEMBER	1235					1320					1247					1312					1300								
OCTOBER	NO SAMPLES																												
29 NOVEMBER	1115					1150					1202					1141					1133								
29 DECEMBER 1982	1305					1350					1315					1335					1325								
26 JANUARY 1983	1305					1357					1317					1338					1328								
25 FEBRUARY	1245					1332					1257					1320					1310								
MARCH 1983	NO SAMPLES																												
AVERAGE:	122	127	175	12	0.02	24			40.7		17			26.3		27			0		27			4					

MAR-MAY 83.7

APR-JUN 85.9

JUN-AUG 107.3

JUL-SEP 105.2

SEP-NOV 92.5

OCT-DEC 107.4

RESERVOIR DEC-FEB 104.7

0.02 JAN-MAR 100.2

YEAR 0.11 EPA

97.05 STATE

94.67

ANALYSIS BY: OCT 1980 - MAR 1982 U.S. ARMY EHA @ Ft McPHERSON, APR 1982 - SEP 1984 + MISSING A QUARTER GRAINGER LABORATORY
 RED SHADDED BOXES CONTAIN VALUES EXCEEDING THE 100PPB (0.1MG/L) LIMIT

CLW

000000708